

STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

IN RE:

APPLICATION OF HOMELAND TOWERS, LLC  
AND NEW CINGULAR WIRELESS PCS, LLC  
d/b/a AT&T FOR A CERTIFICATE OF  
ENVIRONMENTAL COMPATIBILITY AND  
PUBLIC NEED FOR THE CONSTRUCTION,  
MAINTENANCE, AND OPERATION OF A  
TELECOMMUNICATIONS FACILITY AT 60  
VALE ROAD, BROOKFIELD, CONNECTICUT

DOCKET NO. 512

May 1, 2023

**RESPONSES OF HOMELAND TOWERS & NEW CINGULAR WIRELESS PCS, LLC  
(AT&T)  
TO CONNECTICUT SITING COUNCIL INTERROGATORIES**

- Q1. The geotechnical report in the Development and Management Plan (D&M Plan) indicates that weathered/decomposed rock was encountered at approximately 37.5 feet deep. Would blasting be required? If yes, submit a blasting plan that includes work procedures and municipal notifications.
- A1. *No blasting is anticipated for the installation of a pad and pier tower foundation at the site.*
- Q2. Referencing Exhibit A of the D&M Plan, would the 20-kW Cummins diesel generator have a double-walled fuel tank and/or other features to provide containment in the event of spill/leakage of generator fluids? Where would it be installed?
- A2. *The Town's 20-kW Cummins diesel generator will be installed within the "Future Municipal Equipment Area of 10'x16'" shown on sheet CP-1 of the D&M Plans. The fuel tank will be double walled and will also have an alarm in the event of a spill/leakage.*
- Q3. Referencing Sheet SP-2, post-construction stormwater velocity would not exceed existing stormwater velocity of 3.0 feet/second. Identify any specific stormwater management-related features in the design to achieve no net increase.
- A3. *The grading of the proposed compound is set at existing grade. Therefore, the stormwater runoff velocity across the proposed facility will not increase post construction. In addition, the compound is designed with 6" of ¾" crushed stone which will allow for runoff to infiltrate into the voids in the stone and ultimately infiltrate into the ground.*
- Q4. Referencing Sheet N-2 (Environmental Notes), Section 3 – Petroleum Materials Storage and Spill Prevention Plan of the D&M Plan, provide detailed contact information for the spill response contractor.
- A4. *The spill response contractor, if required, would be Clean Harbors, 51 Broderick Road, Bristol, CT, (860) 583-8917.*

- Q5. Referencing Sheet SP-2, what are the approximate heights of the proposed utility poles above grade?
- A5. *The proposed utility pole on Vale Road will have a height of 38'-6" +/- AGL. The proposed utility pole near the compound will have a height of 34' +/- AGL.*
- Q6. Referencing page 1 of the D&M Plan, it states, "Construction activities shall be 7:30 AM to 7:30 PM Monday through Saturday and 10:00 AM through 7:30 PM Sundays and Holidays." Would Sundays and/or holidays be part of the regular/typical work schedule or only as necessary? Explain.
- A6. *Although the Town of Brookfield allows construction activities to take place on Sundays and holidays, Sundays and/or holidays would not be part of the regular/typical work schedule and would only occur if absolutely necessary to address an immediate on site construction issue.*

**CERTIFICATE OF SERVICE**

I hereby certify that on this day, one original and fifteen (15) hard copies of the foregoing was sent via overnight Federal Express and electronically to the Connecticut Siting Council in accordance with the Connecticut Siting Council directives.

May 1, 2023



---

Daniel Patrick, Esq.  
Cuddy & Feder LLP  
445 Hamilton Ave, 14<sup>th</sup> Floor  
White Plains, NY 10601  
(914)-761-1300  
Attorneys for the Applicant

cc: Homeland Towers  
AT&T  
APT  
C SQUARED  
Lucia Chiochio, Esq., Cuddy & Feder LLP