

STATE OF CONNECTICUT *CONNECTICUT SITING COUNCIL* Ten Franklin Square, New Britain, CT 06051 Phone: (860) 827-2935 Fax: (860) 827-2950 E-Mail: siting.council@ct.gov www.ct.gov/csc

VIA ELECTRONIC MAIL

November 23, 2022

Lee D. Hoffman, Esq. Pullman & Comley LLC 90 State House Square Hartford, CT 06103-3702 lhoffman@pullcom.com

RE: **DOCKET NO. 497** – DG Connecticut Solar III, LLC Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a 3.5-megawatt-AC solar photovoltaic electric generating facility located at Lot 33, Prospect Street, Burlington, Connecticut and associated electrical interconnection.

Dear Attorney Hoffman:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated November 22, 2022 regarding the revision to the Development and Management (D&M) Plan for the above-referenced facility that was approved by the Council on September 24, 2021.

Pursuant to Regulations of Connecticut State Agencies (RCSA) §16-50j-62(b), your request for the permanent use of pole-mounted (in lieu of pad-mounted) customer metering equipment on two electrical interconnection poles located on-site west of the access drive and approximately 275 feet north of Prospect Street is hereby approved. Permanent use of the pole-mounted metering equipment is necessary due to supply chain issues associated with the approved pad-mounted equipment and power take-off requirements for the facility.

This approval applies only to the D&M Plan revision dated November 22, 2022.

Please be advised that deviations from the Council's Decision and Order and D&M Plan approvals are enforceable under the provisions of Connecticut General Statutes § 16-50u. Furthermore, the Certificate Holder is responsible for reporting requirements pursuant to RCSA §16-50j-62.

Thank you for your attention and cooperation.

Sincerely,

Miluiphael

Melanie A. Bachman Executive Director

MB/MP



s: dockets/401-500/497/dm plan/d497_dm_plan_modification_11232022.doc