

**From:** [robert.carberry@nu.com](mailto:robert.carberry@nu.com) [<mailto:robert.carberry@nu.com>]  
**Sent:** Friday, March 01, 2013 8:47 AM  
**To:** Walsh, Christina  
**Cc:** Roberts, Linda; Bachman, Melanie  
**Subject:** D&M Plan Change, North Bloomfield Substation, Docket 370  
**Importance:** High

Hi Christina:

I have an urgent D&M Plan change, meaning that construction forces are standing by, that I will call you about this morning.

Here is the plan view drawing for North Bloomfield Substation. The change is to shift the location of one of the 110-foot tall lightning masts by about 20 feet to avoid a foundation excavation too close to an underground duct bank with in-service control cables. There are three such masts on the 115-kV side of the autotransformers (on the original D&M Plan drawing there were five, but two were eliminated in a December 2011 change filing), and two of these have already been installed at their indicated locations. Per the Change Approval Process in the D&M Plan for this substation I am inclined to categorize this change as a minor one that does not need prior CSC approval. If CSC staff thinks otherwise, then I will ask the Council to review this as an "urgent" change under the Change Approval Process.