

Generation	Dispatch 1 MW	Dispatch 2 MW	Dispatch 3 MW
Stony Brook	425	425	0
Berkshire Power	0	229	229
Mt Tom	0	144	0
West Springfield #3	0	94	94
MASSPOWER 1	82	82	0
MASSPOWER 2	82	82	0
MASSPOWER 3	75	75	0
West Springfield #1	0	37	37
West Springfield #2	0	37	37
West Springfield Jet	0	17	0
Cobble Mt	17	17	17
<span style="border: 1px solid black;">SPRINGFIELD REFUSE-NEW PROSPECT</span>	6		

**Springfield Area (Zones 143 - 150)**

<b>Substation</b>	<b>Load kV</b>
Agawam	13.8
Amherst	13.8
Blandford	23
Breckwood	13.8
Buck Pond (WG&E)	23
Chicopee (CELD)	13.8
Clinton	13.8
East Springfield	13.8
Elm (WG&E)	23
Five Corners (NGrid)	13.2
Florence (NGrid)	13.8
Gunn	23
Holyoke (HG&E)	115
Ingleside (HG&E)	115
Ludlow	13.8
Midway (NGrid)	13.8
Orchard	13.8
Pineshed (SHEL)	13.8
Piper	13.8
Podick	13.8
Prospect (HG&E)	13.8
West Springfield	13.8

Scitico (CL&P)	23
Franconia (CL&P)	13.8
Silver (CL&P)	13.8
Southwick (CL&P)	13.8

Section 2.1, Appendix A.2 and B.1)

Total 30901,863

33586,132

31023,971

Section 2.1 and 3.1  
 Summer - Winter Peak  
 January 1st, (January 3, 2008)  
 2008  
 Expected

Section 3.2  
 and 3.1  
 Summer  
 2008  
 Expected

ASSET ID	CUSTOMER?	GEN NAME	FPS STATE	FPS COUNTY	RSP AREA	SUMMER CLAIMED CAPABILITY	WINTER CLAIMED CAPABILITY	SUMMER CLAIMED CAPABILITY	GEN TYPE	EIN PLANT NUM	DATE IN SERVICE	GEN TYPE DESC	CUSTOMER NAME
812	HGE	BEEBE HOLBROOK	25	013	VMMA	0.586	0.586	0.586	HDR	1602	1-Jan-48	HYDRO (DAI)	Holyoke Gas & Electric Department
859	HGE	BOATLOCK	25	013	VMMA	3.094	3.094	3.094	HDR	1603	1-Jan-24	HYDRO (DAI)	Holyoke Gas & Electric Department
766	FPRM	CABOT/TURNERS FALLS	25	011	VMMA	68.200	68.200		HDP	1629	1-Jan-05	HYDRO (DAI)	FirsLight Power Resources Management, LLC
1122	MEC	CASCADE-DIAMOND-OF	25	013	VMMA	0.000	0.000	0.000	HDR		31-Dec-19	HYDRO (DAI)	Massachusetts Electric Company
862	HGE	CHEMICAL	25	013	VMMA	1.600	1.600	1.600	HDR	1604	1-Jan-35	HYDRO (DAI)	Holyoke Gas & Electric Department
1050	NSTAR	CHICOPEE HYDRO	25	013	VMMA	2.170	2.170	2.170	HDR	50832	1-May-85	HYDRO (DAI)	NSTAR Electric Company
379	HGE	COBBLE MOUNTAIN	25	013	VMMA	32.642	33.479	32.642	HV	1630	1-Jan-23	HYDRO (WE)	Holyoke Gas & Electric Department
1049	NSTAR	COLLINS HYDRO	25	013	VMMA	1.250	1.250	1.250	HDR	52186	1-Dec-84	HYDRO (DAI)	NSTAR Electric Company
849	GELD	CRESCENT DAM	25	013	VMMA	1.306	1.575	1.306	HDR		1-Jan-93	HYDRO (DAI)	Groton Electric Light Department
465	TCPM	DEERFIELD ZILWR DRFIELD	25	011	VMMA	19.500	19.500	19.500	HDR	6047	1-Jan-12	HYDRO (DAI)	TransCanada Power Marketing, Ltd
393	TCPM	DEERFIELD 5	25	011	VMMA	13.990	13.990	13.990	HDR	1620	1-Oct-74	HYDRO (DAI)	TransCanada Power Marketing, Ltd
864	CEEI	DWIGHT	25	013	VMMA	0.229	1.746	0.229	HDR	6378	1-Aug-99	HYDRO (DAI)	Consolidated Edison Energy, Inc
413	BSP	FIFE BROOK	25	003	VMMA	9.900	9.900	9.900	HDR	8004	1-Oct-74	HYDRO (DAI)	Bear Swamp Power Company LLC
861	CEEI	GARDNER FALLS	25	011	VMMA	1.804	3.580	1.804	HDR	1634	1-Jan-24	HYDRO (DAI)	Consolidated Edison Energy, Inc
850	GELD	GLENDALE HYDRO	25	003	VMMA	0.838	1.138	0.838	HDR		1-Dec-89	HYDRO (DAI)	Groton Electric Light Department
769	HGE	HADLEY FALLS 1&2	25	013	VMMA	33.400	33.400	33.400	HDR	1605	1-Jan-83	HYDRO (DAI)	Holyoke Gas & Electric Department
12168	HGE	HARRIS ENERGY	25	013	VMMA	2.421	2.421	2.421	HDR		1-Dec-05	HYDRO (DAI)	Holyoke Gas & Electric Department
957	HGE	HGA&E HYDRO/CABOT 1-4	25	013	VMMA	3.147	3.147	3.147	HDR	9864	1-Jan-80	HYDRO (DAI)	Holyoke Gas & Electric Department
867	CEEI	2	25	013	VMMA	0.191	3.142	0.191	HDR	6379	1-Aug-99	HYDRO (DAI)	Consolidated Edison Energy, Inc
359	BSP	J COCKWELL 1	25	011	VMMA	288.475	292.275	288.475	PS	8005	1-Sep-74	HYDRO (PUN)	Bear Swamp Power Company LLC
350	BSP	J COCKWELL 2	25	011	VMMA	291.256	292.763	291.256	PS	8005	1-Oct-74	HYDRO (PUN)	Bear Swamp Power Company LLC
14217	FPRM	NORTHERFIELD MOUNTAIN 1	25	011	VMMA	270.000	270.000	270.000	PS	54895	30-Nov-72	HYDRO (PUN)	FirsLight Power Resources Management, LLC
14218	FPRM	NORTHERFIELD MOUNTAIN 2	25	011	VMMA	270.000	270.000	270.000	PS	54895	30-Nov-72	HYDRO (PUN)	FirsLight Power Resources Management, LLC
14219	FPRM	NORTHERFIELD MOUNTAIN 3	25	011	VMMA	270.000	270.000	270.000	PS	54895	30-Nov-72	HYDRO (PUN)	FirsLight Power Resources Management, LLC
14220	FPRM	NORTHERFIELD MOUNTAIN 4	25	011	VMMA	270.000	270.000	270.000	PS	54895	30-Nov-72	HYDRO (PUN)	FirsLight Power Resources Management, LLC
854	ITMLP	ORANGE HYDRO 1	25	011	VMMA	0.145	0.150	0.145	HDR		1-Aug-87	HYDRO (DAI)	Templeton Municipal Lighting Plant
855	ITMLP	ORANGE HYDRO 2	25	011	VMMA	0.112	0.120	0.112	HDR		1-Nov-93	HYDRO (DAI)	Templeton Municipal Lighting Plant
873	CEEI	PUTTS BRIDGE	25	013	VMMA	1.008	3.940	1.008	HDR	1637	1-Aug-99	HYDRO (DAI)	Consolidated Edison Energy, Inc
874	CEEI	RED BRIDGE	25	013	VMMA	0.333	4.632	0.333	HDR	1638	1-Aug-99	HYDRO (DAI)	Consolidated Edison Energy, Inc
1034	HGE	RIVERSIDE 4-7	25	013	VMMA	3.435	3.435	3.435	HDR	1607	1-Jan-21	HYDRO (DAI)	Holyoke Gas & Electric Department
1035	HGE	RIVERSIDE 8	25	013	VMMA	4.500	4.500	4.500	HDR	1607	1-Jan-31	HYDRO (DAI)	Holyoke Gas & Electric Department
567	TCPM	SHERMAN	25	011	VMMA	6.334	6.237	6.334	HW	6012	1-Dec-26	HYDRO (WE)	TransCanada Power Marketing, Ltd
878	HGE	SKINNER	25	013	VMMA	0.280	0.280	0.280	HDR	1608	1-Jan-24	HYDRO (DAI)	Holyoke Gas & Electric Department
14623	HGE	Valley Hydro (Station No. 5)	25	013	VMMA	0.280	0.280	0.280	HDR		1-Apr-08	HYDRO (DAI)	Holyoke Gas & Electric Department
1048	NSTAR	WARE HYDRO	25	015	VMMA	0.133	0.514	0.133	HDR	60419	1-Mar-84	HYDRO (DAI)	NSTAR Electric Company
10770	SMED	WEST SPRINGFIELD HYDRO US	25	003	VMMA	0.743	1.250	0.743	HDR		10-Jan-05	HYDRO (DAI)	Sterling Municipal Electric Light Department

SECTION	3.2 EXPECTED SUBMIT DATE	ANG 7, 2008	LEAD	AGREEMENT	ACRONYM	STATE	COUNTY	LEAD PARTICIPANT NAME	LEAD PARTICIPANT	DATE RECEIVED	ISSUANCE	FILE	TYPE	GEN TYPE ID	PRIMARY	RESOURCE NAME	RESOURCE
								PAULCKET Power Holding	PPH	01-Sep-90	FO2	NG	CC			ALTRESO	
								Domain Energy Market	DEM	01-Jul-96		IC	LFG			BARRE LANDFILL	
								Shell Energy North Ameri	SENA	19-Jun-00		NG	CC			BERKSHIRE POWER	
								Holyoke Gas & Electric L	HGE	01-Jan-48		HDR	WAT			BEEBE HOLBROOK	
								Holyoke Gas & Electric L	HGE	01-Jan-24		HDR	WAT			BOATLOCK	
								FirstLight Power Resourc	FPRM	27-Mar-08		HDP	WAT			CABOT/TURNERS FALLS	
								Holyoke Gas & Electric L	HGE	01-Jan-35		HDR	WAT			CHEMICAL	
								Holyoke Gas & Electric L	HGE	01-Jan-23		HDR	WAT			COBBLE MOUNTAIN	
								Holyoke Gas & Electric L	HGE	01-Jan-84		HDR	WAT			COLLINS HYDRO	
								Groton Electric Light Deg	GELD	01-Jan-93		HDR	WAT			CRESCENT DAM	
								TransCanada Power Mat	TCPM	01-Jan-12		HDP	WAT			DEERFIELD 2LWR DRFIELD	
								TransCanada Power Mat	TCPM	01-Oct-74		HDP	WAT			DEERFIELD 5	
								Consolidated Edison Enr	CDEI	01-Jan-89		HDR	WAT			DORREN	
								Consolidated Edison Enr	CDEI	01-Jan-20		HDR	WAT			DWIGHT	
								Bear Swamp Power Cor	BSP	01-Oct-74		HDP	WAT			PIPE BROOK	
								Chicopee Municipal Light	CMLP	01-Dec-80		FO2	IC			FRONT STREET DIESELS 1-3	
								Consolidated Edison Enr	CDEI	01-Jan-24		HDR	WAT			GARDNER FALLS	
								Groton Electric Light Dep	GELD	01-Dec-89		HDR	WAT			GLENDALE HYDRO	
								Massachusetts Electric C	MEC	12-Jul-02		ST	MSW			GANBAY SANITARY LANDFILL OF US	
								Holyoke Gas & Electric L	HGE	01-Jan-83		HDR	WAT			HADLEY FALLS 1&2	
								Holyoke Gas & Electric L	HGE	01-Dec-06		HDR	WAT			HARRIS ENERGY	
								Holyoke Gas & Electric L	HGE	01-Jan-80		HDR	WAT			HG&E HYDRO/CABOT 1-4	
								Holyoke Gas & Electric L	HGE	01-Jan-49		ST	NG	FO6		HOLYOKE 6/CABOT 6	
								Holyoke Gas & Electric L	HGE	01-Jan-28		HDR	WAT			INNIAN ORCHARD	
								Bear Swamp Power Cor	BSP	01-Sep-74		PS	WAT			J COCKWELL 1	
								Bear Swamp Power Cor	BSP	01-Oct-74		PS	WAT			J COCKWELL 2	
								MASSPOWER	MASSPOWE	01-Jul-93		FO2	CC	NG		MASS POWER	
								Merrill Lynch Commoditie	MLC	06-Apr-01		CC	NG			MILLENNIUM	
								FirstLight Power Resourc	FPRM	01-Jun-60		ST	BIT			MT TOM	
								Massachusetts Electric C	MEC	01-Jul-07		WAT	MND			Turners Falls Hydro	
								Swift River Trading Com	SRTC	01-Nov-08		HDR	WAT			Turners Falls Hydro	
								FirstLight Power Resourc	FPRM	30-Nov-72		PS	WAT			NORTHFIELD MOUNTAIN 1	
								FirstLight Power Resourc	FPRM	30-Nov-72		PS	WAT			NORTHFIELD MOUNTAIN 2	
								FirstLight Power Resourc	FPRM	30-Nov-72		PS	WAT			NORTHFIELD MOUNTAIN 3	
								FirstLight Power Resourc	FPRM	30-Nov-72		PS	WAT			NORTHFIELD MOUNTAIN 4	
								Templeton Municipal Light	TTMLP	01-Aug-87		HDR	WAT			ORANGE HYDRO 1	
								Templeton Municipal Light	TTMLP	01-Nov-93		HDR	WAT			ORANGE HYDRO 2	
								Consolidated Edison Enr	CDEI	01-Jan-18		HDR	WAT			PUTTS BRIDGE	
								Consolidated Edison Enr	CDEI	01-Jan-26		HDR	WAT			RED BRIDGE	
								Holyoke Gas & Electric L	HGE	01-Jan-21		HDR	WAT			RIVERSIDE 4-7	
								Holyoke Gas & Electric L	HGE	01-Jan-31		HDR	WAT			RIVERSIDE 8	
								TransCanada Power Mat	TCPM	01-Dec-26		HDR	WAT			SHERMAN	
								Holyoke Gas & Electric L	HGE	01-Jan-24		HDR	WAT			SKINNER	
								Western Massachusetts	WMMECO	01-Sep-88		ST	MSW	FO6		SPRINGFIELD REFUSE-NEW	
								Holyoke Gas & Electric L	HGE	01-Apr-08		HDR	WAT			Valley Hydro (Station No. 5)	
								NSSTAR Electric Compan	NSSTAR	01-Mar-84		HDR	WAT			WARE HYDRO	
								Consolidated Edison Enr	CDEI	01-Jan-68		GT	KER			WEST SPRINGFIELD 10	
								Consolidated Edison Enr	CDEI	01-Jan-57		ST	FO6	NG		WEST SPRINGFIELD 3	
								Consolidated Edison Enr	CDEI	07-Jun-02		GT	NG	FO2		WEST SPRINGFIELD GT-1	
								Consolidated Edison Enr	CDEI	07-Jun-02		GT	NG	FO2		WEST SPRINGFIELD GT-2	
								Harvard Dedicated Ener	HDEL	10-Jan-05		HDR	WAT			WEST SPRINGFIELD HYDRO US	
								Westfield Gas and Elect	WGEC	01-Mar-04		IC	OEG			WESTFIELD #1 US	
								Consolidated Edison Enr	CDEI	01-Jul-69		GT	KER			WOODLAND ROAD	

Project Name	Location	State	Year	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)	Capacity (MW)
BEEBE HOLBROOK	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586	0.586
BOATLOCK	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.580	0.580	0.850	0.850	0.850	1.705	1.705	1.705	1.705	1.705	1.705	1.705	1.705	1.705	1.705
CHEMICAL	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	1.6	1.6	1.6	1.8	1.8	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6
CHICOEE HYDRO	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.573	0.573	0.573	0.573	0.573	1.334	1.334	1.334	1.334	1.334	1.334	1.334	1.334	1.334	1.334
COBBLE MOUNTAIN	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	30.892	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862	30.862
COLLINS HYDRO	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.27	0.27	0.27	0.27	0.27	0.892	0.892	0.892	0.892	0.892	0.892	0.892	0.892	0.892	0.892
CROSCENT DAM	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.305	0.305	0.305	0.305	0.305	0.799	0.799	0.799	0.799	0.799	0.799	0.799	0.799	0.799	0.799
DEERFIELD ZILWA ORFIELD	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483	19.483
DEERFIELD 5	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682	13.682
DUDLEY HYDRO	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.367	0.367	0.367	0.367	0.367	0.512	0.512	0.512	0.512	0.512	0.512	0.512	0.512	0.512	0.512
DWIGHT	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	16.042	16.042	16.042	16.042	16.042	25.865	25.865	25.865	25.865	25.865	25.865	25.865	25.865	25.865	25.865
HADLEY FALLS 1&2	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0	0	0	0	0	1.731	1.731	1.731	1.731	1.731	1.731	1.731	1.731	1.731	1.731
HARRIS ENERGY	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147	3.147
HICOLE HYDRO/CAROL 1-4	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.188	0.188	0.188	0.188	0.188	1.237	1.237	1.237	1.237	1.237	1.237	1.237	1.237	1.237	1.237
INDIAN ORCHARD	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.841	0.841	0.841	0.841	0.841	2.06	2.06	2.06	2.06	2.06	2.06	2.06	2.06	2.06	2.06
PULLS BRIDGE	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.438	0.438	0.438	0.438	0.438	2.322	2.322	2.322	2.322	2.322	2.322	2.322	2.322	2.322	2.322
RED BRIDGE	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.396	0.396	0.396	0.396	0.396	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663
RIVERSIDE 4-7	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	1.573	1.573	1.573	1.573	1.573	2.243	2.243	2.243	2.243	2.243	2.243	2.243	2.243	2.243	2.243
RIVERSIDE 8	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0	0	0	0	0	0.194	0.194	0.194	0.194	0.194	0.194	0.194	0.194	0.194	0.194
SKINNER	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.096	0.096	0.096	0.096	0.096	0.943	0.943	0.943	0.943	0.943	0.943	0.943	0.943	0.943	0.943
WEST SPRINGFIELD HYDRO US	Water at a Conventional Hydroelectric Turbine	MA	WCM/ASS	Existing	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
Valley Hydro (Station No. 5)	Water	MA	WCM/ASS	New	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213	1550.213