

STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

IN RE:

APPLICATION OF NEW CINGULAR WIRELESS
PCS, LLC (AT&T) FOR A CERTIFICATE OF
ENVIRONMENTAL COMPATIBILITY AND
PUBLIC NEED FOR THE CONSTRUCTION,
MAINTENANCE AND OPERATION OF A
TELECOMMUNICATIONS TOWER FACILITY
AT ST. MATTHEW LUTHERAN CHURCH AT
224 LOVELY STREET IN THE TOWN OF AVON

DOCKET NO. 373A

JUNE 22, 2010

NEW CINGULAR WIRELESS ("AT&T")
RESPONSES TO SITING COUNCIL
PRE-HEARING INTERROGATORIES - REOPENING

Q1. Estimate the number of trees six inches in diameter at breast height that would be removed to develop the site and access road.

See Exhibit A attached which includes a memorandum from Hudson Design Group, LLC and an updated comparative site plan (Drawing C-3) with flood zones and tower distances delineated.

Q2. What would be the effect of site development on habitat for the eastern box turtle?

A2. See Jeffrey Shamas, Direct Testimony Q.4 and response thereto.

Q3. Is it possible to realign the access road in the following manner:

From the cul-de-sac, extend northward immediately east of the 16" spruce (easement centerline with the 12" maple), curving slightly northwest to remain east of the row of cedars and west of the 16" oaks north and south of the shed.

A3. Yes. See Exhibit A attached and also alternative access road recommended by Jeffrey Shamas and the plan titled "Optional Access Plan" Drawing C-3B which is also attached as prepared by Hudson Design Group, LLC.

A



MEMORANDUM

TO: Cuddy & Feder, LLP

FROM: Derek Creaser, HDG Sr. Project Manager

A handwritten signature in black ink, appearing to be 'DC', is written over the name 'Derek Creaser'.

SUBJ: Docket 373A Interrogatories Re-opening & Additional Information
New Cingular Wireless PCS LLC CT1257 (SR 2013)

DATE: June 22, 2010

Q1: Estimate the number of trees six inches in diameter at breast height that would be removed to develop the site and access road.

A1: Approximately six trees greater than or equal to 6" DBH would need to be removed.

(1) 12" Maple

(2) 16" Oak

(1) 11" Black Birch

(1) 17" White Pine

(1) 10" poplar

Q3: Is it Possible to realign the access road in the following Manner:

From the cul-de-sac, extend northward immediately east of the 16" spruce (easement centerline with the 12" maple), curving slightly northwest to remain east of the row of cedars and west of the 16" oaks north and south of the shed.

A3: Yes.

Corrections: Drawing C-1, Note 23 should be revised to state that the proposed site is within 100' of delineated wetlands.


Additional Information Requested by AT&T:

Approved tower distance to Parsonage = 68'+/-

Proposed tower distance to Parsonage = 139'+/-

APPROXIMATE VOLUME OF CUT WITHIN COMPOUND:	9.9 CU. YD.
APPROXIMATE VOLUME OF FILL WITHIN COMPOUND:	7.4 CU. YD.
APPROXIMATE VOLUME OF CUT WITHIN ACCESS EASEMENT:	20.4 CU. YD.
APPROXIMATE VOLUME OF FILL WITHIN ACCESS EASEMENT:	11.4 CU. YD.
APPROXIMATE # OF TREES TO BE REMOVED >= 6" DBH	6

NOTE: FLOOD ZONE & BASE FLOOD ELEVATION DETERMINED FROM FLOOD INSURANCE RATE MAP 3177, DATED 9/26/2008
 ZONE AE: AREA INUNDATED BY 100 YEAR FLOODING. 278' BASE FLOOD ELEVATION
 ZONE X: AREA DETERMINED TO BE OUTSIDE THE 500 YEAR FLOODPLAIN. NO BASE FLOOD ELEVATION GIVEN.



500 ENTERPRISE DRIVE
 ROCKY HILL, CT 06067



1600 OSWOOD STREET
 BUILDING 20 NORTH, SUITE 2-101
 N. ANDOVER, MA 01845
 TEL: (978) 557-5553
 FAX: (978) 336-5586

ENGINEER/LAND SURVEYOR
 IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

REVISIONS		
REV. #	DATE	DESCRIPTION
4	06/21/10	ADD FLOOD ZONES DIMS. & CUT/FILL CALC.
3	05/28/10	SHOW OPTION 3 ORIGINAL LOCATION
2	04/13/10	REVISE SHELTER DETAILS
1	03/31/10	REVISE EASEMENTS
0	03/09/10	ISSUED FOR REVIEW

PROJECT NO.	DESIGNED BY: DC	SCALE:
	DRAWN BY: SB	AS SHOWN
	CHECKED BY: DPH	


SITE NAME:
 1257-AVON

SITE ADDRESS:
 224 LOVELY STREET
 AVON, CT 06067

DRAWING TITLE:
 COMPARATIVE SITE PLAN


DRAWING NO:
 C-3

GREENWOOD DRIVE



APPROXIMATE VOLUME OF CUT WITHIN COMPOUND:	9.9 CU. YD.
APPROXIMATE VOLUME OF FILL WITHIN COMPOUND:	7.4 CU. YD.
APPROXIMATE VOLUME OF CUT WITHIN ACCESS EASEMENT:	10.0 CU. YD.
APPROXIMATE VOLUME OF FILL WITHIN ACCESS EASEMENT:	10.7 CU. YD.
APPROXIMATE # OF TREES TO BE REMOVED >= 6" DBH	4

NOTE: FLOOD ZONE & BASE FLOOD ELEVATION DETERMINED FROM FLOOD INSURANCE RATE MAP 317F, DATED 9/26/2008
 ZONE AE: AREA INUNDATED BY 100 YEAR FLOODING. 278' BASE FLOOD ELEVATION
 ZONE X: AREA DETERMINED TO BE OUTSIDE THE 500 YEAR FLOODPLAIN. NO BASE FLOOD ELEVATION GIVEN.



500 ENTERPRISE DRIVE
 ROCKY HILL, CT 06067



1400 OSGOOD STREET
 BUILDING 20 NORTH, SUITE 2-101
 N ANDOVER, MA 01845
 TEL: (978) 557-5553
 FAX: (978) 336-5586

ENGINEER/LAND SURVEYOR

IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

REVISIONS		
REV. #	DATE	DESCRIPTION
3	06/21/10	REVISE ACCESS EASEMENT
2	04/13/10	REVISE SHELTER DETAILS
1	03/31/10	REVISE EASEMENTS
0	03/09/10	ISSUED FOR REVIEW

PROJECT NO.	DESIGNED BY: DC	SCALE:
	DRAWN BY: SB	AS SHOWN
	CHECKED BY: DPH	

SITE NAME:
 1257-AVON

SITE ADDRESS:
 224 LOVELY STREET
 AVON, CT 06067

DRAWING TITLE:
 OPTIONAL ACCESS PLAN

DRAWING NO:
 C-3B

GREENWOOD DRIVE

