



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

January 25, 2010

TO: Parties and Intervenors

FROM: S. Derek Phelps, Executive Director


RE: **DOCKET NO. 388** - New Cingular Wireless PCS, LLC (AT&T) application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance and operation of a telecommunications facility located at 1990 Litchfield Turnpike, Woodbridge, Connecticut.

Comments have been received from the Department of Public Health, Drinking Water Section, dated January 14, 2010. A copy of the comments is attached for your review.

SDP/MP/laf

Enclosure

c: Council Members



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

ORIGINAL

MEMORANDUM

TO: S. Derek Phelps
Executive Director
Connecticut Siting Council

FROM: Eric McPhee *EPM*
Supervising Environmental Analyst
Drinking Water Section
Department of Public Health

DATE: 1/14/10

SUBJECT: Docket No. 388

DATE RECEIVED: 12/14/09

APPLICANT: New Cingular Wireless PCS, LLC

TOWN: Woodbridge

PROJECT: Certificate of Environmental Compatibility and Public Need for the construction, maintenance and operation of a telecommunications facility at 1990 Litchfield Turnpike, Woodbridge, Connecticut

RECEIVED
JAN 25 2010
CONNECTICUT
SITING COUNCIL

_____ No Comments.

X

Other Comments: This proposed construction activity is within the West River System watershed for the Lake Dawson Reservoir which is owned by Regional Water Authority. This Department's concern is for the protection of the source of public drinking water that serves this area. The following Best Management Practices (BMP's) should be reviewed to ensure the safety of the drinking water supply:

- No equipment, machinery, or vehicles shall be cleaned, repaired, fueled or stored on the project site. Oil, solvents, or hazardous substances shall be disposed of off the watershed.
- No construction shall take place until water pollution controls and erosion and sedimentation controls are in place. It must be ensured these controls are installed, properly functioning, inspected regularly, and remain in place throughout the project



Phone: (860) 509-7333
Telephone Device for the Deaf (860) 509-7191
410 Capitol Avenue - MS # 51WAT
P.O. Box 340308 Hartford, CT 06134
Affirmative Action / An Equal Opportunity Employer

- Any malfunction or breakdown of erosion and/or sedimentation control devices or water pollution control devices shall be repaired immediately. Construction activities shall be discontinued until repairs have been completed.
- Disturbed areas must be seeded or sodded as soon as possible to provide a vegetative cover against erosion. Seed mixtures and erosion control fabric shall be free from any herbicide or pesticide additive or treatment.
- RWA should be allowed to inspect the site during construction activities to make sure all Best Management Practices are being followed.

**LIST OF PARTIES AND INTERVENORS
SERVICE LIST**

Status Granted	Document Service	Status Holder (name, address & phone number)	Representative (name, address & phone number)
<p align="center">Applicant</p>	<p><input checked="" type="checkbox"/> U.S. Mail</p>	<p>New Cingular Wireless PCS, LLC (AT&T)</p>	<p>Christopher B Fisher, Esq. Daniel M. Laub, Esq. Cuddy & Feder LLP 445 Hamilton Avenue, 14th Floor White Plains, NY 10601 (914) 761-1300 (914) 761-5372 fax cfisher@cuddyfeder.com dlaub@cuddyfeder.com</p> <p>Michele Briggs AT&T 500 Enterprise Drive Rocky Hill, CT 06067-3900 michele.g.briggs@cingular.com</p>
	<p><input checked="" type="checkbox"/> U.S. Mail</p>		