



**Connecticut
Light & Power**

The Northeast Utilities System

**APPLICATION TO THE
CONNECTICUT SITING COUNCIL**

FOR A

**CERTIFICATE OF ENVIRONMENTAL
COMPATIBILITY AND PUBLIC NEED**

FOR THE

Sherwood Substation

**6 New Creek Road
Westport, Connecticut**

December 29, 2009

Submitted by:

**The Connecticut Light & Power Company
107 Selden Street
Berlin, CT 06037**

Volume I of II

Volume I, Application

TABLE OF CONTENTS

CSC APPLICATION GUIDELINES CHECKLIST i

A. SUMMARY DESCRIPTION AND PROJECT LOCATION..... A-1

A.1. Municipal Participation During The Consultation Process..... A-4

B. PURPOSE OF THE APPLICATION.....B-1

C. STATUTORY AUTHORITY FOR APPLICATION C-1

D. LEGAL NAME AND ADDRESS OF APPLICANT D-1

E. APPLICANT CONTACTSE-1

F. DESCRIPTION OF FACILITY.....F-1

F.1. Estimated Cost of the Project..... F-4

F.2. Facility Service Life..... F-4

G. NEED FOR FACILITY G-1

G.1. System Alternatives G-8

G.1.1 Absence of Expansion Options at Existing Substations..... G-8

G.1.2 Other Alternatives G-11

G.1.2.1 Distributed Generation..... G-11

G.1.2.2 Demand Response..... G-12

G.1.2.3 Conservation and Load Management Programs G-14

G.1.2.4 Summary of Other Alternatives G-14

G.2 Conclusion G-15

H. EXISTING CONDITIONS H-1

H.1. Existing Development..... H-1

H.2. Site Access..... H-5

H.3. Wetlands and Watercourses..... H-5

H.4. Vegetation and Wildlife..... H-6

H.5. Rare, Threatened, and Endangered Species..... H-7

H.6. Water Supply Areas..... H-8

H.7. Scenic Areas..... H-8

H.8. Historic and Archaeological Resources..... H-8

H.9. Natural Resources..... H-10

H.10. Floodplain Areas..... H-10

H.11. Recreational Areas..... H-10

H.12. Seismic Areas..... H-11

H.13. Noise..... H-11

H.14. Lighting..... H-11

H.15. Coastal Zone Management Areas..... H-12

H.16. Other Surrounding Features..... H-12

I. ALTERNATIVE SITES EVALUATED.....I-1

I.1. 6 New Creek Road (the Property)..... I-3

I.2.	Terminus of Post Office Lane (between I-95 and Metro-North Railroad)	I-4
I.3.	Interstate Right-of-Way, north of Sherwood Island Connector	I-5
I.4.	West of existing Sasco Creek Substation	I-5
I.5.	Saugatuck Avenue at Exit 17, south side of I-95	I-6
I.6.	Wooded Lot across from #247 Greens Farms Road	I-7
I.7.	Summary of Alternate Site Analysis	I-7
J.	<u>SAFETY AND RELIABILITY INFORMATION</u>	J-1
K.	<u>EFFECTS ON THE ENVIRONMENT</u>	K-1
K.1.	Public Health and Safety	K-1
K.2.	Local, State and Federal Land Use Plans	K-1
K.3.	Existing and Future Development	K-3
K.4.	Roads	K-3
K.5.	Wetlands	K-4
K.6.	Wildlife and Vegetation	K-5
K.6.1.	Rare, Threatened, and Endangered Species	K-5
K.7.	Water Supply Areas	K-6
K.8.	Historic and Archaeological Resources	K-6
K.9.	Noise	K-6
K.10.	Floodplains	K-7
K.11.	Seismic Areas	K-7
K.12.	Lighting	K-7
K.13.	Natural Resources	K-7
K.14.	Coastal Zone Management Areas	K-8
K.15.	Other Surrounding Features	K-11
L.	<u>MITIGATION MEASURES</u>	L-1
L.1	Pre-Construction Considerations	L-1
L.2	Construction-Related Activities	L-1
L.3	Post-Construction Features	L-2
L.4	Construction Sequencing	L-4
M.	<u>HEALTH AND SAFETY</u>	M-1
M.1	Electric and Magnetic Fields	M-1
M.2	Site Security	M-13
M.2.1	Energy Facility Security	M-13
M.3	Traffic Considerations and Hours of Operation	M-14
N.	<u>PROJECT SCHEDULE</u>	N-1
O.	<u>GOVERNMENT APPROVALS OBTAINED</u>	O-1
P.	<u>BULK FILING OF MUNICIPAL DOCUMENTS</u>	P-1
Q.	<u>ADMINISTRATIVE NOTICE, PUBLIC AND ABUTTERS NOTICE, SERVICE AND OTHER FILING REQUIREMENTS</u>	Q-1
Q.1	Administrative Notice	Q-1
Q.2	Pre-Application Process (Conn. Gen. Stat. § 16-50l(e))	Q-3
Q.3	Application Filing Fees (Conn. Gen. Stat. § 16-50v-la)	Q-3
Q.4	Proof of Service (Conn. Gen. Stat. § 16-50l(b))	Q-3

Q.5	Public Notices (Conn. Gen. Stat. § 16-50l(b)).....	Q-4
Q.6	Notice to Owners of Property Abutting Substation Site	Q-5
R.	<u>OTHER RELEVANT INFORMATION</u>	R-1
R.1	Public Outreach.....	R-1
R.2	Exemption from CEAB Mandatory RFP Process	R-2

List of Figures

Figure A-1	Site Location Map, USGS	A-2
Figure A-2	Site Location Map, Aerial.....	A-3
Figure F-1	Substation Location	F-2
Figure G-1	Existing Westport Area Substation System	G-3
Figure G-2	Future Westport Area Substation System	G-4
Figure H-1	Existing Conditions Map	H-2
Figure H-2	Nearest Residences	H-4
Figure H-3	Surrounding Features.....	H-14
Figure I-1	Alternative Sites Evaluated.....	I-2
Figure K-1	Proposed Conditions Map.....	K-2
Figure M-1	Locations of Magnetic Field Calculations	M-3
Figure M-2	Magnetic Field Profile	M-5
Figure M-3	Magnetic Field Profile	M-6
Figure M-4	Magnetic Field Profile	M-7
Figure M-5	Magnetic Field Profile	M-8

List of Tables

Table G-1	August 2, 2005 Outage Summary	G-2
Table G-2	Estimated Peak Electric Demand in MVA	G-6
Table G-3	Area Substation Load and Capacity in MVA-2012	G-7
Table G-4	System Alternative Summary Table	G-11
Table G-5	CL&P Demand Response - Westport	G-12
Table G-6	Approved EG Projects	G-13
Table G-7	CL&P Energy Efficiency	G-14
Table H-1	Non-Residential Features within Two Miles of the Property in Westport.....	H-13
Table I-1	Sherwood Substation Site Alternatives Analysis Matrix	I-9
Table M-1	Existing Magnetic Fields in 2009	M-4
Table M-2	Projected Magnetic Field Levels in 2017	M-11
Table O-1	Permits Applicable to the Sherwood Substation Project	O-4

List of Exhibits

See Volume II, Exhibits

Volume I, Application

CONNECTICUT SITING COUNCIL APPLICATION GUIDELINES CHECKLIST **ELECTRIC SUBSTATION FACILITY**

June 2007

This application guide is to assist applicants in filing for a Certificate of Environmental Compatibility and Public Need (Certificate) from the Connecticut Siting Council (Council) for the construction of an electric substation facility. Such facilities are defined in General Statutes § 16-50i (a) (4).

Applicants should consult General Statutes §§ 16-50g through 16-50aa and Sections 16-50j-1 through 16-50z-4 of the Regulations of Connecticut State Agencies to assure complete compliance with the requirements of those sections. Where appropriate, statutory and regulatory references are noted below.

Pre-Application Process (General Statutes § 16-50/ (e)) **Refer to Municipal Consultation Filing in separate Bulk attachment**

"....at least 60 days prior to the filing of any application with the Council, the applicant shall consult with the municipality in which the facility may be located and with any other municipality required to be served with a copy of the application under subdivision (1) of subsection (b) of this section [any adjoining municipality having a boundary not more than 2500 feet from such facility] concerning the proposed and alternative sites of the facility....Such consultation with the municipality shall include, but not be limited to, good faith efforts to meet with the chief elected official of the municipality. At the time of the consultation, the applicant shall provide the chief elected official with any technical reports concerning the public need, the site selection process and the environmental effects of the proposed facility. The municipality may conduct public hearings and meetings as it deems necessary for it to advise the applicant of its recommendations concerning the proposed facility. Within 60 days of the initial consultation, the municipality shall issue its recommendations to the applicant. No later than 15 days after submitting the application to the Council, the applicant shall provide to the Council all materials provided to the municipality and a summary of the consultations with the municipality including all recommendations issued by the municipality."

I. Application to Municipal Agencies (General Statutes § 16-50x (d))

Municipal zoning and inland wetland agencies may regulate and restrict the location of an electric substation facility. Such action must be taken within 30 days of application filed with the Council. Orders made by the municipal zoning and inland wetland agencies may be appealed within thirty days by any party or municipality required to be served with a copy of the application.

Refer to Volume II, Exhibit 10

II. Quantity, Form, and Filing Requirements (Regs., Conn. State Agencies § 16-50j-12)

- A. Except as may be otherwise required, at the time applications are filed with the Council, there shall be furnished to the Council an original and 20 copies. All filings from the applicant, parties, or interveners must consist of original and 20 copies, labeled with the docket number, properly collated and paginated, and bound. An electronic version of all filings, as appropriate, should be provided.

Refer to Volumes I and II of this CSC Filing

- B. Bulk filing should be provided of not less than four (4) copies of the applicable town zoning and Inland wetlands regulations (including a map showing the location of inland wetlands if relevant) and plan of development and any other publicly available material in support of the application.

Refer to Volumes I and II of this CSC Filing

- C. Applications filed for the purpose of any proceeding before the Council shall be printed or typewritten on paper cut or folded to letter size, 8 1/2 by 11 inches. Width of margins shall be not less than one inch. The impression shall be on only one side of the papers, unless printed, and shall be double spaced, except that quotations in excess of five typewritten lines shall be single spaced and indented. Mimeographed, multigraphed, photoduplicated, or the like copies will be accepted as typewritten, provided all copies are clear and permanently legible. In accordance with the State Solid Waste Management Plan, all filings should be submitted on recyclable paper, primarily regular weight white office paper. Applicants should avoid using heavy stock paper, colored paper, and metal or plastic binders and separators.

Refer to Volumes I and II of this CSC Filing

- D. Every original shall be signed by the applicant or by one or more attorneys in their individual names on behalf of the applicant. All applications shall be filed at the office of the Council, 136 Main Street, Suite 401, New Britain, Connecticut 06051. Service of all documents and other papers filed as applications, briefs, and exhibits, but not limited to those categories, shall be by personal delivery or by first class mail to the Council and all parties and interveners to the proceeding, unless service has been waived.

Refer to Volumes I and II of this CSC Filing

- E. Any exhibits, sworn written testimony, data, models, illustrations, and all other materials that the applicant deems necessary or desirable to support the granting of the application shall be attached to the application. In addition, annexed materials shall include such exhibits, sworn written testimony, and other data that any statute or regulations may require. The applicant may request that administrative notice be taken of and refer in the application to portions of other Council docket records and generic hearings or statements prepared by the Council as a result of generic hearings.

Refer to Volumes I and II of this CSC Filing

- F. Applicants may present material in a sequence and format most appropriate for the particular proposal. To allow timely Council review, include with the application a copy of this form with page references for each item required in Section VII below.

Included Herein

- G. Potential applicants are urged to carefully review General Statutes §§ 16-50/(e), 16-50i and 16a-7c to determine whether the proposed project falls within the Connecticut Energy Advisory Board (CEAB) "request-for-proposal" process.

**Pursuant to Conn. Gen. Stats. § 16-50/ (a) (2), this project is exempt from the mandatory RFP process.
See Volume I, Section R.2**

III. Application Filing Fees (Regs., Conn. State Agencies § 16-50v-1a)

The filing fee for an application is determined by the following schedule:

<u>Estimated Construction Cost</u>	<u>Fee</u>
Up to \$5,000,000	0.05% or \$1,000.00, whichever is greater;
Above \$5,000,000	0.1% or \$25,000.00, whichever is less.

All application fees shall be paid to the Council at the time an application is filed with the Council. Additional assessments may be made for expenses in excess of the filing fee. Fees in excess of the Council's actual costs will be refunded to the applicant.

**See Volume I, Section Q.1
Filing Fees accompany CSC Application**

IV. Proof of Service (General Statutes § 16-50/ (b))

Each application shall be accompanied by proof of service of such application on:

See Volume I, Section Q.4

- A. The chief elected official, the zoning commission, planning commission, the planning and zoning commissions, and the conservation and wetlands commissions of the site municipality and any adjoining municipality having a boundary not more than 2500 feet from the facility;
- B. The regional planning agency that encompasses the site municipality;
- C. The State Attorney General;
- D. Each member of the Legislature in whose district the facility is proposed;
- E. Any federal agency, department, commission or instrumentality which has jurisdiction over the proposed facility; and
- F. The state departments of environmental protection, public health, public utility control, economic and community development, and transportation; the council on environmental quality; the State Historic Preservation Officer and the office of policy and management.

V. Public Notice (General Statutes § 16-50/ (b))

Notice of the application shall be published at least twice prior to the filing of the application in a newspaper having general circulation in the site municipality or municipalities. The notice shall state the name of the applicant, the date of filing, and a summary of the application. The notice must be published in not less than ten point type.

See Volume I, Section Q.5

VI. Notice to Abutting Landowners (General Statutes § 16-50/ (b))

Notice of the application shall be sent by certified or registered mail to all abutting landowners of the proposed and alternative sites of the facility. Notice shall be sent at the same time that notice of the application is given to the general public.

See Volume I, Section Q.6

The application shall be accompanied by an affidavit of notice to all abutting landowners and an affidavit of publication each time notice of application is published.

See Volume II, Exhibit 9

The Council also advises each applicant that at least ten business days prior to the public hearing such applicant should erect and maintain in a legible condition a sign not less than six feet by four feet upon the site at the entrance to the property from a public road where such facility is to be located. The sign shall set forth the name of the applicant, the type of facility, the public hearing date, and contact information for the Council (Web site and phone number).

Example:

PUBLIC NOTICE:

CL&P has filed an application with the Connecticut Siting Council (Council) for construction of an electric substation facility on this site. The Council will hold a public hearing on March 27, 2004 at the Newington Town Hall Auditorium at 3 and 7 p.m. A copy of the application can be reviewed at the town hall or at the Council offices in New Britain, CT. For more information, please contact the Council by telephone at 860-827-2935, electronically at www.ct.gov/csc, or by mail at 10 Franklin Square, New Britain, Connecticut 06051.

VII. Contents of Application (General Statutes § 16-50/ (a) (1) and Regulations § 16-50j-74)

An application for a Certificate for the construction of an electric substation facility should include or be accompanied by the following:

A. An executive summary of the first page of the application with the address of the facility. A brief description and the location of the proposed facility, including an artist's rendering and/or narrative describing its appearance.

See Volume I, Section A

1. A statement of the purpose for which the application is being made.

See Volume I, Section B

2. A statement describing the statutory authority for such application.

See Volume I, Section C

3. The exact legal name of each person seeking the authorization or relief and the address or principal place of business of each such person. If any applicant is a corporation, trust association, or other organized group, it shall also give the state under the laws of which it was created or organized.

See Volume I, Section D

4. The name, title, address, and telephone number of the attorney or other person to whom correspondence or communications in regard to the application are to be addressed. Notice, orders, and other papers may be served upon the person so named, and such service shall be deemed to be service to the applicant.

See Volume I, Section E

B. A description of the proposed facility including:

See Volume I, Section F

1. Access roads and utility services;

2. Special design features;

3. The following list should be included where applicable;

a. Itemized estimated costs;

b. Comparative costs of alternatives considered;

c. Facility service life;

d. Bus and specifications;

e. Overhead take-off design, appearance, and heights, if any;

- f. Length of interconnections to transmission and distribution;
- g. Initial and design voltages and capacities;
- h. Rights-of-way and access-way acquisition;
- i. Transmission connections and distribution feeders; and
- j. Service area;

C. A statement and full explanation of why the proposed facility is needed and how the facility would conform to a long-range plan for the expansion of the electric power grid serving the state and interconnected utility systems that would serve the public need for adequate, reliable, and economic service, including:

See Volume I, Section G

- 1. A description and documentation of the existing system and its limitations;
- 2. Justification for the proposed in-service date;
- 3. The estimated length of time the existing system is judged to be adequate with and without the proposed facility;
- 4. Identification of system alternatives with the advantages and disadvantages of each; and
- 5. If applicable, identification of the facility in the forecast of loads and resources pursuant to General Statutes § 16-50r.

D. A statement of the benefits expected from the proposed facility with as much specific information as is practicable.

See Volume I, Section G

E. A description of the named sites, including:

- 1. The most recent U.S.G.S. topographic quadrangle map (scale 1 inch = 2,000 feet) marked to show the site of the facility and any significant changes within a one mile radius of the site;

See Volume I, Sections A and H

- 2. A map (scale not less than 1 inch = 200 feet) of the lot or tract on which the facility is proposed to be located showing the acreage and dimensions of such site, the name and location of adjoining public roads or the nearest public road, and the names of abutting owners and the portions of their lands abutting the site;

See Volume I, Section H, and Volume II, Exhibit 1

- 3. A site plan (scale not less than 1 inch = 40 feet) showing the proposed facility, set back radius, existing and proposed contour elevations, 100 year flood zones, waterways, wetlands, and all associated equipment and structures on the site;

See Volume I, Section H, and Volume II, Exhibit 1

- a. Settled areas;
- b. Schools and daycare centers;
- c. Hospitals;
- d. Group homes;
- e. Forests and parks
- f. Recreational areas;
- g. Seismic areas;
- h. Scenic areas;
- i. Historic areas;

- j. Areas of geologic or archaeological interest;
 - k. Areas regulated under the Inland Wetlands and Watercourses Act;
 - l. Areas regulated under the Tidal Wetlands Act and Coastal Zone Management Act;
 - m. Public water supplies;
 - n. Hunting or wildlife management areas; and
 - o. Existing transmission lines within one mile of the site.
4. Where relevant, a terrain profile showing the proposed facility and access road with existing and proposed grades; and **See Volume II, Exhibit 1**
5. The most recent aerial photograph (scale not less than 1 inch = 1,000 feet) showing the proposed site, access roads, and all abutting properties.

See Volume I, Section A and H

F. A justification for selection of the proposed site including a comparison with alternative sites which are environmentally, technically, and economically practicable. Include enough information for a complete comparison between the proposed site and any alternative site contemplated. **See Volume I, Section I**

G. Safety and reliability information, including:

- 1. Provisions for emergency operations and shutdowns; and
- 2. Fire suppression technology.

See Volume I, Section J

H. A description of the effect that the proposed facility would have on the environment, ecology, and scenic, historic, and recreational values, including effects on:

See Volume I, Section K

- 1. Public health and safety;
- 2. Local, state, and federal land use plans;
- 3. Existing and future development;
- 4. Roads;
- 5. Wetlands;
- 6. Wildlife and vegetation, including rare and endangered species, and species of special concern, with documentation by the Department of Environmental Protection Natural Diversity Data Base;
- 7. Water supply areas;
- 8. Archaeological and historic resources, with documentation by the State Historic Preservation Officer; and
- 9. Other environmental concerns identified by the applicant, the Council, or any public agency.

I. Sight line graphs to the named sites from visually impacted areas such as residential developments, recreational areas, and historic sites;

J. A statement explaining mitigation measures for the proposed facility including:

See Volume I, Section L

- 1. Construction techniques designed specifically to minimize adverse effects on natural areas and sensitive areas;
- 2. Special routing or design features made specifically to avoid or minimize adverse effects on natural areas and sensitive areas;
- 3. Establishment of vegetation proposed near residential, recreational, and scenic areas; and

4. Methods for preservation of vegetation for wildlife habitat and screening.

K. Justification that the location of the proposed facility would not pose an undue safety or health hazard to persons or property at the site of the proposed facility including:

See Volume I, Section M

1. Measurements of existing electric and magnetic fields (EMF) at site boundaries, and at boundaries of adjacent schools, daycare facilities, playgrounds, and hospitals, with extrapolated calculations of exposure levels during expected normal and peak normal line loading;

2. Calculations of expected EMF levels at the above-listed locations that would occur during normal and peak normal operation of the facility; and

3. A statement describing consistency with the Council's "Best Management Practices for Electric and Magnetic Fields," as amended.

L. A schedule of the proposed program for right-of-way or property acquisition, construction, rehabilitation, testing, and operation.

See Volume I, Section N

M. A statement of estimated costs for site acquisition, construction, and equipment for a facility at the various proposed sites of the facility, including all candidates referred to in the application;

See Volume I, Section F.1

N. Such information as any department or agency of the State exercising environmental controls may, by regulation, require including:

See Volumes I and II

1. A listing of any federal, State, regional, district, and municipal agencies, including but not limited to the Federal Aviation Administration; State Historic Preservation Officer; State Department of Environmental Protection; and local conservation, inland wetland, and planning and zoning commissions with which reviews were conducted concerning the facility, including a copy of any agency position or decision with respect to the facility; and

See Volume I, Section O

2. The most recent conservation, inland wetland, zoning, and plan of development documents of the municipality, including a description of the zoning classification of the site and surrounding areas, and a narrative summary of the consistency of the project with the Town's regulations and plans.

See Volume I, Sections H and K, and Bulk Filing

O. Such information the applicant may consider relevant.

See Volume I, Section R

P. Description of proposed site clearing for access road and compound including type of vegetation scheduled for removal and quantity of trees greater than six inches diameter at breast height and involvement with wetlands;

**See Volume I, Section K, and Volume II, Exhibit 1
Proposed for Development & Management Plan Submission**

VIII. Procedures

A. The Council will review and may reject the application within 30 days if it fails to comply with specific data or exhibit requirements or if the applicant fails to promptly correct deficiencies. (Regs., Conn. State Agencies §§ 16-50/-4 through 16-50/-5)

B. The Council and any party or intervener to the proceeding may file exhibits and interrogatories requesting supplemental or explanatory materials. All filings will be subject to cross-examination and the Council's discretion for admission into the record. (General Statutes § 16-50o)

C. A public hearing must be held at a location selected by the Council in the county in which the facility is proposed, with one session held after 6:30 p.m. for the convenience of the public. If the proposed facility is to be located in more than one county, the Council shall fix the location for at least one public hearing session in whichever county it deems appropriate, provided that the Council may hold hearing sessions in more than one county. The Council's record must remain open for 30 days after the close of the hearing. (General Statutes § 16-50n (f))

D. The Council must render a decision within 180 days of receipt of an application, extendible by 180 days upon consent of applicant. (General Statutes § 16-50p)

PLEASE NOTE THAT THIS GUIDE IS NO SUBSTITUTION FOR OBTAINING ADVICE FROM LEGAL COUNSEL. IN THE EVENT OF ANY CONFLICT BETWEEN THIS GUIDE AND THE ACTUAL STATUTES AND REGULATIONS, THE STATUTES AND REGULATIONS SHALL GOVERN.

A. SUMMARY DESCRIPTION AND PROJECT LOCATION

The Applicant, The Connecticut Light and Power Company (“CL&P”), seeks to construct a new bulk power 115-kilovolt (“kV”) to 13.8-kV substation (the “Sherwood Substation” or “Substation”) on CL&P property located at 6 New Creek Road in Westport, Connecticut (the “Property” or “Site”). The Sherwood Substation would improve reliability and add needed distribution delivery-system capacity to serve the growing electric power demands in the Greens Farms section and immediately adjacent portions of the southeast area of Westport. In addition, the Sherwood Substation would eliminate the need for temporary equipment now in use.

The current system configuration of existing substations will not meet the Town’s growing electric demand and future reliability needs. Currently, the electric load in town is served by two distribution substations in Westport and by three bulk transmission power substations, two in Westport and one in Weston. Growing peak demands are straining the capacity of these substations. The addition of a new bulk power substation in Westport would create a more robust and reliable system that would serve the growing needs of the Town while effectively alleviating loads on the existing substations.

The Substation would be located on a 2.56-acre parcel (6 New Creek Road) identified by the Westport Assessor’s Office on Map G06, as Lot 5. CL&P acquired the Property in 2008 for the specific purpose of building a substation. The Property’s location is identified on a United States Geological Survey (“USGS”) and aerial photograph provided as Figure A-1 (*Site Location Map, USGS*) and Figure A-2 (*Site Location Map, Aerial*), respectively. The Property lies immediately south of existing overhead transmission circuits and an active railroad in the southern portion of Westport and is currently occupied by a single-family dwelling.


Figure A-1: Site Location Map, USGS



VHB Vanasse Hangen Brustlin, Inc.
Transportation Land Development Environmental Services



1,000 500 0 1,000
Feet



Proposed Substation Location
6 New Creek Road
Westport, Connecticut




**Connecticut
Light & Power**

The Northeast Utilities System

Figure A-2: Site Location Map, Aerial



VHB Vanasse Hangen Brustlin, Inc.
Transportation Land Development Environmental Services



150 75 0 150
Feet

 **Connecticut Light & Power**
The Northeast Utilities System

Prior to and during the municipal consultation process, CL&P consulted with the Town of Westport Chief Elected Official (“CEO”) and other town officials and personnel to present an overview of the Project, answer questions, and provide a point of contact to obtain additional information. As part of the location approval and MCF processes, CL&P presented Project information to the Town of Westport Conservation Commission and the Westport Planning and Zoning Commission in June and November, 2009.

This Project was identified in the *Connecticut Siting Council Review of the Connecticut Electrical Utilities Ten-Year Forecast of Loads and Resources*, published in 2007, 2008 and again in 2009 (by reference to the 2008 report). The proposed Project plan received technical approval from ISO-NE (New England’s Independent System Operator) on December 12, 2008.

CL&P has designed the Substation in a manner that minimizes the potential environmental and visual effects to the greatest extent practicable and has incorporated measures to ensure the protection of existing resources during construction and operation of the Substation facilities.

A.1. Municipal Participation During The Consultation Process

On many occasions over the past eighteen months, CL&P has consulted with Town of Westport officials, including First Selectman Gordon F. Joseloff, regarding the electric service provided by CL&P to the Westport community and CL&P’s desire to improve the reliability of that service. CL&P has also met with the Westport Planning and Zoning Commission, Conservation Commission, Architectural Review Board, Greens Farms Academy, and Greens Farms Association to discuss the Project.

As explained in detail in the remainder of this submission, the Sherwood Substation will:

- address a need for additional distribution system capacity and increased reliability in the Town of Westport by establishing a new, strategically positioned bulk-power source;
- comply with regional planning and reliability standards and Northeast Utilities' transmission planning guidelines;
- occupy a property purchased by CL&P for this specific use that is immediately adjacent to an existing electric transmission corridor, providing direct interconnection to an existing transmission line;
- be consistent with applicable public health and safety requirements, standards and codes;
- be constructed in compliance with the standards of the National Electrical Safety Code, the Connecticut Department of Public Utility Control, and good utility practice;
- be consistent with local, State and federal land use plans;
- be designed to avoid effects on existing wetlands and watercourses on the Property;
- be designed to minimize effects on existing wildlife, vegetation, and rare, threatened and endangered species habitat;
- not result in any adverse effects on public water supplies;
- be strategically located and designed to minimize visual impacts to surrounding areas;
- have no adverse effect on historic, cultural and/or archaeological resources;
- be designed to minimize earthwork and soil disturbance during construction, including development of appropriate plans to stabilize and restore affected areas;
- not be located within a floodplain;
- comply with applicable State noise regulations; and,
- have no significant permanent adverse effects on the environment.

B. PURPOSE OF THE APPLICATION

CL&P is applying to the Connecticut Siting Council (“CSC” or the “Council”) for a Certificate of Environmental Compatibility and Public Need (“Certificate”) for the Sherwood Substation project (the “Project”). The purpose of this Project is to increase electric distribution system capacity and improve reliability in the Town of Westport by establishing a new bulk-power substation in the Greens Farms section of town. The current system configuration of existing substations will not meet the Town’s growing electric demand and future reliability needs.

C. STATUTORY AUTHORITY FOR APPLICATION

CL&P is applying to the Council pursuant to Section 16-50g et seq. of the General Statutes of Connecticut.

This filing includes information concerning the Applicant, existing conditions at the Property, and the proposed conditions for construction of the Substation, including:

- its location and design;
- the various alternatives considered to date and the process by which the Property was identified and selected;
- the need for its construction and operation;
- its potential effects on the environment; and
- mitigation measures proposed by CL&P.

D. LEGAL NAME AND ADDRESS OF APPLICANT

The Connecticut Light and Power Company (a specially chartered Connecticut corporation)
107 Selden Street
Berlin, CT 06037

Mailing Address:

CL&P
P.O. Box 270
Hartford, CT 06141-0270
Telephone: (860) 665-5000

Internet Address: Northeast Utilities Transmission website
www.transmission-nu.com

E. APPLICANT CONTACTS

Correspondence and other communications with regard to the Sherwood Substation should be addressed to, and notices, orders and other papers should be served upon, the following:

Mr. John R. Morissette, Manager
Transmission Siting and Permitting
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
Telephone: (860) 665-2036
E-mail address: morisjr@nu.com

Mr. Chris Swan, Director
Municipal Relations
Siting and Permitting
Northeast Utilities Service Company
9 Tindall Avenue
Norwalk, CT 06851
Telephone: (203) 845-3421
E-mail address: swancc@nu.com

Mr. Kris Aberg, Project Manager
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
Telephone: (860) 665-6733
E-mail address: abergk@nu.com

Duncan MacKay, Esq.
Jeffery Cochran, Esq.
Legal Department
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
Telephone: (860) 665-3495
E-mail address: mackadr@nu.com
E-mail address: cochrjd@nu.com

Marianne Barbino Dubuque, Esq. and
Robert S. Golden, Jr., Esq.
Carmody & Torrance LLP
50 Leavenworth Street
P.O. Box 1110
Waterbury, CT 06721-1110
Telephone: (203) 573-1200
E-mail addresses:
mdubuque@carmodylaw.com
rgolden@carmodylaw.com


F. DESCRIPTION OF FACILITY

The Property was acquired in 2008 for the purpose of building a bulk power substation. The 2.56-acre Property consists of a residential house parcel located at 6 New Creek Road. The Property is identified by the Westport Assessor's Office on Map G06, as Lot 5.







The Substation would be accessible from New Creek Road and would be located to the south of the existing overhead transmission line and railroad corridor. Two 115-kV circuits (#1130 & #1890) exist within this corridor (see Figure F-1, *Substation Location*). The Substation would occupy an irregularly shaped area of 21,370± square feet (measuring approximately 137 feet by 160 feet at its longest dimensions) to be covered with a trap rock surface and secured by a seven-foot high chain link fence topped with one foot of barbed wire (three strands). The Property would accommodate the construction and operation of the Substation while allowing adequate space for extensive landscaping.

At present, the 1130 and 1890 circuits are routed west to east with respect to the Property. The centerline of the 1890 circuit is approximately 35 feet to the north of the Property's northerly border and the centerline of the 1130 circuit is approximately 100 feet to the north of the Property's northerly border. The existing 1890 circuit would be rerouted into the Substation. The segment of the existing 1890 circuit to the east of the Property would be renamed the 1578 circuit; the remaining segment of the existing circuit to the west of the Property would remain the 1890 circuit.

Figure F-1: Substation Location



Legend

-  Existing Line Support Structures
-  Proposed Line Support Structures
-  Existing Transmission Circuit
-  Proposed Interconnecting Circuit
-  Proposed Substation Location
-  Approximate Property Boundary

*Base Map Source: 2006 color aerial photograph with 1 foot resolution



Connecting the Substation to the existing 1890 circuit requires the installation of two new steel monopoles, similar in height to the transmission structures currently occupying the transmission line corridor. The interconnections between the Substation and the new transmission line poles would be accomplished by installing two new line-terminal structures (approximately 50 feet in height) within the Substation. The Substation would also be outfitted with a circuit breaker, seven disconnect switches, five circuit switchers and two 60-Megavolt-Ampere (MVA) power transformers that would step down the voltage from 115 kV to 13.8 kV. A third transformer position would be provided to accommodate a temporary, mobile transformer for emergency conditions.

Four metal switchgear enclosures, each approximately 21 feet long, 14 feet wide and 14 feet high, would be installed to provide the switching equipment, relaying and control equipment as well as the battery and charger associated with the distribution equipment. In addition to the switchgear enclosures, a metal control enclosure, approximately 48 feet long by 14 feet wide by 14 feet high, would be installed at the east end of the Substation. This enclosure would be designed to house the protective relaying and control equipment as well as the battery and charger associated with the transmission equipment. A new, approximately 15-foot wide access drive originating from New Creek Road to the Substation would be established in the eastern portion of the Property. The existing residential driveway would be used during construction and ultimately eliminated and its associated pavement removed. The existing residence located on the Property would also be removed as part of the Project.

Technical specifications and related information are presented in Volume II, Exhibit 1 (*Site Plan Drawings*).

Development of the Substation requires protective relay system changes within the existing control enclosures at Norwalk Harbor, Glenbrook, and Sasco Creek Substations. These upgrades are required for the safe and proper operation of the Substation. A fiber optic cable would be installed between the Substation and the two new transmission line structures.

F.1. Estimated Cost of the Project

The estimated cost for the siting, design, and construction of the Substation and supporting infrastructure is approximately \$19,800,000.

F.2. Facility Service Life

The Substation equipment and supporting infrastructure would have a service life of approximately 40 years and would be capable of capacity increases during this time.


I. ALTERNATIVE SITES EVALUATED

CL&P identified an area in Westport, Connecticut where additional bulk substation capacity is needed (i.e., the “load pocket”). In this case, the Westport load pocket area is bordered on the south by Long Island Sound, to the east by the Westport/Fairfield Line, to the north by Easton Road, and to the west by Compo Road (Route 136).

At present, the Town is supplied power from three substations with no ability to increase capacity at these facilities as discussed in Section G-1. The most viable solution to address this need is to construct a new bulk power substation in the Greens Farms section of Westport. The primary selection criteria for the location of a new bulk power substation are: proximity to an existing 115-kV transmission circuit; proximity to the distribution load pocket; and, accessibility to and from a public road. Locating the facility near an existing 115-kV transmission circuit avoids new transmission line construction and ROW acquisitions. A site centrally located within the load pocket minimizes distribution circuit lengths and enhances contingency tie capabilities with distribution circuits emanating from adjacent substations. Additionally, direct access to a substation site is important to minimize land clearing for new road construction and to reduce overall environment impacts along the transmission line corridor.

Six site locations in Westport were identified and evaluated to determine their potential viability for development of the new Substation. These locations are depicted on Figure I-1 (*Alternate Sites Evaluated*).

Figure I-1: Alternative Sites Evaluated



The following major criteria were used to determine the most suitable location for construction of this new Substation:

- Proximity to distribution load pocket and existing feeders;
- Proximity to existing transmission electrical circuits;
- Ease of access;
- Earthwork requirements;
- Sufficient size and shape;
- Zoning and land-use constraints;
- Wildlife and habitat;
- Wetlands, vernal pools, watercourses and floodplains; and
- Proximity to public water supply watershed and/or aquifer protection areas.

The New Creek Road Property best satisfied the criteria and is therefore the most feasible location. A summary of the potential site locations is provided below.

I.1. 6 New Creek Road (the Property)

This 2.56-acre site is situated in the center of the load pocket area and immediately south of a multi-use transportation and energy infrastructure corridor; its location provides for direct connections to an existing 115-kV transmission circuit resulting in minimal, additional infrastructure needs. There are also optimal connection opportunities to the existing distribution feeder network along New Creek Road, Greens Farms Road, and Maple Lane. The Property has sufficient size and shape to provide for substantial landscaping to screen the Substation from surrounding areas, and has direct access from New Creek Road. In summary, 6 New Creek Road possesses the following characteristics:

- Direct connections are available to existing 115-kV transmission circuit;
- Optimal connections can be made to existing distribution feeders;
- Sufficient room exists to establish vegetative screening;

- Direct access is available from New Creek Road;
- No wetland impacts would occur as a result of construction or operation of the Substation; and
- The Site is not located in an aquifer protection area.

I.2. Terminus of Post Office Lane (between I-95 and Metro-North Railroad)

Located adjacent to transportation corridor, this 2± acre site would provide relatively short interconnections to an existing 115-kV circuit; however, connections to the existing distribution network serving the load area would require bundling several new overhead circuits onto one existing line along Greens Farms Road. The site's configuration would limit CL&P's ability to fit all of the required equipment within the substation at this location, as it could only accommodate two transformers with no room for a mobile transformer position. Access to the parcel and utility infrastructure would require obtaining an easement from a third party; upon further investigation, it was determined that an easement would not be made available.

Negotiations with the landowner were unsuccessful and the parcel is not available for purchase.

In summary, this location is not viable due to the following considerations.

- Site configuration would limit ability to fit all required equipment within the substation; the site could only accommodate two transformers with no room for a mobile transformer position;
- Connections to existing distribution network would require bundling several new overhead circuits onto one existing line on Greens Farms Road;
- Potential wetland impacts would exist;
- Parcel would require an access/utility easement from third party; easement not available; and
- Parcel is not available for purchase.

I.3. Interstate Right-of-Way, north of Sherwood Island Connector

This parcel is of sufficient size (three acres) to accommodate the substation, but it has several technical and physical limitations. Although interconnection with the existing 115-kV transmission circuit to the south would be relatively easy, this property is located west of the load area and would present substantial challenges for connecting to the existing distribution facilities, which are located over 3,500 feet to the north. Access to the site would have to be gained directly from the highway ramp, requiring ConnDOT approvals. Historic dumping has occurred on this property, raising the likelihood of significant excavation and disposal of contaminated media, and resulting in substantial earthwork requirements to accommodate a substation at this location.

This site has limited development potential for CL&P due to:

- Its location west of load pocket;
- Poor connection possibilities to existing distribution network;
- Substantial earthwork that would be required for substation development; and
- Limited access from the highway ramp.

I.4. West of existing Sasco Creek Substation

At the site of CL&P's temporary transformer, Metro-North and ConnDOT will not allow development of a permanent substation for non-railroad-related uses. Technically, the 1.08-acre site possesses some positive features, most notably the existing infrastructure. A 115-kV line loop exists to the nearby 1890 circuit which could be brought inside a new substation to supply new power transformers. In addition, the site is accessible from Clayton Street off Maple Lane and is of sufficient size to accommodate the substation facility with two transformer positions,

but no room for a mobile transformer position. On the negative side, the existing transformer and substation are located in a residential neighborhood and there have been complaints historically by nearby residents. Regardless of the potential opportunities, this site is not feasible for further consideration because:

- The site was constructed for the sole purpose of supplying traction power to Metro-North and, as such, ConnDOT will not allow permanent use of the Sasco Creek site for another purpose; and
- Several neighboring residences are located in close proximity.

I.5. Saugatuck Avenue at Exit 17, south side of I-95

Roughly 1.5 acres in size, this site is nestled between Saugatuck Avenue to the east, I-95 to the north, and the I-95 northbound entrance ramp to the south and west. This property is currently developed and partially paved; clearing and earthwork requirements would be minimal. However, the site is located west of the load center and an existing business would require relocation. Further, connection to the existing transmission circuits would require extensive new infrastructure. There are numerous neighboring residences located along Ferry Lane West, Indian Hill Road and Hiawatha Lane immediately south of this property. In summary, this site was not considered further because:

- Connection to existing transmission circuits would require extensive new infrastructure;
- Numerous neighboring residences are located immediately to the south; and
- Redevelopment would impact an existing business operation.

I.6. Wooded Lot across from #247 Greens Farms Road

Approximately 1.2 acres of this wooded portion of the ConnDOT/I-95 Right-of-Way, located south of Greens Farms Road and immediately east of Beachside Avenue, could accommodate a substation. Connection to the existing 115-kV circuits would require crossing I-95 and installing several new support structures and interconnections. Connecting to the existing distribution network serving the load area would require bundling several new overhead circuits onto one existing line along Greens Farms Road. Significant clearing of trees that currently buffer the neighborhood north of I-95 would be required. The area also slopes down approximately 20 to 30 feet from Greens Farms Road to I-95 and would require significant earthwork to develop a site to accommodate the substation pad. Numerous homes are located to the west and north along Greens Farms Road. The following developmental constraints limit this site's potential:

- Connection to the existing 115-kV circuit would require extensive new infrastructure;
- There are poor connection possibilities to the existing distribution network;
- Substantial clearing and earthwork would be required; and
- Several residences are located in the immediate area.

I.7. Summary of Alternate Site Analysis

Six sites were evaluated for development of the Sherwood Substation. Expansion of the existing Sasco Creek Substation, where CL&P currently houses a temporary transformer, is not viable for future development because ConnDOT and Metro-North are unwilling to commit to uses other than those dedicated to the railroad. The privately-owned parcel located at the terminus of Post Office Lane was originally considered a viable alternative; however, it is not available for purchase. In addition, further evaluation of CL&P's long-term needs and the site's

configuration, showed that this parcel would provide fewer long-term benefits because it does not have sufficient space for more than two transformer positions. The Property at 6 New Creek Road is the most suitable location due primarily to its proximity to an existing circuit, accessibility to optimal feeder interconnections, and sufficient size to establish ample vegetative screening.

The other sites evaluated have technical, physical and/or environmental constraints and are not considered viable alternatives for development of the new Substation.

A comparative analysis of the sites considered for the Project is provided in Table I-1.

Table I-1: Sherwood Substation Site Alternative Analysis Matrix

Review Criteria	Location 1 6 New Creek Road Proposed Site	Location 2 Terminus of Post Office Lane	Location 3 Interstate Right-of- Way	Location 4 West of Sasco Creek Substation	Location 5 Saugatuck Avenue	Location 6 Wooded Lot Greens Farms Road
Close Proximity to Distribution Load Area and Existing Feeders	√	√		√		
Close Proximity to Existing Transmission Circuits	√	√		√		
Ease of Access	√			√	√	√
Minimal Earthwork Requirements		√		√	√	
Sufficient Size and Shape	√		√	√	√	√
No Zoning and Adjacent Land Use Constraints	√		√			
No Environmental Constraints	√			√	√	√
Sufficient Distance from Public Watershed/Aquifers	√	√		√		√

J. SAFETY AND RELIABILITY INFORMATION

The Substation would be constructed in full compliance with the standards of the National Electrical Safety Code, the Connecticut Department of Public Utility Control, and good utility practice. In the event that an energized line or substation equipment fails, protective relaying equipment would immediately remove the failed line or equipment from service, thereby protecting the public and the remaining equipment within the Substation.

The Sherwood Substation would be equipped with measures to ensure continued service in the event of outages or faults on transmission or substation equipment. Continued reliability would be achieved by incorporating a “loop through” design configuration for the existing 115-kV overhead transmission line, transformer protection, and redundant automatic protective relaying equipment.

Protective relaying equipment would be provided to automatically detect abnormal system conditions (e.g., a faulted overhead transmission line) and would send a protective trip signal to circuit breakers to isolate the faulted section of the transmission system. The protective relaying schemes would include fully redundant primary and backup equipment so that a failure of one scheme would not require the portion of the system being monitored by the protective relaying equipment to be removed from service.

The protective relaying and associated equipment, along with a Supervisory Control and Data Acquisition (“SCADA”) system for remote control and equipment monitoring by the Connecticut Valley Electric Exchange (“CONVEX”) System Operator, would be housed in a weatherproof, environmentally-controlled electrical equipment enclosure.

CL&P incorporates IEEE/ANSI and NFPA standards for fire protection in its substation design and operates these facilities to minimize the impact of fire, in the unlikely event it occurs. CL&P also trains its employees and the local fire department on the safe methods to deal with a substation fire. The control enclosure would be locked and equipped with fire extinguishers, as well as smoke detectors that would be monitored from a remote location. Smoke detection would automatically activate an alarm at CONVEX and the system operators would then take appropriate action.

Additional devices would constantly monitor the Substation to alert CL&P of any abnormal or emergency situations. The perimeter of the Substation would be enclosed by a seven-foot high chain link fence topped with an additional foot of three strands of barbed wire to discourage unauthorized entry and/or vandalism. The Substation entrance would be gated and locked. Lighting would be available within the Substation yard to facilitate work at night or during inclement weather.

CL&P would install sumps to serve as oil-spill containment reservoirs around the proposed transformers. The sumps would be sized with sufficient capacity to contain a spill in the event of an inadvertent release of oil. CL&P plans to install an Imbiber Beads Drain Protection System® for the sump, similar to containment systems installed at other CL&P substations.

K. EFFECTS ON THE ENVIRONMENT

The development of the Sherwood Substation would not have any long-term adverse effects on the existing environment and ecology, nor would it affect the scenic, historic and recreational values of the vicinity. A *Proposed Conditions Map* is included as Figure K-1.


K.1. Public Health and Safety

The Sherwood Substation would be designed to applicable CL&P, industry, State, and local codes and standards and would not pose a safety concern or create undue hazard to the general public. The Substation would not consume any raw materials, would not produce any by-products and would be unmanned during normal operating conditions. Applicable signage would be installed alerting the general public of the dangers of high voltage associated with the Substation, as well as a seven-foot tall chain-link fence topped with one foot of barbed wire (three strands). There are no plans to store fuels or hazardous materials at the Substation.

K.2. Local, State and Federal Land Use Plans

The Project is consistent with local, State, and federal land use plans. Local land use application processes do not specifically apply to the Project. However, the Project has been designed to meet the intent of local land use regulations. According to the Town of Westport Zoning Regulations, the Property lies within an area zoned as Residential (AAA), and is not within an Aquifer Protection Zone. Pursuant to Section 11-2.2.8 of the Westport Zoning Regulations, public utility buildings and facilities necessary for the services of the surrounding residential area are a permitted use with a Special Permit and Site Plan Approval. The general area of the Property is identified in the *Westport 2007 Plan of Conservation and Development* (a copy of which has been provided to the Council under a separate Bulk Filing) to be land for

Figure K-1: Proposed Conditions



single-family development and transportation/utility infrastructure. CL&P has met with Town officials and provided Location Review submissions to Westport's Conservation Commission and Planning and Zoning Commission. These Commissions provided comments which have been addressed by CL&P.

K.3. Existing and Future Development

The Sherwood Substation would benefit the community by improving electrical service for existing development in the Town and surrounding areas, as well as supporting additional development through enhanced reliability and the capacity to serve additional load. The Town of Westport currently has two older distribution substations and one temporary substation. None of the existing substations have the ability to expand.

The Substation would be situated immediately south of the existing overhead transmission line corridor, generally in the eastern portion of the Property. The Substation would be located within an irregularly shaped fenced compound that would encompass a 21,370 ± square foot area (measuring approximately 137 feet by 160 feet at its longest dimensions). Connecting the Substation to the existing transmission circuit requires the installation of two new steel monopoles within the railroad ROW immediately north of the Site. These new structures would be similar in height to those currently occupying the transmission line corridor, and two new line-terminal structures within the Substation.

K.4. Roads

CL&P initially evaluated using the existing driveway for permanent access to the Substation; however, its grade would not be compatible with that of the Substation final base

elevation. Further, the existing driveway configuration would not allow for delivery and removal of a mobile transformer in the event of an emergency.

A new 15-foot wide paved driveway would be developed to serve as entry/egress from New Creek Road to the Substation. A bituminous concrete apron would be provided at the entrance of the Property along New Creek Road, south of the railroad overpass and west of the entrance to the Metro-North commuter station parking lot. This would serve as the only access to the Site once the Substation is operative. The existing driveway would be used during construction; anti-tracking mats would be installed to prevent tracking of soil onto local streets.

During construction of the Substation, the new driveway would be stabilized with stone, and anti-tracking mats would also be installed in this location. Upon completion of the Project, the new driveway would be finished with a gravel base and gated. Once the Project is completed, the existing driveway and pavement would be removed and the area landscaped. After construction is completed, approximately three to four vehicular trips per month to the Property would be anticipated for maintenance and inspection activities.

K.5. Wetlands

No direct impacts to on-site wetlands would occur as a result of construction or operation of the Substation. No portion of the 21,370± square foot Substation fenced compound would be located within wetlands and none of the Substation components/structures would be situated within 50 feet of the on-site wetlands. A small section of the Substation's northwest corner (consisting of trap rock and fencing) would fall within 50 feet of the wetlands.

No impacts to the tidal wetland system located across New Creek Road would occur.

K.6. Wildlife and Vegetation

The Substation would occupy what is currently a developed residential building lot. Construction of the Substation would require the removal of several existing trees and landscape shrubs, but would not have significant adverse effects on wildlife or habitat values.

Any effects on wildlife and wildlife habitat would be minimal and limited to temporary disturbances during construction. The Property is currently used by wildlife species that are typically generalists, commonly found in the area, and adaptable to habitat modifications. The wetland habitat found on the Property would remain intact and the adjoining upland area to its east would be enhanced, ultimately increasing its wildlife value. Based on the habitat types found on the Property and surrounding area, species diversity and abundance should be maintained after the Substation is completed and operational.

K.6.1. Rare, Threatened, and Endangered Species

No state or federally endangered, threatened or special concern species have been identified on the Property. Based on current CTDEP NDDB review criteria, the Project does not present a potential conflict with a listed species or significant natural community. CL&P received confirmation in writing on June 19, 2008 and December 18, 2009 that no known extant populations of federal or state endangered, threatened, and special concern species occur at the Property (refer to *CTDEP Correspondence*, in Volume II, Exhibit 4). In email correspondence dated December 18, 2009, CTDEP personnel indicated that special care should be taken to adhere to coastal regulations as they relate to avoiding run-off or impacts to the nearby marsh, including avoiding siltation into the marsh or any other long-term impacts from the Project. As discussed in Section L of this Application, CL&P will implement measures to protect this resource throughout construction and during operation of the Substation.

K.7. Water Supply Areas

There are no known public water supply wells located in the vicinity of the Property. The transformers at the Sherwood Substation would contain mineral oil. However, this equipment would have secondary containment and accidental spill prevention provisions in place. Based on these design considerations, the Project would have no adverse environmental effect on the water resources.

K.8. Historic and Archaeological Resources

Based on the consultation with the SHPO, the Property lacks historical and architectural importance. As a result, no impacts to historic/cultural resources are anticipated.

K.9. Noise

After the Substation is placed in service, infrequent impulse noise would be generated from switching and circuit breaker opening and closing. The impulse noise levels and steady-state transformer noise levels are not expected to exceed the levels permitted at the Property line by CTDEP's noise control regulations.

The construction and testing of the Substation facilities is expected to occur over a 12- to 18-month period. In general, construction hours would be from 7 a.m. to 5 p.m., Monday through Friday. Site preparation, including grading and installation of foundations, would take place during the initial six months of construction and involve the use of earth-moving equipment and construction vehicles.

The installation and testing of equipment would take approximately nine months and would involve the use of cranes to unload and install structural elements and large equipment. The installation of the 115-kV line and Substation terminal structures, interconnection of the

supply lines to the Substation, and connections to the distribution system would occur outside of normal work hours because these activities necessitate taking critical transmission and/or distribution equipment out of service. As a result, this work would be scheduled for off-peak electrical demand hours and coordinated with the Town.

K.10. Floodplains

Although portions of the Site are located within the 100-year floodplain and 500-year floodplain, the activities associated with the Substation would be located entirely outside of these areas.

K.11. Seismic Areas

As with all substations constructed by CL&P, this Substation would meet or exceed the State Building Code, which includes seismic loading, wind loading, and snow and ice loadings, among others.

K.12. Lighting

The Sherwood Substation would have low-level lighting for safety and security purposes. These lights would be recessed or activated manually to minimize visual effects at night. Lighting would not affect existing residences in the vicinity of the Property. Additional lighting capability would exist in the Substation to allow for work at night under abnormal or emergency conditions.

K.13. Natural Resources

No adverse effects are anticipated on natural resources occurring at and/or nearby the Property. Vegetative clearing and earthwork would be required for construction of the

Substation; however, no impacts to wetlands would occur. Select areas within 75 feet of the wetland resource on the Property would be disturbed by grading activities, a small (northwest) corner of the Substation (which would include a breaker arrangement), and installation of a bioswale and a level spreader. Cut and fill slopes would not exceed two to one (2:1) grades, and would be loamed and seeded where not incorporated into the landscape plan.

Existing trees that require removal at the Property, several of which are non-native species, would be replaced with a variety of specimens, the majority of which are native to the region. CL&P also proposes to enhance the buffer area between the Substation and the adjacent wetland resource.

K.14. Coastal Zone Management Areas

The Site falls within the Coastal Area Management Boundary, as defined by Conn. Gen. Stat. § 22a-94(a). No tidal wetlands/ watercourses or coastal resources are located on the Site. A tidal (wetland) salt marsh is located approximately 50 feet from the Site immediately southeast of New Creek Road. Greens Farms Brook flows within the marsh interior. An on-site inland freshwater wetland system discharges to the tidal marsh via a 15-inch culvert beneath New Creek Road. The on-site freshwater wetland is not subject to tidal influence due to its elevation.

The Project would not result in adverse impacts to coastal resources as defined in the Connecticut Coastal Management Act (CCMA). The CCMA identifies eight adverse impacts to coastal resources. This section provides a definition of each adverse impact for each resource area and explains why the Project would not adversely affect each resource.

- 1) *Degrading **water quality** of coastal waters by introducing significant amounts of suspended solids, nutrients, toxics, heavy metals or pathogens, or through the significant alteration of temperature, pH, dissolved oxygen or salinity.*

The Project would not affect water quality within the adjacent tidal marsh or Greens Farms Brook. Erosion and sediment controls would be established as required by CTDEP Bulletin 34 *Connecticut Guidelines for Soil and Erosion and Sediment Control, dated 2002*. Stormwater generated by the Project would be adequately treated, both in quantity and quality, in general accordance with the 2004 CT Stormwater Quality manual.

- 2) *Degrading **existing circulation patterns of coastal waters** by impacting tidal exchange or flushing rates, freshwater input, or existing basin characteristics and channel contours.*

The Property is currently developed and outside of tidally influenced areas and as such would not impact current drainage or circulation patterns.

- 3) *Degrading **natural erosion patterns** by significantly altering littoral transport of sediments in terms of deposition or source reduction.*

The Project would not affect littoral transport of sediments.

- 4) *Degrading **natural or existing drainage patterns** by significantly altering groundwater flow and recharge and volume of runoff.*

Drainage patterns would not be significantly altered by the Project. It is anticipated that the proposed stormwater treatment practices would maintain or increase groundwater recharge at the Site and not increase runoff for the 5-, 10- and 25-year design storms.

- 5) *Increasing the hazard of **coastal flooding** by significantly altering shoreline configurations or bathymetry, particularly within high velocity flood zones.*

Portions of the Site occur within the 100-year and 500-year floodplains; however, the proposed activities would be located outside of the 100-year and 500-year floodplains and would not affect the shoreline configuration.

- 6) *Degrading **visual quality** by significantly altering the natural features of vistas and viewpoints.*

The Project is located approximately 1,000 feet from the nearest coastal resource and would not degrade the visual quality of the area. The Project consists of demolishing an existing residential structure and constructing the Substation in the eastern portion of the Site. The Substation would be located at a ground elevation approximately 4 to 8 feet lower than what exists today. Planned landscaping would incorporate earthen berms and extensive vegetative screening, resulting in the lower portions of the Substation being largely out of view.

- 7) *Degrading or destroying **essential wildlife, finfish or shellfish habitat** by significantly altering the composition, migration patterns, distribution, breeding or other population characteristics of the natural species or significantly altering the natural components of the habitat.*

No essential wildlife, finfish or shellfish habitat exist on portions of the Property planned for construction activities.

- 8) *Degrading **tidal wetlands, beaches and dunes, rocky shorefronts, and bluffs and escarpments** by significantly altering their natural characteristics or function.*

The Project would not alter the natural characteristics of any coastal resource area as none exist on the Site.

K.15. Other Surrounding Features

No adverse effects are anticipated to the facilities listed in Table H-1, primarily because of their sufficient distance from the Substation and/or the presence of the existing transportation and utility infrastructure corridor.

L. MITIGATION MEASURES

CL&P has incorporated measures into all phases of Project development and implementation to promote protection of the environment in accordance with federal, State and local requirements.

L.1 Pre-Construction Considerations

Before any construction activities occur, CL&P would prepare a Development and Management Plan (“D&M Plan”), which would be submitted for approval by the CSC. The D&M Plan would include *CL&P’s 2005 Construction Best Management Practices*, which are designed to minimize or eliminate potential adverse environmental effects that may result from construction activities. The D&M Plan would include specific procedures and information on erosion and sedimentation control, spill prevention and control, construction staffing and hours, traffic control, and provisions for restoration and landscaping after construction of the Substation. The D&M Plan would also provide contact information should questions or concerns arise during construction or operation of the facility.

Prior to commencement of construction, CL&P intends to install erosion controls at the limits of work in accordance with the approved D&M Plan and the *2002 Connecticut Guidelines for Soil Erosion and Sedimentation Control*. The erosion controls would be inspected and maintained throughout the course of the Project until final site stabilization has been achieved.

L.2 Construction-Related Activities

All construction activities would be conducted in accordance with the required D&M Plan as approved by the CSC. The siting and design of the Substation provides for a sufficient

setback from on-site wetlands. Vegetation loss resulting from the development would be compensated by establishing a substantial natural buffer of tree and shrub landscaping and enhancement of the upland area adjacent to the wetlands. The Substation would be graded to contain and treat stormwater runoff on the Property via an infiltration trench. The remainder of the stormwater would infiltrate through the gravel base of the Substation or would be allowed to run off through vegetated uplands.

Approximately 21,800 square feet within 75 feet of on-site wetlands (and 13,800± square feet within 50 feet) would be disturbed as a result of the proposed construction activities. These activities primarily include landscaping and, to a lesser degree, grading, construction of a portion of the fenced Substation compound (1,620 square feet within 75 feet and 52 square feet within 50 feet of wetlands), and the installation of a bioswale and level spreader to treat stormwater.

CL&P's Best Management Practices would be utilized in accordance with the *2002 Connecticut Guidelines for Erosion and Sediment Control* (see typical details on enclosed drawing C-6 in Volume II, Exhibit 1, *Site Plans*) throughout the course of construction activities at the Site and maintained until disturbed areas have been stabilized. Geotextile fabric sediment barriers would be placed between the development footprint and wetland resource areas during construction and maintained until the Site is stabilized and rehabilitated.

L.3 Post-Construction Features

Upon completion of construction activities, all disturbed/exposed areas would be stabilized with topsoil and seeded with a New England conservation/wildlife mix, to establish a

cover of native grasses, forbs, wildflowers and legumes that would provide both soil stability and wildlife habitat value. Erosion controls would remain in place until final site stabilization is achieved.

After construction, a small portion of the northwest corner of the Substation (which would include a breaker arrangement) and the bioswale and a level spreader would be located within 75 feet of wetlands. Construction-related disturbances to the remaining area within 75 feet between the Substation and the adjacent wetland resource would be enhanced by a combination of seed mixes containing native grasses and forbs for post-construction stabilization in all exposed areas, including those within the proposed landscaped areas.

Areas along the east side of the on-site wetland resource would be undersown with a New England wet mix to create a wetland meadow environment. The adjoining upland area to the east, currently occupied by a portion of an existing driveway, lawn and landscaped areas would be undersown with a New England conservation mix to establish a tall meadow; non-native plant species (excluding mature trees) and lawn would be removed within this area and trees and shrub species native to the region would be planted. Along the south and east portions of the Site, a low meadow mix would be used in combination with landscaping of native trees. A Concept Planting Plan is provided in Volume II, Exhibit 1, *Site Plans*.

All of the 21,800± square feet of disturbance within 75 feet of the on-site wetland resource would be pervious to stormwater following Site construction activities. This represents a net gain of 4,209± square feet of pervious surfaces within this area from existing conditions, due to the conversion of the on-site residence and paved driveway to landscaping.

The Project includes the installation of two 60-MVA transformers that would contain insulating (mineral) oil. The transformer equipment would each have secondary containment designed to hold 110 percent of a transformer's fluid capacity, and accidental spill prevention measures in place. CL&P proposes to install Imbiber Bead® Containment Systems for the sumps, similar to containment systems installed at other CL&P substations, to assist in preventing oil discharges from the containment sumps. Further, a low oil level alarm that is integral to the system would be monitored remotely and would notify CL&P in the event of abnormal conditions. Periodic inspections of the sumps would be performed by CL&P personnel to promote proper functioning of the systems. Based on these design considerations, the Project would have no adverse environmental effect.

CL&P would provide extensive landscaping around the Substation perimeter, resulting in the fencing and lower portions of internal equipment being largely out of view. Lighting would be available within the Substation yard to facilitate work at night under emergency conditions and during inclement weather. The Substation would have low-level lighting for safety and security purposes. However, these lights would be recessed or activated manually to minimize visual effects at night. Lighting would not extend beyond the limit of the fenced area.

L.4 Construction Sequencing

The general construction sequence for the Substation and line interconnection would include:

- Installation of erosion and sedimentation control measures;
- Construction of the access drive;
- Removal of the existing residential dwelling;
- Removal of trees and shrubs within the areas to be graded;
- Preparation of the Site (cut, fill, grading);
- Installation of Substation foundations, conduits and grounding grid;
- Spreading trap rock;

- Installation of steel structures and Substation equipment;
- Installation of transmission line interconnections;
- Removal of existing driveway;
- Commissioning the Substation;
- Completion of Site restoration activities; and
- Removal of erosion and sedimentation control measures.

As requested by the Town and consistent with CL&P's Best Management Practices for construction of substations:

- The erosion and sediment controls would be employed by the contractor during the earthwork and construction phases of the Project in accordance with the *2002 Connecticut Guidelines for Soil Erosion and Sediment Control*;
- Prior to starting any other work on the site, CL&P's contractor would notify the appropriate agencies and install appropriate erosion control measures as depicted on the Site Plans in Volume II;
- CL&P's contractor would inspect and maintain erosion-control measures, remove sediment from the erosion-control measures on a weekly basis and within twenty-four hours after each storm event and dispose of sediments in an upland area such that they do not encroach into other protected areas;
- CL&P's contractor would be fully responsible for controlling construction activities such that sedimentation will not affect regulated areas, whether such sedimentation is caused by water, wind or direct deposit;
- CL&P's contractor would perform construction sequencing such that earth materials are exposed for a minimum of time before they are covered, seeded, or otherwise stabilized to prevent erosion; and,
- Upon completion of construction and establishment of permanent ground cover, CL&P's contractor would remove and dispose of erosion-control measures, and remove sediment and debris from areas where control measures were used.

M. HEALTH AND SAFETY

M.1 Electric and Magnetic Fields

Electric fields (“EF”) are produced within the surrounding area of a conducting object (e.g., a wire) when a voltage is applied to it. EF are measured in units of kilovolts per meter (“kV/m”). The level of an EF near to energized power line depends on the applied voltage, the distance between the conductors, and the distance to the measurement location.

Magnetic fields (“MF”) are produced within the surrounding area of a conductor or device which is carrying an electric current. MF are measured in units of milliGauss (“mG”). The level of a MF near to line conductors carrying current depends on the magnitude of the current, the distance between conductors, and the distance from the conductors to the measurement location.

Both electric and magnetic fields decrease rapidly as the distance from the source increases, and even more rapidly from electric equipment in comparison to line conductors. EF levels are further weakened by obstructions such as trees and building walls, while MF pass through most obstructions. In the case of parallel lines of circuit conductors, the levels of EF and MF are also dependent on the phasings of the circuits.

The highest levels of electric and magnetic fields around the perimeter fence of a substation occur where transmission and distribution circuits cross over or under the substation boundary. The levels of fields from substation equipment decrease rapidly with distance, reaching very low levels at relatively short distances beyond the fenced-in equipment. Substation-caused MF off the property of a substation will commonly be in the same range as the background MF levels in homes, which commonly range up to four (4) mG.

Pre-Project Magnetic Fields on Boundaries of the Property

At and beyond the Property boundaries of the Substation, the predominant existing sources of power-frequency MF are the 1130 and 1890 transmission line conductors, which are routed west to east with respect to the Property. The centerline of the 1890 Line's conductors, which are mounted on the railroad catenary structures, is approximately 35 feet to the north of the Property's northerly border; the centerline of the 1130 Line's conductors is approximately 100 feet to the north of the Property's northerly border. The two circuits as they are constructed today utilize phasings such that cancelling of interaction of their power-frequency MF is optimum.

The MF calculations of the pre-project circuits were made using projected seasonal peak and peak day average currents in the two transmission circuits in 2012, before the proposed Substation is placed in service. For this purpose, the projected peak transmission circuit currents were estimated using ISO New England's 90/10, system power-flow forecast of the summer peak in 2012. The projected pre-project, seasonal peak and peak day average circuit currents in the 1130 Line used in these calculations are 637 and 705 amperes, respectively. The projected pre-project, seasonal peak and peak day average circuit currents in the 1890 Line are 354 and 606 amperes, respectively.

The magnetic fields resulting from the pre-project circuit configuration in 2012 were calculated along a path perpendicular to the existing lines that extend 300 feet from each of the existing transmission lines. This path is labeled "Line West" on the Figure M-1 (*Locations of MF Calculations*) and MF values at four points along Line West are provided in Table M-1. Please refer to Figures M-2, M-3, M-4 and M-5 for graphs of Magnetic Fields.

Figure M-1: Locations of MF Calculations




Table M-1: Existing Magnetic Fields in 2012

Location along Perpendicular Path – Line West	Magnetic Field (mG) Levels at Projected Seasonal Peak Circuit Currents in 2012	Magnetic Field (mG) Levels at Projected Seasonal Peak Day Average Currents in 2012
300 feet north of the northernmost transmission circuit (1130)– North of the Property	0.53	0.44
Beneath northernmost transmission circuit (1130)	12.79	15.07
Beneath southernmost transmission circuit (1890)	11.64	20.10
300 feet south of the southernmost transmission circuit (1890) – West of the Property	0.20	0.36

MAGNETIC FIELD PROFILE PERPENDICULAR TO THE TRANSMISSION CIRCUITS EAST OF PROPOSED SHERWOOD SUBSTATION USING OPTIMUM CIRCUIT PHASING IN THE PROPOSED LINE CONFIGURATION AND PROJECTED SEASONAL PEAK DAY AVERAGE CURRENTS IN 2017




Figure M-2

MAGNETIC FIELD PROFILE PERPENDICULAR TO THE TRANSMISSION CIRCUITS WEST OF PROPOSED SHERWOOD SUBSTATION USING OPTIMUM CIRCUIT PHASING IN THE PROPOSED LINE CONFIGURATION AND PROJECTED SEASONAL PEAK DAY AVERAGE CURRENTS IN 2017




Figure M-3

MAGNETIC FIELD PROFILE PERPENDICULAR TO THE TRANSMISSION CIRCUITS EAST OF PROPOSED SHERWOOD SUBSTATION USING OPTIMUM CIRCUIT PHASING IN THE PROPOSED LINE CONFIGURATION AND PROJECTED PEAK CURRENTS IN 2017




Figure M-4

MAGNETIC FIELD PROFILE PERPENDICULAR TO THE TRANSMISSION CIRCUITS WEST OF PROPOSED SHERWOOD SUBSTATION USING OPTIMUM CIRCUIT PHASING IN THE PROPOSED LINE CONFIGURATION AND PROJECTED PEAK CURRENTS IN 2017




Figure M-5

Changes That Would Affect Magnetic Fields

The existing 1890 transmission circuit would be looped into the proposed Substation. The segment of the existing 1890 transmission circuit to the east of the Property would be renamed the 1578 transmission circuit; the remaining segment of this transmission circuit to the west of the Property would remain the 1890 transmission circuit. The currents on these transmission circuits would remain predominantly east to west but would change slightly because distribution loads would be moved to the new Substation. The projected seasonal peak and peak day average currents in the year 2017 on the 1578 transmission circuit are 539 and 441 amperes, respectively; projected seasonal peak and peak day average currents in the year 2017 on the 1890 transmission circuit are 334 and 278 amperes, respectively; projected seasonal peak and peak day average currents in the year 2017 on the 1130 transmission circuit are 679 and 574 amperes, respectively.

The fence of the Substation would be approximately 40 feet at its closest point from any Property line, specifically the northerly Property line. At this distance, and because the line conductors and electric railroad lines are sources of MF on the north side, the Substation equipment within the fenced area would not noticeably contribute to any change in MF along the Property lines. However, there would be a small change to the existing magnetic field levels at points on and beyond the Property lines due to the change in loads flowing in the looped transmission line into the Substation.

Projected Magnetic Fields on Boundaries of the Property

CL&P made calculations of the projected magnetic field levels along two paths that run perpendicular to the transmission lines. These paths are located 300 feet to the west and 300 feet to the east of the proposed Substation and are referred to herein as Line West and Line East, respectively (see Figure M-1, *Locations of MF Calculations*). The location of Line West was specifically chosen because the closest residential dwelling is located along this calculation path at about 300 feet south of the nearest transmission line and 150 feet from the Substation's westerly Property boundary.

The magnetic fields of the existing lines were calculated using projected levels of system power-flow model simulations using ISO New England's 90/10 forecast of seasonal peak circuit currents in the year 2012, before the Substation is placed in service, and projected seasonal peak day average circuit current five years after the Substation is placed in service (2017). The transmission circuits connecting to the Substation were modeled with their typical minimum clearance to ground of 40 feet in this area. In addition, the proposed modifications to the transmission lines would retain the optimum circuit phasings.

Table M-2 tabulates projected magnetic field levels at points along the calculation paths Line West and Line East after the Substation is placed in service.

Table M-2: Projected Magnetic Field Levels in 2017

Line West		
Location along Perpendicular Path – Line West	Magnetic Field (mG) Levels at Projected Seasonal Peak Circuit Currents in 2017	Magnetic Field (mG) Levels at Projected Seasonal Peak Day Average Currents in 2017
300 feet north of the northernmost transmission circuit (1130)– North of the Property	0.55	0.48
Beneath northernmost transmission circuit (1130)	14.66	12.32
Beneath southernmost transmission circuit (1890)	16.79	13.72
300 feet south of the southernmost transmission circuit (1890) – West of the Property	0.28	0.24
Line East		
300 feet north of the northernmost transmission circuit (1130) – North of the Property	0.57	0.49
Beneath northernmost transmission circuit (1130)	13.55	11.44
Beneath southernmost transmission circuit (1578)	11.01	9.18
300 feet south of the southernmost transmission circuit (1578) – East of the Property	0.25	0.21

Consistent with the Connecticut Siting Council's *Electric and Magnetic Field Best Management Practices for the Construction of Electric Transmission Lines in Connecticut*, the design of the Substation incorporates field management practices as follows:

- The Substation has been located very close to an existing transmission line so that the lengths of Substation entry spans are very short.
- Optimum circuit phasing would be retained to enhance magnetic field cancellation. While the line loads projected on the 1890 transmission circuit during seasonal peak conditions in 2017 are expected to decrease from the existing levels, the magnetic field levels would increase by 0.08 mG at a point 300 feet south along Line West. The magnetic fields at this same point would increase 0.12 mG during the seasonal peak average load conditions, five years after the Substation is placed in service. This is due to the fact that the 1890 transmission circuit would provide less cancellation of the magnetic fields caused by the 1130 transmission circuit.
- The Substation equipment has been located at a sufficient distance from Property lines so that this equipment makes no noticeable contribution to magnetic field levels along these Property lines.

There are no state or federal limits for magnetic field levels at the property line of a substation. However, the Institute of Electrical and Electronic Engineers ("IEEE") and the International Commission on Non-ionizing Radiation Protection ("ICNIRP") have issued guideline limits for long-term public exposures to magnetic fields. These limits are:

	<u>Magnetic Field (mG)</u>
IEEE	9,040
ICNIRP	833

The existing and proposed levels of magnetic fields at and beyond the Property lines are typical for all similar substations and well below these IEEE and ICNIRP limits. Based on these aforementioned guidelines and science peer group reviews of epidemiological and laboratory studies, these magnetic field exposure levels would not pose an undue safety or health hazard to persons or property at or adjacent to the Property.

M.2 Site Security

A seven-foot-high chain link fence topped with one foot of barbed wire (three strands) would enclose the Substation yard to prevent unauthorized access. The Substation yard would also be gated and locked. All gates would be padlocked at the end of the work day during construction activities and at all times once the Substation is in service. Appropriate signage would be posted at the Substation alerting the general public of high voltage facilities located within the Substation. Should equipment experience a failure, protective relaying would immediately remove the equipment from service, thereby protecting the public and the equipment within the Substation. Other devices installed within the Substation would constantly monitor the equipment to alert CL&P of any abnormal or emergency situations.

M.2.1 Energy Facility Security

As a general rule, in its planning process for new facilities, CL&P carefully designs its facilities to protect the security of the site and the on-going transmission of electricity. In response to the Council's concerns expressed in its White Paper on the security of siting energy facilities, in addition to the design features and the measures discussed above to monitor the operation of the Sherwood Substation and to discourage unauthorized entry onto the Site, CL&P met with law enforcement and emergency response personnel in Westport to discuss the Substation and coordination of efforts to protect its security. On November 5, 2009, Project team members, along with CL&P's Southern Division Safety Administrator, met with the Westport First Selectman Gordon Joseloff, Police Chief Al Fiore, and Assistant Fire Chief Jonathan Gottfried. CL&P provided a briefing on the lay-out of the Substation and site features, including the fencing design for the Substation yard, including height (7 feet), three strands of

barbed wire atop the fence, and chain link with vinyl coating, as well as plantings and landscaping.

In addition, CL&P discussed moving the main entrance driveway from its initial location in the vicinity of the existing driveway to a point facing almost due east towards the northbound railroad parking lot entrance, to help reduce the impact and visibility of the Substation yard from nearby properties and people driving down Maple Lane towards New Creek Road.

CL&P also suggested that the Town of Westport increase the number of streetlights from the Greens Farms Academy exit drive to the train station. CL&P recommended the use of small, 70 watt lights, on existing utility poles currently without lights, to increase security for all properties in the vicinity and pedestrian safety. The Town and CL&P plan to continue their discussions on additional lighting as the Project progresses.

Site construction was also discussed. CL&P will work closely with the Westport Police Department to establish off-duty police protection at the site during the course of major construction activity.

M.3 Traffic Considerations and Hours of Operation

Access would be gained from the proposed, at-grade driveway to be established along New Creek Road. Post-construction site conditions would not substantially affect existing traffic patterns. Once construction of the Substation is complete, the facility may be remotely operated, with personnel on site only for periodic inspections, maintenance and emergency work.

N. PROJECT SCHEDULE

Construction is expected to begin in the fall of 2010, with the Substation in service in January 2012.

O. GOVERNMENT APPROVALS OBTAINED

Pursuant to Conn. Gen. Stats. § 16-50l(e), the Municipal Consultation Filing (“MCF”) was completed and delivered to the chief elected official of the Town of Westport on October 14, 2009, beginning the 60-day (minimum) consultation process.

On many occasions over the past eighteen months, CL&P has consulted with Town of Westport officials, including First Selectman Gordon F. Joseloff, regarding the electric service provided by CL&P to the Westport community and CL&P’s desire to improve the reliability of that service. On April 12, 2009, CL&P officials also met with Mr. Joseloff, the Director of Planning and Zoning, Laurence Bradley, the Conservation Director, Alicia Mozian, and the Director of Public Works, Stephen Edwards. These officials were briefed on CL&P’s determination that a new substation would be required in Westport, based on the Town’s growing need for additional electrical distribution capacity and to improve system reliability.

As part of the State review process, Connecticut law provides a mechanism for input by certain town land use agencies on electric substation locations. Specifically, Conn. Gen. Stat. §16-50x(d) permits zoning commissions and inland wetland commissions to “regulate and restrict the proposed location” of such public utility facilities. CL&P filed “Location Review” submissions with the Westport Conservation Commission and the Planning and Zoning Commission (the “P&Z”) on May 14, 2009.

At the request of the Town, a June 8, 2009 site walk was hosted by CL&P for Town staff and members of the P&Z and Conservation Commission to familiarize themselves with the Property and the Project. On June 9, 2009, the Town’s Conservation Analyst, Lynne Krynicki,

provided her written comments to CL&P. CL&P responded to these comments in a June 17, 2009 letter.

On June 11, 2009, CL&P gave a presentation to the P&Z at its regular meeting. At its next working session on June 25, 2009, the P&Z discussed and agreed upon its preliminary findings and subsequently provided a recommendations letter (dated June 26, 2009) to the Council. CL&P responded to the P&Z on September 23, 2009. CL&P similarly presented the Substation to the Conservation Commission on June 17, 2009. One member of the public spoke and asked questions. The Conservation Commission indicated that the minutes of their meeting would serve as its comments. CL&P responded to the Conservation Commission meeting minutes on September 23, 2009.

CL&P also met with the Westport Architectural Review Board (the “ARB”) on July 14, 2009 to present the Substation. The ARB expressed a preference for painting the control enclosures an earth tone color (either green or brown), incorporating dense, tall plantings into the site landscaping, and inclusion of a decorative gate at the Site entrance. As discussed in Section M.2.1 of this Application, Project team members, along with CL&P's Southern Division Safety Administrator, met with the Westport First Selectman Gordon Joseloff, Police Chief Al Fiore, and Deputy Fire Chief Jonathan Gottfried on November 5, 2009, to discuss energy security issues.

After the filing of the MCF, the First Selectman requested that CL&P meet again with the Conservation and P&Z Commissions and Town staff provided its comments regarding the MCF on October 13, 2009. CL&P responded in writing to the Town staff comments in a letter dated November 16, 2009. On November 18 and 19, 2009, CL&P attended public meetings of the

Conservation and P&Z Commissions, respectively. At such meetings, CL&P provided an overview of the changes to the site plan since the Location Review process (including comments received from the Commissions and Town staff) and addressed all issues raised by Commission members. No members of the public spoke in favor or opposition to the Project when provided the opportunity. By letter dated November 20, 2009, the Conservation Commission informed CL&P that it was prepared to support the Project upon filing of the updated site plan. The P&Z Commission commended CL&P for its excellent responses to the Town's questions raised throughout the process. By letter dated December 7, 2009, the P&Z Director stated that the P&Z Commission was satisfied with the Project as presented. By letter dated December 7, 2009, the First Selectman indicated the Town's support for the Sherwood Substation.

Copies of correspondence between CL&P and the Town are included in Volume II, Exhibit 6, *Government Approvals Obtained*.

Table O-1 summarizes the applicable approvals required for this Project.

TABLE O-1: PERMITS APPLICABLE TO THE SHERWOOD SUBSTATION PROJECT				
AGENCY	PERMIT	DATE SUBMITTED	DATE RECEIVED	LOCATION
Connecticut Siting Council	Certificate of Environmental Compatibility and Public Need under Connecticut General Statutes Section 16-50l(a)(1)	December 29, 2009		
Connecticut Natural Diversity Data Base	T&E clearance under state Endangered Species Act (Connecticut General Statutes Sec. 26-303 to Sec. 26-315)	Consultation initiated on May 19, 2008; and, December 18, 2009	June 19, 2009; and, December 18, 2009	CSC Application Volume II Exhibit 4, CTDEP Correspondence
Connecticut Historical Commission	Cultural Resource Consultation under Section 106 of the National Historic Preservation Act	Consultation initiated on May 19, 2009	May 21, 2009	CSC Application Volume II Exhibit 5, SHPO Correspondence
Town of Westport	Municipal Consultation Filing under Connecticut General Statutes Section 16-50l(e)	October 14, 2009	60-day period ended December 14, 2009	CSC Application Bulk Filing #1
Town of Westport Conservation Commission	Location Review Application under Connecticut General Statutes Section 16-50 x(d)	May 14, 2009	September 23, 2009	CSC Application Bulk Filing #1
Town of Westport Planning and Zoning Commission	Location Review Application under Connecticut General Statutes Section 16-50 x(d)	May 14, 2009	June 26, 2009	CSC Application Bulk Filing #1

P. BULK FILING OF MUNICIPAL DOCUMENTS

A bulk filing of municipal regulations and documents that were submitted to the Town of Westport is being provided solely to the Council under a separate attachment, as part of this Application, including the below-referenced applications submitted by CL&P and applicable local regulations, respectively:

- Application to the Town of Westport Conservation Commission pursuant to Conn. Gen. Stats. § 16-50x(d) Location Review;
- Application to the Town of Westport Planning and Zoning Commission pursuant to Conn. Gen. Stats. § 16-50x(d) Location Review;
- Inland Wetlands and Watercourses Regulations of the Town of Westport;
- Town of Westport, Connecticut Zoning Regulations;
- Westport Plan of Conservation and Development; and,
- Municipal Consultation Filing.

Q. ADMINISTRATIVE NOTICE, PUBLIC AND ABUTTERS NOTICE, SERVICE AND OTHER FILING REQUIREMENTS

As requested by the CSC, CL&P is furnishing to the CSC one original and 20 copies of the Application, as well as an electronic version of the Application.

This Application is presented based on the CSC's June 2007 *Application Guide for Electric Substation Facility* to assist applicants in filing for a Certificate from the CSC for the construction of an electric substation as defined in Conn. Gen. Stat. § 16-50i (a) (4).

CL&P also consulted Conn. Gen. Stat. §§ 16-50g through 16-50aa and Sections 16-50j-1 through 16-50z-4 of the Regulations of Connecticut State Agencies in preparing this Application.

Q.1 Administrative Notice

CL&P requests administrative notice of the following CSC docket records, generic hearings or statements prepared by the CSC as a result of generic hearings, and other pertinent documents. We would suggest the following documents be included.

- *Energy Plan for Connecticut Prepared by the Connecticut Energy Advisory Board, Connecticut Energy Advisory Board, February 6, 2007*
- *An Assessment and Report of Distributed Generation Opportunities in Southwest Connecticut, Institute for Sustainable Energy at Eastern Connecticut State University with assistance from XENERGY, January 14, 2003*
- *Distributed Generation Market Potential: 2004 Update/Connecticut and Southwest Connecticut, Institute for Sustainable Energy at Eastern Connecticut State University with assistance from XENERGY, March 15, 2004*
- *Connecticut Department of Public Utility Control, Docket 05-07-17RE01 and Docket 05-07-17RE02, DPUC Review of the Development of a Program to Provide Monetary Grants for Capital Costs of Customer-Side Distributed Resources, final decision dated September 25, 2007 and March 18, 2009, respectively*

- *Connecticut Siting Council Review of the Connecticut Electric Utilities Ten-Year Forecast of Loads and Resources, 2007, 2008, and 2009.*
- *Connecticut Guidelines for Soil Erosion and Sediment Control 2002*
- *Conservation and Development Policies Plan for Connecticut 2005-2010, adopted by the Connecticut General Assembly, 2006. <http://www.opm.state.ct.us/igp/cdplan/cdplan2.htm>*
- *Connecticut General Statutes Section 16-243 and Sections 16-11-134, and 135 of the Regulations of Connecticut State Agencies (and by reference, the National Electrical Safety Code ANSI C2, 2007 Edition)*
- *National Electrical Safety Code, ANSI C2-2007, August 1, 2006*
- *IEEE Standard Procedures for Measurement of Power Frequency Electric and Magnetic Fields From AC Power Lines, IEEE Std 644-1994, December 13, 1994*
- *IEEE Guide for the Design, Construction, and Operation of Electric Power Substations for Community Acceptance and Environmental Compatibility, IEEE Std 1127-1998 (R2004), March 2004. (Revision of IEEE Std 1127-1990)*
- *Current Status of Scientific Research, Consensus, and Regulation Regarding Potential Health Effects of Power-Line Electric and Magnetic Fields (EMF), January 2006*
- *Connecticut Siting Council's Electric and Magnetic Field Best Management Practices for the Construction of Electric Transmission Lines in Connecticut, December 14, 2007*
- *Interagency Task Force Studying Electric and Magnetic Fields, Connecticut 1998 Report on Task Force Activities to Evaluate Health Effects from Electric and Magnetic Fields, January 1998*
- *NIEHS Report to Congress on Health Effects from Exposure to Power-Line Frequency Electric and Magnetic Fields, 1999*
- *EMF, Electric and Magnetic Fields Associated with the Use of Electric Power, Questions and Answers, NIEHS, 2002*
- *Research on Power-Frequency Fields, National Research Council, 1999*
- *Review of the Scientific Evidence for Limiting Exposure to EMF, National Radiation Protection Board, 2004*

Q.2 Pre-Application Process (Conn. Gen. Stat. § 16-50l(e))

CL&P met with representatives of the Town of Westport on several occasions prior to distribution of the MCF. On September 29, 2009, the MCF was preliminarily distributed to the CEO, P&Z, Conservation Commission, Department of Public Works, and the Town Librarian. On October 14, 2009, the MCF was submitted to the CEO and the Connecticut Energy Advisory Board, thereby commencing the formal municipal consultation period.

Q.3 Application Filing Fees (Conn. Gen. Stat. § 16-50v-la)

The filing fee for this Application is determined by the following schedule:

<u>Estimated Construction Cost</u>		<u>Fee</u>
Up to	\$5,000,000	0.05% or \$1,000.00, whichever is greater
Above	\$5,000,000	0.1% or \$25,000.00, whichever is less

Based on this schedule and the estimated construction cost for the Project presented in Section F, a check for the filing fee in the amount of \$19,800 payable to the CSC accompanies this Application. CL&P understands that additional assessments may be made for expenses in excess of the filing fee, and that fees in excess of the CSC's actual costs will be refunded to CL&P.

Pursuant to Conn. Gen Stat. § 16-50l(a)(1), CL&P also encloses a separate check in the amount of \$25,000 payable to the CSC for the municipal participation fee.

Q.4 Proof of Service (Conn. Gen. Stat. § 16-50l(b))

This Application was served on the following:

- A. The chief elected official/chief executive officer, and where applicable, the zoning commission, planning commission, the planning and zoning commissions, and the conservation and wetlands commissions of the site municipality and any adjoining municipality having a boundary not more than 2,500 feet from the facility;
- B. The regional planning agency;
- C. The State Attorney General;
- D. Each member of the Legislature in whose district the facility is proposed;
- E. Any federal agency which has jurisdiction over the proposed facility; and,
- F. The State Departments of Agriculture, Environmental Protection, Public Health, Public Utility Control, Economic and Community Development, and Transportation; the Council on Environmental Quality; and the Office of Policy and Management.

The names of governmental officials and agencies on which a copy of the Application is being served (the “Proof of Service”) are provided in Volume II, Exhibit 7 (*Form of Affidavit and Service List*).

Q.5 Public Notices (Conn. Gen. Stat. § 16-50I(b))

Notice of the Application (the “Notice”) was published at least twice prior to the filing of the Application in a newspaper having general circulation in the site municipality. The Notice included the name of the applicant, the date of filing and a summary of the Application. The Notice was published in not less than ten point type and run in the following newspapers:

- The Westport News on December 18, 2009 and again on December 23, 2009.
- Norwalk Hour on December 17, 2009 and again on December 22, 2009.

Copies of the Affidavit of Notice and the legal ad are provided in Volume II, Exhibit 8 (*Affidavit and Public Notice*).

Q.6 Notice to Owners of Property Abutting Substation Site

Notice of the proposed Sherwood Substation was provided to abutters and other property owners proximate to CL&P's Property via certified mail, return receipt requested.

An Affidavit regarding the notice, a list of recipients, and a copy of the legal notice are provided in Volume II, Exhibit 9 (*Affidavit of Notice to Abutting Landowners*).

R. OTHER RELEVANT INFORMATION

This Project was identified in the *Connecticut Siting Council Review of the Connecticut Electrical Utilities Ten-Year Forecast of Loads and Resources*, published in 2007, 2008, and again in the 2009 (by reference to the 2008 report). CL&P received ISO-NE approval per *Section I.3.9 of the ISO New England Inc. Transmission, Markets and Service Tariff* for the proposed Project plan (see letter dated December 12, 2008, in Volume II, Exhibit 10, *Other Relevant Information*).

R.1 Public Outreach

CL&P sent out information by mail on May 19, 2009 to 28 residences in the vicinity to introduce the Substation. CL&P received a response from residents at 10 Clayton Street whose primary interest was additional screening of the temporary CL&P transformer at Sasco Creek Substation. This issue was subsequently resolved to the residents' satisfaction.

On June 9, 2009, CL&P presented the Substation to Greens Farms Academy. At the request of Greens Farms Academy, CL&P provided copies of preliminary landscaping concept plans and a digital video disc (DVD) discussing electric and magnetic fields. Greens Farms Academy also expressed interest in CL&P exploring pedestrian improvements to New Creek Road and its intersection with Maple Lane to provide for the enhanced safety of students using the nearby rail station for access to the school. CL&P is committed to resolving the Academy's concerns. CL&P also presented the Project to members of the Greens Farms Association on June 9, 2009.

A listing of those residents and abutting land owners provided copies of the public outreach information and associated correspondence with residents and Greens Farms Academy are included in Volume II, Exhibit 10, (*Other Relevant Information*).

R.2 Exemption from CEAB Mandatory RFP Process

Pursuant to Conn. Gen. Stats. § 16-50l (a) (2), as an electric substation designed to change or regulate voltage of electricity greater than 69kV, this project is exempt from the mandatory request for proposal process of the Connecticut Energy Advisory Board ("CEAB"). CL&P furnished to the CEAB a copy of the municipal consultation filing on October 14, 2009, and a copy of the legal notice and this Application on December 29, 2009.

GENERAL GLOSSARY OF TERMS

(Not all terms are used in this document)

115-kV: 115 kilovolts or 115,000 volts.

345-kV: 345 kilovolts or 345,000 volts.

AC: (alternating current)

An electric current which reverses its direction of flow periodically. (In the United States this occurs 60 times a second-60 cycles or 60 Hertz.) This is the type of current supplied to homes and business.

A-frame Structure: A steel structure constructed of two A-shaped uprights with horizontal cross-members and bracings.

Autotransformer: A single winding step-down transformer (see Transformer).

Ampere (Amp): A unit measure for the flow (current) of electricity. A typical home service capability (i.e., size) is 100 amps; 200 amps are required for homes with electric heat.

Arrester: Protects lines, transformers and equipment from lightning and other voltage surges by carrying the charge to ground. Arresters serve the same purpose on a line as a safety valve on a steam boiler.

Bundle: (circuit) Two or more parallel 3-conductor circuits joined together to operate as one single circuit.

Bundle: (conductor) Two or more phase conductors or cables joined together to operate as a single phase.

Bus: A conductor capable of carrying large amounts of current in a substation.

Cable: A fully insulated conductor usually installed underground but in some circumstances can be installed overhead.

CTDEP: Connecticut Department of Environmental Protection.

CELT: NEPOOL, Annual Capacity, Energy, Load and Transmission report.

CGS: Connecticut General Statutes.

Circuit: A system of conductors (three conductors or three bundles of conductors) through which an electrical current is intended to flow and which may be supported above ground by transmission structures or placed underground.

Circuit Breaker:	A switch that automatically disconnects power to the circuit in the event of a fault condition. Located in substations, this switch performs the same function as a circuit breaker in a home.
CHP:	Combined heat power
CL&P:	The Connecticut Light & Power Company.
CMEEC:	Connecticut Municipal Electric Energy Cooperative, Inc.
Conductor:	A metallic wire, busbar, rod, tube or cable which serves as a path for electric flow.
Conduit:	Pipes, usually PVC plastic, typically encased in concrete, for underground power cables.
Conversion:	Change made to an existing transmission line for use at a higher voltage, sometimes requiring the installation of more insulators. (Lines are sometimes pre-built for future operation at the higher voltage.)
CSC:	Connecticut Siting Council; the Council.
CONVEX:	Connecticut Valley Exchange.
dBA:	Decibel, on the A-weighted scale.
DC:	Direct current; electricity that flows continuously in one direction. A battery produces DC power.
Demand:	The total amount of electricity required at any given time by an electric supplier's customers.
Distribution:	Line, system; the facilities that transport electrical energy from the transmission system to the customer.
DG:	Distributed generation
D&M Plan:	Development & Management Plan.
DPUC:	(Connecticut) Department of Public Utility Control.
Duct:	Pipe or tubular runway for underground power cables (see also Conduit).
Duct Bank:	A group of ducts or conduit usually encased in concrete in a trench.

Electric Field:	Result of voltages applied to electrical conductors and equipment.
Electric Transmission:	The facilities (69-kV+) that transport electrical energy from generating plants to distribution substations.
EMF:	Electric and magnetic fields.
Fault:	A failure or interruption in an electrical circuit (short circuit).
FEMA:	Federal Emergency Management Agency.
Fiber Optic Shield Wire (FOSW):	See Lightning Shield Wire
G:	Gauss; 1G = 1000 mG (milligauss); the unit of measure for magnetic fields.
GIS:	Gas insulated substation using sulfur hexafluoride (SF ₆).
Glacial till:	These deposits are predominantly nonsorted, nonstratified sediment and are deposited directly by glaciers. These deposits consist of boulders, gravel, sand silt, and clay mixed in various proportions.
Gneiss:	Light and dark, medium- to coarse-grained metamorphic rock characterized by compositional banding of light and dark minerals, typically composed of quartz, feldspar and various amount of dark minerals.
Granofels:	Light to dark, medium- to coarse-grained, massively to poorly layered metamorphic rock composed primarily of quartz and feldspar; lacking the compositional banding of gneiss.
Ground Wire:	Cable/wire used to connect wires and metallic structure parts to the earth. Sometimes used to describe the lightning shield wire.
H-frame Structure:	A wood or steel structure constructed of two upright poles with a horizontal cross-arm and bracings.
Hz:	Hertz, a measure of frequency; one cycle/second.
ISO:	Independent System Operator.
ISO-NE:	ISO New England, Inc.; referred to as New England's Independent System Operator.
kcml:	1000 circular mils, approximately 0.0008 sq. in.

kV:	kilovolt, equals 1000 volts.
kV/m:	Electric field measurement (kilovolts/meter).
Lattice-type Structure:	Transmission or substation structure constructed of lightweight steel members.
Lightning Shield Wire:	Electric cable intended to prevent lightning from striking transmission circuit conductors. May contain glass fibers for communication use, “Fiber Optic Shield Wire”, or “FOSW”.
Line:	A series of overhead transmission structures which support one or more circuits; or in the case of underground construction, a single electric circuit.
Load:	Amount of power delivered as required at any point or points in the system. Load is created by the power demands of customers' equipment (residential, commercial, and industrial).
LOLE:	Loss of Load Expectation; a measure of bulk power system reliability.
Magnetic Field:	Produced by the flow of electric current; strength measured as magnetic flux density in units called gauss (G) or milligauss (mG) – 1/1000Gauss.
Magnetic Flux Density:	Strength of magnetic field
mG:	milligauss (see Magnetic Field) – 1/1000Gauss.
MOD:	Motor-Operated Disconnect switch.
MVA: Megavolt Ampere:	Measure of electrical capacity equal to the product of the voltage times the current. Electrical equipment capacities are sometimes stated in MVA.
MW: Megawatt.	Megawatt equals 1 million watts, measure of the work electricity can do.
NDDB:	Natural Diversity Data Base (CTDEP).
NEPOOL:	New England Power Pool.
NERC:	North American Electric Reliability Council.

NESC:	National Electrical Safety Code.
NPCC:	Northeast Power Coordinating Council.
NU:	Northeast Utilities.
OH (Overhead):	Electrical facilities installed above the surface of the earth.
Palustrine:	Marshy, wetland areas described as palustrine include marches, swamps and bogs.
Peaking Facility:	A generating station that runs when demand on the grid exceeds base load generation capacity in the region.
Phases:	Transmission (and some distribution) AC circuits are comprised of three phases that have a voltage differential between them.
PUESA:	Public Utility Environmental Standards Act.
Reinforcement:	Any of a number of approaches to improve the capacity of the transmission system, including rebuild, reconductor, conversion and bundling methods.
Rebuild:	Replacement of an existing overhead transmission line with new structures and conductors generally along the same route as the replaced line.
Reconductor:	Replacement of existing conductors with new conductors, but with little if any replacement or modification of existing structures.
Right of way:	ROW; corridor.
Riprap:	A permanent erosion-resistant ground cover of large, loose, angular stone with filter fabric or granular underlining used to protect soil from the erosion fences of concentrated runoff.
RTEP:	Regional Transmission Expansion Plan prepared by ISO-NE.
SCADA:	System Control and Data Acquisition system – A system installed at the substation which allows control and monitoring from a remote location.
Schist:	Light, silvery to dark, coarse- to very coarse-grained, strongly to very strongly layered metamorphic rock whose layering is typically defined by parallel alignment of micas. Primarily composed of mica, quartz and feldspar; occasionally spotted with conspicuous garnets.

- SF₆:** Sulfur hexafluoride, an insulating gas used in GIS substations and circuit breakers.
- Shield Wire:** See Lightning Shield Wire.
- SHPO:** State Historic Preservation Office (State of Connecticut Commission on Culture and Tourism, Historic Preservation and Museum Division).
- Statutory Facilities:** Environmental, ecological, scenic, historic, recreational or other resources identified by the Connecticut Siting Council in its *Electric Substation Facility Application Guidelines, section VII, items H and K (CGS Section 16-50l (a) (1))*.
- Substation:** A fenced-in yard containing switches, transformers, line terminal structures, and other equipment enclosures and structures. Adjustments of voltage, monitoring of circuits and other service functions take place in this installation.
- Switching Station:** A fenced-in yard containing switches, line terminal structures and other equipment, enclosures and structures. Switching of circuits and other service functions take place in this installation.
- Steel Lattice Tower:** See Lattice-Type Structure.
- Steel Monopole Structure:** Transmission structure consisting of a single tubular steel column with horizontal arms to support insulators and conductors.
- Step-down Transformer:** See Transformer.
- Step-up Transformer:** See Transformer.
- Switchgear:** General term covering electrical switching and interrupting devices. Device used to close or open, or both, one or more electric circuits.
- Terminal Points:** The substation or switching station at which a transmission line terminates.
- Terminal Structure:** Structure typically within a substation that ends a section of transmission line.
- Terminator:** A flared pot-shaped insulated fitting used to connect underground cables to overhead lines.

- Transformer:** A device used to transform voltage levels to facilitate the efficient transfer of power from the generating plant to the customer. A step-up transformer increases the voltage while a step-down transformer decreases it.
- Transmission Line:** Any line operating at 69,000 or more volts.
- Upgrade:** See Reinforcement.
- USGS:** United States Geological Survey (U.S. Department of the Interior).
- V/m:** volts per meter; kilovolt per meter; $1000 \text{ V/m} = 1\text{-kVm}$.
- Voltage:** A measure of the push or force which transmits electricity.
- Voltage Collapse:** A condition where voltage drops to unacceptable levels.
- Watercourse:** Rivers, streams, brooks, waterways, lakes, ponds, marshes, swamps, bogs, and all other bodies of water, natural or artificial, public or private.
- Wetland:** Land, including submerged land, which consists of any of the soil types designated as poorly drained, very poorly drained, alluvial or flood plain by the U.S. Department of Agriculture, Natural Resources Conservation Service. Connecticut jurisdictional wetlands are based solely on soil type; federal jurisdictional wetlands are classified based on a combination of soil type, wetland plants, and hydrologic regime.
- Wire:** See Conductor