



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

April 20, 2012

Daniel M. Laub, Esq.
Christopher B. Fisher, Esq.
Cuddy & Feder LLP
445 Hamilton Avenue, 14th Floor
White Plains, NY 10601

RE: **DOCKET NO. 420** - SBA Towers III Certificate of Environmental Compatibility and Public Need for the construction, maintenance and management of a telecommunications facility at one of three sites located at 350B Cossaduck Hill Road, North Stonington, Connecticut.

Dear Attorneys Laub and Fisher:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 24, 2012. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office and a PDF version to be filed electronically. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

Linda Roberts
Executive Director

LR/MP

c: Council Members
Parties and Intervenors

Docket No. 420
D&M Plan Questions
Set One

1. According to the structural design drawings in the Development and Management Plan (D&M Plan), the tower will be designed for ANSI/TIA-222 Version G. Would the tower also comply with Version F? Explain.
2. On the Site Development Plan drawing C-1.2, the number of trees to be removed is 62. This is significantly higher than the 7 to 12 trees six-inches diameter or more at breast height (dbh) that were estimated to be removed during the Docket No. 420 proceeding. Explain this discrepancy. For example, does the D&M Plan list all trees to be removed, even those under 6 inches dbh?
3. Are the erosion and sedimentation controls consistent with the *2002 Connecticut Guidelines for Soil Erosion and Sediment Control*?

LIST OF PARTIES AND INTERVENORS
SERVICE LIST

Status Granted	Document Service	Status Holder (name, address & phone number)	Representative (name, address & phone number)
Applicant	<input checked="" type="checkbox"/> U.S. Mail	SBA Towers III (SBA) and New Cingular Wireless PCS, LLC (AT&T)	<p>Daniel M. Laub, Esq. Christopher B Fisher, Esq. Cuddy & Feder LLP 445 Hamilton Avenue, 14th Floor White Plains, NY 10601 (914) 761-1300 (914) 761-5372 fax dlaub@cuddyfeder.com cfisher@cuddyfeder.com</p> <p>Hollis Redding SBA One Research Drive, Suite 200C Westborough, MA 01581 hredding@sbsite.com</p> <p>Michele Briggs AT&T 500 Enterprise Drive Rocky Hill, CT 06067-3900 michele.g.briggs@cingular.com</p>
Party (granted 09/20/11)		<p>Peter R. and Gisele A. Buehler 350D Cossaduck Hill Rd. North Stonington, CT 06359</p> <p>16247 Fringe Tree Drive Spring Hill, FL 34610 (860) 245-5050 or (727) 856-1963 buehlerga@comcast.net</p>	