
New England East-West Solution (NEEWS) Interstate Reliability Project Updated Needs Assessment

Connecticut Energy Advisory Board December 3, 2010

Stephen J. Rourke, VP System Planning

About ISO New England

- Not-for-profit corporation created in 1997 to oversee New England's restructured electric power system
- Independent System Operator
- Independent of companies doing business in the market
- No financial interest in companies participating in the market
- Regulated by the Federal Energy Regulatory Commission
- Major responsibilities:
- Reliable power system operations
- Efficient and competitive wholesale electricity markets
- Long-term regional system planning



Reliability Standards Guide Regional Transmission Planning

- North American Electric Reliability Corporation
- Reliability Standards for the Bulk
 Power System in North America
- Northeast Power Coordinating Council
- Basic Criteria for the Design and Operation of Interconnected Power Systems
- ISO New England
- Reliability Standards for the New England Area Bulk Power Supply System



Standards are used to ensure that the regional transmission system can reliably deliver power to consumers under a wide range of future system conditions.

Preface

- of the details of the issues represented here.* presentation to the Planning Advisory Committee, which contains all This presentation is a high-level overview of the Aug. 12
- regardless of system changes that have occurred since original serving requirements, a portion of the Interstate project must be built It is important to note that to meet Rhode Island's continuing load-NEEWS needs assessment.
- assumption. include the entire Salem Harbor plant out-of-service as a base-line The analysis that the Aug.12 presentation was based on did not

http://www.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/ceii/mtrls/2010/aug122010/neews_interstate.pdf



Presentation Objective


- for the New England East-West Solution (NEEWS) Interstate Reliability Project To review ISO New England's determination of the need
- Status of four NEEWS projects
- Geographic overview
- Updated needs assessment
- Modified Interstate Reliability Project

Status of NEEWS Projects

- Rhode Island Reliability Project (RIRP)
- ☑ RI Energy Facility Siting Board approved Aug. 12, 2010
- ☑ ISO testified that a portion of Interstate was needed to complete
- Greater Springfield Reliability Project (GSRP)
- ☑ CT Siting Council approved with modifications March 16, 2010
- ☑ MA Energy Facilities Siting Board approved Sept. 28, 2010
- Interstate Reliability Project (Interstate)
- ☑ ISO presented updated needs assessment to stakeholders at the Planning Advisory Committee in August and November
- Central Connecticut Reliability Project (CCRP)
- □ Under study by ISO



NEEWS Interstate: Geographic Overview



Existing 345 kV line (post GSRP and RIRP)

Study? What's Changed Since the Original

- Load forecast
- ISO forecasts continued, but slower growth in load
- transmission studies Resources that come forward through the Forward Capacity Market (FCM) or state RFPs are inputs to
- ISO reassesses system needs as required under the regional transmission tariff
- Scope
- Original concerns, combined with above changes, led to restrictions and other issues spanning broad geographic areas extensive review and analysis of load-serving capability, resource


Future Loads Still Exceed Critical Level

- than the critical load level identified in the original **NEEWS** needs assessment (primarily due to the economic recession), but still higher Load forecast is lower than ISO's original projection
- ISO identified ~30,000 MW as critical load level
- Original (2005) and updated (2010) CELT load forecasts project peak loads above 30,000 MW in 2015
- Load forecast is net of reductions from passive demand resources



New Resources Triggered Updated Needs Assessment








Ability to Add New Resources Current Transmission System Limits

- New generating facilities proposed in MA and RI failed to qualify in FCM due to transmission system limits
- Four power plants totaling more than 430 MW
- Similar issues identified in original Lake Road studies






Electrically, New England is Two Regions

Power flows are limited East to West (and West to East)*

- New England East-West Interface bisects
- Along CT-RI border
- Except for jog around Lake Road/ Killingly facilities in northeast CT
- Just west of Millbury, MA
- Northeast into NH
- West of generating facilities in southern NH
- North through NH and VT
- West of HVDC line from Québec
- these areas pre-date markets Transmission limits between
- Long-standing limits observed earlier by NEPOOL operators




^{*} There are other limiting interfaces in New England, which are not included in the scope of this study.

West Only Three 345 kV Lines Connect East and

- With only three 345 kV transmission lines connecting the two regions, the system has limited capability to move power across the interface
- Power flows are limited moving East-to-West and West-to-East


CT Card Street	MA Carpenter Hill	NH Amherst	State From	
Lake Road	Millbury	Scobie	То	





Corridor Through Greater Rhode Island Further imits Power Flows Between East and West


- flows between East and West corridor of the Greater Rhode Island subarea further restrict Transmission constraints in a
- the Card substation in Connecticut Rhode Island to Lake Road and Medway in Massachusetts through Corridor connects from West
- Limits flows in two directions
- From the West and Greater RI to
- the West From the East and Greater RI to
- Corridor also has limited ability to add qualified capacity



East and West Other Lines Affect Flows Between

- Transmission constrained corridor in MA-RI-CT adds limits on moving power between East and West
- The East-West interface, combined with limits on two lines in the Greater RI area, limits power flows from the West and Greater RI to the East, and from the East and Greater RI to the West


MA	MA	State
West Medway	West Medway	From
ANP Bellingham	ANP Blackstone	То





Conditions Limiting Interface Shifts with System

RI to the East E-W interface and Greater RI corridor limit flows from the West and Greater



and Greater RI to the West E-W interface limits flows from the East



Interstate: Updated Needs

Scope of Needs Assessment	Finding
Eastern New England	Interstate project is needed
Load-serving requirements	
Rhode Island	Interstate project is needed
Load-serving requirements	
Western New England	Interstate project is needed
Load-serving requirements	
Connecticut	Interstate project is needed
Load-serving requirements	
Some resources that are required to serve load can be unacceptably restricted	Interstate project is needed
Resolve equipment protection concerns Transmission switching causes mechanical stress on Lake Road generation	Mitigation of issue is a benefit of Interstate project



and Resource Restriction Issues Region Has Simultaneous Load-serving


Challenges

- inadequate resources and transmission to reliably serve load in the Eastern New England and Western New England are projected to have 2010-2012 and 2015-2019 timeframes, respectively
- Current transmission system restricts existing resources and limits ability to add new resources to serve load

Potential solutions

- Adding qualified resources in both Eastern and Western New England to resolve load-serving requirements
- A transmission solution that allows for transfer of power across Eastern and Western New England to reliably serve load

Line Overloads Widespread in 2015, 2020






What are the Options?


Add Resources

solve problems in each area, but this requires region to build excess supply, which will Add qualified resources in the East and West to increase the amount of locked-in resources



Strengthen Transmission

with existing resources between East and West to reliably serve load Strengthen transmission connections




Generation on and Transmission are conceptual and are shown for illustration purposes only.

© 2010 ISO New England Inc

Summary of Needs

- Western New England and Greater Rhode Island transmission planning criteria violations in Eastern New England, Need an integrated regional transmission solution to resolve
- Reliably serve load in accordance with North American Electric Reliability Corporation (NERC), Northeast Power Coordinating Council (NPCC) and ISO Planning Standards and Criteria in four areas
- Eastern New England
- Rhode Island
- Western New England
- Connecticut
- Resolve the unacceptable resource restriction conditions
- Address transmission constraints along the Card-Lake Road-West Medway Corridor (CT-RI-MA)

Modified Interstate Reliability Project*



^{*}This configuration is one of five transmission alternatives being evaluated by the study group.

Conclusions

- The need for an Interstate project is confirmed
- Additional reliability needs identified
- Western New England resources are unable to adequately serve
- load in the East due to West-East transmission limitations
- resolving a majority of the issues The original Interstate project goes a long way in
- Does not resolve all criteria violations in serving Eastern New England load
- Studies to date demonstrate that the Interstate plan with constraints modifications addresses the East-West and West-East
- Modified plan is one of five transmission alternatives under study