


STATE OF CONNECTICUT  
DEPARTMENT OF PUBLIC HEALTH

Jewel Mullen, M.D., M.P.H., M.P.A.  
Commissioner



Dannel P. Malloy  
Governor  
Nancy Wyman  
Lt. Governor

June 27, 2014

Melanie Bachman  
Acting Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051

RECEIVED  
JUN 30 2014

CONNECTICUT  
SITING COUNCIL

RE: Docket No.449 -Message Center Management and New Cingular Wireless PCS, LLC application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a telecommunications facility located at Redding Tax Assessor Map 23, Lot 72, Redding Ridge Fire Department, 186 Black Rock Turnpike, Redding, Connecticut.  
DPH Project # 2014-0155

Dear Ms. Bachman:

The Drinking Water Section (DWS) of the Department of Public Health has reviewed the location and specific work items associated with the above noted Docket Number. This project is contained within the public water supply watershed of Aquarion Water Company (Hemlock Reservoir watershed) an active source of public drinking water for the Aquarion Water Company (PWSID #CT0150011). The DWS offers the following recommendations to protect this source of public drinking water:

- Erosion and sedimentation controls should be in place and properly maintained as necessary.
- A responsible party should be identified for maintenance, inspection, repair, and replacement and incorporation of new controls as may become necessary.
- Servicing of machinery should be completed outside of the public water supply watershed.
- Refueling of vehicles or machinery should take place on an impervious pad with secondary containment designed to contain fuels.
- Fuel and other hazardous materials should not be stored within the public water supply watershed. Any fuel or hazardous materials that must be kept within the public water supply watershed during working hours should be stored on an impervious surface utilizing secondary containment.
- A fuel spill remediation kit should be stored on-site so that any spills may be contained and cleaned quickly.
- Aquarion Water Company should be contacted prior to starting this project to review the scope of this project.
- Aquarion Water Company personnel should be allowed to periodically inspect this project to ensure that drinking water quality is not being adversely impacted.



Phone: (860) 509-7333 • Fax: (860) 509-7359 • VP: (860) 899-1611  
410 Capitol Avenue, MS#51WAT, P.O. Box 340308  
Hartford, Connecticut 06134-0308  
[www.ct.gov/dph](http://www.ct.gov/dph)

*Affirmative Action/Equal Opportunity Employer*

Melanie Bachman  
June 27, 2014

Page 2

If you have any questions regarding this matter, please contact Mira S. Lami of this office at 860-509-7333.

Sincerely,

A handwritten signature in black ink, appearing to read "Eric McPhee", with a long horizontal flourish extending to the right.

Eric McPhee  
Supervising Environmental Analyst  
Drinking Water Section

Cc: Brian Roach, Source Water Protection Manager, Aquarion Water Company