

Distance from Center of Transmission Lines (feet)	Calculated Magnetic Fields (mG)		
	Average Annual Load	Peak Day Average Load	Annual Peak Load
-300	0.00	0.00	0.00
-275	0.00	0.00	0.00
-250	0.00	0.00	0.00
-225	0.00	0.00	0.00
-200	0.00	0.00	0.00
-175	0.00	0.00	0.00
-150	0.00	0.00	0.00
-125	0.00	0.00	0.00
-100	0.00	0.00	0.01
-75	0.00	0.01	0.01
-50	0.01	0.02	0.02
-25	0.04	0.07	0.08
0	0.47	0.86	1.02
25	0.04	0.07	0.08
50	0.01	0.02	0.02
75	0.00	0.01	0.01
100	0.00	0.00	0.01
125	0.00	0.00	0.00
150	0.00	0.00	0.00
175	0.00	0.00	0.00
200	0.00	0.00	0.00
225	0.00	0.00	0.00
250	0.00	0.00	0.00
275	0.00	0.00	0.00
300	0.00	0.00	0.00