



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [www.ct.gov/csc](http://www.ct.gov/csc)

### VIA ELECTRONIC MAIL

June 26, 2020

Susan J. Bellion  
Project Siting Specialist - Transmission Siting  
Eversource Energy  
P.O. Box 270  
Hartford, CT 06141  
[susan.bellion@eversource.com](mailto:susan.bellion@eversource.com)

RE: **DOCKET NO. 461A** - Eversource Energy Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a 115-kilovolt (kV) bulk substation located at 290 Railroad Avenue, Greenwich, Connecticut, and two 115-kV transmission circuits extending approximately 2.3 miles between the proposed substation and the existing Cos Cob Substation, Greenwich, Connecticut, and related substation improvements.

Dear Ms. Bellion:

Pursuant to Regulations of Connecticut State Agencies §16-50j-62 (b) and in response to your email of June 24, 2020, the Connecticut Siting Council (Council) staff hereby approves a temporary change to the Development and Management (D&M) Plan to allow for additional work hours for June 26, June 27, July 10, and July 11, 2020 from 9PM to 5AM to complete trenching and duct bank installation on Arch Street and Railroad Avenue between Stations #113 and #119. The additional hours are necessary to complete work that has been slowed by the discovery of unanticipated subsurface infrastructure and utilities.

This approval applies only to the temporary additional work hours requested in your email of June 24, 2020. Any additional changes to the D&M Plan require advance notification and approval in accordance with the Council's approval of the D&M Plan (Vol. 2, Part 1) on January 17, 2019. Furthermore, the Certificate Holder is responsible for reporting requirements pursuant to Regulations of Connecticut State Agencies Section 16-50j-62.

Please be advised that deviations from this plan are enforceable under the provisions of the Connecticut General Statutes § 16-50u.

Thank you for your attention and cooperation.

Sincerely,

*s/Melanie Bachman*

Melanie Bachman  
Executive Director

c: Kathleen M. Shanley

**From:** Bellion, Susan J <susan.bellion@eversource.com>  
**Sent:** Wednesday, June 24, 2020 3:48 PM  
**To:** Bachman, Melanie <Melanie.Bachman@ct.gov>; CSC-DL Siting Council <Siting.Council@ct.gov>  
**Cc:** Clarke, Robert P <robert.clarke@eversource.com>; Shanley, Kathleen M <kathleen.shanley@eversource.com>  
**Subject:** Docket 461A-GSLP-Extended Work Hours, Friday, June 26, 2020, Saturday, June 27, 2020, Friday, July 10, 2020 and Saturday, July 11, 2020: Arch Street and Railroad Avenue

Dear Ms. Bachman:

Eversource is requesting an extension of work hours for Friday, June 26, 2020; Saturday, June 27, 2020; Friday, July 10, 2020 and Saturday, July 11, 2020 from 9PM to 5AM on Arch Street and on Railroad Avenue between Stations #113 and #119 to complete trenching and duct bank installation. The approved work hours at this location are Sunday through Thursday, 9PM-5AM. The reason for the request is because of the unanticipated difficult subsurface conditions in this area caused by the discovery of underground wooden piles, a large sewer main and other unrecorded utilities.

The Town of Greenwich has been notified and they understand and have no issues with the extended hours.

Thank you for your consideration of this request.

Susan J. Bellion | Project Siting Specialist - Transmission Siting | Eversource Energy | [susan.bellion@eversource.com](mailto:susan.bellion@eversource.com) | Direct: (860) 728-4628 Cell: (203) 313-4143