

56 Prospect Street P.O. Box 270 Hartford, CT 06103

Kathleen M. Shanley Manager – Transmission Siting Tel: (860) 728-4527

January 3, 2024

Melanie Bachman, Executive Director Connecticut Siting Council Ten Franklin Square New Britain, CT 06051

Re: **DOCKET NO. 461A** – Greenwich Substation and Line Project Decision and Order – Condition #6 - Third Year Operating Report

Dear Ms. Bachman:

On November 7, 2017 in Docket 461A, the Connecticut Siting Council ("Council") granted a Certificate of Environmental Compatibility and Public Need for The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") Greenwich Substation and Line Project ("GSLP"). Condition 6 of the Council's Decision and Order directed Eversource "provide the Council an operating report within three months after the conclusion of the first year of operation of all facilities herein, and annually thereafter for a period of three years, with information relative to the condition, safety, reliability and operation of the new transmission lines."

Eversource submits the following information to the Council in compliance with Condition #6.

As of November 16, 2020, the transmission facilities and restoration were deemed complete for this project. The overall condition and safety of the two new 115-kV lines (i.e., the 1703 and 1020 lines) and associated facilities extending from Cos Cob Substation to the new Greenwich Substation has been excellent. There have been no disturbances on these two lines during the third year of operation. The 1703 Line was briefly removed from service between November 15, 2023 at 23:17 hours and returned November 16, 2023 at 17:16 hours for repairs on equipment within the Greenwich Substation associated with the line.

Should you have any questions regarding this request, please do not hesitate to contact me via email at <u>kathleen.shanley@eversource.com</u> or telephone at (860)728-4527.

Sincerely,

fathlaf. Tenly