STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL
Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935   Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
www.ct.gov/csc

VIA ELECTRONIC MAIL

January 13, 2020

Kathleen M. Shanley
Manager-Transmission Siting
Eversource Energy
P.O. Box 270
Hartford, CT 06103

RE: **DOCKET NO. 466** - The Connecticut Light & Power Company d/b/a Eversource Energy Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kilovolt (kV) electric transmission line project that traverses the municipalities of Watertown, Thomaston, Litchfield, and Harwinton, which consists of (a) construction, maintenance and operation of a new 115-kV overhead electric transmission line entirely within existing Eversource right-of-way and associated facilities extending approximately 10.4 miles between Eversource's existing Frost Bridge Substation in the Town of Watertown and existing Campville Substation in the Town of Harwinton; (b) related modifications to Frost Bridge Substation and Campville Substation; and (c) reconfiguration of a 0.4 mile segment of two existing 115-kV electric transmission lines across the Naugatuck River in the Towns of Litchfield and Harwinton within the same existing right-of-way as the new 115-kV electric transmission line.

Dear Ms. Shanley:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated January 9, 2020 regarding submission of the First Year Operating Report, in compliance with Conditon No. 8 of the Council's Decision and Order of April 14, 2016 for the above-referenced project.

This acknowledgment applies only to the First Year Operating Report. Decision and Order Condition 8 requires the submission of an annual report for a period of three years. Any significant changes to the above-referenced project require advance Council notification and approval.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman
Executive Director

MB/RDM/laf

c: Council Members

S:\DOCKETS\401-500\466\13_D&M Plan\466-20200114-Cond8AckLtr-1styroperatingrpt.docx