# STORY TO STO

## STATE OF CONNECTICUT

#### CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051 Phone: (860) 827-2935 Fax: (860) 827-2950 E-Mail: siting.council@ct.gov www.ct.gov/csc

#### VIA ELECTRONIC MAIL

January 6, 2020

Kenneth C. Baldwin, Esq. Robinson & Cole LLP 280 Trumbull Street Hartford, CT 06103-3597

RE: **DOCKET NO. 482 -** Cellco Partnership d/b/a Verizon Wireless application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a telecommunications facility on town-owned property behind Lyman Memorial High School located at 917 Exeter Road, Lebanon, Connecticut. Development and Management Plan.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than January 17, 2020. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman Executive Director

MB/RM





# STATE OF CONNECTICUT

#### CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051 Phone: (860) 827-2935 Fax: (860) 827-2950 E-Mail: siting.council@ct.gov www.ct.gov/csc

### Docket 482 – Lebanon Cellco Partnership d/b/a Verizon Wireless Development and Management Plan Interrogatories

January 6, 2020

- 1. D&M Plan Sheet SP-1 footnote lists the 2016 State Building Code/110 mph design wind speed as applicable to this project. Is this information correct? If not, please revise.
- 2. D&M Plan Sheet C-1 depicts a 50-kW generator rather than the 35-kW generator and battery units initially proposed. Provide the estimated run time of the generator before refilling of the propane tank is required. Are battery units still proposed?
- 3. Will Cellco's emergency power system be shared with the Town?
- 4. The DTE Geotechnical Report, Section 7.0 states dewatering should be anticipated. Please provide dewatering details.
- 5. Are there any changes to the proposed antenna deployment for Cellco or the Town? If so, provide a revised power density analysis.
- 6. Have the proposed construction hours (Sheet SP-2) been coordinated with Town/School officials?

