



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

VIA ELECTRONIC MAIL

February 10, 2022

Bruce L. McDermott, Esq.  
Murtha Cullina LLP  
265 Church Street  
New Haven, CT 06510  
[bmcdermott@murthalaw.com](mailto:bmcdermott@murthalaw.com)

RE: **DOCKET NO. 483** - The United Illuminating Company Certificate of Environmental Compatibility and Public Need for the Pequonnock Substation Rebuild Project that entails construction, maintenance, and operation of a 115/13.8-kilovolt (kV) gas insulated replacement substation facility located 700 feet southwest of UI's existing Pequonnock substation on an approximately 3.7 acre parcel owned by PSEG Power Connecticut, LLC at 1 Kiefer Street, Bridgeport, Connecticut, and related transmission structure and interconnection improvements.  
**D&M Plan Revision.**

Dear Attorney McDermott:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated February 9, 2022 regarding the revision to the Development and Management (D&M) Plan for the above-referenced site that was approved by the Council on August 28, 2020.

Pursuant to Regulations of Connecticut State Agencies §16-50j-62(b), your request for the following revisions is hereby approved:

- a) Re-route the overhead #1130 transmission line crossing of the railroad tracks to connect to the replacement Pequonnock Substation while avoiding the installation of a transmission structure north of the railroad corridor; and
- b) Re-route an overhead transmission line from PSEG interconnection to the existing Pequonnock Substation.

The re-routing of the #1130 Line is to address adjacent property owner concerns and more effectively accommodate the future alignment with The United Illuminating Company's (UI) planned Fairfield to Congress Project to be filed with the Council.

The re-routing of the Bridgeport Harbor #3 line connection is to address the retirement of PSEG's Unit 3 and allow UI to energize the replacement substation and facilitate the testing and commissioning process.

This approval applies only to the D&M Plan revision dated February 9, 2022. Any significant changes to the D&M Plan require advance Council notification and approval.

Please be advised that deviations from this plan are enforceable under the provisions of Connecticut General Statutes § 16-50u. Furthermore, the Certificate Holder is responsible for reporting requirements pursuant to Regulations of Connecticut State Agencies Section 16-50j-62.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman  
Executive Director

MB/MP

