



STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

VIA ELECTRONIC MAIL

May 22, 2013

Christopher Curtis  
General Manager  
Lake Road Generating Company  
56 Alexander Parkway  
Dayville, CT 06241

RE: **DOCKET NO. F-2012/2013** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Mr. Curtis:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than June 11, 2013. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as one electronic Adobe .pdf version via email. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

Melanie Bachman  
Acting Executive Director

MB/MP

c: Council Members  
Parties and Intervenors

**Docket F-2012/2013**  
**Lake Road Pre-Hearing Interrogatories**

1. Break down each annual megawatt-hours in Lake Road Generating Company, LP's (Lake Road) forecast report by fuel type (i.e. natural gas or oil).
3. How does Lake Road compute seasonal claimed capability?
4. Listed below are the data from the May 2013 ISO-NE Seasonal Claimed capability Report. Does Lake Road agree with these numbers? If no, provide the correct data.

<b>Net Capability - MW</b>	<b>Summer</b>	<b>Winter</b>
<b>Lake Road 1</b>	245.79	281.42
<b>Lake Road 2</b>	251.21	286.84
<b>Lake Road 3</b>	248.01	276.78

5. Does Lake Road have black start capability?
6. Does ISO-NE currently consider any of the Lake Road units as Connecticut capacity?
7. What is the typical service life (in years) for each of the above facilities? At what point in the service life is each facility currently?
8. Does Lake Road have a decommissioning plan for the facilities when such facilities are retired or removed from service? If yes, provide the decommissioning plan. If no, explain.