



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

May 22, 2013

D. Blake Wheatley
Wallingford Energy, LLC
400 Chesterfield Center, Suite 110
St. Louis, MO 63017

RE: **DOCKET NO. F-2012/2013** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Mr. Wheatley:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than June 11, 2013. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as one electronic Adobe .pdf version via email. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

Melanie Bachman
Acting Executive Director

MB/MP

c: Council Members
Parties and Intervenors

Docket F-2012/2013
Wallingford Pre-Hearing Interrogatories

1. How does Wallingford Energy, LLC (Wallingford) compute seasonal claimed capability?
2. Listed below are the data from the May 2013 ISO-NE Seasonal Claimed capability Report. Does Wallingford agree with these numbers? If no, provide the correct data.

3.

Net Capability - MW	Summer	Winter
Wallingford #1	42.30	48.41
Wallingford #2	42.30	48.24
Wallingford #3	42.30	47.84
Wallingford #4	42.30	47.19
Wallingford #5	42.30	49.00

4. Do any of these Wallingford units in Connecticut have black start capability?
5. What is the typical service life (in years) for each of the above facilities? At what point in the service life is each facility currently?
6. Does Wallingford have a decommissioning plan for the facilities when such facilities are retired or removed from service? If yes, provide the decommissioning plan. If no, explain.