



**Northeast
Utilities**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(860) 665-5000
www.nu.com

June 5, 2012

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RECEIVED
JUN - 6 2012

ORIGINAL

CONNECTICUT
SITING COUNCIL

Re: Docket No. F-2012/2013 - Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Ms. Roberts:

This letter provides the response to requests for the information listed below.

Response to CSC-02 Interrogatories dated 05/22/2012
CSC-001, 002

Very truly yours,

Christopher R. Bernard
Manager
Regulatory Policy - Transmission
NUSCO
As Agent for CL&P

cc: Service List

Witness: Charles R. Goodwin
Request from: Connecticut Siting Council

Question:
Provide the actual and weather-normalized annual net electrical energy output requirements in GWh for The Connecticut Light and Power Company's (CL&P) service area for 2002 through 2006.

Response:
The table below shows the actual and weather-normalized annual net electrical energy output requirements in GWh for CL&P service area for 2002 through 2006.

<u>Year</u>	<u>Actual</u>	<u>Weather Normalized</u>
2002	24,880	24,860
2003	25,190	25,077
2004	25,496	25,578
2005	26,119	25,498
2006	24,871	24,926

Witness: Charles R. Goodwin
Request from: Connecticut Siting Council

Question:
As a comparison, provide the predicted weather-normalized (i.e. 50/50) annual net electrical energy output requirements in GWh for 2002 through 2006 from the 2002 CL&P forecast report.

Response:
The table below shows the forecasted weather-normalized (i.e., 50/50) annual net electrical energy output requirements in GWh for CL&P for 2002 - 2006 as shown in CL&P's "2002 Forecast of Loads and Resources for 2002 - 2011".

<u>Year</u>	<u>Output</u>
2002	25,138
2003	25,258
2004	25,610
2005	25,772
2006	25,983