



February 19, 2019

Melanie Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

RE: Docket No. F-2014/2015

Dear Melanie Bachman:

I am writing in response to the 2012 Connecticut General Statutes Title 16 – Public Service Companies Chapter 277a – Public Utility Environmental Standards Act Section 16-50r – Report of forecast of loads and resources for the Town of Wallingford CT Department of Public Utilities.

The attached document includes:

- A tabulation of estimated peak loads
- Data on energy use and peak loads for the five preceding calendar years

Enclosed is one signed original and 15 hard copies of the report.

*Sincerely,*

*Michelle Coscia*

*Michelle Coscia*

ENCLOSURE



2/19/2019



Michelle Coscia  
Energy New England  
100 Foxborough Blvd. #110  
Foxborough, MA 02035

Melanie Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

**Melanie Bachman,**

(1) A tabulation of estimated peak loads for each year 2019-2028

YEAR	2019	2020	2021	2022	2023
Peak MW	127.266	128.157	129.054	129.958	130.867
YEAR	2024	2025	2026	2027	2028
Peak MW	131.784	132.706	133.635	134.570	135.512

(2) Data on energy use and peak loads for the five preceding calendar years 2014-2018

YEAR	2018	2017	2016	2015	2014
Peak MW	129.912	126.632	130.687	125.860	123.241
YEAR	2018	2017	2016	2015	2014
MWH Load	615,485	596,391	611,919	617,641	613,652

Sincerely

*Michelle Coscia*

Michelle Coscia  
Senior Energy Analyst  
Energy New England