



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

**VIA ELECTRONIC MAIL**

February 6, 2025

Correne Auer, P.E.  
Manager Environmental Programs/Projects  
The United Illuminating Company  
100 Marsh Hill Road  
Orange, CT 06477  
[c.auer@uinet.com](mailto:c.auer@uinet.com)

RE: **DOCKET NO. 3B** – The United Illuminating Company Amended Certificate of Environmental Compatibility and Public Need for replacement of a portion of the existing Derby – Shelton 115-kV electric transmission line facility. **Partial Development and Management (D&M) Plan II Revision.**

Dear Correne Auer:

The Connecticut Siting Council (Council) is in receipt of correspondence dated February 5, 2025, regarding a revision to Partial Development and Management (D&M) Plan II for the above-referenced facility that was approved by the Council on July 21, 2023.

Pursuant to Regulations of Connecticut State Agencies (RCSA) §16-50j-62(b), the request to relocate Structure 4 approximately 5 feet to the west is hereby approved.

This approval applies only to the Partial D&M Plan II revision in the correspondence dated February 5, 2025.

Please be advised that deviations from the Council's Decision and Order and D&M Plan approvals are enforceable under the provisions of Connecticut General Statutes § 16-50u. Furthermore, the Certificate Holder is responsible for reporting requirements pursuant to RCSA §16-50j-62.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman  
Executive Director

MB/MP

c: Bruce McDermott, Esq., Harris Beach Murtha Cullina PLLC ([bmcdermott@harrisbeachmurtha.com](mailto:bmcdermott@harrisbeachmurtha.com))



February 5, 2024

Melanie A. Bachman, Esq.  
Executive Director/Staff Attorney  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: RE: Docket No. 3B – The United Illuminating Company Application for a Certificate of Environmental Compatibility and Public Need for the Derby Junction to Ansonia 115-kV Transmission Line Rebuild Project, Notice of Design Modification for Structure #4

Dear Ms. Bachman:

Pursuant to the Regulations of Connecticut State Agencies Section 16-50j-62(b)(2) and the project's Development & Management Plan approved on July 20, 2023, The United Illuminating Company ("UI") is hereby notifying the Connecticut Siting Council (the "Council") of a modification. The modification that will occur is the shifting of STR #4 approximately 5-feet to the west to allow for adequate clearance from UI's underground distribution duct bank.

During the vacuum excavation for STR #4, a 26-inch-wide duct bank was discovered at a depth of approximately 6-feet. The duct bank is currently 2-feet from the center stake of the proposed structure. To allow for adequate clearance for the 9'3" diameter temporary pipe starter casing, STR #4 will be shifted approximately 5-feet to west within the existing work right-of-way/easement.

Should the Council have any questions regarding this filing, please do not hesitate to contact me.

Very truly yours,

Correne Auer, PE  
Manager Environmental Programs/Projects  
c.auer@uinet.com