



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

November 14, 2024

Bruce McDermott, Esq.
Murtha Cullina LLP
One Century Tower
265 Church Street, 9th floor
New Haven, CT 06510-1220
bmcdermott@murthalaw.com

RE: **DOCKET NO. 3B** – The United Illuminating Company Amended Certificate of Environmental Compatibility and Public Need for replacement of a portion of the existing Derby – Shelton 115-kV electric transmission line facility. **Partial Development and Management (D&M) Plan II Revision.**

Dear Attorney McDermott:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated November 14, 2024, regarding a revision to Partial Development and Management (D&M) Plan II for the above-referenced facility that was approved by the Council on July 21, 2023.

Pursuant to Regulations of Connecticut State Agencies (RCSA) §16-50j-62(b), your request to relocate Structure 361B approximately three feet to the north is hereby approved.

This approval applies only to the Partial D&M Plan II revision in the correspondence dated November 14, 2024.

Please be advised that deviations from the Council's Decision and Order and D&M Plan approvals are enforceable under the provisions of Connecticut General Statutes § 16-50u. Furthermore, the Certificate Holder is responsible for reporting requirements pursuant to RCSA §16-50j-62.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman
Executive Director

MB/MP

c: Correne Auer, PE, Manager Environmental Programs/Projects, The United Illuminating Company
(c.auer@uinet.com)



November 14, 2024

Melanie A. Bachman, Esq.
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: RE: Docket No. 3B – The United Illuminating Company Application for a Certificate of Environmental Compatibility and Public Need for the Derby Junction to Ansonia 115-kV Transmission Line Rebuild Project, Notice of Design Modification for Structure 361B

Dear Ms. Bachman:

Pursuant to the Regulations of Connecticut State Agencies Section 16-50j-62(b)(2) and the project's Development & Management Plan approved on July 20, 2023, The United Illuminating Company ("UI") is hereby notifying the Connecticut Siting Council (the "Council") of a modification. The modification that will occur is the shifting of Structure 361B approximately 36-inches to allow for adequate clearance from nearby fencing.

After review of final staking, Str 361B's center stake is 41" from a fence. A 7'6" temporary starter casing will be required to properly install the foundation, causing a conflict with the fence. UI requests that the foundation center be shifted 36-inches north from its current location, away from the fence to allow adequate clearance to install foundation casing.

Should the Council have any questions regarding this filing, please do not hesitate to contact me.

Very truly yours,

Correne Auer, PE
Manager Environmental Programs/Projects
c.auer@uinet.com