



APPLICATION TO THE CONNECTICUT SITING COUNCIL

for a

***CERTIFICATE OF ENVIRONMENTAL COMPATIBILITY AND
PUBLIC NEED***

for the

OLD TOWN SUBSTATION REBUILD PROJECT

City of Bridgeport, Fairfield County, Connecticut

June 2020

Prepared By:

THE UNITED ILLUMINATING COMPANY

This page intentionally left blank

TABLE OF CONTENTS

FORMAL REQUIREMENTS AND APPLICATION GUIDE FR-1

A. Purpose of the Application..... FR-1

B. Statutory Authority FR-1

C. Legal Name and Address of Applicant FR-1

D. Applicant’s Contacts FR-1

APPLICATION DIRECTORY..... FR-2

EXECUTIVE SUMMARYES-1

1. PROJECT OVERVIEW AND NEED 1-1

1.1 PROJECT BACKGROUND, LOCATION, AND PURPOSE 1-1

1.2 SUMMARY OF PROPOSED PROJECT FACILITIES..... 1-7

1.3 ORGANIZATION OF THE APPLICATION 1-10

2. TECHNICAL SPECIFICATIONS FOR THE PROJECT..... 2-1

2.1 LAND AND ACCESS REQUIREMENTS 2-1

2.2 NEW SUBSTATION FACILITIES 2-2

2.3 SUBSTATION TRANSMISSION LINE CONNECTIONS 2-4

2.4 ESTIMATED PROJECT COSTS AND FACILITY SERVICE LIFE 2-5

2.5 DECOMMISSIONING APPROACH: EXISTING OLD TOWN SUBSTATION AND RELATED TRANSMISSION LINE CONNECTIONS 2-5

3. PROPOSED CONSTRUCTION AND OPERATION/MAINTENANCE PROCEDURES 3-1

3.1 CONSTRUCTION PROCEDURES: GENERAL..... 3-1

3.2 SUBSTATION AND 115-kV LINE CONNECTIONS CONSTRUCTION 3-1

3.3 EXISTING SUBSTATION DECOMMISSIONING..... 3-6

3.4 EROSION/SEDIMENTATION CONTROL AND STORMWATER MANAGEMENT 3-6

3.5 CONSTRUCTION SCHEDULE AND WORK HOURS..... 3-7

3.6 DISTRIBUTION LINE RELOCATION AND CONNECTIONS 3-8

3.7 PROJECT FACILITIES RELIABILITY, SAFETY AND SECURITY INFORMATION 3-8

3.7 TRAFFIC MANAGEMENT DURING SUBSTATION OPERATION 3-9

4. EXISTING ENVIRONMENTAL CONDITIONS 4-1

4.1 TOPOGRAPHY, GEOLOGY, AND SOILS 4-1

4.2 WATER RESOURCES AND WATER QUALITY 4-2

4.3 BIOLOGICAL RESOURCES 4-3

4.4 LAND USE, RECREATION, AND COMMUNITY FACILITIES 4-5

4.5 VISUAL AND AESTHETIC CHARACTERISTICS 4-12

4.6 TRANSPORTATION AND UTILITIES..... 4-12

4.7 CULTURAL (ARCHAEOLOGICAL AND HISTORIC) RESOURCES 4-14

4.8 AIR QUALITY, NOISE, AND LIGHTING..... 4-15

5. POTENTIAL ENVIRONMENTAL EFFECTS AND MITIGATION MEASURES..... 5-1

5.1	TOPOGRAPHY AND GEOLOGY	5-2
5.2	SOILS, GROUNDWATER, AND STORMWATER MANAGEMENT	5-2
5.3	WATER RESOURCES AND WATER QUALITY	5-3
5.4	SPELL PREVENTION AND CONTROL.....	5-4
5.5	BIOLOGICAL RESOURCES	5-4
5.6	LAND USE, RECREATION, AND COMMUNITY FACILITIES	5-6
5.7	VISUAL AND AESTHETIC CHARACTERISTICS	5-7
5.8	TRANSPORTATION AND UTILITIES.....	5-9
5.9	CULTURAL (ARCHAEOLOGICAL AND HISTORIC) RESOURCES	5-9
5.10	AIR QUALITY, NOISE, AND LIGHTING.....	5-10
6.	ELECTRIC AND MAGNETIC FIELD CONSIDERATIONS	6-1
6.1	OVERVIEW	6-1
6.2	EMF MEASUREMENTS AND MODELING	6-3
6.3	ASSESSMENT CRITERIA.....	6-4
6.4	CONSISTENCY WITH CSC BEST MANAGEMENT PRACTICES	6-5
6.5	CONCLUSIONS.....	6-6
7.	PROJECT SCHEDULE	7-1
8.	PROJECT PERMITS, APPROVALS AND CONSULTATIONS	8-1
8.1	FEDERAL AND STATE AGENCY APPROVALS REQUIRED AND CONSULTATIONS	8-1
8.2	MUNICIPAL CONSULTATION FILING AND OUTREACH	8-1
9.	ALTERNATIVES CONSIDERED	9-1
9.1	INTRODUCTION AND SUMMARY	9-1
9.2	NO ACTION ALTERNATIVE	9-2
9.3	SUBSTATION SITE ALTERNATIVES	9-3
9.4	SUBSTATION DESIGN AND TRANSMISSION LINE CONFIGURATION OPTIONS	9-9
10.	ACRONYMS AND GLOSSARY OF TERMS	10-1

APPENDICES

Appendix A: Maps and Drawings

Appendix B: Agency Correspondence

B.1: State Historic Preservation Officer (SHPO)

B.1.1: SHPO Project Review Form

B.1.2: SHPO Concurrence Letter

B.2: Connecticut Department of Energy and Environmental Protection
Natural Diversity Database (NDDDB)

B.2.1: NDDDB Request Form

B.2.2: NDDDB Determination Letter

B.3: U.S. Fish and Wildlife Service (USFWS) Consultation

Appendix C: Ecological Assessment Report

Appendix D: Visual Assessment and Photo-Simulations

Appendix E: Cultural Resources Report

Appendix F: Environmental Noise Assessment

Appendix G: Electric and Magnetic Field (EMF) Report

Appendix H: Formal Requirements

This page intentionally left blank

LIST OF FIGURES

Figure ES-1: Project Area ES-1
 Figure ES-2: Project Site ES-2
 Figure ES-3: Proposed Substation Layout and Transmission Line Connections ES-3
 Figure 1-1: General Location of Existing and Proposed Old Town Substation Sites 1-2
 Figure 1-2: Existing Old Town Substation Site and Vicinity 1-4
 Figure 1-3: Street-Level View of Existing Old Town Substation 1-4
 Figure 1-4: Existing Old Town Substation, Proposed Project Site, and Eversources Transmission Line ROW 1-8
 Figure 1-5: Proposed Rebuilt Substation Layout 1-9
 Figure 2-1: Proposed Substation Layout 2-3
 Figure 4-1: Existing Land Use: Vicinity of Project Site 4-6
 Figure 4-2: Zoning in Vicinity of the Project Site 4-8
 Figure 4-3: Community Facilities within 2,000 Feet (0.38 mile) of the Project Site 4-11
 Figure 4-4: Representative View of Existing Old Town Substation, UI Property, Eversource ROW, and Immediate Vicinity (View to the East) 4-13
 Figure 5-1: Photo simulation of Proposed Old Town Substation (Fence with Screening) and Vicinity (View to East, Existing Old Town Substation Removed) 5-8
 Figure 6-1: EMF Levels in the Environment 6-2
 Figure 7-1: Project Schedule 7-1
 Figure 9-1: Alternative Substation Site Locations 9-6

LIST OF TABLES

Table 3-1: General Project Construction Sequence 3-2
 Table 4-1: List of Community Facilities within 2,000 Feet (0.38 mile) of Project Area 4-10
 Table 4-2: Typical Noise Levels Associated with Different Indoor and Outdoor Activities 4-16
 Table 4-3: State of Connecticut and City of Bridgeport: Maximum Noise-Control Levels 4-17
 Table 6-1: Measurements of Existing Magnetic Field Levels (mG) 6-3
 Table 6-2: ICNIRP and ICES guidelines for EMF exposure at 60-Hz 6-5
 Table 8-1: Permits and Approvals Expected to be Applicable to the Project 8-3
 Table 9-1: Summary of Alternative Sites Identified for the New Old Town Substation 9-8

This page intentionally left blank

FORMAL REQUIREMENTS AND APPLICATION GUIDE

A. PURPOSE OF THE APPLICATION

In this Application, The United Illuminating Company (“UI” or the “Company”) is requesting that the Connecticut Siting Council (the “Council”) issue a Certificate of Environmental Compatibility and Public Need (the “Certificate”) for the reconstruction and operation of the existing Old Town Substation, a 115/13.8- kilovolt (kV) air-insulated facility located at 282 Kaechele Place in the City of Bridgeport, County of Fairfield, and State of Connecticut. The existing Old Town Substation is more than 50 years old and occupies a 0.9-acre parcel of UI property. Referred to as the Old Town Substation Rebuild Project (the “Project”), the new substation will be built on approximately 2.25 acres of UI property on Kaechele Place. Approximately 1.35 acres will be on UI’s approximately 3-acre property that borders the existing Old Town Substation site. In its final configuration the new substation will also encompass the 0.9-acre existing decommissioned substation site. As part of the Project, the transmission and distribution lines that connect to the existing substation will be relocated to the new substation. The Project is needed to improve the reliability of service to customers in the Bridgeport area (the “Service Area”) and to the New England power grid. Appendix H of this Application provides additional information in response to the Council’s formal requirements.

B. STATUTORY AUTHORITY

UI is applying to the Council pursuant to Connecticut General Statutes Section 16-50g et seq.

C. LEGAL NAME AND ADDRESS OF APPLICANT

UI is a subsidiary of AVANGRID, Inc.

UI’s name and permanent place of business is:

The United Illuminating Company
180 Marsh Hill Road
Orange, CT 06477

Mailing Address: 180 Marsh Hill Road
Orange, CT 06477

D. APPLICANT’S CONTACTS

Correspondence and other communications about the Project are to be addressed to, and notices, orders, and other papers may be served upon the following individuals:

Bruce McDermott
Attorney
Murtha Cullina LLP
One Century Tower
265 Church Street
New Haven, CT 06510-1220
Contact numbers:
203.772.7787 (Telephone)
860.240.5723 (FAX)
bmcdermott@murthalaw.com

Ronald Rossetti
Manager – Electric Capital
Projects
The United Illuminating
Company
100 Marsh Hill Road
Orange, CT 06477
203.926.4517 (Telephone)
203.926.5297 (FAX)
ron.rossetti@uinet.com

Samantha Marone
Outreach Manager
The United Illuminating
Company
100 Marsh Hill Road
Orange, CT 06477
203.499.3824 (Telephone)
203.926.5297 (FAX)
samantha.marone@uinet.com

APPLICATION DIRECTORY

The following table cross-references the Council's *Application Guide for an Electric Substation Facility* (June 2016) to the sections of this Application.

Council's Application Guide (Section No. and Summary Description)	Old Town Substation Rebuild Project Application (Section Reference)
General Applicants shall consult Connecticut General Statutes (C.G.S.) §§ 16-50g et. seq. and Sections 16-50j-1 et. seq. of the Regulations of Connecticut State Agencies (RCSA) to assure complete compliance with the requirements of those sections.	Application meets the intent of these requirements
I. Pre-Application Process (C.G.S § 16-50l) Requirements for municipal consultation.	Executive Summary, Section 8
II. Form of Application (RCSA § 16-50l-2) Review of information to be included in the application.	Application Formal Requirements and entire Application.
III. Filing Requirements (RCSA § 16-50j-12) Review of requirements for submission of copies of application (original plus 15 copies), bulk filings (2 copies), application format, format for exhibits and sworn testimony. All application fees shall be paid to the Council at the time an application is filed with the Council. Municipal participation fee.	Application Formal Requirements and Application
IV. Application Filing Fees Proof of Service (C.G.S. § 16-50l(a) and RCSA § 16-50v-1a) Filing fees shall be paid to the Council at the time the application is filed.	Procedural requirement, completed at Application submission to the Council
V. Municipal Participation Account (C.G.S. § 16-50bb; § 16-50l(a)(3)) Each application shall be accompanied by a payment of \$25,000 to be deposited in the Municipal Participation Account.	Procedural requirement, completed at Application submission to the Council
VI. Contents of Application (C.G.S. § 16-50l; RCA § 16-50j-59) An application for a Certificate for the construction of an electric substation or switchyard shall include or be accompanied by the following:	
A. An executive summary	Executive Summary
B. A description of the technical specifications	Section 2, Appendix A
C. A statement describing the need for the project.	Section 1
D. A justification for overhead portions, if any, including life cycle cost studies comparing overhead alternatives with underground alternatives.	N/A except for new structures for 115-kV line connections (refer to Sections 1-3)
E. A schedule of dates showing the proposed program of ROW or property acquisition, construction, completion and operation.	Section 7
F. A description of the named sites, including:	Sections 1-4, Appendix A
1. A USGS topographic map (scale 1" = 2,000') showing the site of the facility and any changes within a 1-mile radius of the site.	Section 1, Appendix A
2. A map (scale note less than 1" = 200') showing the Project Site, locations and names of public roads, abutting property owners, and proximity to environmental features, cultural resources, and community facilities.	Sections 1, 4, Appendix A
3. A site plan (scale not less than 1" = 40') showing the proposed facility, setback radius, existing and proposed contour elevations, 100-year flood zones, waterways, wetlands, and all associated equipment and structures on the site.	Appendix A
4. Where relevant, a terrain profile showing the proposed facility and access road with existing and proposed grades.	Appendix A

<p align="center">Council's Application Guide (Section No. and Summary Description)</p>	<p align="center">Old Town Substation Rebuild Project Application (Section Reference)</p>
<p>5. The most recent aerial photograph (scale not less than 1"=1,000 feet) showing the proposed site, access roads, and all abutting properties.</p>	<p>Section 1, Appendix A</p>
<p>G. Justification for selection of the proposed site, including a comparison with alternative sites which are environmentally, technically, and economically practical. Include enough information for a complete comparison between the proposed site and any alternative site contemplated</p>	<p>Section 9</p>
<p>H. Safety and reliability information, including provisions for emergency operations and shutdowns and fire suppression technology.</p>	<p>Section 3</p>
<p>I. A description of the effect that the proposed facility would have on the environment, ecology, and scenic, historic, and recreational values, including effects on:</p>	<p>Sections 3-6</p>
<p>1. Public health and safety;</p>	<p>Section 6</p>
<p>2. Local, state, and federal land use plans;</p>	<p>Sections 4, 5</p>
<p>3. Existing and future development;</p>	<p>Section 4, 5</p>
<p>4. Roads;</p>	<p>Sections 3, 4, and 5</p>
<p>5. Wetlands;</p>	<p>Sections 4, 5, Appendix C</p>
<p>6. Wildlife and vegetation, including rare and endangered species, and species of special concern, with documentation by the CT DEEP Natural Diversity Data Base;</p>	<p>Sections 4 and 5; Appendices B and C</p>
<p>7. Water supply areas;</p>	<p>N/A</p>
<p>8. Archaeological and historic resources, with documentation by the SHPO; and</p>	<p>Sections 4 and 5, Appendix E</p>
<p>9. Other environmental concerns identified by the applicant, the Council, or any public agency:</p>	
<ul style="list-style-type: none"> ▪ Coastal Consistency Analysis 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Connecticut Heritage Areas 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Ridgeline Protection Zones 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Aquifer Protection Zones 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ DOT Scenic Lands 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ State Parks and Forests 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Agricultural Lands 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Wild and Scenic Rivers 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Protected Rivers 	<p>N/A</p>
<ul style="list-style-type: none"> ▪ Endangered, Threatened, and Special Concern Species 	<p>Sections 4 and 5; Appendices B and C</p>
<p>J. Sight line graphs to the named sites from visually impacted areas such as residential developments, recreational areas, and historic sites.</p>	<p>Sections 4 and 5, Appendix D</p>
<p>K. A statement explaining mitigation measures for the proposed facility, including:</p>	
<p>1. Description of proposed site clearing for access and compound, including type of vegetation scheduled for removal and quantity of trees greater than 6" diameter at breast height and involvement with wetlands</p>	<p>Sections 3.2.3, 4, and 5, Appendices A and C</p>
<p>2. Construction techniques designed specifically to minimize adverse effects on natural areas and sensitive areas;</p>	<p>Sections 3 and 5</p>
<p>3. Special routing or design features made specifically to avoid or minimize adverse effects on natural areas and sensitive areas;</p>	<p>Sections 3 and 5</p>
<p>4. Establishment of vegetation proposed near residential, recreational, and scenic areas;</p>	<p>Section 5</p>
<p>5. Methods for preservation of vegetation for wildlife habitat and screening;</p>	<p>Section 5</p>
<p>L. Justification that the location of the proposed facility would not pose an undue safety or health hazard to persons or property along the area traversed by the proposed facility, including:</p>	<p>Sections 3 and 6, Appendix G</p>

<p align="center">Council’s Application Guide (Section No. and Summary Description)</p>	<p align="center">Old Town Substation Rebuild Project Application (Section Reference)</p>
<p>1. Measurements of existing EMF at site boundaries and at boundaries of adjacent schools, daycare facilities, playgrounds, and hospitals, with extrapolated calculations of exposure levels during expected normal and peak normal line loading;</p>	<p>Section 6, Appendix G</p>
<p>2. Calculations of expected EMF levels at the above-listed locations that would occur during normal and peak normal operation of the transmission line;</p>	<p>Section 6, Appendix G</p>
<p>3. A statement describing consistency with the Council’s “Best Management Practices for Electric and Magnetic Fields”, as amended; and</p>	<p>Section 6, Appendix G</p>
<p>4. A description of siting security measures for the proposed facility, consistent with the Council’s “White Paper on the Security of Siting Energy Facilities”, as amended.</p>	<p>Section 3</p>
<p>M. A schedule of proposed program for ROW or property acquisitions, construction, rehabilitation, testing and operation.</p>	<p>Section 7</p>
<p>N. A statement of estimated costs for site acquisition, construction, and equipment for a facility at the various proposed sites of the facility, including all candidates referred to in the application.</p>	<p>Sections 3 and 9</p>
<p>O. Identification of each federal, state, regional, district and municipal agency with which proposed route or site reviews have been undertaken or will be undertaken, including a copy of each written agency position on such route or site, and a schedule for obtaining approvals not yet received.</p>	<p>Sections 4, 5, and 8, Appendix B</p>
<p>P. Bulk filing of the most recent conservation, inland wetland, zoning, and plan of development documents of the municipality, including a description of the zoning classification of the site and surrounding areas, and a narrative summary of the consistency of the project with the Town’s regulations and plans.</p>	<p>Narrative summary and maps in Sections 4 and 5 Bulk filing submitted separately</p>
<p>Q. Such information any department or agency of the state exercising environmental controls may, by regulation, require.</p>	<p>Application</p>
<p>R. Pursuant to C.G.S. § 16-50o, the applicant shall submit into the record the full text of the terms of any agreement, and a statement of any consideration therefore, if not contained in such agreement, entered into by the applicant and any party to the certification proceeding, or any third party, in connection with the construction or operation of the facility. This provision shall not require the public disclosure of proprietary information of trade secrets.</p>	<p>Easement to be entered into with the City of Bridgeport</p>
<p>S. Such information the applicant may consider relevant.</p>	<p>Application</p>

<p align="center">Council’s Application Guide (Section No. and Summary Description)</p>	<p align="center">Old Town Substation Rebuild Project Application (Section Reference)</p>
<p>VII. Proof of Service (C.G.S § 16-50f) Each application shall be accompanied by proof of service of such application on:</p> <ul style="list-style-type: none"> A. The chief elected official, the zoning commission, planning commission, the planning and zoning commissions, and the conservation and wetlands commissions of the site municipality and any adjoining municipality having a boundary not more than 2,500 feet from the facility; B. The regional planning agency that encompasses the route municipalities; C. The State Attorney General; D. Each member of the Legislature in whose district the facility is proposed; E. Any federal agency with jurisdiction over the proposed facility; and F. The state departments of Energy and Environmental Protection, Public Health, Public Utilities Regulatory Authority, Economic and Community Development, Agriculture and Transportation; the Council on Environmental Quality; and the Office of Policy and Management; and G. Other state and municipal bodies as the Council may designate by regulation, including but not limited to the SHPO and the Department of Emergency Management and Homeland Security. 	<p>Procedural requirement, completed at Application submission to the Council; refer to Formal Requirements section, Appendix H</p>
<p>VIII. Notice to Community Organizations The applicant shall use reasonable efforts to provide notice of the application on the following:</p> <ul style="list-style-type: none"> A. Affected community groups including Chambers of Commerce, land trusts, environmental groups, trail organizations, historic preservation groups, advocacy groups for the protection of Long Island Sound, and river protection organizations within the watershed affected by the proposed facility that have been identified by the municipality where the facility is proposed to be located or that have registered with the Council to be provided notice; and B. Any affected water company that would provide water to, or be within the watershed affected by, the proposed facility. 	<p>Section 8 provides summary information; data filings related to the Municipal Consultation Filing (MCF) for the Project are submitted separately as part of Application filing process; refer to other portions of Formal Requirements section, Appendix H</p>
<p>IX. Public Notice (C.G.S. § 16-50f) Provide appropriate notice of the Application, pursuant to the Council’s regulations. Notice must be published at least twice prior to the filing of the application, in a newspaper having general circulation in the site municipalities and shall be in a format as specified by the Council’s requirements.</p>	<p>Completed as part of Application submission process; refer to Formal Requirements section, Appendix H</p>
<p>X. Notice to Abutting Landowners (C.G.S. § 16-50f) Notice of the application shall be sent by certified or registered mail to each person appearing of record as an owner of property which abuts the primary or alternative sites on which the proposed facility would be located. Notice shall be sent at the same time that notice of the application is given to the general public. The application shall be accompanied by an affidavit of notice to all abutting landowners and an affidavit of publication each time notice of the application is published.</p>	<p>Completed as part of Application submission process; refer to Formal Requirements section, Appendix H</p>


This page intentionally left blank



OLD TOWN SUBSTATION REBUILD PROJECT CITY OF BRIDGEPORT EXECUTIVE SUMMARY

Proposed Project: To improve the bulk electric system in Connecticut, and particularly in the Greater Bridgeport Region, UI proposes to rebuild its existing Old Town Substation, located in the City of Bridgeport, County of Fairfield, and State of Connecticut. The existing Old Town Substation is a 115/13.8-kilovolt (kV) air-insulated substation (“AIS”) transmission and distribution facility that is on a 0.9-acre parcel of UI-owned land located at 280 Kaechele Place in northwest Bridgeport, Connecticut (refer to Figure 1). The station is more than 50 years old and provides electric service to the Greater Bridgeport area. Three overhead 115-kV transmission lines (referred to as the 1222, 1710, and 1714 lines) owned by The Connecticut Light and Power Company d/b/a Eversource Energy (“Eversource”) occupy a right-of-way (the “Eversource ROW”) that extends through the existing substation site; two of the 115-kV lines (1710 and 1222 lines) connect to the existing substation while the 1714 Line bypasses the substation. Within and adjacent to the substation, these transmission lines are supported on approximately 105-foot-tall lattice steel structures.

Figure 1: Project Area



After conducting studies to review current and future electric supply needs and to assess the physical condition of the substation equipment and infrastructure, UI determined that the existing Old Town Substation does not conform to Company and industry system performance standards for maintaining adequate, safe, and reliable service. As a result, UI determined that the substation must be replaced.

The Old Town Substation Rebuild Project (the “Project”) will entail the construction and operation of a new 115/13.8-kV transmission and distribution substation, proposed to be built on presently undeveloped, UI-owned property adjacent to the existing substation at 312 and 330 Kaechele Place (the “Project Site”; see Figure 1). The undeveloped property, which is characterized by upland forest, shrub vegetation, and a wetland, totals approximately 3 acres.

Overall, the new substation will occupy approximately 2.25 acres, including all the existing 0.9-acre substation parcel and approximately 1.35 acres of the adjacent 3-acre parcel. The remainder of the 3-acre parcel (i.e., approximately 1.63 acres) is not expected to be developed (refer to Figure 2).

Figure 2: Project Site



In addition, the Project will include modifications to link the new substation to the existing 115-kV transmission and distribution lines that presently connect to the existing Old Town Substation, including a new approximately 0.15-acre easement proposed on City of Bridgeport property for the 115-kV transmission line connections to the new substation and for an access road to one of the Eversource transmission line structures. After the new substation is placed into service, the existing Old Town Substation will be decommissioned.

Need for the Project: The existing Old Town Substation is more than 50 years old, and most of the substation’s equipment must be replaced now or in the near future to meet industry and UI standards. The proposed Project is needed for UI to continue to provide reliable electric service to the Greater Bridgeport region, meeting both existing and future demands for electricity and conforming to industry and UI standards.

Proposed Project Facilities: The proposed Old Town Substation will consist of new facilities to directly replace and upgrade all the existing 115-kV and 13.8-kV components within the existing substation. The new AIS substation will initially be designed as a two-transmission line, single-breaker arrangement, expandable to a two-bay breaker and one-half arrangement, with two 45/60/75 MVA, 115/13.8-kV power transformers with a plan for a future third transformer, as well as a future 115-kV capacitor bank. The substation will include new 115-kV and 13.8-kV switchyard equipment, a new control enclosure and a 13.8-kV switchgear enclosure, as well as modifications to the 115-kV overhead transmission lines and optical ground wire fiber optic cables.

A perimeter chain link fence with privacy slats, approximately 14 feet tall and topped with an additional 1 foot of barbed wire, will be installed around the new substation. In addition, to accommodate the existing site topography and minimize grading to the extent practical, a concrete retaining wall will be


built around portions of the perimeter of the substation. The chain link fencing will be installed on top of the retaining wall.

The Project will not affect the alignment of the Eversource ROW through UI's property. However, the two Eversource transmission lines (1710 and 1222) that presently connect to the existing Old Town Substation will be modified and rerouted to connect to line terminals at the new substation. A third transmission line (1714 Line), which presently bypasses the existing substation to connect UI's Trumbull Substation and Eversource's Weston Substation, will be re-routed to the new substation yard to accommodate a future connection.

In total, nine new steel monopoles will be installed. Specifically, the two lattice towers will be replaced with four monopoles. Such monopoles will be located within the Eversource ROW: two within the substation and two within the Eversource ROW immediately to the east of the substation. The five remaining new monopoles, all within the new substation boundaries, will support the existing and future 115-kV line connections to the new substation. UI will rebuild the transmission lines within the new substation. The transmission line modifications will be coordinated with Eversource.

Figure 3 illustrates the proposed layout of the new substation, including the transmission line connections. *See Appendix A for the full-sized view.*

Figure 3: Proposed Substation Layout and Transmission Line Connections



The cost of the proposed Project is estimated to be approximately \$40 million. The substation equipment, transmission lines, and supporting infrastructure are expected to have a service life of about 40 years.

Construction Activities, Schedule, and Work Hours: The Project will require approximately 18 to 24 months to construct. Standard work hours will be 7:00 AM to 7:00 PM, Monday through Saturday; however, some construction tasks will require work on Sundays or beyond these standard daily work hours.

To construct the new substation, site preparation work will be required, including vegetation removal, grading, and filling. Blasting could be required, depending on the depth and type of bedrock encountered. To minimize the amount of grading, UI will construct a concrete retaining wall, approximately 700 feet in length and ranging in height from approximately 2 to 10 feet, depending on cut and fill requirements, around portions of the substation perimeter.

Other typical substation construction activities will include foundation, enclosure, and equipment installation; 115-kV and distribution line connections; testing, commissioning, and restoration. The construction activities required to realign the existing 115-kV overhead transmission lines to connect to the new substation will involve vegetation clearing, foundation excavation, structure and conductor installation and ROW restoration. After the installation of the new facilities, the old substation equipment will be decommissioned, and the two existing lattice transmission structures will be removed.

All primary construction activities are expected to be confined to UI property or to the Eversource ROW in the immediate vicinity of the substation. However, an approximately 0.15-acre easement from the City of Bridgeport (the “City” or “Bridgeport”) (on property within the City’s Elton Rogers Woodland Park (the “Park”)) will be required to accommodate the overhead lines extending into the new substation from the Eversource ROW at the southeastern corner of the UI property. Although the lines will span this easement area, forested vegetation will have to be cut to maintain mandatory safe clearance from the realigned 115-kV lines. UI has consulted with and will continue to coordinate with the City of Bridgeport regarding this easement. Similarly, an easement from the City for an access road from Kaechele Place to the Eversource ROW will be required; UI and Eversource are coordinating with the City for this easement.

In addition, to support the development of the new substation, temporary construction staging areas may be located at existing commercial or industrial sites in the vicinity of the Project. Such staging areas, if required, would be used for construction office trailers, equipment and materials storage, parking, etc. Typically, the location for a staging area/contractor yard would be identified in later stages of the Project planning process, with input from the Project construction contractor.

The Project will comply with the latest revisions of standards of the National Electrical Safety Code, the Institute of Electrical and Electronic Engineers and the American National Standards Institute; good utility practice; Connecticut regulations governing the method and manner of construction; UI’s specifications and final engineering plans; and the conditions of approvals obtained for the Project.

Environmental Setting, Impacts, and Mitigation: UI researched data on existing environmental features in the region and conducted studies of environmental resources on and in the vicinity of the Project Site. Information was compiled regarding ecological resources (soils, wetlands, watercourses, vernal pools, floodplains), vegetation and wildlife, federal and state listed species, land uses, cultural resources, visual resources, transportation, air quality, and noise. The Project Site is in a mixed-use area, where properties include retail, professional office facilities, a funeral home, residential development, and the Park, an undeveloped largely forested area that borders the Project Site to the east and south. The Eversource ROW extends through the Park. Access to the Project Site is by way of Kaechele Place and Main Street (State Route 111). The Merritt Parkway (State Route 15) is located about 0.3 miles north of the Project Site.

UI determined that the Project is consistent with the long-established utility uses in the vicinity (i.e., the existing Old Town Substation and the Eversource ROW) and will have a positive long-term effect on the reliability of the electric system in the Greater Bridgeport area, as well as in the State. The new Old Town Substation and associated 115-kV line interconnections will be located entirely on UI property or within the Eversource ROW, with the exception of the approximately 0.15-acre easement that is proposed on Bridgeport property to accommodate the overhead 115-kV transmission line connections to the new substation. UI anticipates that the Project will be designed and constructed to avoid permanent fill in the wetlands located on the northern portion of its property.

Although the construction and operation of the Project will require the conversion of approximately 1.35 acres of UI owned forested land to utility purposes, the Project will be consistent with the adjacent utility uses and will not result in any expansion of the Eversource ROW. The Project's proposed easement on Bridgeport's property within the Park will not affect the overall passive (e.g., hiking) recreational use of the park and will be consistent with the Eversource ROW.

As a result, any environmental effects are expected to be minor and localized to the Project vicinity. UI and Eversource will mitigate such impacts to the extent practical by implementing standard construction best management practices and conforming to the conditions of Project permits and approvals. Additional measures to avoid or minimize environmental effects may be identified as part of the ongoing engineering design and constructability reviews and consultations with the municipalities and/or regulatory agencies.

Electric and Magnetic Fields:

UI commissioned a study to measure the electric and magnetic fields (EMF) associated with the existing Old Town Substation and to model the anticipated EMF levels from the new substation. The study found that the proposed Project will not significantly change EMF levels in the vicinity because the configuration of the new substation and connecting transmission lines will be like that of the existing substation and lines. Thus, the EMF levels in the vicinity of the new substation are expected to be a small fraction of those recommended for the general public by international health-based standards.

Alternatives: The proposed Project was selected as a result of a process whereby various alternatives were identified and assessed. Initially, UI evaluated the existing substations' asset condition, in relation to existing and future needs and found that the existing Old Town Substation equipment must be updated to conform to Company and industry standards and to address existing and future electric demand. UI eliminated the "No Action" alternative (i.e., "do nothing") because it would pose unacceptable risks to the resiliency of the electric transmission system and the continued provision of reliable service to customers in the Greater Bridgeport area. UI then conducted an analysis, identifying two primary options for upgrading Old Town Substation:

- (1) In-kind replacement of the substation on the existing 0.9-acre substation site; or
- (2) A rebuild alternative, involving the development of a new, upgraded 115/13.8-kV substation, either on UI property adjacent to the existing Old Town Substation or on a site located elsewhere, near the Eversource ROW that includes the 115-kV lines to which the substation must connect.

UI determined that Option 1 (in-kind replacement) was not feasible. As a result, UI focused on Option 2 (rebuild alternative), identifying and reviewing seven alternative properties, including the proposed Project Site. To facilitate the required connections to Eversource's 115-kV lines, all the alternative

sites had to be located adjacent to or near the Eversource ROW in Bridgeport or the Town of Trumbull (the “Town” or “Trumbull”).

UI assessed each of the alternative sites, based on size, property ownership, proximity to the Eversource ROW, required distribution line connections, land use and environmental features, constructability, and general cost. Except for the proposed Project Site, all the alternatives would require UI to acquire property for the new substation. As a result of this review, all but the Project Site were dismissed from consideration because of various overriding factors (e.g., cost, feasibility of property acquisition, existing land use and environmental constraints, potential for regulatory/siting issues). In summary, the proposed Project represents the optimal solution for rebuilding the Old Town Substation, thereby enhancing the reliability of the electric system to the benefit of Connecticut and New England consumers.

Agency and Municipal Consultations.

The proposed Project is subject to the statutes and regulations of the Council and other state agencies. Accordingly, for the Project, UI submits to the Council this *Application for a Certificate of Environmental Compatibility and Public Need* (the “Application”).

Pursuant to the Connecticut Public Utility Environmental Standards Act and the Council requirements, as part of the planning for the Project, UI contacted representatives of the City of Bridgeport and, in January 2020, submitted to Bridgeport’s Mayor a Municipal Consultation Filing (the “MCF”) that described the proposed Project, including alternatives considered. As Trumbull’s southern boundary is approximately 0.2 mile north of the proposed Project Site and several of the alternatives considered for the Project are within the Town, UI also provided a copy of the MCF to the Trumbull First Selectman.

The municipal consultation process, which included a 60-day comment period, is a primary mechanism for informing municipal representatives about the proposed Project and for soliciting input about the Project from the public, stakeholders, and local representatives. As part of this process, UI met with City representatives on August 27th, 2019, and January 2nd, 2020; consulted with property owners adjacent to the planned substation site; and held a public meeting regarding the proposed Project on March 9, 2020. UI also offered to meet with Town of Trumbull representatives.

In addition to the municipal consultation process, UI consulted with various state agencies, including the Connecticut Department of Energy and Environmental Protection (“CT DEEP”) and the Connecticut State Historic Preservation Office (“SHPO”). UI also consulted with the U.S. Fish and Wildlife Service.

1. PROJECT OVERVIEW AND NEED

1.1 PROJECT BACKGROUND, LOCATION, AND PURPOSE


1.1.1 Project Objectives

To improve the bulk electric system in Connecticut, and in particular the Greater Bridgeport area, The United Illuminating Company (UI or the Company) proposes to rebuild its existing Old Town Substation, a 115/13.8-kilovolt (kV) transmission and distribution facility. The existing air-insulated substation (AIS), which was built more than 50 years ago is classified as a North American Electric Reliability Corporation (“NERC”) Bulk Electric System substation. The substation is located on an approximately 0.9-acre site at 280 Kaechele Place, in the northwestern portion of the City of Bridgeport, County of Fairfield, State of Connecticut (“Existing Substation Parcel”). After conducting studies to review current and future electric supply needs and to assess the physical condition of the existing substation equipment and infrastructure, UI determined that the existing Old Town Substation does not conform to Company and industry system performance standards for maintaining adequate, safe, and reliable service, and therefore must be replaced.

The Project will entail the construction and operation of a new 115/13.8-kV transmission and distribution substation, proposed to be built on an adjacent parcel to the existing substation, on presently undeveloped property. The undeveloped property totals approximately 3 acres and is owned by UI at 312 and 330 Kaechele Place (collectively, the “Undeveloped Parcels”). Once completed, the new substation also will encompass the existing substation site. Overall, the new substation will occupy approximately 2.25 acres, including the 0.9-acre Existing Substation Parcel and approximately 1.35 acres of the Undeveloped Parcels. The remainder of the 3-acre site (i.e., approximately 1.63 acres) will not be developed. In addition, the Project will include modifications to link the new substation to the 115-kV transmission and distribution lines that presently connect to the existing Old Town Substation. After the new substation is placed into service, the existing Old Town Substation will be decommissioned.

Figure 1-1 identifies the general Project Site, illustrating the location of the existing Old Town Substation and adjacent UI property in relation to the surrounding region. Appendix A includes maps and drawings that provide details regarding the proposed Project.

Figure 1-1: General Location of Existing and Proposed Old Town Substation Site



Source: USGS Topographic Map, Bridgeport, CT 06605 Quadrangle

1.1.2 Description of Existing Old Town Substation and 115-kV/13.8-kV Line Connections

The existing Old Town Substation was constructed and placed into service in the early 1960s. The substation connects to two 115-kV transmission lines and steps down power delivered from these lines to feed UI's local distribution system. The substation is geographically located to feed the distribution capacity needs of the City of Bridgeport, as well as the neighboring towns of Easton, Fairfield, and Trumbull. However, approximately 90% of the substation's load is centered in Bridgeport and Trumbull.


The substation consists of the following facilities: substation yard, a control enclosure with two electrical distribution buses and distribution switchgear, 115-kV oil circuit breaker (OCB), two 60 megavolt ampere (MVA) 115/13.8-kV power transformers, a 115-kV bus structure, Number 3 13.8-kV bus enclosure, and one 13.8-kV 7.2 megavolt ampere reactive (MVAR) capacitor bank enclosure. The substation also includes the supporting structures for overhead transmission line switches and electric components, such as current transformers (CTs), capacitive coupled voltage transformers (CCVTs), and lightning arrestors. The substation bus structure is constructed primarily with 2,156 kcmil stranded wire strain bus.

A transmission line right-of-way ("ROW") owned by the Connecticut Light and Power Company d/b/a Eversource Energy ("Eversource") traverses east-west across the Project area and extends through the northern portion of the substation. This ROW supports two Eversource overhead 115-kV transmission lines on double-circuit steel lattice towers. Eversource's existing 1710 and 1222 Lines terminate within the Old Town Substation fence line on an existing Eversource lattice steel tower. A third Eversource 115-kV transmission line (the 1714 Line) bypasses Old Town Substation and links UI's Trumbull Substation and Eversource's Weston Substation. As a result, the double-circuit 115-kV line configurations at the substation are as follows:

- Extending east from the substation, the Eversource ROW supports both the 1714 Line and the 1710 Line. The 1710 Line connects Old Town Substation to Eversource's Devon Substation in the City of Milford and UI's Pequonnock Substation in southern Bridgeport.
- Extending west from the substation, the Eversource ROW supports both the 1714 Line and the 1222 Line. The 1222 Line connects Old Town Substation to UI's Hawthorne Substation in the Town of Fairfield.

Figure 1-2 provides an aerial view of the existing substation in relation to the surrounding region, while Figure 1-3 presents a street-level view of the existing substation.

Figure 1-2: Existing Old Town Substation Site and Vicinity



Source: Google Earth (2019)

Figure 1-3: Street-Level View of Existing Old Town Substation (Looking East from Kaechele Place)



As illustrated generally in Figures 1-1 and 1-2, the existing Old Town Substation is located on a 0.9-acre UI property bordered by undeveloped land owned by UI to the north and east and by the Park to the south. Kaechele Place, a local road, borders the site to the west. Lands in the immediate vicinity of Kaechele Place are used for a mix of commercial purposes (funeral home, office buildings, businesses), with some residences located to the south and west.

Old Town Substation is accessed by way of two driveways off Kaechele Place, both of which connect to Main Street (State Route 111). Old Town Road and the Merritt Parkway (State Route 15) are located approximately 0.2 mile and 0.4 mile to the north (by way of Main Street), respectively, providing primary east-west access in the vicinity of the Project. Sequoia Road, which extends east from Main Street and extends northeast to connect to Old Town Road, is located approximately 0.1 mile north of the existing substation.

Old Town Substation has been expanded several times over the past 50 years. For example, the control enclosure was expanded in the early 1980s to add transmission relaying and a Supervisory Control and Data Acquisition (SCADA) system; this expansion is on the south side of the existing enclosure. In response to distribution substation capacity needs in early 1980s, UI installed a prefabricated power distribution center referred to as the Number 3 bus enclosure, which houses the circuit breakers and associated relaying schemes for four distribution feeders linked through two underground cables, one from each transformer.

In addition, the substation has distribution feeder ties with UI's Hawthorne, Pequonnock, New Congress 1 & 2, and Trumbull substations, allowing for load transfers between these stations. This interconnectivity is extremely valuable during regular switching operations, contingency conditions, and for permanent load transfers to relieve potential overloads on adjacent stations. Such switching is the primary means of balancing regional load between substations and as a preliminary measure to defer construction of additional distribution capacity.

1.1.3 Issues Regarding the Existing Old Town Substation and Need for the Project

The need for the Project was identified as a result of detailed analyses of the condition of the existing Old Town Substation, taking into consideration both existing and future requirements for assuring the reliability of the electric system. Overall, the need for the new substation stems from the age of the existing Old Town facility (more than 50 years old) and the fact that most of the substation's equipment

needs to be replaced now or in the near future in order to conform to industry and UI standards, as well as to provide reliable electric service to the region.

Specifically, as part of efforts to assess the condition of its transmission line and substation infrastructure, UI conducted studies to evaluate the present and future viability of the existing Old Town Substation. These studies included the following:

1. A comprehensive physical evaluation of the substation, involving analyses of the station foundations, perimeter fencing, grounding components, control wiring, conduit, and control room;
2. A condition assessment of the existing short-circuit adequacy of equipment and bus structures, lightning protection, and conformance to National Electrical Safety Code (“NESC”) clearance requirements and UI Design Standards; and
3. A 3D Light Detection and Ranging (“LiDAR”) survey of the 115-kV yard to evaluate conformance to American National Standards Institute (“ANSI”), NESC, and UI clearance requirements with a focus on the areas surrounding the 115-kV OCB and associated disconnect switches.

As a result of these studies, UI determined that the Old Town Substation exhibited the following deficiencies in terms of reliability performance and physical condition:

- **Inadequate Lightning Protection.** The substation’s bus structure does not adequately protect the exposed equipment (e.g., disconnect switches) from direct stroke lightning strikes. A statistical analysis determined that there is a 99.8% probability that the exposed equipment would be damaged from lightning strikes.
- **Insufficient Control Enclosure Space.** The existing small control enclosure does not meet NESC criteria for sufficient work room and cannot be expanded further due to the small size of the existing substation site. As a result, the control enclosure cannot be upgraded to support any needed improvements at the station.
- **Single Point of Failure.** Both mains to, and feeders from, the Number 3 bus enclosure extend through the same manhole in the substation yard. This design is unique to Old Town Substation and is not found elsewhere on UI’s system. A catastrophic event in this manhole, such as a cable fault, has the potential to de-energize the entire substation as these sections of cable are covered by the transformer differential protection scheme. Thus, there is a significant risk of interrupting all customer load supplied by the substation for an extended period due to the design of this manhole.
- **Bus No. 3 Enclosure Problems.** The Number 3 Bus enclosure requires remediation to eliminate reoccurring issues associated with the buckling of the bus room floor. While maintenance has been performed to address the incoming breaker issues, the underlying problem leading to these failures persists, requiring increasingly frequent and more difficult maintenance due the age of the equipment and the lack of available replacement parts.

- **OCB Replacement.** The substation's 115-kV OCB is obsolete and poses increased risks of failure.
- **Lack of Mobile Substation Access.** UI owns two 50 MVA 115/13.8-kV mobile substation transformers that can be deployed to substations in the event of a transformer failure, thus maintaining service to customers. However, the existing Old Town Substation was designed for a single point of access for mobile substation deployment and has insufficient space to deploy even UI's smallest mobile substation transformer without violating clearances to the overhead strain bus. Further, the only available location for a mobile substation transformer is over the substation's septic system; no other space is available due to the location of substation equipment and the small overall size of the existing station site.
- **Disconnect Switch Maintenance Issues.** The OCB disconnect switches are outdated and are increasingly difficult to maintain due to the absence of replacement parts and long lead times for specialty fabricated components. Moreover, the disconnect switches do not conform to current ANSI standards.
- **Corroded CCVTs.** Two 1710 Line CCVTs require replacement. These CCVTs are badly corroded with a high risk of moisture penetration into the internal components.

After assessing the issues associated with the existing Old Town Substation equipment and determining that the existing substation site was not large enough to accommodate the improvements required, UI determined that the optimal solution would be to rebuild the substation, upgrading all facilities to conform to current Company and industry standards.

1.2 SUMMARY OF PROPOSED PROJECT FACILITIES

The Project will entail (i) the construction and operation of a new Old Town Substation, which, like the existing substation, will be an AIS design, and (ii) the relocation of the 115-kV transmission and distribution line connections to the substation. Appendix A includes detailed maps and drawings of the proposed Project facilities.

1.2.1 Proposed Project Site: Location and History

The new Old Town Substation is planned to be built on approximately 2.25 acres of UI property. Approximately 1.35 acres will be on UI's approximately 3-acre property that borders the Existing Substation Parcel. In its final configuration, the new substation will also encompass the 0.9-acre existing decommissioned substation site (refer to Figure 1-4). The approximately 3-acre Undeveloped Parcels are presently undeveloped, consisting mostly of forested areas and are bordered to the east by the Park, to the north by the back yards of residences along Sequoia Road and the parking lot of a funeral home, to the south by the existing substation and undeveloped property, and to the west by Kaechele Place. The Eversource ROW extends east-west through the existing substation.

Figure 1-4: Existing Old Town Substation, Proposed Project Site, and Eversource Transmission Line ROW



Source: Google Earth (2020)


Historically, the Project Site was undeveloped through the first portion of the twentieth century, although aerial photography dated 1934 shows the existing Eversource ROW extending across the current UI property. Between 1935 and 1951, a residence was built on a portion of the 3-acre property, adjacent to Kaechele Place. This residence was demolished and removed in 2011.

UI purchased the 0.9-acre existing substation site in 1961 and built the existing Old Town Substation in the mid-1960s. UI acquired the two adjacent properties (312 and 330 Kaechele Place) in December 2009.

1.2.2 Proposed Substation Facilities and Transmission Line Connections

The proposed Old Town Substation will consist of new facilities to directly replace and upgrade all the existing 115-kV and 13.8-kV components at the substation. The new substation will occupy approximately 2.25 acres and will encompass the 0.9-acre site of the existing Old Town Substation. The alignment of the Eversource ROW through the UI property will not be affected. Figure 1-5 illustrates the proposed layout for the new substation.

Figure 1-5: Proposed Rebuilt Substation Layout



Source: UI 2019

The new 115-kV AIS substation will be designed in a two-transmission line, single-breaker arrangement, expandable to a two-bay breaker and one-half arrangement, with two 45/60/75MVA, 115/13.8-kV Power Transformers with a plan for a future third transformer, as well as a future 115-kV capacitor bank. The substation will include new 115-kV and 13.8-kV switchyard equipment, a new control enclosure and 13.8-kV switchgear enclosure, as well as modifications to the 115-kV overhead transmission lines and optical ground wire (OPGW) fiber optic cables along with 13.8-kV distribution system connections.

Two of the Eversource 115-kV transmission lines (1710 and 1222) that presently connect to the existing Old Town Substation will be modified and rerouted at the north side of the Project Site to connect to line terminals at the new substation. The third Eversource transmission line (the 1714¹

¹ The 1714 Line, which presently bypasses the existing substation, will be re-routed to the new substation and will connect to the takeoff structures within the fence line. Initially this line will bypass the new station, but will be constructed in such a way that future interconnections can be easily made.

Line), which presently bypasses the existing substation, will be re-routed through the new substation yard to accommodate a future connection.

In total, nine new steel monopoles will be installed to support the 115-kV lines. Eversource's two existing lattice towers will be replaced with four monopoles. These four new monopoles will be located within the Eversource ROW: two within the substation and two within the ROW to the east of the substation (refer to Figure 1-5 and the detailed site plans in Appendix A). The five remaining new monopoles, all within the substation boundaries, will support the 115-kV line connections to the new substation, as well as the 1714 Line realignment through the substation yard. UI will coordinate the transmission line modifications with Eversource.

After the new Old Town Substation is placed in-service, the point of change in ownership for the 1222 and 1710 lines, as well as the potential future interconnection with the 1714 Line, will be established at the Eversource-owned steel monopoles located within the Eversource ROW. Eversource will own the monopoles, insulators, conductor loop, and hardware attached to the monopoles. UI will own the monopoles, conductor, and associated equipment located within the substation fence line.

After the new substation is placed into service, the existing Old Town Substation will be taken out of service, decommissioned and removed. Similarly, after the new 115-kV structures are installed and the 115-kV transmission lines are connected to the new substation, Eversource's two existing lattice steel structures on UI property/Eversource ROW will be removed.

1.3 ORGANIZATION OF THE APPLICATION

The Project is subject to the regulations of the Council and other state regulatory agencies. Accordingly, UI submits to the Council this Application. The Application addresses all the Council's requirements; specifically, the Application:

- Describes the need for the proposed Project, the location of and assets at the existing substation, and the proposed substation site and facilities (Section 1);
- Provides technical specifications for the proposed Project facilities, including the new substation facilities and transmission/distribution line relocations, as well as the Project cost (Section 2);

- Describes construction and operation/maintenance information for the proposed Project facilities, including anticipated construction work hours (Section 3);
- Discusses existing environmental resources (including cultural resources and visual resources), potential Project impacts, and impact mitigation measures (Sections 4 and 5);
- Provides data concerning electric and magnetic fields (EMF) associated with the Project facilities. (Section 6);
- Identifies the proposed Project schedule (Section 7);
- Reviews the permits, approvals, and consultations completed to date and expected to be performed for the Project (Section 8); and
- Discusses the alternatives analyses that led to the selection of the Project at the proposed site (Section 9).

Section 10 provides a glossary of terms and acronyms used in the Application. Appendices include supporting information compiled to date regarding the Project, including plans and drawings, as well as cross-sections for the transmission line connections to the substation (Appendix A); copies of agency correspondence (Appendix B); environmental resource and technical reports (Appendices C-F); a detailed report on electric and magnetic field (EMF) studies for the Project (Appendix G); and information in response to the Council's Formal Requirements (Appendix H).

This page intentionally left blank

2. TECHNICAL SPECIFICATIONS FOR THE PROJECT

The technical specifications contained in this section are based on currently available data concerning the Project. As the Project engineering design processes proceed, these technical specifications will be refined.

2.1 LAND AND ACCESS REQUIREMENTS

The new Old Town Substation is planned to be built on UI property, including the Undeveloped Parcels and the Existing Substation Parcel. The new substation, like the existing station, will be accessible by way of two separate entrances/exits located on Kaechele Place.

All primary substation construction activities will be confined to UI property or to the Eversource ROW in the immediate vicinity of the substation. However, as needed to support the development of the new substation, temporary construction staging areas/contractor yards may be located at existing commercial or industrial sites in the vicinity of the Project. Such staging areas, as required, would be used for construction office trailers, equipment and materials storage, parking, etc. Typically, the location for a staging area/contractor yard would be identified in later stages of the Project planning process, with input from the Project construction contractor.

In addition, UI and Eversource will acquire easements from the City of Bridgeport for the Project. An approximately 0.15-acre easement will be conveyed by from the City on the southeast side of the substation site to accommodate clearance requirements for the 115-kV line connections to the new substation. Further, an easement on City property for an existing off-ROW access road from Kaechele Place to the Eversource ROW will be required to replace the Eversource lattice transmission line structure that is located east of the existing substation and to reroute the 1710 and 1714 lines. UI and Eversource have discussed the need for these easements with the City of Bridgeport.

The Appendix A maps illustrate the locations of the Project's currently proposed access roads and work areas.

2.1.1 Proposed Substation

The new substation will be built on approximately 2.25 acres of UI property. Approximately 1.35 acres will be on UI's approximately 3-acre property that borders the Existing Substation Parcel. In its final

configuration the new substation will also encompass the 0.9-acre Existing Substation Parcel. The new substation will be situated northeast of and adjacent to the existing Old Town Substation. (Refer to Figure 1-5 and the Appendix A maps.)

All access for the construction and operation of the new substation is expected to be by way of Kaechele Place, which provides direct connections to Main Street. As part of the Project, UI will develop a new access road into the site from Kaechele Place and, as necessary, will improve the current access that extends off Kaechele Place to the existing Old Town Substation.

2.1.2 Transmission Line Connections to the New Substation

Access roads and work pads will be required to remove the two existing lattice steel towers and install the new monopole structures necessary to realign Eversource's 1710, 1714, and 1222 lines from the existing substation to the new Old Town Substation. Such access roads and work pads will be on UI property or within the Eversource ROW, except for a potential off-ROW access from Kaechele Place to reach the lattice tower located in the Eversource ROW south of and adjacent to the substation. The Appendix A maps illustrate the anticipated locations of the access road and work areas in the Eversource ROW that will be required to install the new transmission line structures and remove the existing lattice steel towers.

2.1.3 Existing Substation Decommissioning and Transmission Line Removals

Work to decommission the existing Old Town Substation, which will be conducted principally after the new substation is placed in service, will be performed within UI's existing 0.9-acre property, using existing access from Kaechele Place. Similarly, the removal of the existing transmission line connections will be within the Eversource ROW on UI property.

2.2 NEW SUBSTATION FACILITIES

The proposed Old Town Substation will include new 115-kV switchyard equipment, a new control enclosure and 13.8-kV switchgear enclosure, overhead transmission line and OPGW fiber optic cable modifications, and related new equipment along with 13.8-kV distribution system connections. The substation will be designed for future expansion to a four-transmission-line, two-bay, breaker-and-one-half arrangement with three power transformers and a future 115-kV capacitor bank connection.

Figure 2-1 generally illustrates the proposed substation layout. Additional site plan information is included in Appendix A.

Figure 2-1: Proposed Substation Layout



The primary substation equipment and facilities will include:

- A new approximately 3,840 square-foot control enclosure and 13.8-kV switchgear enclosure, with approximate dimensions of 16 feet in height by 120 feet long by 32 feet wide. This enclosure will include the following components:
 - Protection and control panels with associated relay and metering equipment
 - Battery banks and associated chargers
 - AC/DC distribution panels
 - Lavatory facility
 - Communication equipment
 - HVAC equipment
 - The switchgear room will accommodate construction of four new lineups of indoor 13.8-kV GIS switchgear separated with space for future additions
- Two 115/13.8-kV 45/60/75 MVA power transformers
- Three 115-kV SF6 dead tank circuit breakers
- 115-kV disconnect switches
- CCVTs
- Associated 115-kV insulators, tubular aluminum bus, surge arrestors, and connectors
- Provisions to accommodate a temporary mobile transformer for emergency conditions
- Lightning masts
- Associated structural steel to support electrical equipment

A perimeter chain link fence with privacy slats, approximately 14 feet in height and topped with an additional 1 foot of barbed wire, will be installed around the substation. In addition, to accommodate the existing site topography and minimize grading to the extent practical, a concrete retaining wall will be built around portions of the perimeter of the substation. The chain link fencing will be installed on top of the retaining wall. UI will provide access to Eversource for the maintenance of the new monopole structures to be located within the Eversource ROW inside the substation. The site plan in Appendix A illustrates the proposed location of the substation's perimeter fence and retaining wall.

The new Old Town Substation will be designed to meet or exceed all State building and fire codes, including provisions for seismic loading, wind loading, and snow/ice loading.

2.3 SUBSTATION TRANSMISSION LINE CONNECTIONS

UI proposes to relocate Eversource's two 115-kV transmission lines (i.e., the 1710 and 1222 lines) that presently feed the existing Old Town Substation to connect to the new substation. In addition, Eversource's 1714 Line, which bypasses the existing substation, will be realigned to allow a potential connection to the Old Town Substation, if needed to meet future electricity demand. Technical specifications regarding the existing and proposed 115-kV line connections are described below and illustrated on the Appendix A maps, cross-sections, and drawings.

2.3.1 Existing 115-kV Line Connections

At the existing Old Town Substation, the Eversource's overhead transmission lines are supported on two approximately 105-foot-tall lattice steel structures, one located adjacent to the existing substation property and one located on the Eversource ROW/easement within the existing substation.

2.3.2 Proposed 115-kV Line Connections

The existing Eversource transmission line connections to the new substation will be relocated as shown on Figure 2-1 and the Appendix A maps and drawings. Specifically, the 1710 and 1222 lines will connect to the line terminals at the new substation. The 1714 Line will be re-routed through the substation yard in anticipation of a future connection to the new substation. In total, nine new steel monopoles will be installed.

Eversource will own the four structures that will replace the two steel lattice towers, as well as the line conductors, ground wire, insulators, conductor loop, and hardware that will be attached to each

structure for the 1714, 1222 and 1710 lines. UI will own the insulators and conductors leading to the Old Town Substation.

As illustrated in Figure 2-1 and Appendix A, the two existing lattice steel towers will be replaced with four new steel monopoles, which are expected to be approximately 105-feet tall. All four of these monopoles will be within the Eversource ROW; two on the Eversource ROW east of the substation and two on the portion of the Eversource ROW that extends through the substation. The remaining five new monopoles that will be built within the substation are expected to be less than 100 feet tall.

After the new Old Town Substation is placed in-service, the point of change in ownership for the 1222, 1710, and 1714 lines will be established at the Eversource-owned steel monopoles located within the Eversource ROW. Eversource will own the monopoles, insulators, conductor loop, and hardware attached to the monopoles. UI will own the monopoles, conductor, and associated equipment located within the substation fence line along with the insulators and conductors heading into the substation from the Eversource owned monopoles.

The transmission line structures will be constructed and owned by Eversource. UI and Eversource will coordinate the line work attaching to the new structures. As UI proceeds with the engineering design of the Project, the final locations and heights of the new transmission line structures may be modified from those illustrated in Figure 2-1 and Appendix A.

2.4 ESTIMATED PROJECT COSTS AND FACILITY SERVICE LIFE

The estimated cost for the siting, design, and construction of the Project is approximately \$40 million. As detailed engineering progresses a more detailed estimated project cost will be developed. The substation equipment, transmission lines, and supporting infrastructure are expected to have a service life of approximately 40 years.

2.5 DECOMMISSIONING APPROACH: EXISTING OLD TOWN SUBSTATION AND RELATED TRANSMISSION LINE CONNECTIONS

After the new Old Town Substation is constructed, the 115-kV transmission lines and 13.8-kV distribution lines are connected, and the facility is commissioned and placed into service, UI will decommission the existing Old Town Substation and associated 115/13.8-kV line connections. This work will include:

- Decommissioning and removing electrical components within the substation (e.g., 115-kV 60 MVA Transformers, OCB, bus and structures, CCVTs, switchgear, control enclosure);
- Removing above-ground structural components within the substation; and
- Eversource will dismantle and remove the existing overhead transmission line connections to the substation (e.g., removal of conductors, arms, and structures).

3. PROPOSED CONSTRUCTION AND OPERATION/MAINTENANCE PROCEDURES

UI will construct, operate, and maintain the new Old Town Substation in full compliance with the current standards of the NESC, the Institute of Electrical and Electronic Engineers (IEEE) and the American National Standards Institute (ANSI); good utility practices; and UI's specifications, final engineering plans; and any conditions set forth in approvals obtained for the Project.

3.1 CONSTRUCTION PROCEDURES: GENERAL

Pursuant to the Council's requirements, after Council approval of the Application but prior to the commencement of construction activities, UI will prepare and submit to the Council a detailed Development and Management Plan ("D&M Plan") for review and approval. Project construction will be performed in accordance with the D&M Plan, which will reflect conformance to the conditions of the Council's approval of the Project, as well as compliance with other regulatory requirements and UI specifications. UI will monitor and inspect Project construction activities for conformance with these requirements.

3.2 SUBSTATION AND 115-kV LINE CONNECTIONS CONSTRUCTION

3.2.1 Construction Sequence

The Project will require construction staging areas (refer to 3.2.2 Construction Staging Areas and Traffic Management) and will be developed in several stages. Table 3-1 summarizes the general sequence of activities for the construction of the new substation and the relocation of the associated 115-kV lines. These activities are discussed in Sections 3.2.3 and 3.2.4.

During construction, certain work activities and sequences may vary, based on factors such as final Project design and conditions of the Council's, or other regulatory, approvals. Additional details regarding construction procedures and sequencing will be provided in the D&M Plan.

Table 3-1: General Project Construction Sequence

TYPICAL CONSTRUCTION ACTIVITIES	
Substation	
<ul style="list-style-type: none"> • Perform vegetation management (tree and vegetation removal); and concurrent installation of erosion and sedimentation control measures 	
<ul style="list-style-type: none"> • Prepare the site for development (fill, grading) and construct retaining wall; install temporary perimeter fencing 	
<ul style="list-style-type: none"> • Install pre-engineered control enclosure and control room foundation, substation foundations, conduits, grounding grid, and distribution facilities 	
<ul style="list-style-type: none"> • Install overhead transmission line structure foundations 	
<ul style="list-style-type: none"> • Install 13.8-kV equipment enclosure 	
<ul style="list-style-type: none"> • Install 115-kV equipment inside enclosure 	
<ul style="list-style-type: none"> • Install underground 115-kV duct banks 	
<ul style="list-style-type: none"> • Spread trap rock 	
<ul style="list-style-type: none"> • Offload and install power transformers 	
<ul style="list-style-type: none"> • Install 13.8-kV switchgear in 13.8-kV equipment enclosure; steel structures and outdoor substation equipment 	
<ul style="list-style-type: none"> • Install permanent fence 	
<ul style="list-style-type: none"> • Pull and terminate control wiring 	
<ul style="list-style-type: none"> • Commission/test the substation 	
<ul style="list-style-type: none"> • Install overhead transmission line conductors and insulators 	
<ul style="list-style-type: none"> • Perform 115-kV circuit by circuit transmission line cutovers; perform 13.8-kV circuit by circuit distribution line cutovers 	
<ul style="list-style-type: none"> • Install asphalt access drive; complete site restoration activities; remove temporary erosion and sedimentation control measures after site stabilization is achieved 	
<ul style="list-style-type: none"> • Decommission old substation 	
Transmission Line Connections	
<ul style="list-style-type: none"> • Locate and mark utilities, stake work area boundaries 	
<ul style="list-style-type: none"> • Establish erosion and sedimentation controls; prepare access and work pads to the structure locations 	
<ul style="list-style-type: none"> • Install new structure foundations and assemble/erect new structures 	
<ul style="list-style-type: none"> • Install conductors, shield wire, and OPGW on relocated transmission line connections 	
<ul style="list-style-type: none"> • Remove structures, conductors, shield wire, and OPGW from the existing line connections to the old substation 	
<ul style="list-style-type: none"> • Energize the line connections in conjunction with new substation energization 	
<ul style="list-style-type: none"> • Remove temporary construction access and work pads, and restore/stabilize areas affected by construction 	
<ul style="list-style-type: none"> • Maintain erosion and sedimentation controls until area affected by construction are stabilized 	

3.2.2 Construction Staging Areas and Traffic Management

UI owns all property required for the new substation. UI will coordinate with Eversource regarding temporary or permanent easements for workspace and access for the installation of the new overhead structures within and adjacent to the substation, in the Eversource ROW. UI also will coordinate with Eversource for the removal of the existing 115-kV line connections to the present Old Town Substation.

Staging for Project construction support (e.g., for material laydown, parking for vehicles and equipment, temporary construction trailer) will be located on the Project Site and/or at one or more industrial/commercial sites nearby. Temporary access for the transmission line relocations will be through UI's property and the Eversource ROW, as depicted on the Project plans in Appendix A. UI anticipates that approximately 1 acre, including access, of temporary workspace will be required to install the two new 115-kV monopole structures and remove the existing lattice structure on the Eversource ROW immediately east of the new substation. Other work areas are expected to be within the Project Site. Additional details about staging and temporary work areas will be provided in the D&M Plan.

During construction, primary access the Project Site will be by way of Main Street and Kaechele Place. To minimize the potential for traffic delays, UI will coordinate as necessary with the City and (if necessary) the Town of Trumbull (the "Town" and "Trumbull") regarding vehicular traffic management. Information regarding traffic management will be provided in the D&M Plan.

3.2.3 Substation Construction

Site Preparation

Site preparation work will include vegetation removal (including tree removal), as well as grading and filling. On the Existing Substation Parcel and the Undeveloped Parcels, shrub vegetation as well as approximately 60 trees greater than 6-inch diameter breast height (dbh) will be cleared. In addition, on the easement area within the Park, it is estimated an additional 10 trees greater than 6-inch dbh will be removed to provide clearance for the relocated overhead 115-kV transmission line connections to the substation. The trees to be removed are primarily deciduous species (maple, ash, oak, and beech) with some conifers intermixed. Trees outside of the proposed substation footprint will be preserved, except as necessary to maintain required clearances for the safe operation of electric equipment and transmission lines.

Because of the varied topography on the Project Site, considerable grading and filling work is expected to be required. To minimize the amount of grading required, a concrete retaining wall, approximately 700

feet in length and ranging in height from approximately 2 to 10 feet depending on cut and fill requirements, will be built around the portions of the substation perimeter (refer to Figure 2-1 and the Appendix A maps).

Blasting

On portions of the Project Site, bedrock may be encountered at shallow depths. To the extent practical, UI will use mechanical measures (e.g., hoe ramming, chipping) to remove bedrock as necessary to create a level site for the development of the substation and for substation equipment foundations. However, based on the depth, extent, and type of bedrock identified during detailed subsurface studies of the Project Site, controlled blasting could be required.

If blasting is necessary, UI will retain a blasting contractor licensed by the Connecticut Commissioner of Emergency Services and Public Protection to develop a blasting plan for the Project Site. The resulting blasting plan, which would be provided to the Bridgeport Fire Marshall, would comply with State and local regulations and would take into consideration the site's geologic conditions, as well as the locations of nearby utilities and land uses. The blasting plan typically would contain information about the blasting work to be performed, schedule, safety, noise and vibration monitoring, pre- and post-blast inspections, and traffic control measures, as warranted. Detailed information regarding the contents of a blasting plan will be included in the Project's D&M Plan.

Foundation and Equipment Installation

The installation of foundations will typically involve excavation, form work, use of steel reinforcement, and concrete placement. Excavated materials will be handled in accordance with appropriate regulatory requirements and will be disposed of properly off-site, as required. After foundations are in place, structures and equipment will be installed pursuant to the new substation plans. The installation of the major 115-kV equipment is expected to take approximately 12 months and will involve the use of cranes to unload and place large equipment and structural elements.

The installation of the 115-kV monopoles, interconnection of the supply lines to the substation, and connections to the existing distribution system will occur inside and outside of normal work hours (refer to Section 3.5) because these activities necessitate taking critical transmission and/or distribution equipment out of service. As a result, UI will schedule this work for off-peak electrical demand hours and will coordinate, as appropriate, with the City.

The substation will include two 115/13.8-kV transformers that will contain insulating (mineral) oil. The transformer equipment will each have a secondary containment designed to hold 110% of a transformer's fluid capacity and will include accidental spill prevention measures. UI proposes to install a petro barrier gravity drain system to assist in minimizing the potential for inadvertent oil discharges from the containment. Further, UI will remotely monitor a low oil level alarm that is integral to the system that will notify UI's operations center in the event of an abnormal condition at the substation.

Wiring, Testing, and Interconnections

Wiring that will allow the equipment to operate and communicate with the system protection equipment will be installed. After all equipment is installed and wired, the new equipment will be tested to confirm that it is in proper functioning condition and is operating as specified.

Final Site Cleanup/Restoration and Site Security

The portions of the substation not otherwise occupied by equipment and enclosures will be stabilized as necessary, typically with rock/gravel. UI will enclose the perimeter of the substation with a 14-foot-high chain link fence with privacy slats, topped with an additional 1 foot of barbed wire to discourage unauthorized entry and/or vandalism. On those portions of the site where the retaining wall will be built, UI will install the chain link fence on top of the retaining wall. UI also will install task lighting within the substation yard.

3.2.4 Substation Connections: 115-kV Line Relocations

Site Preparation

Temporary construction work pads will be established as needed to install the new transmission line structures. In addition, a previously-used access road from Kaechele Place to the Eversource ROW will be improved, as needed to replace the lattice steel structure located adjacent to the eastern boundary of the existing substation. The locations of work pads and access to them will be identified in the D&M Plan.

Foundation and Structure Assembly/Installation and Conductor Work

The seven new monopole structures to be located inside the perimeter of the substation (five on UI property, two within the Eversource ROW) are expected to be installed on concrete drilled pier foundations. The two new monopoles that will be installed within Eversource's ROW to the east of the substation would be drilled shaft foundations. The transmission line foundation designs will be determined as the Project planning proceeds and will be described in the D&M Plan.

The excavation for the transmission line structure foundations will require use of heavy equipment. The foundations will utilize steel rebar for strength and anchor bolts for equipment mounting. The concrete will be brought to the structure locations in concrete trucks from a local ready-mix concrete plant.

The construction of the new structures will be sequenced based on structure location. The new structures (and conductors) located farthest from the existing transmission line connections are expected to be installed first. When the new substation is ready to accept the 115-kV lines, the remaining structures and conductors/OPGW will be installed. Transmission terminations and any other transmission structures which can be installed without causing an outage will be constructed prior to any structures which requires an outage in order to relocate the new lines. New conductors will be installed between structures where outages are not required.

Removal of Existing 115-kV Structures

UI will coordinate with Eversource regarding the removal of the two existing lattice steel towers. Removal activities will typically include dismantling the towers and recycling materials to the extent practical. Materials that cannot be recycled or reused will be disposed of properly.

Cleanup and Restoration

After the installation of the new 115-kV structures and the removal of the old structures, temporary work pads and access will be removed, and the areas affected by Project construction will be restored and stabilized. Permanent work pads and permanent access roads (if any) would remain.

3.3 EXISTING SUBSTATION DECOMMISSIONING

The existing Old Town Substation and associated line connections will be decommissioned in accordance with standard UI protocols and any applicable regulatory requirements. Details regarding the decommissioning of these facilities, which will be performed after the Project facilities are operational, will be provided as appropriate in the D&M Plan.

3.4 EROSION/SEDIMENTATION CONTROL AND STORMWATER MANAGEMENT

The Project will conform to applicable regulations concerning soil and erosion control and stormwater management. In accordance with the CT DEEP's *General Permit for the Discharge of Stormwater and Dewatering Wastewaters from Construction Activities (General Permit)*, UI will submit to CT DEEP a Notice of Intent and will prepare a Stormwater Pollution Control Plan (SWPCP) for the construction of the Project. UI also will adhere to the *2002 Connecticut Guidelines for Sedimentation and Erosion Control*,

which are designed to avoid or minimize potential adverse environmental effects that may result from construction activities. In addition, any spoils generated during Project construction will be managed in accordance with UI procedures and applicable regulatory requirements.

3.5 CONSTRUCTION SCHEDULE AND WORK HOURS

All construction activities will be conducted in accordance with the work hours to be identified in the D&M Plan, which must be approved by the Council. In general, Project construction (the new substation and line connections, as well as the removal of the 115-kV line connections to the existing Old Town Substation) is expected to require approximately 18-24 months.² (Refer to the Project schedule in Section 7 for additional information.)

Work Hours. Typical construction hours will be from 7:00 AM to 7:00 PM, Monday through Saturday. Construction personnel may arrive before and leave the Project Site after these times; however, noise-generating construction activities typically will not be performed before 7:00 AM or after 7:00 PM.

Some extended hours and Sunday work will be necessary on a limited basis. For example, extended hours will be needed for construction work that must occur on a continuous basis (e.g., concrete pours and foundation installation) or that must be scheduled in accordance with outage requirements.

General Schedule. Site preparation (e.g., vegetation removal, grading, filling, installation of the retention wall) and foundation installation will be performed during the initial six months of Project construction and will involve the use of earth-moving equipment and other construction vehicles. The installation and testing of substation equipment are expected to take approximately 18 months. These activities will involve the use of cranes to unload and install structural elements and large equipment.

To connect the 115-kV lines, substation terminal structures, and the distribution lines, certain transmission and/or distribution equipment will have to be taken temporarily out of service. As a result, this work will be coordinated with the Connecticut Valley Electric Exchange (“CONVEX”), which operates the electric transmission system in Connecticut and western Massachusetts. To complete these interconnections as efficiently as possible with minimal service disruptions, work will have to be performed continuously, requiring construction activities outside of normal work hours, as noted above.

² UI has not finalized plans for decommissioning the existing Old Town Substation. However, the decommissioning work could extend beyond the schedule for the completion of the new substation and line connections.

3.6 DISTRIBUTION LINE RELOCATION AND CONNECTIONS

To deliver power from the substation into UI's electric distribution system in the Greater Bridgeport area, the distribution circuits that connect to the existing Old Town Substation will be extended and reconfigured as necessary to link to the new substation. These distribution circuits will consist of duct lines and splice chambers, which will be buried on UI property, as well as beneath local roads. The distribution circuit get-away from the new substation will be two new polyvinyl chloride ("PVC") underground duct banks from the substation property exiting directly from new splice chambers. The new PVC duct banks will be installed from the splice chambers to existing distribution duct banks or overhead pole lines.

3.7 PROJECT FACILITIES RELIABILITY, SAFETY AND SECURITY INFORMATION

UI will operate and maintain the new Old Town Substation in accordance with standard Company protocols, required industry standards, and good utility practice.

Emergency Operations and Shutdown

UI will equip the substation with measures designed to ensure continued service in the event of outages or faults in transmission or substation equipment. If an energized line or piece of substation equipment fails, protective relaying equipment will immediately remove the failed line or equipment from service, thereby protecting the public and the remaining equipment within the substation.

The Project design includes protective relaying equipment to automatically detect abnormal system conditions (e.g., a faulted overhead transmission line) and to send a protective trip signal to circuit breakers to isolate the faulted section of the transmission system. The protective relaying schemes will include fully redundant primary and backup equipment so that a failure of one scheme will not require the portion of the system being monitored by the protective relaying equipment to be removed from service. The protective relaying and associated equipment, along with a SCADA system for 24/7 remote control and equipment monitoring, will be housed at UI's System Operations Center.

Fire Detection and Suppression Technology

UI incorporates IEEE/ANSI and National Fire Protection Association (NFPA) standards for fire protection in its substation design and operates its facilities to minimize the impact of fire, in the unlikely event of such an occurrence. UI also trains its employees and the local fire department on the safe methods to deal with a substation fire.

At the new Old Town Substation, UI will secure the control enclosure and equip it with fire extinguishers and remotely monitored smoke detectors. In the event of a fire, the smoke detectors will automatically activate an alarm at UI's System Operations Center, and the system operators will then take appropriate action.

Physical Site Security

UI will use fencing and gates to protect the Old Town Substation; access will be limited to authorized personnel only. Security devices will constantly monitor the substation to alert UI of any abnormal or emergency situations. UI's planned physical site security measures for the substation are outlined as follows:

- A 14-foot-high chain link fence with privacy slats, topped with an additional 1 foot of barbed wire, will be installed around the substation perimeter to discourage unauthorized entry and/or vandalism. The fence will be installed on top of the retaining wall that will encompass the perimeter of portions of the substation.
- Security cameras and motion detectors will be installed to provide complete visibility within the interior of the proposed substation and perimeter fence.
- The substation yard will be gated and locked. All gates will be padlocked at the end of the workday during construction activities and at all times once the substation is in service.
- Appropriate signs will be posted at the substation fence and gates, alerting the general public of the presence of high-voltage facilities.
- UI will install low-level LED lighting within the substation yard to facilitate work at night or during inclement weather, as well as to identify entry by unauthorized personnel.

3.7 TRAFFIC MANAGEMENT DURING SUBSTATION OPERATION

UI will design the substation for remote operation, with personnel on site only for periodic inspections, maintenance, and (as needed) emergency work. Permanent access to the substation will be through two main gates located on Kaechele Place, which is accessible from Main Street.

The substation access gates will be located such that vehicles entering the site will not impede traffic while unlocking the security gates. UI also will develop an on-site access road (which will loop around the interior of the substation site) to facilitate the movement of maintenance equipment and access to the control enclosure.

This page intentionally left blank

4. EXISTING ENVIRONMENTAL CONDITIONS

This section summarizes the existing environmental conditions at the Project Site and in the general vicinity. This information was compiled from published data, including studies conducted of the UI property, Eversource ROW, and areas of the Park associated with the Project, as well as environmental and land use data maintained by federal, state, and local governments. In addition, UI conducted multiple field investigations of the Project Site and consulted with various agencies concerning environmental resources in the vicinity. UI expects to continue such consultations, as needed, as the Project evolves.

In addition to the information included in this section, Appendix A includes an aerial base map that illustrates the existing conditions in the vicinity of the Project. Appendix B includes correspondence from state agencies concerning the Project, while Appendices C, D, E, and F contain the ecological resources, visual resources, cultural resources, and noise reports commissioned by UI to assess the Project Site's environmental characteristics.

4.1 TOPOGRAPHY, GEOLOGY, AND SOILS

The Project area is located within the Coastal Lowlands physiographic province. Portions of the Project Site, including the existing Old Town Substation and the Eversource ROW that connects to it, have been modified by previous development. However, except for a single home that was built in the mid-20th century and was subsequently demolished and removed, most of the UI property at 312 and 330 Kaechele Place has not been affected by prior land uses. As a result, the topography of the approximately 3-acre property is variable, and generally slopes downward to the northeast. Elevations range from about 240 feet to 200 feet per the North American Vertical Datum 1988 ("NAVD 88").

The U.S. Department of Agriculture, Natural Resources Conservation Service ("NRCS") identifies soils on most of the Project Site, including along the Eversource ROW immediately adjacent to the existing Old Town Substation, as in the Urban Land-Charlton-Chatfield complex, which is characterized as rocky, with 3-15% slopes. The northern portion of the Project Site consists of Ridgebury, Leicester, and Whitman soils, which are defined as extremely stony, poorly drained, and very poorly drained (hydric). These soils qualify as Connecticut wetlands (refer to Section 4.2). The soils map in Appendix C illustrates the locations of the soil types mapped on the Project Site. Most of the surficial (unconsolidated) materials are classified as till.³

³ Map Catalog, Connecticut Environmental Conditions Online, accessed September 2019, available at <http://www.cteco.uconn.edu>.

Bedrock in the Project vicinity consists of the Shelton member of the Trap Falls Formation (granitic gneiss)³. Depth to bedrock at the Project Site is identified in the Fairfield County soil survey as approximately 29-80 inches.

4.2 WATER RESOURCES AND WATER QUALITY

Surface Water Resources

The City of Bridgeport is located within Connecticut's Southwest Coast Drainage Basin, which includes the Rooster River watershed, an approximately 15.2-square mile area that encompasses urbanized portions of Bridgeport and the towns of Fairfield and Trumbull. The Project Site is within the Horse Tavern Brook sub-watershed, which encompasses approximately 5 square miles and is one of six such primary sub-watersheds within the Rooster River watershed. Horse Tavern Brook is located approximately 0.5 mile west of the Project Site, west of Main Street. Horse Tavern Brook discharges into the Rooster River approximately 1.5 miles southwest of the Project Site, south of State Route 59 in the Town of Fairfield. Lake Forest, a man-made reservoir, is located approximately 0.5 mile southeast of the Project Site.

Horse Tavern Brook is designated as a Class A surface water body, pursuant to Connecticut Water Quality Standards (C.G.S. Section 22a-426). Class A surface waters have the following designated uses: potential drinking water supply, fish and wildlife habitat, recreational, agricultural, and industrial supply uses, and other purposes, including navigation.

Both the existing Old Town Substation and proposed substation site, along with the existing and proposed transmission line interconnections along the Eversource ROW, are in uplands. As determined by a review of the NRCS soil survey mapping and on-site field investigations (refer to Appendix C), one inland wetland/watercourse, which encompasses about 0.49 acre, is located on the northern portion of the UI property. This wetland/watercourse meets federal and state jurisdictional criteria and is characterized primarily by forested wetland vegetation. Hydrology associated with this wetland originates from shallow, groundwater seeps, as well as surficial runoff and stormwater from the surrounding developed watershed.

In addition to the wetland/watercourse identified on the northern portion of the Project Site, a wetland/watercourse is located approximately 100 feet southeast of the Project Site, within the Park. This wetland, which is described in the Appendix C report, extends across a portion of the Eversource ROW.

Flood Zones

Based on a review of Federal Emergency Management Agency (FEMA) Flood Insurance Rate Maps for Bridgeport (FEMA maps 09001C0426F and 09001C0427F, both dated 6/18/2010), the Project Site is not within any mapped FEMA floodplains. Portions of the Eversource ROW to the east of the Project Site (within the Park) encompass small FEMA-designated flood Zone A areas (i.e., floodplains that are mapped but do not have a FEMA-assigned Base Flood Elevation) associated with the Rooster River.

Groundwater Resources, Public Water Supply, and Aquifer Protection Areas

The depth to groundwater in the Project Site is estimated at approximately 10 feet below grade. Regional groundwater flows are to the northeast. Based on CT DEEP Groundwater Quality Classification Map data, groundwater in the Project Site is classified as GB. Water with a GB classification includes industrial process and cooling waters and base flow for hydraulically connected water bodies. Such water is presumed not suitable for human consumption without treatment. Based on a review of CT DEEP data, no Aquifer Protection Areas or public water supply wells are within 0.5 mile of the Project Site.

4.3 BIOLOGICAL RESOURCES

Vegetation

The Existing Substation Parcel is entirely developed for utility use (i.e., substation equipment within graveled/paved areas) and contains no vegetation other than lawn and ornamental vegetation fronting on Kaechele Place. The Undeveloped Parcels consist primarily of upland deciduous early successional forest (primarily oak, ash, maple, and beech species) with minimal understory and scattered coniferous trees (e.g., pines). The property at 312 Kaechele Place (formerly occupied by a residence) includes some scrub-shrub and ornamental vegetation.

A palustrine forested/scrub-shrub deciduous seasonally flooded/saturated wetland (PFO/SS1E) is located along the northern border of the 330 Kaechele Place property. The vegetation community within this wetland is classified as red maple/skunk cabbage seasonally flooded forest. Dominant vegetation in this wetland include red maple, green ash, spicebush and skunk cabbage (refer to Appendix C).

The Park, an undeveloped 73-acre area that borders the UI property to the east and south, consists of a mix of mostly upland forest with a section of forested wetlands. The Eversource ROW extends east-west across the Park.

The Eversource ROW that abuts the existing Old Town Substation to the east (within the park) is characterized by low-growing vegetation (shrubs and herbaceous species) that is compatible with overhead

transmission line use. After extending through the exiting Old Town Substation, the Eversource ROW that extends to the west spans paved, developed areas (where vegetation is limited to ornamental vegetation adjacent to roads and parking lots), as well as a small undeveloped area of herbaceous vegetation between Kaechele Place and Main Street.

Wildlife

The wildlife that may inhabit the Project Site can be expected to be typical of that found in a mix of forested and residential/commercial urban areas. For example, in the developed suburban/urban areas along Main Street, Kaechele Place, and Sequoia Road, common wildlife may include various birds, nuisance species such as rats and other small rodents, squirrels, and other species common to such developed areas.

In the Park, the undeveloped approximately 3-acre portion of the Project Site, and along the Eversource ROW to the east of the existing Old Town Substation, additional wildlife species could occur. Such species may include various birds, mammals such as deer, coyote, and raccoon; various reptiles and amphibians, and other species acclimated to suburban/urban areas (refer to Appendix C).

Vernal Pools

A vernal pool survey was conducted to determine whether the wetland/watercourse located on the northern portion of the Project Site, as well as the wetland located across the Eversource ROW in the Park, could meet CT DEEP's definition of a vernal pool (refer to Appendix C). Vernal pools are characterized by appearance, water source, hydroperiod, water quality, and surrounding habitats. Additionally, in order to determine if an area is a functioning vernal pool, an assessment must be performed during amphibian breeding and/or larval development time periods – typically in the spring.

The wetland/watercourse located on the northern portion of the Project Site does not provide potential habitat for breeding amphibians due to inadequate hydrology. Thus, no vernal pools are located on the Project Site (refer to Appendix C). Similarly, the wetlands in the Park (approximately 100 feet east of the Project Site) do not support vernal pool habitat.

State-Listed Threatened, Endangered, or Special Concern Species

Based on review of the CT DEEP Natural Diversity Database (“NDDB”) map for Bridgeport dated June 2019, no listed threatened, endangered, or special concern species are present in the area of the Project Site (refer to the NDDB map included in Appendix B). However, UI consulted with CT DEEP NDDB to obtain an assessment of the species that might be present in the area of the Project. According to the NDDB, the

extant populations of a state-listed species of special concern - *Terrapene c. carolina* (eastern box turtle) are known to live on or around the Project Site (refer to CT DEEP NDDDB correspondence in Appendix B).


In addition, UI consulted with the U.S. Fish and Wildlife Service (“USFWS”) regarding the potential for the Project Site to include trees that provide suitable summer roosting habitat for the federally listed threatened Northern Long-Eared Bat. The USFWS indicated that no habitat for federally listed species occurs in the area of the Project (refer to USFWS correspondence in Appendix B). However, based on the results of the ecological assessment performed of the Project Site, three to five viable Northern Long-Eared Bat roosting trees were identified on the Project Site (refer to Appendix C). In the unlikely event that Northern Long-Eared Bats use the trees at the Project Site as roosting or nursery habitat, UI has agreed to limit clearing activities to occur outside of the pup season (June 1 to July 31).

4.4 LAND USE, RECREATION, AND COMMUNITY FACILITIES

Existing Land Use and Zoning

The Project is in the northwestern portion of Bridgeport, in the city’s North End neighborhood, an area historically used and zoned primarily for residential and commercial purposes. Currently, commercial development, including professional offices and retail, is centered along Main Street and institutional and open space uses are scattered throughout the area (refer to Figure 4-1). The North End consists of approximately 675 acres and is bounded on the south by the city’s Brooklawn/St. Vincent’s neighborhood, on the east by the Reservoir neighborhood, on the north by the Town of Trumbull, and on the west by the Town of Fairfield.

Figure 4-1: Existing Land Use: Vicinity of Project Site



Source: Excerpted from City of Bridgeport Existing Land Use Map (2018)


As illustrated in Figure 4-1 and the Appendix A aerial-based map, lands in the vicinity of the Project Site consist of a mix of commercial uses along Main Street, utility uses (including the existing Old Town Substation and the Eversource ROW that extends through the substation), undeveloped open space (the Park), and residential uses to the south along Kaechele Place and to the north along Sequoia Road. A variety of densely developed commercial uses are situated along Main Street (State Route 111), west of the Project Site. Such uses include medical offices (Yale New Haven Health, Commerce Park Dental), retail facilities (Michaels Craft Store, Stop & Shop, Petco, Marshalls), and professional offices.

Commercial uses in the immediate vicinity of the Project Site include the Commerce Hill Funeral Home, which abuts the Project Site to the north and west, as well as Andy and T Nail Spa and Labco, which have rear parking lots that extend to Kaechele Place. The Park occupies approximately 73 acres, which abut the Existing Substation Parcel and the Undeveloped Parcels to the east. Access to the Park is through Frenchtown Road. The Westfield Trumbull Mall is located approximately 0.5 mile north of the Project Site, west of Main Street in Trumbull.

Single-family residential uses are located southwest of the Project Site along Kaechele Place, Hillview Street, and White Oak Street, as well as to the north along Sequoia Road. The Green Tree townhouse/condominium development is situated approximately 0.2 mile to the east of the Project Site, east of the Park, along Frenchtown Road. Lake Forest, a man-made lake, is located approximately 0.5 mile southeast of the Project Site, east of the Park. Lake Forest is bordered by private residences.

According to Bridgeport's 2018 Zoning Map, lands in the vicinity of the Project, including the Existing Substation Parcel and the Project Site, are zoned for residential (R-A) use (refer to Figure 4-2). However, areas along Main Street are zoned predominantly for office/retail regional zone (OR-R) use, with some mixed use – educational medical (ME-EM) areas.

Figure 4-2: Zoning in Vicinity of the Project Site



Source: Excerpted from City of Bridgeport Zoning Map, June 25, 2018.

Recreation

Except for the Park, which abuts the Project Site to the east and south, there are no public recreational areas within 2,000 feet of the Project Site. The Park is forested and is accessible to the public only through a small, unimproved parking area located off Frenchtown Road. The park includes hiking trails, but no other recreational facilities. The Eversource ROW, which is managed in low-growth vegetation consistent with the operation of such overhead electric lines, extends east-west through the park. The utility ROW has extended through the area for many years, pre-dating the creation of the park.

Land Use Plans

As the central planning document for the City, *Plan Bridgeport (the City's Plan of Conservation and Development)* (April 2019)) focuses on four major themes relating to the municipality's physical form, economic and social health, and quality of life. These themes include waterfront redevelopment, transit-oriented development, neighborhood strengthening, and creating conditions for increased residential development.

Plan Bridgeport does not specifically address utility infrastructure improvements, but notes the importance of attracting economic development, including reducing the tax burden on residents by growing the municipal Grand List and encouraging the development of vacant or underutilized properties. The plan also identifies a goal of promoting the growth of the energy industry in Bridgeport, with a focus on green energy generation and support for such energy.

Connecticut's revised draft *Conservation & Development Policies Plan 2018-2023* (March 2019) identifies the Project Site as north and west of Bridgeport's Regional Center. The Plan advocates redeveloping and revitalizing regional centers with existing or currently planned physical infrastructure (Growth Management Principle #1).

As identified in the Plan, the Project Site is within a neighborhood conservation area; the Park is shown as within a preservation zone, and a conservation zone is identified along Horse Tavern Brook and its tributaries. The latest revision to the Plan, which is currently pending review by the Connecticut General Assembly, identifies most of Bridgeport as a priority funding area for various development.


Community Facilities

The community facilities (daycare facilities, community centers, senior centers, hospitals, schools, recreational areas, and youth camps) within 2,000 feet of the Project Site (all located in Bridgeport) are listed in Table 4-1 and illustrated on Figure 4-3.

Table 4-1: List of Community Facilities within 2,000 Feet (0.38 mile) of Project Area

Community Facility Type/Name	Address	Distance from Proposed Project Site (miles, direction)
Medical Facilities		
Planned Parenthood – Bridgeport Health Center	4697 Main Street	0.28-mile, W
Complete Health	4699 Main Street	0.28-mile, W
Sanitas Medical Center	451 Main Street	0.27-mile, SW
Daycare Facilities		
The Precious Moment Daycare	36 Linda Drive	0.31-mile, NE
Cheyenne’s Early Learning Center	4600 Main Street	0.15-mile, SW
Keyla’s Day Care	108 Acton Road	0.34-mile, W
Recreational Areas/Parks		
Elton Rogers Woodland Park	West of Frenchtown Road	Adjacent

Figure 4-3: Community Facilities within 2,000 Feet (0.38 mile) of the Project Site



- Legend**
- Project Area
 - 1-mile Radius
 - Municipal Boundary
 - Open Water (CTDEEP)
 - Open Space Property (CTDEEP)
 - Natural Diversity Database Area (Dec 2019)
- Map Note:**
 Base Map Source: 2019 CT ECO Imagery
 Map Scale: 1:18,000
 Map Date: March 2020

- Surrounding Features**
- Park / Recreation / Open Space
 - School
 - Daycare



Surrounding Features

Proposed Substation Rebuild
 280-330 Kaechle Place
 Bridgeport, Connecticut



4.5 VISUAL AND AESTHETIC CHARACTERISTICS

In the immediate vicinity of the Project Site, the visual environment is characterized by the existing Old Town Substation, the Eversource ROW and lattice steel structures, and a variety of different types of commercial buildings clustered along Main Street, including a funeral home and its parking lot that abut the UI property to the northwest. Single-family residential areas along Sequoia Road back up to the forested areas on the northern portion of UI's property, as well as the funeral home parking lot.

The Park, located to the south and east of the site, is undeveloped and includes hiking trails. However, there are no identified scenic vistas within the park, which is traversed by the Eversource ROW.⁴

Because of the mix of commercial, residential, and utility uses, the Project Site has no special visual characteristics. Further, there are no publicly designated scenic vistas located near the Project Site.

Figure 4-4 provides a representative aerial view of the Project Site and immediate vicinity. Refer also to the *Visual Assessment and Photo-Simulations* (Appendix D).

4.6 TRANSPORTATION AND UTILITIES

Bridgeport has a well-developed transportation network and is served by a full complement of utilities (electric, natural gas, sewers, public water, telephone, cable). The primary transportation routes in the vicinity of the Project are the Merritt Parkway (State Route 15) and Main Street (State Route 111); local roads such as Old Town Road and Kaechele Place also provide access to the site. Greater Bridgeport Transit provides bus service along both Main Street and Old Town Road.

No airports are in the immediate area of the Project Site. The nearest airport is Sikorsky Memorial Airport, a general aviation facility owned by the City that is situated approximately 6 miles to the southeast, adjacent to Long Island Sound in the Town of Stratford.

⁴ Along Main Street (State Route 111), there are no scenic land strips, as designated by the Connecticut Department of Transportation (CT DOT). (Such lands are roadside properties, located primarily outside of highway ROWs, that were purchased at least in part with 1965 federal Highway Beautification Act funds in order to control the development of billboards and other unsightly views along highways.)

Figure 4-4: Representative View of Existing Old Town Substation, UI Property, Eversource ROW, and Immediate Vicinity (View to the East)



Nearby transmission facilities include the two Eversource 115-kV lines that connect to the existing Old Town Substation, as well as the additional 115-kV line that presently passes through the existing substation. In addition, 13.8-kV lines link the existing Old Town Substation to UI's distribution system.

The existing Old Town Substation is not connected to municipal sewers, but rather has a septic system. The station is connected to the Aquarion Water Company public water system.

4.7 CULTURAL (ARCHAEOLOGICAL AND HISTORIC) RESOURCES

To assess the potential sensitivity of the Project Site for the location of archaeological resources and to identify any known archaeological and historic sites in the vicinity, UI initially commissioned Heritage Consultants LLC ("Heritage") to perform a cultural resource review of the proposed Project Site and vicinity. Subsequently, Fitzgerald & Halliday conducted additional studies of the Project's Area of Potential Effect ("APE")⁵ and of the potential historic resources in the area of the Project Site. These cultural resource reports are included in Appendix E.

Both studies reviewed records maintained by the SHPO, as well as historical mapping, historic aerial photography, and GIS data. These analyses determined that the APE for direct effects is limited to the area where construction and construction-related activities will occur for the development of the Project. In comparison, the APE for visual effects includes a wider area, but due to the presence of mature trees and extensive building development, is restricted to certain locations along Kaechele Place, Hillview Street, and Main Street. Although the actual viewshed of the Project will be limited, standing structures within a 0.25-mile radius of the Project Site were investigated to assess their potential eligibility for listing on the National or State Registers of Historic Places ("NRHP" or "SRHP" as applicable).

The cultural resource studies found no structures or archaeological sites listed on or eligible for the NRHP/SRHP within 0.25 mile of the Project Site. Further, due to the past modifications on the existing Old Town Substation site and Eversource ROW, as well as the variable topography and previous

⁵ Pursuant to the National Historic Preservation Act (36 CFR 800.16[d]), the APE refers to the geographic area within which a project may directly or indirectly cause changes in the character or use of historic properties, if any such properties exist. The APE is influenced by the scale and nature of an undertaking and may be different for different kinds of effects caused by the undertaking. Direct impacts would result from ground disturbance, whereas indirect effects may involve change in the visual environment and context of standing historic structures.

residential development on UI's adjacent approximately 3-acre parcel, the Project Site was identified as not sensitive for the location of buried archaeological sites.

In November 2019, UI submitted the cultural resources reports, along with a "Project Review Cover Form" to the Connecticut SHPO, seeking the SHPO's concurrence with Heritage's findings (refer to Appendix E). UI received response on January 16, 2020 that additional archaeological investigations of the Project Site are not warranted and that no historic properties will be affected by the proposed activities.

4.8 AIR QUALITY, NOISE, AND LIGHTING

Air Quality

Ambient air quality is affected by emissions from mobile sources (e.g., vehicles) and stationary sources (e.g., manufacturing facilities, gasoline stations, power plants). Naturally occurring pollutants, such as radon gas, also affect air quality. Ambient air quality in Connecticut is monitored by CT DEEP and air quality conditions are assessed based on compliance with the National Ambient Air Quality Standards ("NAAQS") for six criteria pollutants (e.g., sulfur dioxide, carbon monoxide, nitrogen dioxide, particulate matter, lead, and ozone).

The State is in attainment for all criteria pollutants except ozone. CT DEEP data shows that measured ozone levels in southern Connecticut (Fairfield, New Haven, and Middlesex counties) exceed the NAAQS on several days each summer, depending on weather conditions. Ambient air quality in the area of the Project Site can generally be expected to mirror these conditions in the State as a whole.

Noise

Existing noise levels in the Project Site are representative of a developed urban/suburban setting and are particularly influenced by commercial uses and traffic along Main Street. Table 4-2 lists the typical sound levels associated with different types of land use conditions and activities, as defined by sound pressure level (decibels on the A-weight scale [dbA] – an expression of the relative loudness of sounds in air as perceived by the human ear).

Both the City's Noise Ordinance and the State's noise regulations (RCSA §§ 22a-69-1 to 22a-69-7.4, 2015) prescribe the same A-weighted maximum sound pressure levels, based on land use at the noise emitter and receptor. These regulations define daytime vs. nighttime noise periods, classify noise zones based on land uses, and identify noise standards for each zone, specifying that noise emitters

must not cause the emission of excessive noise beyond the boundaries of their noise zone so as to exceed the allowable noise levels on a receptor's land.

Table 4-2: Typical Noise Levels Associated with Different Indoor and Outdoor Activities

SOUND PRESSURE LEVEL, dBA	SUBJECTIVE EVALUATION	COMMON OUTDOOR ENVIRONMENT OR SOURCE	COMMON INDOOR ENVIRONMENT OR SOURCE
140	Deafening	Jet aircraft at 75 ft	
130	Threshold of pain	Jet aircraft during takeoff at a distance of 300 ft	
120	Threshold of feeling	Elevated train	Hard rock band
110	Extremely loud	Jet flyover at 1000 ft	Inside propeller plane
100	Very loud	Power mower, motorcycle at 25 ft, auto horn at 10 ft	
90	Very loud	Propeller plane flyover at 1000 ft, noisy urban street	Full symphony or band, food blender, noisy factory
80	Moderately loud	Diesel truck (40 mph) at 50 ft	Inside auto at high speed, garbage disposal, dishwasher
70	Loud	B-757 cabin during flight	Close conversation, vacuum cleaner, electric typewriter
60	Moderate	Air-conditioner condenser at 15 ft, near highway traffic	General office
50	Quiet		Private office
40	Quiet	Farm field with light breeze, birdcalls	Soft stereo music in residence
30	Very quiet	Quiet residential neighborhood	Bedroom, average residence (without TV and stereo)
20	Just audible		Human breathing
10	Threshold of hearing		
0			

Source: Adapted by Black & Veatch from *Architectural Acoustics*, by David M. Egan (1988) and *Architectural Graphic Standards*, by Ramsey and Sleeper (1994).

Table 4-3 lists the City and Connecticut noise zone standards, by emitter (source) and receptor (receiver) noise classification. The existing Old Town Substation is considered an industrial emitter, as will be the proposed substation.

Table 4-3: State of Connecticut and City of Bridgeport: Maximum Noise-Control Levels (By Emitter and Receptor Land Use)

Noise Emitter Land Use	Noise Receptor Land Use			
	Industrial	Commercial	Residential (Day)	Residential (Night)
Residential	62 dBA	55 dBA	55 dBA	45 dBA
Commercial	62 dBA	62 dBA	55 dBA	45 dBA
Industrial	70 dBA	66 dBA	61 dBA	51 dBA

Notes:

The State of Connecticut defines “day” as the hours from 7:00 AM to 10:00 PM, and night from 10:00 PM to 7:00 AM all days of the week. Bridgeport defines “day” as the hours from 7:00 AM to 6:00 PM, and night from 6:00 PM to 7:00 AM, Monday through Friday. On Saturday and Sunday, the City defines “day” as from 9:00 AM to 6:00 PM, and night from 6:00 PM to 9:00 AM.

To define baseline ambient noise levels specific to the Project Site, UI commissioned a noise study (refer to Appendix F). As part of this study, sound measurements were taken at four publicly accessible sites (e.g., along sidewalks or road shoulders) in the vicinity of the Project Site:

1. Along Sequoia Road to the north of the Project Site;
2. At the Greentree townhomes on Frenchtown Road, approximately 0.2 mile west of the site;
3. Along Kaechele Place, behind Hillview Street south of the existing Old Town Substation; and
4. At the corner of Main Street and Minturn Road, approximately 0.1-mile northwest of the site.

At each of the four locations, both daytime and nighttime noise levels were measured for approximately 20-30 minutes.

This ambient noise study demonstrated that the area in the vicinity of the Project Site is considered to have high background (ambient) noise, influenced primarily by traffic movements (especially along Main Street), aircraft, insects, and lawn equipment. Short-term ambient daytime noise levels ranged

from about 46 to 64 dBA, while nighttime ambient noise levels were between 42 and 58 dBA⁶. At one of the sites (Main Street and Minturn Road), the existing ambient sound levels currently exceed both the daytime and nighttime limits for residential areas; the primary noise source is traffic.

In addition to the short-term measurement sites, UI also performed long-term (24 hour) noise measurements along the Project Site's northern property line, south of the boundary with residences at 60 and 76 Sequoia Road. As described in Appendix F, these measurements were taken in August 2019. The purpose of these measurements was to document existing ambient sound levels at the closest residential properties to the Project Site, including any noise influence from the operation of the transformers at the existing Old Town Substation.

Lighting

The Project Site is bordered to the west by an urbanized area that is characterized by a variety of lighting sources from the surrounding commercial and professional uses, as well as by municipal street lighting and commercial signs. To the east, the Project Site is bordered by the Park and the Eversource ROW, where there are no lighting sources. Residences located along Sequoia Road (to the north) and Kaechele Place and Hillside Drive (to the south and southwest) include lighting sources common to such areas.

⁶ These measurements reflect "filtered" sound levels, expressed in Leq (dBA), for each site. The levels were "filtered" to eliminate atypical sounds, such as wind-induced noise, insect noise, etc., and thereby to allow a better comparison of noise levels. (Leq, or equivalent sound level, is the preferred method to describe sound levels that vary over time, resulting in a single decibel value that considers the total sound energy over the time period of interest.)

5. POTENTIAL ENVIRONMENTAL EFFECTS AND MITIGATION MEASURES

The Project will be consistent with the long-established utility uses on the Project Site and in the vicinity (i.e., the existing Old Town Substation and Eversource ROW) and will have a positive long-term effect on the reliability of the electric system. The rebuilt Old Town Substation and associated 115-kV line interconnections will be located entirely on UI property or within the Eversource ROW, in upland areas, with the exception of the approximately 0.15-acre easement proposed on City of Bridgeport property in order to accommodate the overhead transmission line connections to the new substation.

Although the construction and operation of the Project will require the conversion of approximately 1.35 acres of forest land to utility purposes, the Project will be consistent with the adjacent utility uses and will not result in any expansion of the Eversource ROW. The Project will require a small easement (approximately 0.15-acre) proposed on the City's property within the Park to maintain required clearances between the relocated overhead 115-kV lines and vegetation. Some mature trees will have to be removed within the proposed easement, which subsequently will be maintained in low-growth vegetation consistent with overhead transmission line use. However, the easement will not affect the overall passive (e.g., hiking) recreational use of the park and will be consistent with the Eversource ROW, which has extended through the area for decades.

As a result, environmental effects are expected to be minor and highly localized to the Project vicinity. UI will mitigate such impacts to the extent practical by implementing standard construction best management practices and conforming to the conditions of Project permits and approvals.

The anticipated impacts and proposed mitigation measures identified in this section are based on UI's experience in constructing, operating, and maintaining substations and associated electric transmission and distribution connections, as well as on the results of the Project-specific environmental studies, engineering and constructability reviews, and agency consultations conducted to date. Additional measures to avoid or minimize environmental effects may be identified as part of the ongoing engineering design and constructability reviews, the Council's Application review process, and further consultations with the City or State regulatory agencies.

5.1 TOPOGRAPHY AND GEOLOGY

The Project will not affect geological conditions and will have only highly localized effects on topography. Specifically, the construction of the Project will involve both grading and filling to create a level area as required for the development of the new substation, including the installation of substation equipment.

These activities will result in long-term topographic modifications to the site. To minimize the amount of grading and filling required, UI proposes to install a retaining wall along the northern, and eastern portions of the substation perimeter to match the existing grade of the station. An existing retaining wall, located along the current Old Town Substation's southern perimeter, is expected to be replaced. Appendix A includes a preliminary the site plan for the new substation.

5.2 SOILS, GROUNDWATER, AND STORMWATER MANAGEMENT

Soils, groundwater, and stormwater will be managed appropriately during the construction of the Project. Further, as part of the design of the new Old Town Substation, UI will incorporate engineering controls to manage stormwater runoff during the operation of the facility and will conform to the CT DEEP requirements for stormwater management pursuant to the *General Permit for the Discharge of Stormwater and Dewatering Wastewaters from Construction Activities* (the "General Permit"). Pursuant to the General Permit, UI will prepare a Project-specific SWPCP.

During construction, in addition to the topographic modifications to the proposed substation site, certain work activities will disturb soils. Groundwater also could be encountered in the excavations for the Project facilities. Appropriate erosion and sedimentation controls, as well as dewatering protocols, will be implemented as needed, consistent with the Project SWPCP and General Permit.

Construction activities that will disturb soils include site preparation work such as grading, filling, and the installation of the retaining wall, as well as excavations required to install foundations for the substation enclosures, equipment, and overhead transmission line structures. Soils will be pre-characterized and subsequently managed in accordance with CT DEEP solid waste regulations and UI requirements. Certain soils excavated during Project construction may be removed from the Project Site and properly managed or disposed of off-site. UI will adhere to state and federal requirements for the disposal of contaminated soils, if any are encountered during construction.

Contaminated groundwater, if any, encountered during construction will be managed in accordance with applicable CT DEEP requirements. For example, prior to discharge, the groundwater may be pumped into

an appropriate treatment system, which may include a fractionization (frac) tank, a series of bag filters, and/or carbon vessels. Specific measures will be further identified in the D&M Plan.

Sediment and erosion controls commonly used during construction activities include hay/straw bales, silt-fence, straw wattles, diversion swales, track pads, hay bale corrals for management of spoils or concrete washout areas, and erosion control blankets. UI will routinely perform monitoring and inspections to verify the effectiveness of the erosion and sedimentation controls and will modify such measures as required during different construction phases.

5.3 WATER RESOURCES AND WATER QUALITY

The Project is not expected to directly affect inland water resources or water quality and is not located near any designated aquifer protection areas or FEMA-designated floodplains. Based on the Project planning conducted to date, UI does not anticipate that permanent fill will be placed in the approximately 0.49-acre wetland located along the northern boundary of the Project Site.

However, as more detailed designs are developed for the new substation, it is possible that some vegetation may have to be cut in the wetlands and that some construction activities, particularly the installation of the retaining wall, may have to be performed, including, but not limited to, temporary construction matting placed in the western portion of the wetlands. If temporary work in the wetland is required, UI will consult with and provide appropriate submittals, as necessary, to the CT DEEP and the United States Army Corps of Engineers – New England District (“USACE”). Similarly, if, based on final Project plans, a portion of the wetland must be unavoidably filled to develop the new substation, UI will consult with and obtain appropriate permits from the CT DEEP and USACE.

During the construction of the Project, UI will implement measures to minimize the potential for runoff into municipal sewers and to protect water resources in the vicinity of the Project (e.g., nearby wetlands and streams). Accordingly, UI will install erosion and sediment controls and will perform environmental inspections, pursuant to the SWPCP and the *General Permit*.

The new substation will have no appreciable increase in impervious surface and thus will create no additional burden for municipal stormwater management.

5.4 SPILL PREVENTION AND CONTROL

UI will require its contractors to adhere to spill prevention and control protocols during construction. Such protocols may include maintaining adequate spill kits on site and assuring that contractor personnel are aware of the proper procedures for promptly containing, cleaning up, and disposing of spilled materials, as well as for reporting spills to the CT DEEP Emergency Response Unit. As part of the decommissioning of the existing Old Town Substation, UI will properly remove and dispose of all equipment and fluids.

For the operation of the new substation, UI will develop and implement a *Spill Prevention Control and Countermeasures Plan (the "SPCC Plan")*. The SPCC Plan will include, but will not be limited to, mitigation measures to be used during facility operation (secondary containment, audio/visual alarms, etc.), environmental emergency contacts, and oil-filled equipment inspections.

5.5 BIOLOGICAL RESOURCES

General

For the construction of the Project, all existing vegetation within the footprint of the proposed substation facilities will be removed. UI estimates that approximately 60 trees, mostly deciduous species, with a dbh of more than 6 inches will have to be cleared for the construction of the new substation. The forested vegetation that currently characterizes most of the undeveloped portion of the Project Site will be replaced near the substation yard, and the wildlife species that presently use the site will be displaced.

In addition, vegetation will be affected on the portion of the Eversource ROW where the existing 115-kV lattice steel tower will be replaced with two monopoles, as well as along an off-ROW access road leading to the structure from Kaechele Place. The vegetation within the Eversource ROW consists of herbaceous or scrub-shrub species, consistent with Eversource ROW management protocols for vegetation clearances from overhead transmission lines. For the Project, such vegetation will be cut or mowed as needed to allow for construction access and work pads near the existing and proposed transmission structure sites. In addition, some trees or tree branches will likely have to be trimmed or cut along Eversource's existing off-ROW access road that extends from Kaechele Place to the lattice steel tower.

Further, to extend the 115-kV transmission lines from the Eversource ROW into the new substation, tall woody vegetation within an approximately 0.15-acre area proposed on municipal property (within the Park) will have to be removed in order to provide appropriate clearance from the overhead lines. Within the easement area, UI anticipates that approximately 10 trees (all deciduous species) with a dbh of greater than

6 inches will have to be cleared. Therefore, in this easement area, existing upland forest will be converted to vegetation, like that found on the adjacent Eversource ROW.

The development of the new substation will represent a conversion of approximately 1.5 acres of UI owned forest land to utility purposes. The remainder of UI's property adjacent to the existing Old Town Substation is not expected to be affected by the Project and will remain as forest land.

Overall, the impacts of the Project on vegetation and wildlife will be minor. Other forest, herbaceous, and scrub-shrub communities are present in the vicinity of the Project Site and can be expected to provide habitat for any displaced wildlife species. As a result, while the development of the substation will represent a long-term change in on-site vegetation, the overall effect will be minor and localized.

State-Listed Threatened, Endangered, or Special Concern Species

UI will implement measures to protect the species identified by the CT DEEP NDDDB and the USFWS as potentially inhabiting the Project Site. Specifically, to avoid impacts to bats, UI will not cut trees on the Project Site during the NLEB maternity roosting season, which is from June 1 to July 31. Similarly, to avoid or minimize the potential for adverse impacts to the Eastern Box turtle, UI will implement the NDDDB's recommended protection strategies, as detailed in the NDDDB's October 18, 2019 correspondence (refer to Appendix B).

Based on consultations with CT DEEP NDDDB, there are potential populations of state-listed species of special concern *Terrapene c. carolina* (eastern box turtle) in the vicinity of the Project Site (refer to Appendix B). CT DEEP indicated that eastern box turtles typically inhabit old fields and deciduous forests, which may include transmission lines and logged woodlands, and are often found near small streams and ponds. The turtles are active between April 1 and October 30; accordingly, CT DEEP advised UI to conduct land clearing during this time period while the turtle is active to allow the animal to move out of harm's way and minimize mortality to hibernating individuals. Given the known extant populations of eastern box turtles in the vicinity of the Project Site, during construction UI will implement the following best management practices as recommended by CT DEEP in their NDDDB letter:

- Hire a qualified herpetologist to be at the Project area to ensure that protection guidelines remain in effect and to prevent turtles from being run over when moving heavy equipment. Having a qualified herpetologist at the Project area in the month of June when turtles are selecting nesting sites will be especially important.

- Exclusionary practices will be implemented to prevent any turtle access into construction areas. These measures will be installed at the limits of disturbance.
- Exclusionary fencing will be at least 20 inches tall and will be secured to and remain in contact with the ground and be regularly maintained (at least bi-weekly and after major weather events) to secure any gaps or openings at ground level that may let turtles pass through. Plastic or netted silt-fence will not be used.
- All staging and storage areas, outside of previously paved locations, will be reviewed to remove individual turtles and exclude them from re-entry.
- All construction personnel working within the turtle habitat will be apprised of the species description and the possible presence of a listed species and instructed to relocate turtles found inside work areas or notify the appropriate authorities to relocate individuals.
- Any turtles encountered within the immediate work area will be carefully moved to an adjacent area outside of the excluded area, and fencing will be inspected to identify and remove access point.
- In area where silt-fence is used for exclusion, it will be removed as soon as the area is stable to allow for reptile and amphibian passage to resume.
- No heavy machinery or vehicles will be parked in any turtle habitat.
- Special precautions will be taken to avoid degradation of wetland habitats, including any wet meadows and seasonal pools.
- The contractor and consulting herpetologist will search the work area each morning prior to any work being done.
- When felling trees adjacent to brooks and streams, the contractor will cut them to fall away from the waterway and will not drag trees across the waterway or remove stumps from banks.
- The contractor will avoid and limit any equipment use within 50 feet of streams and brooks.
- Any confirmed sightings of box, wood, or spotted turtles will be reported and documented with the NDDDB on the appropriate special animal form found on CT DEEP's website.

5.6 LAND USE, RECREATION, AND COMMUNITY FACILITIES

The Project will represent an extension of UI's long-standing use of property along Kaechele Place for utility purposes. The new substation will encompass the Existing Substation Parcel and will be aligned to best interconnect with the long-established Eversource ROW that traverses UI's property. The Project will be consistent with existing and future land use plans for maintaining and upgrading infrastructure as needed for the City to grow as a regional center and will provide needed reliability to the regional electric system, to the benefit of UI customers and others.

The Project will have no adverse effect on community facilities and services or developed recreational areas. The approximately 0.15-acre easement proposed adjacent to UI's property and the Eversource ROW for the proposed 115-kV overhead transmission line connections to the new substation, although within the Park, will not preclude continued recreational use of the area. Further, the use of this small easement area to provide clearance for the overhead transmission lines will be consistent with the Eversource ROW that presently extends through the Park.

Similarly, the off-ROW access that would extend across City property from Kaechele Place to Eversource's lattice steel structure east of the substation boundary, will follow an existing access road. Although some vegetation removal and improvements to the road will be required, any environmental impacts will be minor and mitigated by adherence to best management practices.

5.7 VISUAL AND AESTHETIC CHARACTERISTICS

To evaluate the potential views of the Project from nearby locations, UI completed a *Visual Assessment and Photo-Simulations*, which is provided in Appendix D. This analysis incorporated a combination of field evaluations and three-dimensional computer modeling to portray scaled renderings of the rebuilt substation and associated overhead 115-kV line connections. Figure 5-1 provides a photographic simulation of the new Old Town Substation in relation to surrounding land uses; Appendix D includes additional information about the visual resources review.

The *Visual Assessment and Photo-Simulations* shows that the Project will only have a localized effect on views. The rebuilt substation will be visible from nearby locations along Kaechele Place. In addition, in the winter (under leaf off conditions), the rebuilt substation will be more visible from some residences along Sequoia Road. However, UI intends to retain as much as possible of the existing vegetation (trees and shrubs) along the northeastern portion of its property, and this buffer is expected to provide natural screening.

Within the Eversource ROW, the removal of the existing 105-foot-tall lattice steel towers also will represent a change in the localized visual environment. The new steel monopoles are expected to be no taller than the existing lattice steel towers.

Overall, the extensive nearby commercial developments and forest cover will serve to obstruct most views of the new substation.

Figure 5-1: Photo simulation of Proposed Old Town Substation (Fence with Screening) and Vicinity (View to East, Existing Old Town Substation Removed)



PROPOSED CONDITIONS

LOCATION
OBLIQUE AERIAL VIEW OVER KAECHELE PLACE

ORIENTATION
EAST



5.8 TRANSPORTATION AND UTILITIES

The construction and operation of the proposed Project will not result in any significant adverse effects on transportation or municipal utility systems. Moreover, the Project will have a positive effect on the reliability of the state and regional electric systems, particularly the distribution system in the greater Bridgeport area.

The Project Site is readily accessible from the local and regional highway network. Access for construction will be by way of local roads, including Main Street and Kaechele Place. Some construction activities could result in minor and short-term effects to vehicular traffic on the local roads leading to the Project Site. For example, localized traffic congestion may occur when heavy construction equipment or large components are transported to the work site, when construction personnel travel to and from the Project Site, and when the work is performed along the Eversource ROW to connect the overhead 115-kV lines to the new substation and to remove the existing 115-kV connections to the old substation. However, these effects will be minor and short-term. To the extent practical, UI will coordinate work to minimize potential impacts to traffic on nearby roads.

The Project Site also is served by public water, sewer, and storm sewer systems, as well as other utilities. The Project will not affect any above-grade existing municipal utilities. UI will coordinate with the City regarding other municipal utilities and will design the Project to avoid impacts to existing utility systems.

The operation of the substation will not require full-time on-site personnel and thus will not result in any long-term effects on traffic.

5.9 CULTURAL (ARCHAEOLOGICAL AND HISTORIC) RESOURCES

The Project is not expected to result in any adverse effects to known cultural (archaeological or historic) resources per the SHPO concurrence letter received in January 2020 that states no additional archaeological studies are needed and no historic properties will be affected by the work. Further, as documented in the cultural resource studies (refer to Appendix E), the Project Site does not encompass and is not located near any archaeological sites or historic structures listed on the NRHP or the SRHP. Similarly, due to the varied topography of the presently undeveloped UI property and the historical modifications to the existing Old Town Substation property and the Eversource ROW, the Project Site is not considered archaeologically sensitive.

Although unlikely, buried archaeological materials could be encountered during excavation activities performed during construction. To address this contingency, UI will include in the D&M Plan protocols for implementation if unanticipated cultural materials are unearthed during construction. UI's civil contractor will be briefed on such protocols.

5.10 AIR QUALITY, NOISE, AND LIGHTING

The construction and operation of the Project will have minimal and highly localized effects on air quality, noise, and lighting.

Air Quality

The development of the Project will result in short-term and localized effects on air quality as a result of emissions from construction equipment and vehicles, as well as from fugitive dust emissions generated during earth-moving activities. The operation of the Project facilities will not result in adverse impacts to air quality.

To minimize emissions from construction equipment and vehicles, UI will require Project contractors to properly maintain equipment and to adhere to Connecticut's anti-idling requirements (RCSA § 22a-174-18). In addition, UI will require its contractors to control dust emissions by applying water or equivalent substances to exposed soils on the site, as necessary, per guidance provided in the SWPCP. To minimize tracking of dirt from Project construction areas onto Kaechele Place (and other paved roads, if used for construction access), UI will install anti-tracking pads, and observe a sweeping protocol at entrances to the Project Site.

Noise

The construction of the Project will result in minor and highly localized increases in noise associated with construction activities, such as the operation of equipment, the excavations for foundations and cable trenches, and the installation of the substation and transmission line facilities. However, because the proposed Project facilities are near commercial areas along Main Street, the temporary increases in sound levels are expected to be generally consistent with the existing ambient conditions.

There are no schools, places of worship, or other community facilities, aside from the Park, in the immediate vicinity of the Project Site, although construction noise may be apparent from residences to the north along Sequoia Road and to the west and southwest (along Kaechele Place and other streets). However, typical

construction activities are expected to occur during daylight hours, between 7:00 AM and 7:00 PM, Monday to Saturday, when human sensitivity to noise is typically less than during the nighttime.

Like the existing Old Town Substation, the primary noise sources associated with the operation of the new substation will be the two 115/13.8-kV transformers. Other substation equipment and the 115-kV lines will not produce noise.

As described in detail in Appendix F, a computerized noise model, using input regarding the existing noise environment in the vicinity of the Project Site and the anticipated transformer noise from the new substation, was used to predict the effect of the new substation on ambient sound levels at the receptor locations identified in Section 4.10.

The noise analysis demonstrates that the sound from the new substation is predicted to be within allowable State and municipal sound limits at each of the receptor locations. Predicted noise levels from the two transformers are expected to be within the allowable sound level limits for adjacent land uses in the surrounding community and at the UI property line. When considered in the context of existing ambient sound levels, under certain conditions, the transformers may produce tones as defined by the CT DEEP noise regulations at sites to the north of the Project along Sequoia Road and to the west at the closest residence on Kaechele Place. However, the presence of the tones is not considered excessive noise as the overall A-weighted levels from the transformers at these locations are more than 5 dB below the noise zone standards established by the regulation.

Lighting

The Project is located immediately east of a developed urban area that is well-lit due to existing commercial facilities and nearby transportation network. As a result, the construction and operation of the Project will result in only localized and minor modifications to the lighting environment.

The construction of the Project facilities will typically occur during the daytime, when artificial lighting will not be required. If certain construction activities must be performed during night-time (e.g., to adhere to outage requirements), temporary lighting will be positioned to focus illumination on work areas. Such temporary lighting will not affect areas outside the general vicinity of the Project Site.

At the new Old Town Substation, low-level lighting will be installed for safety and security purposes. The illumination from these lights will be visible in the immediate vicinity of the substation. In general, the

lighting at the substation is expected to be consistent with the lighting at the existing Old Town Substation and the illumination of commercial facilities in the vicinity.

UI will employ additional lighting only for work at night under abnormal or emergency conditions. The lights at the new substation will incorporate UI's standard design for illumination of substation yards (i.e., the use of area lights mounted on equipment support structures, perimeter fence posts, and enclosures).

6. ELECTRIC AND MAGNETIC FIELD CONSIDERATIONS


To assess the electric and magnetic fields (EMF) associated with the Project, UI retained Exponent, a company with specialized expertise in such evaluations. Exponent measured EMF levels near the existing Old Town Substation and modeled the EMF levels of the transmission lines entering and exiting the substation as well as the rerouted transmission lines and new bus structure on the northern side of the substation. Exponent's *Electric and Magnetic Field Report* for the Project is presented in Appendix G. As detailed in the report and summarized below, Exponent's assessment is that because the configurations of the rebuilt substation and relocated 115-kV transmission line connections will be similar to those at the existing substation, the EMF levels will be similar as well, and will be a small fraction of those recommended for the general public by international health-based standards.

6.1 OVERVIEW

EMF surround anything that generates, transmits, or uses electricity. As a result, people living in modern communities are surrounded by various sources of EMF on a daily basis. Figure 6-1 depicts typical EMF levels in residential and occupational environments, as well as on or at the edges of transmission line ROWs. Magnetic and electric fields are described as follows:

- **Magnetic Fields:** The current flowing on the conductors of a substation bus-line or an overhead transmission line generates a magnetic field near the conductor. The strength of Project-related magnetic fields is expressed as magnetic flux density in units of milligauss (mG) where 1 Gauss = 1,000 mG. In the case of alternating current (AC) transmission lines, these currents (and thus magnetic fields) vary in direction and magnitude with a 60-Hertz (Hz) cycle. The level of the magnetic field around conductors varies with the circuit loading. Line loadings are expressed in units of amperes (A). Because of variations in line loadings, measurements or calculations of the magnetic field present a snapshot of the magnetic field at only one moment in time. On a given day, throughout a week, or over the course of months and years, the magnetic field level can change depending upon the patterns of power demand on the bulk transmission system.
- **Electric Fields:** The voltage on the conductors of transmission lines generates an electric field in the space between the conductors and the ground. Electric fields are blocked by many objects that are conductive, including fences, shrubbery, and buildings, and thus shield electric fields. The electric fields from equipment within the Old Town Substation therefore were not calculated since they would be attenuated to insignificant levels by the substation fence and any surrounding vegetation. In addition, the buried distribution lines will not be a source of 60-Hz electric fields above ground, since electric fields are confined by the cables' conductive sheath as well as blocked by the surrounding soil and duct bank. Electric field levels are expressed in units of kilovolts per meter ("kV/m"); 1 kV/m is equal to 1,000 volts per meter ("V/m").

Figure 6-1: EMF Levels in the Environment



6.2 EMF MEASUREMENTS AND MODELING

To assess EMF from existing sources under pre-Project conditions, Exponent took measurements at locations around the perimeter of the existing substation site, at locations along the existing and proposed 115-kV line connections, and on nearby streets on January 6, 2020. Field levels were measured at a height of 3.28 feet (ft) (1 meter [m]) above ground using instruments meeting IEEE Std.1308-1994 (R2010)⁷ for obtaining accurate field measurements at power line frequencies and calibrated by EMDEX, LLC, using methods like those described in IEEE Std. 644-2019⁸. The measurements were taken and reported as the root mean square value of the field in accordance with IEEE Std. C95.3.1-2010⁹ and IEEE Std. 644-2019.

Measurements indicate that the highest field levels measured around the existing Old Town Substation are due to the overhead transmission lines passing through the substation and existing distribution lines exiting the substation. The main results for magnetic fields are summarized in Table 6-1. The measurements of electric fields were less informative because of interference from the dense vegetation surrounding much of the proposed site. The magnetic field levels measured around the substation are generally similar to those measured along Main Street and somewhat higher than those along Sequoia Road, to the north of the substation.

Table 6-1. Measurements of Existing Magnetic Field Levels (mG)

Measurement Path	Min	Mean	Max
Kaechele Place (in front of substation)	2.5	8.1	17
Perimeter of existing substation	4.2	7.9	16
Parking lot of adjacent funeral home	0.2	0.5	3.4
Main Street	1.5	6.5	15
Sequoia Road	0.4	1.4	5.6

Additional magnetic-field measurements, starting at the existing substation fence and moving perpendicularly away from the substation to the north, indicate magnetic-field levels (primarily due to the

⁷ Institute of Electrical and Electronics Engineers (IEEE). IEEE Recommended Practice for Instrumentation: Specifications for Magnetic Flux Density and Electric Field Strength Meters - 10 Hz to 3 kHz. (IEEE Std. 1308-1994, Reaffirmed 2010). New York: IEEE, 1994.

⁸ Institute of Electrical and Electronics Engineers (IEEE). IEEE Approved Draft Standard Procedures for Measurement of Power Frequency Electric and Magnetic Fields from Alternating Current Power Lines (IEEE Std. P644/D7, . New York: IEEE, 2019).

⁹ Institute of Electrical and Electronics Engineers (IEEE). IEEE Recommended Practice for Measurements and Computations of Electric, Magnetic, and Electromagnetic fields with respect to Human Exposure to Such Fields, 0 Hz to 100 kHz. (IEEE Std. C95.3.1-2010). New York: IEEE, 2019.

existing transmission lines) fall to less than 2 mG within approximately 60-65 feet of the existing substation fence. This indicates that the measured magnetic fields at residences along Sequoia Road, approximately 400 feet to the north of the perimeter of the existing substation fence are due to existing local sources (such as underground distribution lines and electrical service for local residents) and not due to the substation. This will continue to be the case after expansion of the new substation where the modeling summarized below confirms that the magnetic field at the nearest residence north of the substation (still more than 200 feet from the rebuilt substation fence) will not be increased.

To assess post-Project conditions, Exponent modeled the EMF levels from the existing and proposed configurations of the 115-kV lines, assuming peak and peak daily average load at the time of UI's submission of the Application to the CSC (i.e., 2020) and projected peak and peak daily average load anticipated after the Project is completed in 2023. This approach is consistent with IEEE Std 1127-2013¹⁰ that summarizes the engineering experience with EMF from substations as follows:

In a substation, the strongest fields near the perimeter fence come from the transmission and distribution lines entering and leaving the substation. The strength of fields from equipment inside the fence decreases rapidly with distance, reaching very low levels at relatively short distances beyond substation fences. (p. 26)

The assumptions to be used in the modeling are consistent with CSC guidelines, as summarized in Section 6.4.

6.3 ASSESSMENT CRITERIA

Neither the Federal government nor the State has enacted standards for EMF from power lines or other sources at power frequencies; however, the CSC has developed best management practices for siting new transmission lines, as summarized in Section 6.4. Several states have statutes or guidelines that apply to fields produced by new transmission lines, but these guidelines are not health based. For example, New York and Florida have limits on EMF that were designed to limit fields from new transmission lines to levels characteristic of the fields from existing transmission lines.

¹⁰ Institute of Electrical and Electronics Engineers (IEEE). IEEE Guide for the Design, Construction, and Operation of Electric Power Substations for Community Acceptance and Environmental Compatibility. New York: IEEE. IEEE Std. 1127-2013.

More relevant EMF assessment criteria include the exposure limits recommended by health scientific organizations. These exposure limits are included in guidelines developed to protect health and safety and are based on reviews and evaluations of relevant health research.

The guidelines include exposure limits for the general public recommended by the International Committee on Electromagnetic Safety (“ICES”) and the International Commission on Non-Ionizing Radiation Protection (“ICNIRP”) to address health and safety issues.¹¹ In a June 2007 Factsheet, the World Health Organization recommended that policy makers adopt international exposure limit guidelines, such as those from ICNIRP or ICES (refer to Table 6-2), for occupational and public exposure to EMF.¹²

Table 6-2: ICNIRP and ICES guidelines for EMF exposure at 60-Hz

	Exposure (60 Hz)	
	Electric Field	Magnetic Field
ICNIRP		
Occupational	8.3 kV/m	10 G (10,000 mG)
General Public	4.2 kV/m	2 G (2,000 mG)
ICES		
Occupational	20 kV/m	27.1 G (27,100 mG)
General Public	5 kV/m*	9.040 G (9,040 mG)

*Within power line ROWs, the guideline is 10 kV/m.

6.4 CONSISTENCY WITH CSC BEST MANAGEMENT PRACTICES

The CSC has adopted *EMF Best Management Practices for the Construction of Electric Transmission Lines in Connecticut* based upon a consensus of health and scientific agencies that the scientific evidence “reflects the lack of credible scientific evidence for a causal relationship between MF [magnetic field] exposure and adverse health effects.” (CSC, 2014, p. 3). Nevertheless, the CSC concluded that precautionary measures for the siting of new transmission lines in Connecticut are appropriate and advocated that “the use of effective no-cost and low-cost technologies and management techniques on a project-specific basis to reduce MF [magnetic field] exposure to the public while allowing for the development of efficient and cost-effective electrical transmission projects” (CSC, 2014, p.4).

¹¹ International Committee on Electromagnetic Safety (ICES). IEEE Standard for Safety Levels with Respect to Human Exposure to Electric, Magnetic, and Electromagnetic Fields, 0 Hz to 300 GHz, Standard IEEE C95.1-2019, Oct. 2019; International Commission on Non-ionizing Radiation Protection (ICNIRP). Guidelines for limiting exposure to time-varying electric and magnetic fields (1 Hz to 100 kHz). Health Phys 99: 818-836, 2010.

¹² World Health Organization (WHO). Fact Sheet No. 322: Electromagnetic Fields and Public Health – Exposure to Extremely Low Frequency Fields. Geneva, Switzerland: World Health Organization, 2007.

The CSC's EMF Best Management Practices (EMF BMPs) formed the basis for Exponent's review of the Project's consistency with the CSC guidelines. Although the EMF BMPs explicitly apply to transmission lines, not substations, Exponent applied the spirit of these BMPs as interpreted for a substation. The Project does not involve the development of new transmission lines, but rather the relocation of existing 115-kV transmission lines. For this reason, the EMF levels from these lines post-Project are expected to be similar to the pre-Project EMF levels.

Exponent considers the Project as consistent with the CSC's EMF BMPs for "no cost/low-cost" design recommendations for reasons that include:

- The Project is not sited adjacent to statutory (community) facilities, with the exception of the Park, an undeveloped municipal park. The Eversource ROW traverses east-west through the Park; the southeastern boundary of the substation abuts the westernmost portion of the park.
- The new Old Town Substation will be located adjacent to and will encompass the existing substation property, and the proposed relocation of the optimally phased overhead transmission lines within the UI property are expected to have essentially no effect on the calculated magnetic field at the closest residences.
- The rebuilt substation and reconfiguration of the existing 115-kV transmission lines are sufficient to achieve the standards for adequate, safe, and reliable service without constructing a new substation in a different location and attendant transmission lines, which would be new sources of EMF.

6.5 CONCLUSIONS

Taking into consideration the current Project design and based on the results of the EMF modeling, the proposed Project would have little effect on existing EMF levels in the vicinity. Because the configurations, voltages, and loadings of the rebuilt substation and relocated 115-kV transmission lines will be similar to those at the existing substation, the EMF levels will also be similar. The calculated magnetic field levels (and measured electric and magnetic field levels) in the vicinity of the substation will be a small fraction of those recommended for the general public by international health-based standards (i.e., ICES and ICNIRP). The engineering design and other activities initiated by UI demonstrate compliance with the CSC's EMF BMPs.

7. PROJECT SCHEDULE

As illustrated in the schedule presented in Figure 7-1, preliminary engineering for the Project was initiated in early 2019. Detailed engineering will be performed in 2020.

Figure 7-1 lists the key activities in UI’s schedule for developing the Project, including permitting, engineering, permitting, procurement, and construction.

The rebuilt Old Town Substation is expected to be placed into service in 2024.

This proposed schedule could change based on the timing of the receipt of approvals from the Council and other involved regulatory agencies.

Figure 7-1: Project Schedule

	2019			2020			2021			2022			2023			2024		
Preliminary Engineering																		
Permitting																		
Detailed Engineering																		
Procurement																		
Construction																		
Operation																		
Demolition																		

This page intentionally left blank

8. PROJECT PERMITS, APPROVALS AND CONSULTATIONS

During the preparation of this Application, UI consulted with representatives of the City and Trumbull, as well as with the CT DEEP, USFWS and SHPO¹³. Appendix B includes correspondence with the regulatory agencies regarding the Project. Section 8.2 summarizes the consultations conducted with the municipalities, as well as public outreach.

UI expects to continue to consult with the involved regulatory authorities as the planning for and development of the Project continues. This section identifies the permits and approvals required for the construction and operation of the Project and summarizes the agency and municipal consultations that UI has conducted to date.

8.1 FEDERAL AND STATE AGENCY APPROVALS REQUIRED AND CONSULTATIONS

In addition to the Application for a *Certificate of Environmental Compatibility and Public Need* from the Council, the Project will require certain approvals from other state regulatory agencies. Table 8-1 summarizes the permits and approvals expected to be required for the Project, along with the status of UI's consultations to date with the involved agencies.

8.2 MUNICIPAL CONSULTATION FILING AND OUTREACH

As part of the Project planning process, UI consulted with City of Bridgeport officials, coordinated with state agencies, and conducted a formal municipal consultation process, pursuant to the Council's pre-application requirements (C.G.S. § 16-50*l*). These requirements specify that applicants intending to apply for a *Certificate of Environmental Compatibility and Public Need* from the Council consult with potentially affected municipalities at least 60 days prior to the Application filing date.

Accordingly, on January 17, 2020, UI submitted a Municipal Consultation Filing (MCF) to the City and Trumbull. The MCF included a description of the Project, as well as information concerning the public need, site selection process, construction schedule, potential environmental effects and mitigation

¹³ As currently planned, the Project is not expected to affect any federal or state inland water resources. As a result, consultation with the USACE, New England District, is not necessary. If, as Project planning proceeds, it is determined that water resources would be affected, UI will consult with and submit appropriate notifications or water resource permit applications to the USACE and CT DEEP.

measures, and EMF analyses. The MCF provided a formal mechanism both for informing the public and elected officials about the proposed Project and for soliciting comments on the Project from local leadership and the interested public.

UI initially met with officials from the City of Bridgeport on August 27, 2019 to provide general information about the proposed Project. UI also offered to meet with representatives of Trumbull but were told by Trumbull representatives that it was unnecessary. After the submission of the MCF, UI met with City officials on January 2, 2020 and on March 9, 2020 held a public meeting regarding the Project. A summary of UI's outreach efforts can be found in Appendix H.

In accordance with the Council's requirements and C.G.S. § 16-50l(e), within 15 days after submitting this Application, UI will supply to the Council all MCF materials provided to the City and Trumbull, along with a summary of the consultations with the municipalities, including any comments or recommendations issued by the City or the Town regarding the Project.

Table 8-1: Permits and Approvals Expected to be Applicable to the Project

Agency	Potential Permit/Approval Required	Application Submitted or Consultation (Date)	Status
FEDERAL			
USFWS	Request for consultation per Section 7 of the Endangered Species Act (e.g., for potential presence of Northern Long Eared Bat)	Request for threatened/endangered species review - 2019	Complete; USFWS response of October 25, 2019 (refer to Appendix B)
STATE			
CONNECTICUT SITING COUNCIL	Municipal Consultation Filing	January 2020	Complete; March 2020
	Certificate of Environmental Compatibility and Public Need under C.G.S. § 16-50(a)(1)	March – April 2020	Review ongoing
	Development and Management Plan (after issuance of certificate and prior to Council's approval to start construction)	To be determined; depends on timing of CSC approval of Application	Pending
CT DEEP • NDDB • Stormwater	Threatened and endangered species review	Review form submitted October 2019. Project Site is not within area of listed habitat per publicly available NDDB mapping.	Complete; NDDB response of October 18, 2019 (refer to Appendix B)
	General Permit for the Discharge of Stormwater and Dewatering Wastewaters from Construction Activities (DEEP-WAPED-GP-015) and SWPCP	Expected to be prepared at generally the same time as the D&M Plan	Pending
CT SHPO	Cultural Resource Consultation under C.G.S. § 16-50(e)	Cultural resources review performed; review form submitted to SHPO in November 2019	Complete; SHPO response included in Appendix B
MUNICIPAL			
City of Bridgeport	Consultations in conjunction with MCF process	Ongoing	MCF consultations complete
	Coordination with Fire Marshall (Blasting Permit)	If necessary, during construction	If necessary
Town of Trumbull	Consultations in conjunction with MCF process	Pending	MCF consultations complete

In accordance with the Council's requirements and Connecticut General Statutes § 16-50l(e), within 15 days after submitting the Application, UI will supply to the Council all MCF materials provided to the City and a summary of the consultations with the City, including any comments or recommendations issued by the City.

9. ALTERNATIVES CONSIDERED

9.1 INTRODUCTION AND SUMMARY

Overview and Conclusions of the Alternatives Evaluation Process

The Project was selected as a result of a process whereby alternatives were identified and assessed. Initially, UI performed a comprehensive evaluation of the asset condition, in relation to existing and future needs, at the existing Old Town Substation. The evaluation found that the equipment at the existing Old Town Substation is more than 50 years old and must be updated to address existing and future demands for providing reliable electricity to the local area. UI determined that the consequences of the “No Action” (i.e., “do nothing”) option would pose unacceptable risks to the resiliency of the electric transmission system and the provision of reliable service to customers in the Greater Bridgeport area. Subsequently, UI commissioned a solutions study to assess options for upgrading Old Town Substation.

As part of the solutions study, two alternatives were evaluated:

1. **In-kind Replacement on the Existing Substation Site.** This alternative involves upgrading and replacing the components and equipment at the existing substation within the footprint of the existing 0.9-acre Old Town Substation site. UI found that the small size of the existing substation site poses critical constraints to the required improvements. Moreover, this alternative would expose UI customers to significant reliability risks (given the long equipment outages required to replace and upgrade the substation) and would have construction challenges and safety hazards.
2. **Rebuild Alternative.** This alternative entails developing a new, upgraded 115/13.8-kV substation, either on UI property adjacent to and including the existing Old Town Substation (i.e., the proposed Project) or on a site located elsewhere, near the 115-kV transmission lines to which the substation must connect.

After determining that in-kind replacement is not a feasible alternative (as it would pose constructability challenges and would be less cost-effective than rebuilding a new upgraded substation), UI conducted a review to identify potential locations for the rebuilt substation. This review resulted in the identification of seven potential sites, including the proposed site northeast of Kaechele Place. To facilitate the required connections to Eversource’s 115-kV lines, all the alternative sites had to be located adjacent to or near the Eversource ROW in Bridgeport or Trumbull. UI assessed each of the seven sites, taking into consideration

site size, property ownership, proximity to existing transmission lines, distribution line connections required, land use, environmental resources, constructability, and cost. As a result of this review, all the sites but the proposed location were dismissed from consideration because of various overriding factors (e.g., cost, feasibility of property acquisition, existing land use and environmental constraints, potential for regulatory/siting issues).

After the proposed site was identified as the preferred location to rebuild the substation, UI reviewed different substation configuration options, centering on an AIS design. A GIS substation design, which would be more costly, was not considered as a preferred option for the new substation because the Project Site includes enough UI-owned property to accommodate an AIS facility. Typically, a GIS substation is installed in a highly urban environment where there is not enough land to construct an AIS type substation.

In summary, based on the results of the alternatives review process, the proposed Project represents the optimal solution for rebuilding the Old Town Substation, thereby enhancing the reliability of the electric system to the benefit of Connecticut and New England consumers. The location of the new Old Town Substation on the proposed site, which is adjacent to the existing substation, will facilitate interconnections to the existing transmission network and to UI's distribution system.

The following sections provide additional information regarding the alternatives process that led to the selection of the proposed Project.

9.2 NO ACTION ALTERNATIVE

Under the No Action Alternative, the existing Old Town Substation would continue in-service at the present site, with no improvements made to mitigate reliability risks by upgrading the substation's existing transmission and distribution system infrastructure. Consequently, no action would be taken to resolve the substation's current infrastructure issues (e.g., reliability and operational issues with respect to the substation's transmission and distribution infrastructure, obsolete 115-kV OCB and associated disconnect switches, inadequate control enclosure, insufficient access/clearance for emergency 115/13.8-kV mobile transformers, inadequate lightning protection).

The No Action Alternative was rejected because it would not resolve the asset condition issues at Old Town Substation, and thus would not improve the reliability of the electric system. As a result, the substation would remain outdated and at risk for equipment failures that would lead to extended duration outages affecting customers and the bulk power system.

9.3 SUBSTATION SITE ALTERNATIVES

The existing Old Town Substation, which is located on a 0.9-acre site, has undergone modifications since it was placed into service in the mid-1960s, and now is fully built out, with no room for expansion. Studies commissioned by UI (i.e., the *Old Town Substation Needs Assessment, March 2014*) confirmed that the substation has significant asset condition deficiencies that require upgrades or replacement. To rectify these deficiencies, UI investigated the two primary alternatives, as discussed in the following subsections:

- In-kind modifications and upgrades to the existing Old Town Substation on the Existing Substation Parcel, as well as on a portion of UI-owned property abutting and to the north of the existing site.
- Full rebuild of the substation, either on geographically distinct sites or on the Undeveloped Parcels (i.e., at 330 and 312 Kaechele Place) located to the north and east of the existing substation site.

9.3.1 In-Kind Modifications/Upgrades at Existing Old Town Substation Site

The in-kind replacement option would require upgrading the existing substation facilities to address all the identified needs, including the replacement of transformers to conform to UI's current standard for substation distribution power transformer sizing, the provision of access for a mobile substation transformer, adding a new pre-fabricated control enclosure, etc. The in-kind upgrades would be concentrated on the existing 0.9-acre substation site. In total, the in-kind substation replacement is estimated to cost approximately \$47 million.

UI determined that the in-kind replacement option poses various constraints and construction challenges. For example, to perform the in-kind replacement, the existing substation equipment would have to be taken out of service for an extensive length of time and construction activities would have to be closely coordinated with available outage periods. Further, a mobile substation would be required at the site to accommodate equipment outages while still maintaining reliable service to UI customers; the use of the mobile substation at Old Town Substation would make it unavailable for other uses and would further increase the complexity of the substation construction. In addition, there would be an increased safety risk during construction because the substation upgrades would have to be performed in proximity to energized equipment. Finally, the in-kind replacement option does not include any provisions for the expansion of the substation to serve the future needs of customers in the region or for the replacement of equipment that may become obsolete in the near future (the equipment to be replaced would focus only on the items specifically identified in the March 2014 *Needs Assessment*).

9.3.2 Full Substation Rebuild

9.3.2.1 Alternative Site Selection Process

After determining that Old Town Substation's asset condition issues could not feasibly be addressed by in-kind replacement on the existing site, UI conducted a review to identify and assess potential sites for rebuilding Old Town Substation. This study was based on UI's general site selection guidelines and specific selection criteria, as summarized below.

General Site Selection Guidelines

To identify potentially feasible alternative sites for rebuilding the existing Old Town Substation, UI used an iterative process whereby potential properties were first identified and screened in accordance with the Company's standard objectives for substation siting, which are to:

- Minimize the need to acquire residences and viable commercial/industrial uses to accommodate substation development.
- Maintain consistency/compatibility with existing land uses and land use plans to the extent possible.
- Minimize adverse effects on sensitive environmental resources and the social environment.
- Maintain public health and safety.
- Demonstrate cost-effectiveness, while adhering to good engineering and sound environmental planning practices.
- Present the public with a clear and well documented methodology for the identification of the proposed and alternative sites.

Site Selection Criteria Specific to the Substation Rebuild

In addition to the criteria described above, key considerations in the identification of potential sites for rebuilding and upgrading Old Town Substation were:

- Distance to the existing Old Town Substation and the Eversource 115-kV transmission lines that must connect to the substation.
- Availability of property (e.g., sites that are UI-owned, vacant/undeveloped, for sale, or would not require the removal or relocation of existing commercial or residential uses).
- Site size (a minimum of about 2.75 acres, including undeveloped buffer areas and setbacks, is needed for a 115/13.8-kV AIS facility of the type required for the new substation).
- Site topography and subsurface conditions.


- Environmental and land use characteristics, including present and past property uses; presence of jurisdictional water resources, cultural resources, or threatened or endangered species; need for environmental remediation, etc.
- Substation constructability.
- Availability of property (e.g., fee ownership or easement) for transmission and distribution line connections to the substation and the lengths of the new transmission and distribution line segments required to connect the new substation to the transmission network and UI's distribution system in the Greater Bridgeport area.
- Accessibility.
- Permitability (the anticipated ability to obtain all required regulatory approvals for construction at the site).
- Cost.

9.3.2.2 Results of the Site Screening Process

Because of the suburban/urban development in the general vicinity of the existing Old Town Substation and the need for any new substation to connect to the transmission network that presently links the existing substation, UI's study focused on potential alternative sites located along the Eversource ROW. The Eversource ROW presently traverses through Old Town Substation and includes three 115-kV lines, two of which connect to the existing Old Town Substation.

As Figure 9-1 illustrates, seven potential alternative sites for the new Old Town Substation, including the proposed site, were identified. All the alternative sites are situated adjacent to or near the Eversource ROW in Bridgeport or Trumbull and consist of privately or publicly owned properties that are presently undeveloped or include vacant areas that potentially could accommodate the substation. Further, due to the need to efficiently and cost-effectively connect the new substation to the transmission grid and to distribution lines in the territory presently served by the existing Old Town Substation, all the alternative sites are within several miles of the existing substation.

Figure 9-1: Alternative Substation Site Locations



UI evaluated each of the sites based on the site selection general guidelines and site-specific criteria. Table 9-1 summarizes information about each alternative site (e.g., address, existing land use) and the results of UI's evaluations of the suitability of each alternative site for the new Old Town Substation.

As Table 9-1 indicates, UI determined that only the proposed Project Site represents a viable, cost-effective alternative for the new Old Town Substation. Specifically, none of the other sites are presently owned by UI or dedicated to utility use. As a result, property acquisition would pose challenges and would increase costs. Several of the sites have land use constraints (e.g., presence of wetlands, recreational uses), while others would require costly distribution system connections. Because none of the alternative sites are in the immediate vicinity of the existing Old Town Substation, no efficiencies would be realized by minimizing new transmission and distribution line connections. As a result, all six of the alternative sites were eliminated from consideration in favor of the proposed Project Site adjacent to Kaechele Place.

9.3.2.3 Justification for the Selection of the Preferred Site

The Project represents the least-cost option for rebuilding Old Town Substation. In addition to cost, UI selected its property at 280, 312, and 330 Kaechele Place as the preferred location for the new substation due primarily to the following factors:

- **Availability of Property.** UI owns the property on which the new Old Town Substation would be rebuilt.
- **Direct Proximity to Existing Old Town Substation and Transmission/Distribution Connections.** The use of the UI-owned property at 330 and 312 Kaechele Place will allow the rebuild of the Old Town Substation, incorporating the existing 0.9-acre site into the new substation's footprint and minimizing the modifications to transmission and distribution lines needed to interconnect with the new facility.
- **Land Use Consistency.** The new substation will be located adjacent to and will encompass the existing Old Town Substation, which has been devoted to utility use for more than 50 years. Although the development of the new substation will require the conversion of currently undeveloped forest to utility purposes, UI will maintain a forested buffer, to the extent practical, between the fenced substation and lands to the north and east.
- **Avoidance / Minimization of Environmental Impacts.** The new substation will be developed on an upland site and will not result in significant impacts to environmental resources.

Table 9-1: Summary of Alternative Sites Identified for the New Old Town Substation

Site Name / Number (refer to Figure 9-1) / Municipality	Existing Land Use	Ownership	Siting Considerations / Constraints
Bridgeport			
4750 Park Avenue (1)	Veterans Memorial Park, north of Discovery Museum. Site consists of woodlands and recreational areas and is immediately east of Fairchild Wheeler Golf Course	Public	Would require acquisition of municipal recreational property and conversion to utility use. Access to the substation from Park Avenue would have to be developed. Residential areas are located to the north and east.
561 Frenchtown Road (2)	Elton Rodgers Woodland Park, wooded	Public	Undeveloped woodland recreational area would have to be converted to utility use. Parcel also contains wetlands, which could be affected by substation development, as well as rock outcrops and steep topography, which would add to constructability issues. Nearby land uses are residential.
280, 312, 330 Kaechele Place (Proposed Site)	Existing Old Town Substation / undeveloped wood and shrub land	Private (UI)	Property is presently owned by UI; the existing Old Town Substation has occupied a portion of the site for over 50 years. Transmission and distribution line connections require minimal modification to link to the rebuilt substation.
Trumbull			
2300 Reservoir Avenue (3)	Former Henderson Hardware, currently being cleared of vegetation.	Private (Sacred Heart University)	After initial alternatives analysis, site was acquired by Sacred Heart University and is no longer available for other development.
Quarry Road (4)	Commercial (movie theater) and various office uses; site is at end of cul-de-sac, near walking/hiking trails and Unity Park	Private	Property is east of State Route 25 and south of the Merritt Parkway interchange, leaving limited land for substation development. Also, extensive additional costs would be required as the alternative site is distant from the existing Old Town Substation. The available acreage is limited and may not accommodate the required new substation build out.
Rocky Ridge Drive/Quail Trail (5)	Woodland, surrounded by single-family residential neighborhoods, wetlands and stream on property	Public	Property is east of State Route 25, near State Route 8, and is distant from the existing Old Town Substation. Access to property is only through residential streets. Extensive additional costs would be required for distribution connections.
Huntington Turnpike (6)	Woodland, with single-family residential neighborhood to the north and residential areas along Huntington Turnpike	Public	Adjacent to and with same feasibility issues as Site 5, above.

9.4 SUBSTATION DESIGN AND TRANSMISSION LINE CONFIGURATION OPTIONS

Substation Design Alternative

The objective of the Project is to replace the existing AIS Old Town Substation with a similar but upgraded AIS facility. A GIS configuration was not considered for the Project because the existing UI property at the proposed Project Site is more than adequate to accommodate an AIS design. Further, a GIS configuration, which would occupy a smaller footprint and is typically implemented in densely developed urban environments where land is limited, would cost more than the proposed AIS design.

Transmission Line Configurations

The relocation of 115-kV line connections from the existing Old Town Substation to the new substation was a consideration in the overall Project planning. UI's proposed alignments for the transmission line reconnections were selected to minimize the length of each line. As a result, the transmission line structure replacements and removals, as proposed, represent the most efficient and cost-effective configurations for realigning the 115-kV lines into the new substation.

The proposed line connections to the new substation will require the acquisition of an easement on approximately 0.15-acre of City property in the Park. The area is directly adjacent to the southeast corner of UI's property, where the overhead transmission lines would extend northwest from the Eversource ROW, crossing over municipal land before entering UI's property into the new substation. Beneath and adjacent to the transmission lines in this location, vegetation clearing will be required to provide appropriate clearances between the overhead 115-kV lines and adjacent vegetation.

Instead of extending the 115-kV transmission lines overhead into the substation, UI considered the alternative use of an underground 115-kV cable configuration. Under this alternative, a short segment of underground transmission line would extend from a transition structure located on the Eversource ROW into the rebuilt substation, where the line would transition back to an overhead configuration. The underground line segment would consist of cross-linked polyethylene (XLPE) cable, contained within a concrete-encased duct bank (consisting of several PVC conduits).

The typical costs for constructing and underground 115-kV transmission system are five to 10 times greater than those for installing an equivalent length of overhead 115-kV transmission. Further, because of the more complicated engineering design and construction, along with the geometry of the land for a hybrid underground/overhead configuration connection to the rebuilt substation, UI prefers the overhead line alignment, as proposed.

This page intentionally left blank

10. ACRONYMS AND GLOSSARY OF TERMS

Acronym	Description
115-kV:	115-kilovolts or 115,000 volts
AC	Alternating current
ACSR:	Aluminum conductors with steel reinforcement, a common type of overhead conductor
ACSS:	Aluminum Conductor with Steel Support, a common type of overhead conductor
AIS:	Air-insulated substation
Ampere:	(Amp): A unit measure for the flow (current) of electricity. A typical home service capability (i.e., size) is 100 amps; 200 amps is required for homes with electric heat
ANSI:	American National Standards Institute
APE	Area of Potential Effect (for cultural resources)
Application:	Application to the Connecticut Siting Council for a Certificate of Environmental Compatibility and Public Need
BMP:	Best Management Practices
Cable:	A fully insulated conductor usually installed underground but, in some circumstances, installed overhead.
CCVT	Capacitor coupled voltage transformer
Certificate:	Certificate of Environmental Compatibility and Public Need (from the Connecticut Siting Council)
C.G.S.:	Connecticut General Statutes
Circuit:	A system of conductors (three conductors or three bundles of conductors) through which an electrical current is intended to flow, and which may be supported above ground by transmission structures or placed underground
Circuit Breaker:	A switch that automatically disconnects power to the circuit in the event of a fault condition. Located in substations. Performs the same function as a circuit breaker in a home
Conductor:	A metallic wire, busbar, rod, tube or cable that serves as a path for electric current flow
Conduit:	Pipes, usually PVC plastic, typically encased in concrete, for housing underground power cables
CONVEX:	Connecticut Valley Electric Exchange
Council (or CSC):	Connecticut Siting Council
CT	Current transformer
CT DEEP:	Connecticut Department of Energy and Environmental Protection
CT DOT	Connecticut Department of Transportation
D&M Plan:	Development and Management Plan (required by the Connecticut Siting Council)
dba:	Decibel, on the A-weighted scale
dbh:	Diameter breast height (tree trunk measurement)
Distribution:	The facilities that transport electrical energy from the transmission system to the customer
Disconnect Switch:	Equipment installed to isolate circuit breakers, transmission lines or other equipment for maintenance or sectionalizing purposes

Acronym	Description
Duct:	Pipe or tubular runway for underground power cables (see also Conduit)
Duct Bank:	A group of ducts or conduit installed underground and usually encased in concrete
EF, Electric Field:	Invisible lines of force produced by voltage applied to conductors and equipment. The electric field is expressed in measurement units of volts per meter (V/m) or kilovolts per meter (kV/m); 1-kV/m is equal to 1,000 V/m
Electric Transmission:	The facilities (69-kV and higher) that transport electrical energy from generating plants to distribution substations
EMF:	Electric and magnetic field
EMF BMP Document:	Electric and Magnetic Fields Best Management Practices for the Construction of Electric Transmission Lines in Connecticut prescribed by the Connecticut Siting Council
Eversource	The Connecticut Light & Power Company dba Eversource Energy
FEMA:	Federal Emergency Management Agency
FIRM	Flood Insurance Rate Map
G:	Gauss; 1G = 1,000 mG (milliGauss); a unit of measure for magnetic field
GIS:	Gas Insulated Substation
Ground Wire:	Cable/wire used to connect wires and metallic structure parts to the earth. Sometimes used to describe the overhead lightning shield wire.
Hz:	Hertz, a measure of alternating current frequency; one cycle/second.
ICES:	International Committee on Electromagnetic Safety, a committee of the Institute of Electrical and Electronics Engineers
ICNIRP:	International Council on Non-Ionizing Radiation Protection, a specially chartered independent scientific organization
IEC:	International Electro-technical Commission
IEEE:	Institute of Electrical and Electronics Engineers
kcil:	1,000 circular mils, approximately 0.0008 sq. in
kV: kilovolt	Equals 1,000 volts
kV/m:	Electric field unit of measurement (kilovolts/meter)
LiDAR	Light detection and ranging (remote sensing technology)
Line:	A series of overhead transmission structures that support one or more circuits; or in the case of underground construction, a duct bank housing one or more cable circuits
MCF:	Municipal Consultation Filing, part of the Connecticut Siting Council application process
MF, Magnetic Field:	Invisible lines of force produced by the flow of electric currents; however, unlike electric fields, most materials do not readily block magnetic fields. The level of a magnetic field is commonly expressed as magnetic flux density in units called gauss (G), or in milliGauss (mG), where 1 G = 1,000 mG.
mG:	milliGauss (see Magnetic Field)
MVA	Megavolt ampere
MVAR	Meagavolt ampere reactive
NAAQS:	National Ambient Air Quality Standards
NAVD88	North American Vertical Datum 1988

Acronym	Description
NDDB:	Connecticut Natural Diversity Data Base (CT DEEP)
NERC:	North American Electric Reliability Council, Inc. (initially, the National Electric Reliability Council)
NESC:	National Electrical Safety Code
NFPA	National Fire Protection Association
NPCC:	Northeast Power Coordinating Council
NRCS:	Natural Resources Conservation Service (United States Department of Agriculture)
NRHP:	National Register of Historic Places
OCB	Oil circuit breaker
OPGW:	Optical groundwire (a shield wire containing optical glass fibers for communication purposes)
Phases:	Transmission (and some distribution) AC circuits are comprised of three phases that have a voltage differential between them.
Project:	Old Town Substation Rebuild Project
PSI:	Pounds per square inch
PVC:	Polyvinyl chloride (material used in making conduits for XLPE-insulated cable and other purposes)
RCSA:	Regulations of Connecticut State Agencies
ROW:	Right-of-way
SCADA:	Supervisory Control and Data Acquisition
SHPO:	State Historic Preservation Office
SPCC:	Spill Prevention and Countermeasures Plan
S/S (Substation):	A fenced-in yard containing switches, transformers, line-terminal structures, and other equipment enclosures and structures. Adjustments of voltage, monitoring of circuits and other service functions take place in this installation.
Steel Monopole Structure:	Transmission structure consisting of a single tubular steel column with horizontal arms to support insulators and conductors.
SWPCP:	Stormwater Pollution Control Plan - A sediment and erosion control plan that also describes all the construction site operator's activities to prevent stormwater contamination, control sedimentation and erosion, and comply with the requirements of the federal Clean Water Act.
Terminal Point:	The substation or switching station at which a transmission circuit terminates.
Terminal Structure:	Structure typically within a substation that ends a section of transmission line.
Transformer:	A device used to transform voltage levels to facilitate the efficient transfer of power from the generating plant to the customer. A step-up transformer increases the voltage while a step-down transformer decreases it.
Transmission Line:	Any line operating at 69,000 or more volts.
UI:	The United Illuminating Company
USACE	United States Army Corps of Engineers
USGS:	United States Geological Survey (U.S. Department of the Interior)
V/m	Volts per meter

Acronym	Description
Voltage:	A measure of the push or force that transmits energy.
WHO	World Health Organization
XLPE	Cross-linked polyethylene
XS:	Cross-section (drawing)