

May 20, 2026

265 Church Street
New Haven, CT 06510
203.772.7700

BRUCE L. McDERMOTT
DIRECT: 203.772.7787
FAX: 203.772.7787
BMCDERMOTT@HARRISBEACHMURTHA.COM

Via Electronic-Mail

Ms. Melanie Bachman
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 0605

Re: Notification of Emergency Response – Bridgeport Train Station

Dear Ms. Bachman:

On January 27, 2026, The United Illuminating Company (“UI”) informed the Connecticut Siting Council (the “Council”) that on January 24, 2026 the static wire for the 8909B 115-kV transmission line (the “Line”) between UI’s Baird Substation and Pequonnock Substation broke mid-span, between structures 775B and 776. Emergency work was conducted on the Line on January 24, 2026. UI wishes to inform the Council that the static line has been replaced and all construction activities have been completed.

Please feel free to contact me if you have any questions or concerns regarding this matter.

Very truly yours,



Bruce L. McDermott



