


Structural Design Calculations



Marc R. Chretien

Site No.: CT3461 - Bristol Middle Street
Client: Centerline Communications
Date: July 18, 2017

Synopsis:

The proposed AT&T equipment installation will consist of six (6) 8' antennas (2 per sector), fifteen (15) remote radio heads (RRHs) (5 per sector), and three (3) surge arrestors mounted to the existing steel-framed catwalk assembly located approximately 120' AGL on the 127' radial brick masonry smoke stack.

Material Properties :

Unit weight of brick,	$\gamma_{\text{brick}} := 125 \cdot \text{pcf}$
Modulus of rupture of brick,	$F_r := 300 \cdot \text{psi}$
Allowable tensile stress in bending,	$F_t := 7.5 \cdot \text{psi}$ (Unreinforced brick, type N mortar)
Ultimate masonry strength,	$f'_m := 2400 \cdot \text{psi}$

Chimney Properties:

The existing stack is a 127' tall radial brick masonry structure. Based on a field investigation by Industrial Communications on 1-29-14, the stack has a 11'-6" dia. base and a 5'10" dia. top. Bottom wall thickness was 24" and top wall thickness was 9". There is currently one antenna array (3 flush-mounted and one MW dish) at 96' AGL. Based on photos taken during the field investigation, the stack appears to be in good condition with minimal mortar and brick loss.

Dimensions:

Stack Height,	$H := 127 \cdot \text{ft}$
Bottom outside dimension,	$D_{\text{bo}} := 11.5 \cdot \text{ft}$
Bottom inside dimension,	$D_{\text{bi}} := 7.75 \text{ft}$
Top inside dimension,	$D_{\text{ti}} := 4.333 \cdot \text{ft}$
Top outside dimension,	$D_{\text{to}} := 5.833 \cdot \text{ft}$

Approx. stack weight,
$$W_{\text{stack}} := \frac{(D_{\text{bo}}^2 - D_{\text{bi}}^2) + (D_{\text{to}}^2 - D_{\text{ti}}^2)}{2} \cdot H \cdot \gamma_{\text{brick}}$$

$$W_{\text{stack}} = 694.03 \cdot \text{kip}$$

Analysis:

Wind load:

Height, $H = 127$ ft AGL

Exposure Category, B (ASCE 7-10 Sec 26.7.3)

Risk category II (ASCE 7-10 Table 1.5-1)

Basic wind velocity, $V := 120$ mph (CSBC Appendix N)

Exposure coefficient, $K_z := 1.07$ (ASCE 7-10 Table 29.3-1)

Topographic multipliers, $K_1 := 0$ (ASCE 7-10 Fig. 26.8)

$$K_2 := 1.0$$

$$K_3 := 1.0$$

Topographic factor, $K_{zt} := (1 + K_1 \cdot K_2 \cdot K_3)^2$ (ASCE 7-10 Sec 26.8.2)
 $K_{zt} = 1$

Velocity wind pressure, $q_z := .00256 \cdot V^2 \cdot K_z \cdot K_{zt}$ psf (ASCE 7-10 Sec 29.3.1)
 $q_z = 39.44$ psf

Gust effect factor, $G := .85$ (ASCE 7-10 Sec 29.3)

Force coeff., $C_{f_f} := 1.4$ Flat (ASCE 7-10 Fig. 29.5-1)


$$C_{f_r} := .70 \text{ Round}$$

Wind Load factor, $LF := .6$ (for use with allowable stress design) (ASCE 7-10 Sect 2.4)

Wind load pressure on stack, $WL_{stack} := q_z \cdot G \cdot C_{f_r}$
 $WL_{stack} = 23.47$ psf

Wind load pressure on antennas/RRHs, $WL_{ant} := q_z \cdot G \cdot C_{f_f} \cdot LF$ (ASCE 7-10 Sec. 29.5-1)
 $WL_{ant} = 28.16$ psf

The proposed AT&T installation will be conservatively analyzed as a 13'x8' flat appurtenance. The existing three flush-mounted antennas will be analyzed assuming that two antennas project entirely beyond the profile of the smokestack (the 3rd will be assumed to be within the profile of the stack and not contribute to wind loading).



Equipment Loads:

Existing/proposed Inventory:

Proposed Antenna Properties:

- Width, $w_{pant} := 14.4 \cdot \text{in}$
- Depth, $t_{pant} := 7.3 \cdot \text{in}$
- Length, $l_{pant} := 92.8 \cdot \text{in}$
- Weight, $W_{pant} := 53 \cdot \text{lb}$

Proposed RRUS 11 Properties:

- Width, $w_{11} := 19.7 \cdot \text{in}$
- Depth, $t_{11} := 7.2 \cdot \text{in}$
- Length, $l_{11} := 17 \cdot \text{in}$
- Weight, $W_{11} := 51 \cdot \text{lb}$

Proposed RRUS 32 Properties:

- Width, $w_{32} := 13.3 \cdot \text{in}$
- Depth, $t_{32} := 9.5 \cdot \text{in}$
- Length, $l_{32} := 29.9 \cdot \text{in}$
- Weight, $W_{32} := 77 \cdot \text{lb}$

Proposed RRH Ericsson RRUS-12:

- Width, $w_{12} := 18.5 \text{in}$
- Depth, $t_{12} := 7.5 \text{in}$
- Height, $l_{12} := 20.4 \text{in}$
- Weight, $W_{12} := 50 \text{lb}$

Existing Antenna Properties:

- Width, $w_{ant} := 12 \cdot \text{in}$
- Depth, $t_{ant} := 6 \cdot \text{in}$
- Length, $l_{ant} := 72 \cdot \text{in}$
- Weight, $W_{ant} := 46 \cdot \text{lb}$

Proposed Surge Properties:

- Diameter, $w_{ss} := 9.7 \cdot \text{in}$
- Length, $l_{ss} := 24 \cdot \text{in}$
- Weight, $W_{ss} := 20 \cdot \text{lb}$

Weight of proposed AT&T equipment, $P_{att} := 6 \cdot (W_{pant}) + 6 \cdot W_{11} + 6 \cdot W_{12} + 3 \cdot W_{32} + 3 \cdot W_{ss}$
 $P_{att} = 1215 \text{ lb}$

Approximate weight of steel catwalk, $P_{cw} := 2000 \cdot \text{lb}$

Proposed AT&T equipment and
catwalk assembly:

Width, $w_{esf_12} := 13 \text{ ft}$

Height, $h_{esf_12} := 8 \cdot \text{ft}$

Weight, $W_{esf_12} := P_{att} + P_{cw}$
 $W_{esf_12} = 3215 \text{ lb}$

Existing flush-mount antennas:

Width, $w_{fm} := w_{ant} = 1 \text{ ft}$

Height, $h_{fm} := l_{ant} = 6 \text{ ft}$

Weight, $W_{fm} := 3 \cdot W_{ant} = 138 \text{ lb}$

Approx. weight of mounting brackets, cable ladders, and cables, $W_{appurt} := 3500 \cdot \text{lb}$

Average diameter of stack, $D_{ave} := \frac{D_{bo} + D_{to}}{2}$
 $D_{ave} = 8.67 \text{ ft}$

Wind load on stack, $WL_{chim} := H \cdot WL_{stack} \cdot D_{ave}$
 $WL_{chim} = 25831.56 \text{ lb}$

Wind load on AT&T installation, $WL_{esf_12} := h_{esf_12} \cdot W_{esf_12} \cdot WL_{ant}$
 $WL_{esf_12} = 2928.99 \text{ lb}$

Wind load on flush-mounted antennas, $WL_{fm} := 2h_{fm} \cdot w_{fm} \cdot WL_{ant}$
 $WL_{fm} = 337.96 \text{ lb}$

Centerline height of antenna arrays:

$$h_1 := 120 \cdot \text{ft} \quad (6 \text{ antennas on catwalk, AT\&T})$$

$$h_2 := 96 \cdot \text{ft} \quad (3 \text{ flush-mounted antennas})$$

Approximate moment at base level due to wind, $M_o := \frac{WL_{\text{chim}} \cdot H}{2} + WL_{\text{esf}_{12}} \cdot (h_1) + WL_{\text{fm}} \cdot (h_2)$

$$M_o = 2024.23 \cdot \text{ft} \cdot \text{kip}$$

Resisting moment due to self-weight of stack and equipment,

$$M_r := (W_{\text{stack}} + W_{\text{appurt}} + W_{\text{esf}_{12}} + W_{\text{fm}}) \cdot \frac{D_{\text{bo}}}{2}$$

$$M_r = 4030.06 \cdot \text{ft} \cdot \text{kip}$$

Factor of safety, $\frac{M_r}{M_o} = 1.99 > 1.5$ **O.K.**

Check stresses:

Section modulus of base of stack, $S := \frac{\pi \cdot D_{\text{bo}}^3}{32} - \frac{\pi \cdot D_{\text{bi}}^3}{32}$ MOI, $I := \frac{\pi \cdot (D_{\text{bo}}^4 - D_{\text{bi}}^4)}{64}$

$$S = 179042.8 \cdot \text{in}^3$$

$$I = 14130723.49 \cdot \text{in}^4$$

Area at base of chimney, $A_b := \left(\frac{\pi \cdot D_{\text{bo}}^2}{4} - \frac{\pi \cdot D_{\text{bi}}^2}{4} \right)$

$$A_b = 56.7 \cdot \text{ft}^2$$

Allowable compressive stress, $F_a := (.2 \cdot f'_m)$

$$F_a = 480 \cdot \text{psi}$$

Allowable tensile stress, $F_t = 7.5 \cdot \text{psi}$

(Pg. 264, Ref 1)

Bending stress, $f_b := \frac{M_o}{S}$

$$f_b = 135.67 \cdot \text{psi}$$

Allowable bending stress, $F_b := .33 \cdot f'_m \cdot \frac{1}{2}$

$F_b = 396 \cdot \text{psi}$

Maximum compressive stress, $f_a := \frac{W_{\text{stack}} + W_{\text{appurt}} + (W_{\text{esf}_{12}} + W_{\text{fm}})}{A_b}$


$f_a = 85.85 \cdot \text{psi} < F_a = 480 \cdot \text{psi} \quad \text{O.K.}$

UnityCheck := $\begin{cases} \text{"OK"} & \text{if } \frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1 \\ \text{"NG"} & \text{otherwise} \end{cases}$

UnityCheck = "OK"

Check Catwalk Framing:

Antennnas will be mounted to the top, mid, and bottom rail of the existing catwalk handrail assembly. Attachments will be made using industry-standard rail brackets.



Wind load on antenna, $P_{\text{ant}} := [I_{\text{pant}} \cdot W_{\text{pant}} + (W_{11} - W_{\text{pant}}) \cdot I_{11}] \cdot WL_{\text{ant}}$

$P_{\text{ant}} = 278.98 \text{ lb}$

Wind load on surge, $P_{\text{SS}} := I_{\text{SS}} \cdot W_{\text{SS}} \cdot WL_{\text{ant}} = 45.53 \text{ lb}$

Wind load per bracket, $P_{\text{brack}} := \frac{P_{\text{ant}}}{2} = 139.49 \text{ lb}$

Moment on pipe, $M := .226 \cdot \text{ft} \cdot \text{kip}$

Allowable moment, $M_{\text{allow}} := 1.245 \cdot \text{ft} \cdot \text{kip}$

(See attached Enercalc output)

MomentCheck := $\begin{cases} \text{"OK"} & \text{if } M \leq M_{\text{allow}} \\ \text{"NG"} & \text{otherwise} \end{cases}$

MomentCheck = "OK"

Check Rails:

Top rail governs

Moment on top rail, $M_{\text{rail}} := .585 \cdot \text{ft} \cdot \text{kip}$

Allowable moment, $M_{\text{allow}} := 1.176 \cdot \text{ft} \cdot \text{kip}$

(See attached
Enercalc output)

MomentCheck := $\begin{cases} \text{"OK"} & \text{if } M_{\text{rail}} \leq M_{\text{allow}} \\ \text{"NG"} & \text{otherwise} \end{cases}$

MomentCheck = "OK"

Check Verticals

Height of verticals, $H_v := 3 \cdot \text{ft}$

Moment on vertical, $M_{\text{vert}} := .858 \cdot \text{ft} \cdot \text{kip}$

Allowable moment, $M_{\text{allow}} := 1.27 \cdot \text{ft} \cdot \text{kip}$

(See attached
Enercalc output)

MomentCheck := $\begin{cases} \text{"OK"} & \text{if } M_{\text{vert}} \leq M_{\text{allow}} \\ \text{"NG"} & \text{otherwise} \end{cases}$

MomentCheck = "OK"

Conclusion:

Based on the results of the analysis, the existing 127' radial brick masonry smoke stack and steel cat walk assembly located at the above-referenced site is structurally capable of supporting the proposed AT&T equipment. The analysis was conducted in accordance with the Connecticut State Building Code (2016) and ASCE 7-10.

References:

1. Amrhein, J.E. (1978), *Reinforced Masonry Engineering Handbook*, Masonry Institute of America, Los Angeles, CA
2. American Society of Civil Engineers (2010), *Minimum Design Loads for Buildings and Other Structures (7-10)*, American Society of Civil Engineers, New York, NY
3. Connecticut State Building Code, 2016 Edition.



500 North Broadway
 East Providence, RI 02914
 (401) 354-2403

Project Title: **Smoke Stack Platform**
 Engineer: **MRC**
 Project Descr: **AT&T NSB**

Project ID: **CT3461**

Title Block Line 6

Printed: 18 JUL 2017, 3:19PM

Steel Beam

File = x:\ENER-P21\CT34-HXW.EC6
 ENERCALC, INC. 1983-2017, Build:6.17.3.29, Ver:6.17.3.29
 Licensee : **ADVANCED ENGINEERING GROUP, PC**

Lic. # : **KW-06008463**

Description : **Top Rail**

Load Combination	Segment Length	Span #	Max Stress Ratios		Summary of Moment Values						Summary of Shear Values			
			M	V	Mmax +	Mmax -	Ma Max	Mnx	Mnx/Omega	Cb	Rm	Va Max	VnxVnx/Omega	
Dsgn. L = 4.67 ft		1	0.298	0.024	0.35		0.35	1.96	1.18	1.12	1.00	0.23	16.20	9.70
+0.60D+0.70E+0.60H														
Dsgn. L = 4.67 ft		1		0.000			2.05	1.23	1.00	1.00		-0.00	16.20	9.70

Overall Maximum Deflections

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
W Only	1	0.0668	2.346		0.0000	0.000

Vertical Reactions

Support notation : Far left is #'

Values in KIPS

Load Combination	Support 1	Support 2
Overall MAXimum	0.390	0.390
Overall MINimum	0.175	0.176
+D+H		
+D+L+H		
+D+Lr+H		
+D+S+H		
+D+0.750Lr+0.750L+H		
+D+0.750L+0.750S+H		
+D+0.60W+H	0.234	0.234
+D+0.70E+H		
+D+0.750Lr+0.750L+0.450W+H	0.175	0.176
+D+0.750L+0.750S+0.450W+H	0.175	0.176
+D+0.750L+0.750S+0.5250E+H		
+0.60D+0.60W+0.60H	0.234	0.234
+0.60D+0.70E+0.60H		
D Only		
Lr Only		
L Only		
S Only		
W Only	0.390	0.390
E Only		
H Only		



500 North Broadway
 East Providence, RI 02914
 (401) 354-2403

Project Title: **Smoke Stack Platform**
 Engineer: **MRC**
 Project Descr: **AT&T NSB**

Project ID: **CT3461**

Title Block Line 6

Printed: 18 JUL 2017, 3:19PM

Steel Beam

File = x:\ENER-P21\CT34-HXW.EC6
 ENERCALC, INC. 1983-2017, Build:6.17.3.29, Ver:6.17.3.29

Lic. #: **KW-06008463**

Licensee: **ADVANCED ENGINEERING GROUP, PC**

Description: **Handrail Vertical**

Load Combination	Segment Length	Span #	Max Stress Ratios		Summary of Moment Values						Summary of Shear Values			
			M	V	Mmax +	Mmax -	Ma Max	Mnx	Mnx/Omega	Cb	Rm	Va Max	Vnx	Vnx/Omega
Dsgn. L = 3.00 ft		1	0.858	0.048		-1.05	1.05	2.05	1.23	1.00	1.00	0.47	16.20	9.70
+0.60D+0.70E+0.60H														
Dsgn. L = 3.00 ft		1		0.000				2.05	1.23	1.00	1.00	-0.00	16.20	9.70

Overall Maximum Deflections

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
W Only	1	0.2227	3.000		0.0000	0.000

Vertical Reactions

Support notation : Far left is #'

Values in KIPS

Load Combination	Support 1	Support 2
Overall MAXimum	0.780	
Overall MINimum	0.351	
+D+H		
+D+L+H		
+D+Lr+H		
+D+S+H		
+D+0.750Lr+0.750L+H		
+D+0.750L+0.750S+H		
+D+0.60W+H	0.468	
+D+0.70E+H		
+D+0.750Lr+0.750L+0.450W+H	0.351	
+D+0.750L+0.750S+0.450W+H	0.351	
+D+0.750L+0.750S+0.5250E+H		
+0.60D+0.60W+0.60H	0.468	
+0.60D+0.70E+0.60H		
D Only		
Lr Only		
L Only		
S Only		
W Only	0.780	
E Only		
H Only		



500 North Broadway
 East Providence, RI 02914
 (401) 354-2403

Project Title: **Smoke Stack Platform**
 Engineer: **MRC**
 Project Descr: **AT&T NSB**

Project ID: **CT3461**

Title Block Line 6

Printed: 18 JUL 2017, 3:19PM

Steel Beam

File = x:\ENER-P21\CT34-HXW.EC6
 ENERCALC, INC. 1983-2017, Build:6.17.3.29, Ver:6.17.3.29
 Licensee : **ADVANCED ENGINEERING GROUP, PC**

Lic. # : **KW-06008463**

Description : **Pipe Mount**

Load Combination	Segment Length	Span #	Max Stress Ratios		Summary of Moment Values						Summary of Shear Values			
			M	V	Mmax +	Mmax -	Ma Max	Mnx	Mnx/Omega	Cb	Rm	Va Max	Vnx	Vnx/Omega
Dsgn. L = 2.50 ft	1			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	2			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	3			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 2.50 ft	4			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
+D+0.750L+0.750S+H														
Dsgn. L = 2.50 ft	1			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	2			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	3			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 2.50 ft	4			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
+D+0.60W+H														
Dsgn. L = 2.50 ft	1		0.109	0.020		-0.14	0.14	2.08	1.25	1.00	1.00	0.12	10.50	6.29
Dsgn. L = 1.50 ft	2		0.109	0.020	0.05	-0.14	0.14	2.08	1.25	2.14	1.00	0.12	10.50	6.29
Dsgn. L = 1.50 ft	3		0.047	0.012	0.05	-0.06	0.06	2.08	1.25	2.22	1.00	0.08	10.50	6.29
Dsgn. L = 2.50 ft	4		0.047	0.012		-0.06	0.06	2.08	1.25	1.00	1.00	0.08	10.50	6.29
+D+0.70E+H														
Dsgn. L = 2.50 ft	1			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	2			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	3			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 2.50 ft	4			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
+D+0.750Lr+0.750L+0.450W+H														
Dsgn. L = 2.50 ft	1		0.082	0.015		-0.10	0.10	2.08	1.25	1.00	1.00	0.09	10.50	6.29
Dsgn. L = 1.50 ft	2		0.082	0.015	0.04	-0.10	0.10	2.08	1.25	2.14	1.00	0.09	10.50	6.29
Dsgn. L = 1.50 ft	3		0.035	0.009	0.04	-0.04	0.04	2.08	1.25	2.22	1.00	0.06	10.50	6.29
Dsgn. L = 2.50 ft	4		0.035	0.009		-0.04	0.04	2.08	1.25	1.00	1.00	0.06	10.50	6.29
+D+0.750L+0.750S+0.450W+H														
Dsgn. L = 2.50 ft	1		0.082	0.015		-0.10	0.10	2.08	1.25	1.00	1.00	0.09	10.50	6.29
Dsgn. L = 1.50 ft	2		0.082	0.015	0.04	-0.10	0.10	2.08	1.25	2.14	1.00	0.09	10.50	6.29
Dsgn. L = 1.50 ft	3		0.035	0.009	0.04	-0.04	0.04	2.08	1.25	2.22	1.00	0.06	10.50	6.29
Dsgn. L = 2.50 ft	4		0.035	0.009		-0.04	0.04	2.08	1.25	1.00	1.00	0.06	10.50	6.29
+D+0.750L+0.750S+0.5250E+H														
Dsgn. L = 2.50 ft	1			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	2			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	3			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 2.50 ft	4			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
+0.60D+0.60W+0.60H														
Dsgn. L = 2.50 ft	1		0.109	0.020		-0.14	0.14	2.08	1.25	1.00	1.00	0.12	10.50	6.29
Dsgn. L = 1.50 ft	2		0.109	0.020	0.05	-0.14	0.14	2.08	1.25	2.14	1.00	0.12	10.50	6.29
Dsgn. L = 1.50 ft	3		0.047	0.012	0.05	-0.06	0.06	2.08	1.25	2.22	1.00	0.08	10.50	6.29
Dsgn. L = 2.50 ft	4		0.047	0.012		-0.06	0.06	2.08	1.25	1.00	1.00	0.08	10.50	6.29
+0.60D+0.70E+0.60H														
Dsgn. L = 2.50 ft	1			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	2			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 1.50 ft	3			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29
Dsgn. L = 2.50 ft	4			0.000				2.08	1.25	1.00	1.00	-0.00	10.50	6.29

Overall Maximum Deflections

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
W Only	1	0.0551	0.000		0.0000	0.000
	2	0.0000	0.000	W Only	-0.0022	0.550
W Only	3	0.0002	0.250	W Only	-0.0005	1.120
W Only	4	0.0146	2.500		0.0000	1.120

Vertical Reactions

Load Combination	Support notation : Far left is #'					Values in KIPS
	Support 1	Support 2	Support 3	Support 4	Support 5	
Overall MAXimum		0.390	-0.324	0.249		
Overall MINimum		0.175	-0.146	0.112		
+D+H						
+D+L+H						
+D+Lr+H						
+D+S+H						
+D+0.750Lr+0.750L+H						
+D+0.750L+0.750S+H						
+D+0.60W+H		0.234	-0.194	0.149		
+D+0.70E+H						
+D+0.750Lr+0.750L+0.450W+H		0.175	-0.146	0.112		
+D+0.750L+0.750S+0.450W+H		0.175	-0.146	0.112		
+D+0.750L+0.750S+0.5250E+H						
+0.60D+0.60W+0.60H		0.234	-0.194	0.149		



500 North Broadway
 East Providence, RI 02914
 (401) 354-2403

Project Title: **Smoke Stack Platform**
 Engineer: **MRC**
 Project Descr: **AT&T NSB**

Project ID: **CT3461**

Title Block Line 6

Printed: 18 JUL 2017, 3:19PM

Steel Beam

File = x:\ENER~P21\CT34~HXW.EC6
 ENERCALC, INC. 1983-2017, Build:6.17.3.29, Ver:6.17.3.29
 Licensee : **ADVANCED ENGINEERING GROUP, PC**

Lic. # : **KW-06008463**

Description : **Pipe Mount**

Load Combination	Support notation : Far left is #'					Values in KIPS
	Support 1	Support 2	Support 3	Support 4	Support 5	
+0.60D+0.70E+0.60H						
D Only						
Lr Only						
L Only						
S Only						
W Only		0.390	-0.324	0.249		
E Only						
H Only						