

December 18, 2019

Melanie A. Bachman, Esq.
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **Notice of Exempt Modification – Facility Modification
225 North Main Street (a/k/a 32 Valley Street), Bristol, Connecticut**

Dear Attorney Bachman:

Cellco Partnership d/b/a Verizon Wireless (“Cellco”) currently maintains a wireless telecommunications facility at 225 North Main Street in Bristol, Connecticut (the “Property”). The facility consists of twelve (12) antennas (six (6) at the 98-foot level and six (6) at the 108-foot level) on an existing roof-top tower, associated equipment located in a 28’-6” x 28’-4” equipment room on the roof of the existing building and a 60 kW generator, located on the roof adjacent to the tower. The tower and Property are owned by Carpenter Realty. The Council approved the establishment of Cellco’s facility in July of 1992. A copy of the Siting Council’s approval letter is included in Attachment 1.

Cellco now intends to modify the existing facility by installing a Centralized Radio Access Network (“C-RAN”) at the Property. The purpose of a C-RAN is to allow several existing cell sites in a particular geographic area (traditional macro cell sites and small cells), to connect to a centralized hub. By doing so, Cellco can deploy less cell site hardware at each individual facility location, giving it more flexibility in the selection of new cell site locations. This approach also allows Cellco to realize some cost savings by not having to deploy fiber connections, for example, from each individual cell site location back to the mobile telephone switching office (MTSO). C-RAN facilities can be established at existing cell sites, as in this instance, or at other locations not currently used for telecommunications purposes.

Robinson+Cole

Melanie A. Bachman, Esq.

December 18, 2019

Page 2

Cellco's proposed C-RAN equipment will be installed inside an expanded equipment room on the roof. Cellco also intends to replace the 60 kW generator with a 100 kW generator in the same location on the roof. Plans showing the C-RAN Facility modifications and the specifications for the 100 kW generator are included in Attachment 2.

Please accept this letter as notification pursuant to R.C.S.A. § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to Bristol's Mayor, Ellen Zoppo-Sassu; Robert Flanagan, Bristol's City Planner; and Carpenter Realty, the owner of the Property and tower.

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).

1. The proposed modifications will not result in an increase in the height of the existing tower.
2. The proposed modifications will not require the extension of the site boundary. All improvements will be located on the roof of the building and will remain within the limits of the Property.
3. The operation of the modified facility will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The proposed facility modifications will not change, in any way, radio frequency (RF) emissions at the facility.
5. The proposed facility modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The building can support the proposed facility modifications. *See* Structural Design Calculations included in Attachment 3.


A copy of the parcel map and owner information for the Property is included in Attachment 4. A Certificate of Mailing verifying that this filing was sent to municipal officials and the owner of the Property is included in Attachment 5.

Robinson+Cole

Melanie A. Bachman, Esq.
December 18, 2019
Page 3

For the foregoing reasons, Cellco respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitutes an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,



Kenneth C. Baldwin

Enclosures

Copy to:

Ellen Zoppo-Sassu, Mayor
Robert Flanagan, City Planner
Carpenter Realty
Steve McGovern

ATTACHMENT 1



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

136 Main Street, Suite 401
New Britain, Connecticut 06051
Phone: 827-7682

July 16, 1992

David S. Malko
Manager, Engineering and
Regulatory Service
Bell Atlantic Metro Mobile
20 Alexander Drive
P.O. Box 5029
Wallingford, CT 06492

RE; Bell Atlantic Metro Mobile notice of intent to modify an existing tower structure on top of an existing building at 32 Valley Street Street, Bristol, Connecticut.

Dear Mr. Malko:

At a public meeting held on July 15, 1992, the Connecticut Siting Council (Council) ruled that the proposed facility would not cause a significant change or alteration in the physical and environmental characteristics of the site by the placement of six cellular antennas on an existing non-facility 30-foot high tower structure, and acknowledged your notice of intent to modify this existing non-facility tower and associated equipment located on the roof of an existing building at 32 Valley Street, Bristol, Connecticut, pursuant to section 16-50j-73 of the Regulations of State Agencies (RSA).


The proposed modifications are to be implemented as specified in your notice dated June 26, 1992. As proposed, the modifications are in compliance with the exemption criteria specified in RSA 16-50j-72 as changes to an existing non-facility site that do not increase the tower height, do not extend the boundaries of the tower site, do not increase noise levels at the tower site boundary by six decibels or more, do not add radio frequency sending or receiving capability which increases total frequency electromagnetic radiation power density measured at the tower site boundary to or above the standard adopted by the State of Connecticut, Department of Environmental Protection pursuant to section 22a-162 of the Connecticut General Statutes, and has received all municipal zoning approvals and building permits.

David S. Malko
July 16, 1992
Page 2

The Council is pleased to note that the use of an existing tower serves the Council's long-term goal of protecting the public interest by avoiding proliferation of additional tower structures.

Please notify the Council upon completion of construction.

Very truly yours,

A handwritten signature in cursive script that reads "Mortimer A. Gelston" followed by a stylized monogram or initials "MAG".

Mortimer A. Gelston
Chairman

MAG/TEF/cp

cc: William T. Stortz, Mayor, City of Bristol

6248E

ATTACHMENT 2

BRISTOL CT CRAN 225 NORTH MAIN STREET BRISTOL, CT 06011

DRAWING INDEX

- LE-1 TITLE SHEET**
- LE-2 PARTIAL ROOF PLAN**
- LE-3 EQUIPMENT ROOM PLAN & EXTERIOR ROOM ELEVATION**
- LE-4 EXTERIOR EQUIPMENT ROOM ELEVATION**

SITE INFORMATION

SITE NAME: BRISTOL CT CRAN
 VERIZON FUZE PROJECT NO.: 2463647
 VERIZON LOCATION CODE: 467663
 VERIZON PROJECT CODE: 20171648057
 SITE ADDRESS: 225 NORTH MAIN STREET,
 BRISTOL, CT 06011

LATITUDE: 41° 40' 35.2259" N (41.6764516° N)
 LONGITUDE: 72° 56' 51.6828" W (72.9476897° W)
 GROUND ELEVATION: 318.6± AMSL
 TOP OF HIGHEST APPURTENANCE: 95.2.0± AGL (413.8± AMSL)
 (ASSOCIATED W/ CRAN FACILITY)
 HEIGHT OF SUPPORT STRUCTURE: 80.7± AGL (399.3± AMSL)
 HEIGHT OF GPS ANTENNAS: 95.2.0± AGL (413.8± AMSL)
 MAP/BLOCK/LOT: 26-----21B

OWNER/LANDLORD: CARPENTER REALTY COMPANY
 CONTACT: P.O. BOX 176
 BRISTOL, CT 06011

APPLICANT: CELCO PARTNERSHIP
 d/b/a VERIZON WIRELESS

SITE TYPE/DESCRIPTION: EXIST. 18'-8"±x28'-6"± (562± SF) EQUIPMENT ROOM W/
 PROP. 9'-2"±x29'-8"± (272± SF) EXPANSION TO
 ACCOMMODATE PROP. LESSEE HUB EQUIPMENT
 FACILITY LOCATED ON 5TH FLOOR (PENTHOUSE) LEVEL
 OF EXIST. BUILDING. IN ADDITION TO THE REPLACEMENT
 OF AN EXIST. LESSEE 60kW NATURAL GAS POWERED
 EMERGENCY STANDBY POWER GENERATOR W/ PROP.
 100kW NATURAL GAS FIRED EMERGENCY STANDBY
 POWER GENERATOR MOUNTED ON EXIST. STEEL
 DUNNAGE FRAME ATOP EXIST. BUILDING ROOF.

CONTACT INFORMATION

VERIZON REAL ESTATE CONSULTANT: STEPHEN McGOVERN
 (617) 913-4849

VERIZON CONSTRUCTION MANAGER: JOHN P. ROMANO
 (203) 858-5500

ENGINEER CONTACT: JASON R. MEAD
 (860) 663-1697 x212

NOTE:
 LATITUDE, LONGITUDE & GROUND
 ELEVATION TAKEN FROM FAA-2C
 SURVEY PREPARED BY MARTIN
 SURVEYING ASSOCIATES LLC,
 DATED MAY 18, 2018.

ABBREVIATION LIST:
 AGL = ABOVE GROUND LEVEL;
 AMSL = ABOVE MEAN SEA LEVEL;
 ARL = ABOVE ROOF LEVEL;
 BCLC = BIT, CONC. LIPPED CURB



LOCATION MAP


SCALE: 1" = 500'



(IN FEET) 1 inch = 500ft.

REVISIONS:

- REV0: 07/11/17: FOR REVIEW: JRM
- REV1: 06/11/18: REVISED PER REGULATORY COMMENTS: JRM
- REV2: 08/01/18: REVISED PER VZW COMMENTS: JRM
- REV3: 08/07/18: REVISED PER VZW COMMENTS: JRM
- REV4: 12/16/19: REVISED PER VZW COMMENTS: JRM




SHEET NUMBER:
LE-1

BRISTOL CT CRAN
 225 NORTH MAIN STREET
 BRISTOL, CT 06011
 VZW PROJECT CODE: 20171648057 LC: 467663 CM: JR
 VZW FUZE ID: 2463647

APT FILING NUMBER: CT141CRAN8900
TITLE SHEET
 DATE OF DV: 02/22/17 DRAWN BY: THK
 DATE: 07/11/17 CHECKED BY: JRM






NOTES:

- LEASE EXHIBIT DRAWINGS ARE DIAGRAMMATIC IN NATURE AND CONVEY GENERAL INFORMATION PERTAINING TO THE SIZE AND LOCATION OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. FINAL SITE LAYOUT AND FACILITY DESIGN WILL BE CONTINGENT UPON COMPLETION OF A STRUCTURAL VERIFICATION OF THE HOST SUPPORT STRUCTURE AND A SITE SURVEY (WHERE APPLICABLE).
- PROPOSED UTILITY ROUTING SHOWN IS PRELIMINARY. FINAL UTILITY ROUTING TO BE DETERMINED DURING CONSTRUCTION DOCUMENT PHASE OF THE PROJECT AND WILL BE COORDINATED WITH BUILDING OWNER AND LOCAL UTILITY COMPANY REQUIREMENTS.

SITE INFORMATION:
 LAT. 41° 40' 35.2259" N (41.6764516° N)
 LONG. 72° 56' 51.6828" W (72.9476897° W)
 GRADE EL. 318.6± AMSL



1 PARTIAL ROOF PLAN
 LE-2 SCALE: 1/16" = 1'-0"



REVISIONS:

- REV0: 07/11/17: FOR REVIEW: JRM
- REV1: 08/11/18: REVISED PER REGULATORY COMMENTS: JRM
- REV2: 08/01/18: REVISED PER VZW COMMENTS: JRM
- REV3: 08/07/18: REVISED PER VZW COMMENTS: JRM
- REV4: 12/16/19: REVISED PER VZW COMMENTS: JRM



SHEET NUMBER:
LE-2

BRISTOL CT CRAN
 225 NORTH MAIN STREET
 BRISTOL, CT 06011

VZW VZW VZW
 PROJECT CODE: 20171648057 LC: 467663 CM: JR
 VZW FUZE ID: 2463647

APT FILING NUMBER: CT141CRAN8900


PARTIAL ROOF PLAN

DATE OF DV: 02/22/17 DRAWN BY: THK
 DATE: 07/11/17 CHECKED BY: JRM




NOTES:

- LEASE EXHIBIT DRAWINGS ARE DIAGRAMMATIC IN NATURE AND CONVEY GENERAL INFORMATION PERTAINING TO THE SIZE AND LOCATION OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. FINAL SITE LAYOUT AND FACILITY DESIGN WILL BE CONTINGENT UPON COMPLETION OF A STRUCTURAL VERIFICATION OF THE HOST SUPPORT STRUCTURE AND A SITE SURVEY (WHERE APPLICABLE).
- PROPOSED UTILITY ROUTING SHOWN IS PRELIMINARY. FINAL UTILITY ROUTING TO BE DETERMINED DURING CONSTRUCTION DOCUMENT PHASE OF THE PROJECT AND WILL BE COORDINATED WITH BUILDING OWNER AND LOCAL UTILITY COMPANY REQUIREMENTS.



1 EQUIPMENT ROOM PLAN
 LE-3 SCALE: 1/8" = 1'-0"



2 EXTERIOR EQUIPMENT ROOM ELEVATION
 LE-3 SCALE: 1/8" = 1'-0"

- REVISIONS:**
- REV0: 07/11/17: FOR REVIEW: JRM
 - REV1: 06/11/18: REVISED PER REGULATORY COMMENTS: JRM
 - REV2: 08/01/18: REVISED PER VZW COMMENTS: JRM
 - REV3: 08/07/18: REVISED PER VZW COMMENTS: JRM
 - REV4: 12/16/19: REVISED PER VZW COMMENTS: JRM

ALL-POINTS TECHNOLOGY CORPORATION
 PHONE: (860) 463-1697
 KILLINGWORTH, CT 06419
 FAX: (860) 463-0935
 WWW.ALLPOINTS-TECH.COM

SHEET NUMBER: LE-3

BRISTOL CT CRAN
 225 NORTH MAIN STREET
 BRISTOL, CT 06011


VZW VZW VZW
 PROJECT CODE: 20171648057 LC: 467663 CM: JR
 VZW FUZE ID: 2463647

APT FILING NUMBER: CT141CRAN8900
EQUIPMENT ROOM PLAN & EXTERIOR ROOM ELEVATION
 DRAWN BY: THK
 CHECKED BY: JRM
 DATE OF DV: 02/22/17
 DATE: 07/11/17

Cellco Partnership d/b/a

NOTES:

- LEASE EXHIBIT DRAWINGS ARE DIAGRAMMATIC IN NATURE AND CONVEY GENERAL INFORMATION PERTAINING TO THE SIZE AND LOCATION OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. FINAL SITE LAYOUT AND FACILITY DESIGN WILL BE CONTINGENT UPON COMPLETION OF A STRUCTURAL VERIFICATION OF THE HOST SUPPORT STRUCTURE AND A SITE SURVEY (WHERE APPLICABLE).
- PROPOSED UTILITY ROUTING SHOWN IS PRELIMINARY. FINAL UTILITY ROUTING TO BE DETERMINED DURING CONSTRUCTION DOCUMENT PHASE OF THE PROJECT AND WILL BE COORDINATED WITH BUILDING OWNER AND LOCAL UTILITY COMPANY REQUIREMENTS.



1 EXTERIOR EQUIPMENT ROOM ELEVATION
 LE-4 SCALE: 1/8" = 1'-0"

REVISIONS:

- REV0: 07/11/17: FOR REVIEW: JRM
- REV1: 06/11/18: REVISED PER REGULATORY COMMENTS: JRM
- REV2: 08/01/18: REVISED PER VZW COMMENTS: JRM
- REV3: 08/07/18: REVISED PER VZW COMMENTS: JRM
- REV4: 12/16/19: REVISED PER VZW COMMENTS: JRM

SG100 | 9.0L | 100 kW
INDUSTRIAL SPARK-IGNITED GENERATOR SET
 EPA Certified Stationary Emergency

DEMAND RESPONSE READY

Standby Power Rating
 100 kW, 125 kVA, 60 Hz

Prime Power Rating
 90 kW, 113 kVA, 60 Hz




Image used for illustration purposes only



*EPA Certified Prime ratings are not available in the US or its Territories

Codes and Standards

Generac products are designed to the following standards:

-   UL2200, UL508, UL489
-  CSA 22.2
-   BS5514 and DIN 6271
-  SAE J1349
-  NFPA 37, 70, 99, 110
-  NEC700, 701, 702, 708
-  ISO 3046, 7637, 8528, 9001
-  NEMA ICS10, MG1, 250, ICS6, AB1
-  ANSI C62.41
-   IBC 2009, CBC 2010, IBC 2012, ASCE 7-05, ASCE 7-10, ICC-ES AC-156 (2012)

Powering Ahead

Generac ensures superior quality by designing and manufacturing most of its generator components, such as alternators, enclosures, control systems and communications software. Generac also makes its own spark-ignited engines, and you'll find them on every Generac gaseous-fueled generator. We engineer and manufacture them from the block up — all at our facilities throughout Wisconsin. Applying natural gas and LP-fueled engines to generators requires advanced engineering expertise to ensure reliability, durability and necessary performance. By designing specifically for these dry, hotter-burning fuels, the engines last longer and require less maintenance. Building our own engines also means we control every step of the supply chain and delivery process, so you benefit from single-source responsibility.

Plus, Generac Industrial Power's distribution network provides all parts and service so you don't have to deal with third-party suppliers. It all leads to a positive owner experience and higher confidence level. Generac spark-ignited engines give you more options in commercial and industrial generator applications as well as extended run time from utility-supplied natural gas.

SG100 | 9.0L | 100 kW INDUSTRIAL SPARK-IGNITED GENERATOR SET

EPA Certified Stationary Emergency

STANDARD FEATURES

DEMAND RESPONSE READY

ENGINE SYSTEM

- Oil Drain Extension
- Air Cleaner
- Fan Guard
- Stainless Steel Flexible Exhaust Connection
- Factory Filled Oil and Coolant
- Radiator Duct Adapter (Open Set Only)
- Critical Exhaust Silencer

Fuel System

- Fuel Line - NPT Connection
- Primary and Secondary Fuel Shutoff

Cooling System

- Closed Coolant Recovery System
- UV/Ozone Resistant Hoses
- Factory-Installed Radiator
- 50/50 Ethylene Glycol Antifreeze
- Radiator Drain Extension

Electrical System

- Battery Charging Alternator
- Battery Cables
- Battery Tray
- Rubber-Booted Engine Electrical Connections
- Solenoid Activated Starter Motor

ALTERNATOR SYSTEM

- GENprotect™
- Class H Insulation Material
- 2/3 Pitch
- Skewed Stator
- Brushless Excitation
- Sealed Bearing
- Amortisseur Winding
- Full Load Capacity Alternator

GENERATOR SET

- Internal Genset Vibration Isolation
- Separation of Circuits - High/Low Voltage
- Separation of Circuits - Multiple Breakers
- Wrapped Exhaust Piping
- Standard Factory Testing
- 2 Year Limited Warranty (Standby Rated Units)
- 1 Year Warranty (Prime Rated Units)
- Silencer Mounted in the Discharge Hood (Enclosed Only)

ENCLOSURE (If Selected)

- Rust-Proof Fasteners with Nylon Washers to Protect Finish
- High Performance Sound-Absorbing Material (Sound Attenuation Enclosures)
- Gasketed Doors
- Stamped Air-Intake Louvers
- Upward Facing Discharge Hoods (Radiator and Exhaust)
- Stainless Steel Lift Off Door Hinges
- Stainless Steel Lockable Handles
- RhinoCoat™ - Textured Polyester Powder Coat Paint

CONTROL SYSTEM



Digital H Control Panel- Dual 4x20 Display

Program Functions

- Programmable Crank Limiter
- 7-Day Programmable Exerciser
- Special Applications Programmable Logic Controller
- RS-232/485 Communications
- 3-Phase Sensing Digital Voltage Regulator
- 2-Wire Start Capability
- Date/Time Fault History (Event Log)
- Isochronous Governor Control
- Waterproof/Sealed Connectors
- Audible Alarms and Shutdowns
- Not in Auto (Flashing Light)

- Auto/Off/Manual Switch
- E-Stop (Red Mushroom-Type)
- NFPA110 Level I and II (Programmable)
- Customizable Alarms, Warnings, and Events
- Modbus® Protocol
- Predictive Maintenance Algorithm
- Sealed Boards
- Password Parameter Adjustment Protection
- Single Point Ground
- 16 Channel Remote Trending
- 0.2 msec High Speed Remote Trending
- Alarm Information Automatically Annunciated on the Display

Full System Status Display

- Power Output (kW)
- Power Factor
- kW Hours, Total, and Last Run
- Real/Reactive/Apparent Power
- All Phase AC Voltage
- All Phase Currents
- Oil Pressure
- Coolant Temperature
- Coolant Level

- Engine Speed
- Battery Voltage
- Frequency

Alarms and Warnings

- Oil Pressure
- Coolant Temperature
- Coolant Level
- Low Fuel Pressure Alarm
- Engine Overspeed
- Battery Voltage
- Alarms and Warnings Time and Date Stamped
- Snap Shots of Key Operation Parameters During Alarms and Warnings
- Alarms and Warnings Spelled Out (No Alarm Codes)

SG100 | 9.0L | 100 kW

INDUSTRIAL SPARK-IGNITED GENERATOR SET

EPA Certified Stationary Emergency

CONFIGURABLE OPTIONS

DEMAND RESPONSE READY

ENGINE SYSTEM

- Engine Block Heater
- Oil Heater
- Air Filter Restriction Indicator
- Stone Guard (Open Set Only)

ELECTRICAL SYSTEM

- 2.5A UL Battery Charger
- 10A UL Battery Charger
- Battery Warmer

ALTERNATOR SYSTEM

- Alternator Upsizing
- Anti-Condensation Heater
- Tropical Coating
- Permanent Magnet Excitation

CIRCUIT BREAKER OPTIONS

- Main Line Circuit Breaker
- 2nd Main Line Circuit Breaker
- Shunt Trip and Auxiliary Contact
- Electronic Trip Breakers

GENERATOR SET

- GenLink® Communications Software (English Only)
- Extended Factory Testing (3-Phase Only)
- 8 Position Load Center
- IBC Seismic Certification

ENCLOSURE

- Standard Enclosure
- Level 1 Sound Attenuation
- Level 2 Sound Attenuation
- Level 2 Sound Attenuation with Motorized Dampers
- Steel Enclosure
- Aluminum Enclosure
- AC/DC Enclosure Lighting Kit
- Door Alarm Switch

CONTROL SYSTEM

- NFPA 110 Compliant 21-Light Remote Annunciator
- Remote Relay Assembly (8 or 16)
- Oil Temperature Indicator with Alarm
- Remote E-Stop (Break Glass-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Flush Mount)
- Remote Communication - Modem
- 10A Run Relay
- Ground Fault Indication and Protection Functions
- Damper Kit Auxiliary Contacts

WARRANTY (Standby Gensets Only)

- 2 Year Extended Limited Warranty
- 5 Year Limited Warranty
- 5 Year Extended Limited Warranty
- 7 Year Extended Limited Warranty
- 10 Year Extended Limited Warranty

ENGINEERED OPTIONS

ENGINE SYSTEM

- Coolant Heater Ball Valves
- Fluid Containment Pan

ALTERNATOR SYSTEM

- 3rd Breaker System

CONTROL SYSTEM

- Spare Inputs (x4) / Outputs (x4)
- Battery Disconnect Switch

GENERATOR SET

- Special Testing
- Battery Box

ENCLOSURE

- Enclosure Ambient Heaters
- Up to 200 MPH Wind Load Rating*

*Consult factory for availability

SG100 | 9.0L | 100 kW INDUSTRIAL SPARK-IGNITED GENERATOR SET

EPA Certified Stationary Emergency



APPLICATION AND ENGINEERING DATA

DEMAND RESPONSE READY

ENGINE SPECIFICATIONS

General

Make	Generac	
Cylinder #	8	
Type	V	
Displacement - Cu In (L)	540 (8.9)	
Bore - in (mm)	4.49 (114.23)	
Stroke - in (mm)	4.25 (107.15)	
Compression Ratio	10.5:1 - G18	9.9:1 - G26
Intake Air Method	Naturally Aspirated	
Number of Main Bearings	5	
Connecting Rods	Forged Steel	
Cylinder Head	Cast Iron	
Cylinder Liners	No	
Ignition	High Energy	
Piston Type	Aluminum Alloy	
Crankshaft Type	Forged Steel	
Lifter Type	Hydraulic Roller	
Intake Valve Material	Steel Alloy	
Exhaust Valve Material	Stainless Steel	
Hardened Valve Seats	Yes	

Engine Governing

Governor	Electronic
Frequency Regulation (Steady State)	±0.25%

Lubrication System

Oil Pump Type	Gear	
Oil Filter Type	Full-Flow Spin-On Cartridge	
Crankcase Capacity - qts (L)	8.0 (8.5) - G18	10.5 (9.9) w/ Filter - G26

Cooling System

Cooling System Type	Pressurized Closed Recovery	
Fan Type	Pusher	
Fan Speed (rpm)	2,330 - G18	2,385 - G26
Fan Diameter - in (mm)	22 (558)	

Fuel System

Fuel Type	Natural Gas, Propane Vapor	
Carburetor	Down Draft	
Secondary Fuel Regulator	Standard	
Fuel Shut Off Solenoid	Standard	
Operating Fuel Pressure in H ₂ O	11 - 14	
Optional Operating Fuel Pressure in H ₂ O	7 - 11	

Engine Electrical System

System Voltage	12 VDC	
Battery Charger Alternator	Standard	
Battery Size	See Battery Index 10000016949	
Battery Voltage	12 VDC	
Ground Polarity	Negative	

NOTE: G18 is all engines manufactured before October 12, 2017. G26 is all engines manufactured after October 12, 2017.

ALTERNATOR SPECIFICATIONS

Standard Model	Generac 390 mm
Poles	4
Field Type	Revolving
Insulation Class - Rotor	H
Insulation Class - Stator	H
Total Harmonic Distortion	<5% (3-Phase)
Telephone Interference Factor (TIF)	<50

Standard Excitation	Synchronous Brushless
Bearings	Sealed Ball
Coupling	Direct Drive
Prototype Short Circuit Test	Yes
Voltage Regulator Type	Full Digital
Number of Sensed Phases	All
Regulation Accuracy (Steady State)	±0.5%

SG100 | 9.0L | 100 kW
INDUSTRIAL SPARK-IGNITED GENERATOR SET
 EPA Certified Stationary Emergency



OPERATING DATA

DEMAND RESPONSE READY

POWER RATINGS - NATURAL GAS/PROPANE VAPOR

	Standby/Demand Response	
Single-Phase 120/240 VAC @1.0pf	100 kW	Amps: 417
Three-Phase 120/208 VAC @0.8pf	100 kW	Amps: 347
Three-Phase 120/240 VAC @0.8pf	100 kW	Amps: 301
Three-Phase 277/480 VAC @0.8pf	100 kW	Amps: 150
Three-Phase 346/600 VAC @0.8pf	100 kW	Amps: 120

STARTING CAPABILITIES (sKVA)

sKVA vs. Voltage Dip

277/480 VAC								208/240 VAC							
Alternator	kW	10%	15%	20%	25%	30%	35%	Alternator	kW	10%	15%	20%	25%	30%	35%
Standard	100	79	118	157	197	236	275	Standard	100	59	89	118	148	177	206
Upsize 1	130	116	174	232	290	348	406	Upsize 1	130	87	131	174	218	261	305

FUEL CONSUMPTION RATES*

Natural Gas – ft ³ /hr (m ³ /hr)		Propane Vapor – ft ³ /hr (m ³ /hr)	
Percent Load	Standby	Percent Load	Standby
25%	494.0 (14.1)	25%	192.1 (5.4)
50%	759.6 (21.5)	50%	290.3 (8.2)
75%	1,011.1 (28.6)	75%	392.6 (11.1)
100%	1,261.4 (35.7)	100%	485.7 (13.8)

* Fuel supply installation must accommodate fuel consumption rates at 100% load.

COOLING

		Standby
Coolant System Capacity	gal (L)	6.0 (22.7)
Coolant Flow	gal/min (L/min)	27.5 (104)
Heat Rejection to Coolant	BTU/hr (kW)	390,000 (114.3)
Inlet Air	cfm (m ³ /hr)	5,797 (164.2)
Maximum Operating Ambient Temperature	°F (°C)	122 (50)
Maximum Operating Ambient Temperature (Before Derate)	See Bulletin No. 0199270SSD	
Maximum Radiator Backpressure	in H ₂ O (kPa)	0.5 (0.12)

COMBUSTION AIR REQUIREMENTS

	Standby
Flow at Rated Power cfm (m ³ /min)	282 (7.9)

ENGINE

EXHAUST

		Standby			Standby
Rated Engine Speed	rpm	1,800	Exhaust Flow (Rated Output)	cfm (m ³ /min)	866 (24.5)
Horsepower at Rated kW**	hp	149	Maximum Exhaust Backpressure	inHg (kPa)	1.5 (5.1)
Piston Speed	ft/min (m/min)	1,273 (388.2)	Exhaust Temp (Rated Output - Post Catalyst)	°F (°C)	1,200 (649)
BMEP	psi	125			



** Refer to "Emissions Data Sheet" for maximum bHP for EPA and SCAQMD permitting purposes.

Deration – Operational characteristics consider maximum ambient conditions. Derate factors may apply under atypical site conditions.
 Please consult a Generac Power Systems Industrial Dealer for additional details. All performance ratings in accordance with ISO3046, BS5514, ISO8528, and DIN6271 standards.
 Standby - See Bulletin 0187500SSB
 Demand Response - See Bulletin 10000018250.

SG100 | 9.0L | 100 kW
INDUSTRIAL SPARK-IGNITED GENERATOR SET
 EPA Certified Stationary Emergency



DIMENSIONS AND WEIGHTS*

DEMAND RESPONSE READY





OPEN SET (Includes Exhaust Flex)

L x W x H in (mm)	94.2 (2,394) x 40.0 (1,016) x 47.5 (1,206)
Weight lbs (kg)	2,064 (936.2)





STANDARD ENCLOSURE

L x W x H in (mm)	111.8 (2,840) x 40.5 (1,027.8) x 56.2 (1,427)
Weight lbs (kg)	Steel: 2,708 (1,228) Aluminum: 2,413 (1,094)



LEVEL 1 ACOUSTIC ENCLOSURE

L x W x H in (mm)	129.4 (3,287) x 40.5 (1,028) x 56.2 (1,427)
Weight lbs (kg)	Steel: 2,798 (1,269.2) Aluminum: 2,355 (1,068)



LEVEL 2 ACOUSTIC ENCLOSURE

L x W x H in (mm)	111.8 (2,840) x 40.5 (1,028) x 68.6 (1,743)
Weight lbs (kg)	Steel: 3,022 (1,370.8) Aluminum: 2,431 (1,103)

* All measurements are approximate and for estimation purposes only.

YOUR FACTORY RECOGNIZED GENERAC INDUSTRIAL DEALER

Specification characteristics may change without notice. Please consult a Generac Power Systems Industrial Dealer for detailed installation drawings.

ATTACHMENT 3

**BRISTOL CT CRAN
225 NORTH MAIN STREET
BRISTOL, CT 06011**

**STRUCTURAL DESIGN
CALCULATIONS**

FOR

**VERIZON WIRELESS
20 ALEXANDER DRIVE
WALLINGFORD, CT 06492**

MARCH 14, 2019

PREPARED BY

TECTONIC
ENGINEERING & SURVEYING CONSULTANTS P.C.
1279 ROUTE 300
NEWBURGH, NY 12550

W.O. 8814.27

**W.O. 8814.27
BRISTOL CT CRAN
225 NORTH MAIN STREET
BRISTOL, CT 06011
STRUCTURAL DESIGN CALCULATIONS
LEAD SHEET**

PURPOSE

Analyze the existing building structure and rooftop platform for the proposed Verizon Wireless CRAN installation.

REFERENCES

1. 2018 Connecticut State Building Code Supplement.
2. Minimum Design Loads for Buildings and Other Structures ASCE 7-10.
3. Tower Structural Analysis report by Centek Engineering dated 6/7/12.

PROCEDURE

1. Determine the design loads.
2. Estimate existing building loads.
3. Check existing rooftop platform members.
4. Perform reaction comparison.
5. Design steel to support batteries.
6. Check floor slab bending and shear.
7. Check floor slab punching shear.

ASSUMPTIONS

1. As noted.

RESULTS / CONCLUSIONS

The existing building structure and rooftop platform are adequate to support the proposed Verizon Wireless CRAN installation.

Prepared By: Craig Buechele
Craig Buechele
Senior Engineer

Date: 03/14/19

Checked By: Edward Iamiceli
Edward N. Iamiceli, P.E.
Senior Project Manager


Date: 03/14/19

ROOF PLAN


**VERIZON WIRELESS
EQUIPMENT ROOM AREA
(SEE EQUIPMENT PLAN)**

**PROPOSED VERIZON WIRELESS 100KW
GENERATOR TO REPLACE THE
EXISTING GENERATOR ON THE
EXISTING ROOFTOP PLATFORM**

**NEW 100 KW
NATURAL GAS
TO REPLACE
EXISTING**



EQUIPMENT PLAN



PROPOSED STEEL BEAMS BELOW BATTERIES AND BPB

PRELIMINARY LAYOUT SHOWN, FINAL LAYOUT AND EQUIPMENT LOCATIONS MAY CHANGE

Indoor Slab Loading

Slab Thickness = 8 in
Density of Concrete = 150 pcf
Slab Weight = 100 psf
Floor Finish = 5 psf (VCT Tile)
Hung Load = 10 psf
Room Width = 28.58 ft
Room Length = 28 ft

Proposed Verizon Wireless Equipment Load

Equipment	Length (ft)	Width (ft)	Weight (lbs)	Quantity
CRAN Racks	2.17	1.25	1500	14
AHU	1.75	2.20	200	4
Power Plant	2.08	1.50	2000	1
FIF Rack	1.75	1.25	1000	1
OVP Rack	2.33	1.50	1000	1
RF Frame	2.00	2.00	1000	2
HD 4.0	1.92	1.92	1000	1
LTE Rack	2.00	1.50	1000	1
FM 200 Tank	2.08	2.04	300	2
BPB	2.38	1.25	2000	1

The proposed Batteries have been excluded, they are being supported by steel beams spanning column to column

Total Equipment Load = 40 psf
Equipment Room Live Load = 75 psf
Floor Span = 20 ft
Total Floor Load = 230 psf

Maximum Moment on Floor = 9.219 k-ft
Maximum Shear on Floor = 2.766 kips

Check Existing Slab for Bending

$$\Phi M_n = \Phi A_s f_y (d - a/2)$$

Where:

$\Phi = 0.9$
 $f_y = 60000$ psi
 $f'_c = 3000$ psi
Width = 12 in
 $p_{min} = 0.0018$ (Consider Minimum Steel Area based on temperature and shrinkage)
 $d = 7.00$ in
 $a = 0.61$ in

$\Phi M_n = 9.34$ k-ft > Max Moment therefore **OK**

Check Deflection

$I = 1003$ in⁴ (Per 12" width)
 $E_{concrete} = 4500$ ksi
 $E_{steel} = 29000$ ksi

Deflection = 1.17 in Therefore the slab deflection is acceptable

Allowable Deflection $L/180 = 1.33$ in

Check Existing Slab for Shear

$$\Phi V_c = \Phi 2 \lambda v f'_c b_w d$$

Where:

$\Phi = 0.75$
 $f'_c = 3000$ psi
 $\lambda = 1.0$
 $b_w = 12$ in
 $d = 7.00$ in
 $\Phi V_c = 6.901$ kips > Max Shear therefore **OK**

Therefore, the existing floor slab is adequate to support the proposed Verizon Wireless installation.

Outdoor Slab Loading

Slab Thickness = 8 in
 Density of Concrete = 150 pcf
 Slab Weight = 100 psf
 Roofing/Insulation = 10 psf
 Hung Load = 10 psf

Proposed Verizon Wireless Equipment Load

Equipment	Length (ft)	Width (ft)	Weight (lbs)	Quantity
HVAC Condensor	3.10	2.85	270	4

Per the Connecticut 2018 supplement and ASCE 7-10

$$P_f = 0.7C_e C_i P_g$$

$$P_f = 29.4 \text{ psf}$$

But not less than (30 psf)

$$P_f = 30 \text{ psf}$$

$$C_e = 1.0 \text{ [Table 7-2]}$$

$$C_i = 1.2 \text{ [Table 7-3]}$$

$$I = 1.0 \text{ [Table 7-4]}$$

$$P_g = 35 \text{ psf [CBC 2018 Supplement]}$$

Appendix N

GOVERNS

Snow Drift Load (Around Bulkhead)

$$\gamma = 0.13 \times p_g + 14 = 18.55 \text{ pcf}$$

$$\text{Height of Bulkhead} = 20 \text{ ft (Approximately)}$$

$$h_b = 1.62 \text{ ft}$$

$$h_c = 18.38 \text{ ft Does not Govern}$$

$$\text{Windward Length of Roof}$$

$$(3/4)h_d = 0.94 \text{ ft Figure 7-9 } l_r = 25 \text{ ft (Use Min)}$$

$$W = 4h_d = 4 \text{ ft}$$

$$p_d = \gamma h_d = 17 \text{ psf}$$

$$\text{Leeward Length of Bulkhead}$$

$$h_d = 3.48 \text{ ft Figure 7-9 } l_b = 90 \text{ ft}$$

$$W = 4h_d = 14 \text{ ft}$$

$$p_d = \gamma h_c = 65 \text{ psf}$$

GOVERNS

$$\text{Roof Span} = 20 \text{ ft}$$

$$\text{Total Roof Load} = 215 \text{ psf}$$

$$\text{Maximum Moment on Roof} = 8.887 \text{ k-ft}$$

$$\text{Maximum Shear on Roof} = 2.845 \text{ kips}$$

Check Existing Slab for Bending

$$\Phi M_n = \Phi * A_s * f_y * (d - a/2)$$

Where:

$$\Phi = 0.9$$

$$f_y = 60000 \text{ psi}$$

$$f'_c = 3000 \text{ psi}$$

$$\text{Width} = 12 \text{ in}$$

$$p_{min} = 0.0018 \text{ (Consider Minimum Steel Area based on temperature and shrinkage)}$$

$$A_s = 0.31 \text{ in}^2$$

$$d = 7.00 \text{ in}$$

$$a = 0.61 \text{ in}$$

$$\Phi M_n = 9.34 \text{ k-ft} > \text{Max Moment therefore OK}$$

Check Deflection

$$I = 1003 \text{ in}^4 \text{ (Per 12" width)}$$

$$E_{concrete} = 4500 \text{ ksi}$$

$$E_{steel} = 29000 \text{ ksi}$$

$$\text{Deflection} = 1.09 \text{ in Therefore the slab deflection is acceptable}$$

$$\text{Allowable Deflection } L/180 = 1.33 \text{ in}$$

Check Existing Slab for Shear

$$\Phi V_c = \Phi * 2 * \lambda * \sqrt{f'_c} * b_w * d$$

Where:

$$\Phi = 0.75$$

$$f'_c = 3000 \text{ psi}$$

$$\lambda = 1.0$$

$$b_w = 12 \text{ in}$$

$$d = 7.00 \text{ in}$$

$$\Phi V_c = 6.901 \text{ kips} > \text{Max Shear therefore OK}$$

Therefore, the existing roof slab is adequate to support the proposed Verizon Wireless installation.



PRACTICAL SOLUTIONS. EXCEPTIONAL SERVICE.

Job No. 8814.27

Calculated By CB

Date : 03/11/19

Proposed Battery Design Loads

Dead Load

BPB CABINET	Height (ft)	Width (ft)	Depth (ft)	Weight (lbs)
	7.94	3.325	2.39	8616

Vertical Force per Connection = 2154 lbs (4 Points of Connection)
 Beam Spacing = 2 ft

Wind Load (Interior)

Per ASCE 7-10

$q_z = 16$ PSF - Section 29.8 (Minimum Wind Load)

Lateral Force per Connection = 106 lbs (4 Points of Connection)
 Overturning Force = 351 lbs (4 Points of Connection)
 Lateral Force (Other Direction) = 152 lbs (4 Points of Connection)

Seismic Load

ASCE 13.3-1

ap	1.00	Table 3.6-1
SDS	0.197	Per USGS
Wp	8616	lbs
Rp	2.5	Table 3.6-1
Ip	1.5	Risk Cat IV
z/h	1	(z/h need not exceed 1.0)

$[(.4*ap*SDS*Wp)*(1+2(z/h))] / (Rp/Ip)$ Fp 1222 lbs Equation 13.3-1 Apply to center of gravity
 $.3*SDS*Ip*Wp$ Fp Min 764 lbs
 $1.6*SDS*Ip*Wp$ Fp Max 4074 lbs

Fp (Lateral) 1222 lbs/Unit

$.2*SDS*Wp$ Fp (Vertical) 339 lbs/Unit

Lateral Force per Connection = 306 lbs (4 Points of Connection)
 Overturning Force = 1213 lbs (4 Points of Connection)
 Vertical Seismic Force = 85 lbs (4 Points of Connection)

By inspection seismic loads govern over wind



PRACTICAL SOLUTIONS. EXCEPTIONAL SERVICE.

Job No. 8814.27

Calculated By CB Date : 03/13/19

Proposed Battery Design Loads

Dead Load

Deka Unigy II AVR125-33 (Typ of 4)	Height (ft)	Width (ft)	Depth (ft)	Weight (lbs)
	8	2.380	1.25	2000

Vertical Force per Connection = 500 lbs (4 Points of Connection)
 Beam Spacing = 2 ft

Wind Load (Interior)

Per ASCE 7-10

$q_z = 16$ PSF - Section 29.8 (Minimum Wind Load)

Lateral Force per Connection = 76 lbs (4 Points of Connection)
 Overturning Force = 487 lbs (4 Points of Connection)
 Lateral Force (Other Direction) = 80 lbs (4 Points of Connection)

Seismic Load

ASCE 13.3-1

ap	1.00	Table 3.6-1 (Batteries)
SDS	0.197	Per USGS
Wp	2000	lbs
Rp	2.5	Table 3.6-1 (Batteries)
Ip	1.5	Risk Cat IV
z/h	1	(z/h need not exceed 1.0)


$[(.4*ap*SDS*Wp)*(1+2(z/h))] / (Rp/Ip)$ Fp 284 lbs Equation 13.3-1 Apply to center of gravity
 $.3*SDS*Ip*Wp$ Fp Min 177 lbs
 $1.6*SDS*Ip*Wp$ Fp Max 946 lbs

Fp (Lateral) 284 lbs/Unit

$.2*SDS*Wp$ Fp (Vertical) 79 lbs/Unit

Lateral Force per Connection = 71 lbs (4 Points of Connection)
 Overturning Force = 284 lbs (4 Points of Connection)
 Vertical Seismic Force = 20 lbs (4 Points of Connection)

By inspection seismic loads govern over wind



NOTE: THE PROPOSED VERIZON WIRELESS BPB CABINET SHALL BE SUPPORTED WITH L4X4X3/8 ANGLES SPANNING BETWEEN THE PROPOSED W8 BEAMS

Envelope Only Solution


Tectonic Engineering

CB

8814.27 Bristol

PROPOSED INDOOR PLATFORM

8814.27 - Battery Support Steel.r3d



Loads: BLC 1, DL
Envelope Only Solution

Tectonic Engineering


CB

8814.27 Bristol

PROPOSED INDOOR PLATFORM

DEAD LOAD

8814.27 - Battery Support Steel.r3d



Loads: BLC3, ELZ
Envelope Only Solution


Tectonic Engineering

CB

8814.27 Bristol

PROPOSED INDOOR PLATFORM
SEISMIC LOAD IN Z DIRECTION

8814.27 - Battery Support Steel.r3d



Loads: BLC 2, ELX
Envelope Only Solution

Tectonic Engineering


CB

8814.27 Bristol

PROPOSED INDOOR PLATFORM

SEISMIC LOAD IN X DIRECTION

8814.27 - Battery Support Steel.r3d



Loads: BLC 4, ELY
Envelope Only Solution

Tectonic Engineering

CB


8814.27 Bristol

PROPOSED INDOOR PLATFORM
VERTICAL SEISMIC LOAD

8814.27 - Battery Support Steel.r3d



MAX MEMBER STRESS DOES NOT EXCEED 85.2% THEREFORE THE PROPOSED MEMBER SIZES ARE ADEQUATE



Member Code Checks Displayed (Enveloped)
Envelope Only Solution

Tectonic Engineering

CB

8814.27 Bristol

PROPOSED INDOOR PLATFORM

BENDING STRESS

8814.27 - Battery Support Steel.r3d



Company : Tectonic Engineering
 Designer : CB
 Job Number : 8814.27 Bristol
 Model Name : PROPOSED INDOOR PLATFORM

Checked By: _____

Hot Rolled Steel Properties

	Label	E [ksi]	G [ksi]	Nu	Therm (1E...	Density[k/ft...	Yield[ksi]	Ry	Fu[ksi]	Rt
1	A36 Gr.36	29000	11154	.3	.65	.49	36	1.5	58	1.2
2	A572 Gr.50	29000	11154	.3	.65	.49	50	1.1	65	1.1
3	A992	29000	11154	.3	.65	.49	50	1.1	65	1.1
4	A500 Gr.B RND	29000	11154	.3	.65	.527	42	1.4	58	1.3
5	A500 Gr.B Rect	29000	11154	.3	.65	.527	46	1.4	58	1.3
6	A53 Gr.B	29000	11154	.3	.65	.49	35	1.6	60	1.2
7	A1085	29000	11154	.3	.65	.49	50	1.4	65	1.3

Hot Rolled Steel Section Sets

	Label	Shape	Type	Design List	Material	Design ...	A [in ²]	I _{yy} [in ⁴]	I _{zz} [in ⁴]	J [in ⁴]
1	W8x24	W8x31	Beam	Wide Flange	A992	Typical	9.13	37.1	110	.536
2	W6x15	W6x15	Beam	Wide Flange	A992	Typical	4.43	9.32	29.1	.101

Basic Load Cases

	BLC Description	Category	X Gravity	Y Gravity	Z Gravity	Joint	Point	Distributed Area(Me...	Surface(...
1	DL	DL		-1.05		16			
2	ELX	ELX	-.142			32			
3	ELZ	ELZ			-.142	32			
4	ELY	ELY		-.039		16			

Load Combinations

Description	S...	P...	S...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	
1	DL	Yes	Y	1	1	2	3															
2	DL + 0.7ELX	Yes	Y	1	1	2	.7	3														
3	DL + 0.7ELZ	Yes	Y	1	1	2		3	.7													
4	DL + 0.7ELY	Yes	Y	1	1	2			4	.7												
5	DL + 0.5(ELX + ELZ+ELY)	Yes	Y	1	1	2	.5	3	.5	4	.5											
6	DL + 0.7EL-X	Yes	Y	1	1	2	-.7	3														
7	DL + 0.7EL-Z	Yes	Y	1	1	2		3	-.7													
8	DL + 0.7EL-Y	Yes	Y	1	1	2			4	-.7												
9	DL + 0.5(EL-X + EL-Z)	Yes	Y	1	1	2	-.5	3	-.5	4	-.5											

Envelope Joint Reactions

Joint		X [k]	LC	Y [k]	LC	Z [k]	LC	MX [k-ft]	LC	MY [k-ft]	LC	MZ [k-ft]	LC	
1	21A	max	1.003	2	12.671	6	.77	3	0	1	0	1	0	1
2		min	-1.003	6	7.529	2	-.77	7	0	1	0	1	0	1
3	22A	max	.442	2	5.548	6	.675	3	0	1	0	1	0	1
4		min	-.442	6	3.369	2	-.675	7	0	1	0	1	0	1
5	N23A	max	.442	2	5.548	2	.675	3	0	1	0	1	0	1
6		min	-.442	6	3.369	6	-.675	7	0	1	0	1	0	1
7	N24A	max	1.003	2	12.671	2	.77	3	0	1	0	1	0	1
8		min	-1.003	6	7.529	6	-.77	7	0	1	0	1	0	1
9	Totals:	max	2.889	2	29.92	4	2.889	3						
10		min	-2.889	6	28.314	8	-2.889	7						



Company : Tectonic Engineering
 Designer : CB
 Job Number : 8814.27 Bristol
 Model Name : PROPOSED INDOOR PLATFORM

Checked By: _____

Envelope AISC 14th(360-10): ASD Steel Code Checks

Member	Shape	Code Check	Loc...	L...	Shea...	Loc.....	L...	Pnc/o...	Pnt/om...	Mnyy/o...	Mnzz/...	Eqn
1	M3	.852	11.25	2	.306	18	y	2	118.068	273.353	35.124	71.152 1..H1-1b
2	M4	.852	11.25	6	.306	18	y	6	118.068	273.353	35.124	71.152 1..H1-1b
3	M5	.130	2.5	9	.201	3	y	6	126.793	132.635	10.834	25.364 1..H1-1b
4	4	.272	.5	5	.460	3	y	6	126.793	132.635	10.834	25.364 1..H1-1b

MAX MEMBER STRESS DOES NOT EXCEED 85.2% THEREFORE THE PROPOSED MEMBER SIZES ARE ADEQUATE

Check Existing Slab for Shear

Normal Shear

Max Reaction (From RISA) = 19.440 kips LC 2 & Max Positive Shear

$$\Phi V_c = \Phi * 2 * \lambda * v f'_c * b_w * d$$

Where:

$$\Phi = 0.75$$

$$f'_c = 3000 \text{ psi}$$

$$\lambda = 1.0$$

$$\text{Slab Thickness} = 8 \text{ in}$$

$$b_w = 48 \text{ in (Consider 48 inch width for analysis based on RISA mesh size)}$$

$$d = 7.00 \text{ in}$$

$$\Phi V_c = 27.605 \text{ kips} > \text{Max Shear therefore OK}$$

Punching Shear

Max Reaction (From RISA) = 19.440 kips LC 2 & 6, Nodes 21A and N24A Govern

$$\Phi V_c = \text{Min} \left\{ \begin{array}{l} \Phi * (2 + 4/\beta) * \lambda * v f'_c * b_o * d \\ \Phi * (\alpha_s d / b_o + 2) * \lambda * v f'_c * b_o * d \\ \Phi * 4 * \lambda * v f'_c * b_o * d \end{array} \right\}$$

Where:

$$\Phi = 0.75$$

$$f'_c = 3000 \text{ psi}$$

$$\lambda = 1.0$$

$$\alpha_s = 40.0 \text{ (interior)}$$

$$\beta = 2.0$$

$$\text{Slab Thickness} = 8 \text{ in}$$

$$b_o = 84 \text{ in (Consider Perimeter of Steel Support)}$$

$$d = 7.00 \text{ in}$$

$$\Phi V_c = 96.618 \text{ kips} > \text{Max Shear therefore OK}$$



PRACTICAL SOLUTIONS. EXCEPTIONAL SERVICE.

Job No. 8814.27 Bristol
 Sheet No. of
 Calculated By CB Date : 03/11/19
 Checked By Date :

Design Loads for Generator Platform

1 - Dead Load

Number of Units	Cabinet Type	Length (in.)	Width (in.)	Height (in.)	Weight (lbs)	Total Weight
1	SG100 Generator	111.8	40.5	68.6	3022	3022 lbs

Length on Loading Strip = 7.33 ft
 Support Beam Spacing = 2.83 ft
 Uniform Distributed Load = **207 lbs/ft**

For Grating, use **10 psf**

2 - Live Load

Per the Connecticut 2018 supplement, the live load for elevated platforms is **60 psf**.

3 - Snow Load

Per the Connecticut 2018 supplement and ASCE 7-10

$$P_f = 0.7 C_e C_t I P_g$$

$$P_f = 29.4 \text{ psf}$$

But not less than (30 psf)

$$P_f = \mathbf{30 \text{ psf}}$$

GOVERNS

$$C_e = 1.0 \text{ [Table 7-2]}$$

$$C_t = 1.2 \text{ [Table 7-3]}$$

$$I = 1.0 \text{ [Table 7-4]}$$

$$P_g = \mathbf{35} \text{ psf [CBC 2018 Supplement]}$$

Appendix N

4 - Wind Load

Per ASCE 7-10 Chapters 26 & 29

$$z = \mathbf{80} \text{ FT (Approx. T/Generator)}$$

$$V = \mathbf{97} \text{ mph 3 Second Gust (Risk Category IV)}$$

[CBC 2018 Supplement Appendix N]

$$\text{Exposure: } \mathbf{C}$$

$$\alpha = 9.5 \text{ Table 26.91}$$

$$Z_g = 900 \text{ ft Table 26.91}$$

$$K_z = 1.208 \text{ Table 29.3-1}$$

$$K_{zt} = \mathbf{1.00} \text{ Section 26.8.2}$$

$$K_d = \mathbf{0.90} \text{ Section 26.6}$$

$$q_z = 26.19 \text{ psf Section 29.3.2}$$

Per on ASCE7-10 Section 29.5 (Other Structures)

$$G = \mathbf{0.85} \text{ Section 26.9}$$

$$C_f = \mathbf{2.0} \text{ Figure 29.5-1 through 29.5-3}$$

$$F = 45 \text{ psf}$$

$$\text{Wind Pressure} = \mathbf{45} \text{ psf}$$

$$\text{Uplift Force Per Support Beam} = \mathbf{520} \text{ lbs/ft}$$

$$\text{Wind Force Per Support Beam} = \mathbf{129} \text{ lbs/ft}$$

$$\text{Lateral force in other direction} = \mathbf{435} \text{ lbs}$$

Wind Load on Members		
W6	23	lbs/ft
W8	30	lbs/ft
W12	45	lbs/ft

CONVERT TOWER WIND PRESSURE FROM REV F (FASTEST MILE) TO REV G
(3 SECOND GUST)



PRACTICAL SOLUTIONS. EXCEPTIONAL SERVICE.

Job No. 8814.27 Bristol
 Sheet No. of
 Calculated By CB Date : 03/14/19
 Checked By Date :

CALCULATION OF WIND LOAD ON ANTENNA - REV-F

Antenna Information:

Model No. = REV F CONVERSION
 Height = 12.0 in
 Width = 12.0 in
 Depth = 12.0 in
 Area, A_a = 1.00 ft²
 Weight = 0.0 lbs
 Antenna Centerline = 112.5 ft +/-

Geographic Information:

County: Hartford County, CT
 Wind Speed = 80 mph (Per Rev F)

Supporting Pipe Information:

Pipe Length = 0 ft
 Pipe Size = 1/2 PIPE in
 Width = 0.84 in
 Area = 0.25 in
 Weight = 0.85 lb/ft

Design Parameters:

Per, TIA/EIA-222-F-1996:

$Design\ Wind\ Load,\ F = q_z G_H (C_A A_A)$

$q_z = 23.26\ psf$
 $K_z = 1.42\ ft$
 $G_H = 1.15\ * Existing\ Mount$
 Antenna C_A = 1.40
 Pipe C_A = 0.8

Normal Force on Antenna, F_N = 37 lbs
 Transverse Force on Antenna, F_T = 37 lbs
 Force on Pipe F_A = 1 lbs/ft

CONVERT TOWER WIND PRESSURE FROM REV F (FASTEST MILE) TO REV G (3 SECOND GUST)

DESIGN OF ANTENNA MOUNT		(PER ANSI/TIA-222-G-2005)		Rev 1	6/12/2006
Job number	8814.27 Bristol	Calculated by:	CB	Date:	3/14/2019
Sheet	1 Of 1	Checked by:		Date:	
(TYPICAL FOR ALL SECTORS)					
Basic Wind (3 Second Gust)					
		Hartford County, CT			
	Without Ice	V	97	-MPH	
	With Ice	V _i	50	MPH	
Design Ice Thickness		t _i	0.75	Inches	
Height above ground level at base of the structure		z	112.60	Feet Per CD's Conservative	
Antenna Information					
		REV F Conversion			
Weight	W _T	0	LBS	Type	Flg
Height	h	12	Inches	No Ice	
Width	w	12	Inches	A _a (Normal)	1.00 FT ²
Depth	d	12	Inches	A _a (Trans)	1.00 FT ²
Wind Area Normal Per Manuf.			FT ²	Ca (Normal)	1.20
Wind Area Trans			FT ²	Ca (Trans)	1.20
				With Ice	
				A _a (Normal)	1.83 FT ²
				A _a (Trans)	1.83 FT ²
				Canf (Normal)	1.20
				Canf (Trans)	1.20
				A _{ANR} (Normal)	0.83 FT ²
				A _{ANR} (Trans)	0.83 FT ²
				Canr (Normal)	0.7
				Canr (Trans)	0.7
Mount Information					
	Pipe Dia	D	NONE	Inches	Ap
	Pole Width		0.00	Inches	Cf
	Length	L	0	Feet	
	Pole Wt	W	0	LBS/FT	
	Structure Class		3	High hazard or Essential facility	
	Exposure Category		C	Open terrain	
	Minimum value of K _z	K _{zmin}	0.85		
	Power law exponent	α	9.5		
Nominal height of atmospheric boundary layer		Z _g	900	Feet	
		K _e	1		
		G _h	1		
		K _{z1}	1	For antennas on a Building	
		K _d	0.95	Constant for antennas on roof	
Importance Factor	Wind only		1.15		
	Wind with ice		1		
	Ice thickness		1.25		
	K _z Calculated		1.30		
	Use for Design		1.30		
	K _{z1} Calculated		1.13		
	Use for Design		1.13		
Design Ice Thickness	t _z		2.12	Inch	
Eff. Projected Area of the Antenna	(EPA) _N		1.20	FT ²	(EPA) _T
Eff. Projected Area of the Antenna (with ice)			1.78	FT ²	
Eff. Projected Area of the Mounting Pipe	(EPA) _{FN}		0.00	FT ²	(EPA) _{FT}
Eff. Projected Area of the Mounting Pipe (with ice)			0.15	FT ²	
Weight of ice around the Antenna	W _N		12.38	LBS	
Weight of ice around the pipe	W _{FN}		1.94	LBS	
Wind Pressure	q _z = 0.00256 · K _z · K _{z1} · K _d · V ²				
	No Ice		34.14	PSF	
	With Ice		6.87	PSF	
Design Wind Force on Appurtenances					
Wind Normal to the Antenna					
On Antenna	F _A = q _z · G _n · (EPA) _N	F _A	41	LBS	CONVERSION FACTOR: 41PSF/37PSF = 1.108
On Mounting pipe	F _A = q _z · G _n · (EPA) _{FN}	F _A	0	LBS	
On Antenna (with Ice)	F _{Ai}	F _{Ai}	12	LBS	
On Mounting pipe (with Ice)	F _{Ai}	F _{Ai}	1	LBS	
Wind Transverse to the Antenna					
On Antenna	F _A = q _z · G _n · (EPA) _T	F _A	41	LBS	
On Mounting pipe	F _A = q _z · G _n · (EPA) _{FT}	F _A	0	LBS	
On Antenna (with Ice)	F _{Ai}	F _{Ai}	12	LBS	
On Mounting pipe (with Ice)	F _{Ai}	F _{Ai}	1	LBS	
USED FOR DESIGN:					
	Wind (Lateral)	Weight			
	LBS	LBS			
On Antenna	41	0			
On Mounting Pipe	0	0	lb/ft		
On Antenna (with ice)	12	40			
On Mounting pipe (with ice)	1	0	lb/ft		

112.5 ft

102.5 ft

92.5 ft

72.5 ft

Section	Legs	Log Grade	Diagonals	Diagonal Grade	Top Girts	Face Width (ft)	# Panels @ (ft)	Weight (K)
11	P2.5x203	A572-50	L1 1/2x1 1/2x1/8	A36	L1 1/2x1 1/2x1/8	8.6625	8 @ 5	0.4
72								
73			L2x2x1/8					1.0
74								1.7

DESIGNED APPURTENANCE LOADING

TYPE	ELEVATION	TYPE	ELEVATION
LPA-171063-8CF (Verizon - Proposed)	110	LPA-80060-4CF (Verizon - Proposed)	100
LPA-171063-8CF (Verizon - Proposed)	110	LPA-80063/4CF (Verizon - Proposed)	100
LPA-171063-8CF (Verizon - Proposed)	110	48"x6"x8" Panel (Verizon - Existing)	100
LPA-171063-8CF (Verizon - Proposed)	110	BXA-70063/8CF (Verizon - Proposed)	100
LPA-171063-8CF (Verizon - Proposed)	110	LPA-80063-4CF (Verizon - Proposed)	100
LPA-171063-8CF (Verizon - Proposed)	110	LPA-80060/4CF (Verizon - Proposed)	100
LPA-80060/4CF (Verizon - Proposed)	100	48"x6"x8" Panel (Verizon - Existing)	100
BXA-70063/8CF (Verizon - Existing)	100	13-ft Wireless Frame (Verizon - Proposed)	100
LPA-80060-4CF (Verizon - Proposed)	100	13-ft Wireless Frame (Verizon - Proposed)	100
BXA-70063/8CF (Verizon - Proposed)	100	13-ft Wireless Frame (Verizon - Proposed)	100

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi	A36	36 ksi	58 ksi


TOWER DESIGN NOTES

1. Tower designed for a 80 mph basic wind in accordance with the TIAEIA-222-F Standard.
2. Tower is also designed for a 69 mph basic wind with 0.50 in ice.
3. Deflections are based upon a 50 mph wind.
4. Weld together tower sections have flange connections.
5. Connections use galvanized A325 bolts, nuts and locking devices. Installation per TIAEIA-222 and AISC Specifications.
6. Tower members are "hot dipped" galvanized in accordance with ASTM A123 and ASTM A153 Standards.
7. Welds are fabricated with ER-70S-6 electrodes.
8. TOWER RATING: 95.3%


TOWER REACTIONS TAKEN FROM STRUCTURAL ANALYSIS BY CENTEK ENGINEERING DATED 6/7/12

MAX. CORNER REACTIONS AT BASE:

- DOWN: 23 K
- UPLIFT: -20 K
- SHEAR: 4 K



TORQUE 2 kip-ft
69 mph WIND - 0.5000 in ICE



TORQUE 2 kip-ft
REACTIONS - 80 mph WIND

Centek Engineering Inc.

63-2 North Branford Rd.

Branford, CT 06405

Phone: (203) 488-0580

FAX: (203) 488-8587

Job: **12001.CO41 - Bristol**

Project: **40' Lattice Tower - 32 Valley St. Bristol, CT**

Client: **Verizon Wireless**

Code: **TIAEIA-222-F**

Date: **06/07/12**

Scale: **NTS**

Dwg No: **E-1**

RISATower Centek Engineering Inc. 63-2 North Branford Rd. Branford, CT 06405 Phone: (203) 488-0580 FAX: (203) 488-8587	Job 12001.CO41 - Bristol	Page 16 of 22
	Project 40' Lattice Tower - 32 Valley St. Bristol, CT	Date 09:40:53 06/07/12
	Client Verizon Wireless	Designed by TJL

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Force K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft
			Max. Vy	18	0.01	0.00	0.00

Maximum Reactions

Location	Condition	Gov. Load Comb.	Vertical K	Horizontal, X K	Horizontal, Z K
Leg C	Max. Vert	13	22.23	2.93	-1.82
	Max. H _x	13	22.23	2.93	-1.82
	Max. H _z	20	-15.35	-2.93	2.25
	Min. Vert	5	-19.45	-2.73	1.70
	Min. H _x	22	-17.48	-3.42	2.08
Leg B	Min. H _z	11	18.99	2.26	-1.89
	Max. Vert	7	22.32	-2.91	-1.85
	Max. H _x	32	-17.23	3.40	2.10
	Max. H _z	34	-15.10	2.90	2.30
	Min. Vert	15	-19.37	2.72	1.73
Leg A	Min. H _x	7	22.32	-2.91	-1.85
	Min. H _z	9	19.08	-2.23	-1.95
	Max. Vert	19	23.38	0.04	2.60
	Max. H _x	14	1.21	1.03	0.03
	Max. H _z	2	23.17	0.04	3.54
	Min. Vert	10	-19.87	-0.04	-3.31
	Min. H _x	6	1.21	-1.03	0.03
	Min. H _z	27	-17.18	-0.03	-4.07

Tower Mast Reaction Summary


Load Combination	Vertical K	Shear _x K	Shear _z K	Overturning Moment, M _x kip-ft	Overturning Moment, M _z kip-ft	Torque kip-ft
Dead Only	3.17	0.00	0.00	-1.10	-0.35	0.00
Dead+Wind 0 deg - No Ice	3.17	0.00	-6.74	-164.01	-0.35	0.57
Dead+Wind 30 deg - No Ice	3.17	3.12	-5.62	-137.87	-75.96	-0.46
Dead+Wind 45 deg - No Ice	3.17	4.39	-4.56	-112.18	-106.70	-0.91
Dead+Wind 60 deg - No Ice	3.17	5.34	-3.20	-79.23	-129.88	-1.30
Dead+Wind 90 deg - No Ice	3.17	6.25	-0.00	-1.10	-151.58	-1.84
Dead+Wind 120 deg - No Ice	3.17	5.63	3.37	80.35	-135.64	-1.98
Dead+Wind 135 deg - No Ice	3.17	4.39	4.56	109.98	-106.70	-1.66
Dead+Wind 150 deg - No Ice	3.17	3.12	5.62	135.66	-75.96	-1.38
Dead+Wind 180 deg - No Ice	3.17	0.00	6.41	155.16	-0.35	-0.52
Dead+Wind 210 deg - No Ice	3.17	-3.12	5.62	135.66	75.27	0.46
Dead+Wind 225 deg - No Ice	3.17	-4.39	4.56	109.98	106.00	0.91
Dead+Wind 240 deg - No Ice	3.17	-5.63	3.37	80.35	134.94	1.41
Dead+Wind 270 deg - No Ice	3.17	-6.25	-0.00	-1.10	150.88	1.84
Dead+Wind 300 deg - No Ice	3.17	-5.34	-3.20	-79.23	129.18	1.82
Dead+Wind 315 deg - No Ice	3.17	-4.39	-4.56	-112.18	106.00	1.66
Dead+Wind 330 deg - No Ice	3.17	-3.12	-5.62	-137.87	75.27	1.38
Dead+Ice+Temp	5.97	-0.00	0.00	-3.44	-1.08	0.00
Dead+Wind 0 deg+Ice+Temp	5.97	0.00	-6.66	-158.64	-1.08	0.56
Dead+Wind 30 deg+Ice+Temp	5.97	3.04	-5.43	-131.60	-72.50	-0.43
Dead+Wind 45 deg+Ice+Temp	5.97	4.25	-4.38	-107.24	-101.24	-0.85
Dead+Wind 60 deg+Ice+Temp	5.97	5.15	-3.07	-76.23	-122.71	-1.20

RISATower Centek Engineering Inc. 63-2 North Branford Rd. Branford, CT 06405 Phone: (203) 488-0580 FAX: (203) 488-8587	Job 12001.CO41 - Bristol	Page 17 of 22
	Project 40' Lattice Tower - 32 Valley St. Bristol, CT	Date 09:40:53 06/07/12
	Client Verizon Wireless	Designed by TJL

Load Combination	Vertical	Shear _x	Shear _y	Overturning Moment, M _x	Overturning Moment, M _y	Torque
	K	K	K	kip-ft	kip-ft	kip-ft
Dead+Wind 90 deg+Ice+Temp	5.97	6.08	0.00	-3.44	-143.93	-1.73
Dead+Wind 120 deg+Ice+Temp	5.97	5.61	3.33	74.16	-131.04	-1.96
Dead+Wind 135 deg+Ice+Temp	5.97	4.25	4.38	100.36	-101.24	-1.55
Dead+Wind 150 deg+Ice+Temp	5.97	3.04	5.43	124.73	-72.50	-1.30
Dead+Wind 180 deg+Ice+Temp	5.97	0.00	6.13	142.15	-1.08	-0.48
Dead+Wind 210 deg+Ice+Temp	5.97	-3.04	5.43	124.73	70.35	0.43
Dead+Wind 225 deg+Ice+Temp	5.97	-4.25	4.38	100.36	99.08	0.85
Dead+Wind 240 deg+Ice+Temp	5.97	-5.61	3.33	74.16	128.89	1.40
Dead+Wind 270 deg+Ice+Temp	5.97	-6.08	0.00	-3.44	141.77	1.73
Dead+Wind 300 deg+Ice+Temp	5.97	-5.15	-3.07	-76.23	120.55	1.68
Dead+Wind 315 deg+Ice+Temp	5.97	-4.25	-4.38	-107.24	99.08	1.55
Dead+Wind 330 deg+Ice+Temp	5.97	-3.04	-5.43	-131.60	70.35	1.30
Dead+Wind 0 deg - Service	3.17	0.00	-2.63	-64.74	-0.35	0.22
Dead+Wind 30 deg - Service	3.17	1.22	-2.20	-54.53	-29.89	-0.18
Dead+Wind 45 deg - Service	3.17	1.71	-1.78	-44.49	-41.89	-0.36
Dead+Wind 60 deg - Service	3.17	2.09	-1.25	-31.62	-50.95	-0.51
Dead+Wind 90 deg - Service	3.17	2.44	0.00	-1.10	-59.42	-0.72
Dead+Wind 120 deg - Service	3.17	2.20	1.32	30.72	-53.19	-0.77
Dead+Wind 135 deg - Service	3.17	1.71	1.78	42.29	-41.89	-0.65
Dead+Wind 150 deg - Service	3.17	1.22	2.20	52.32	-29.89	-0.54
Dead+Wind 180 deg - Service	3.17	0.00	2.50	59.94	-0.35	-0.20
Dead+Wind 210 deg - Service	3.17	-1.22	2.20	52.32	29.19	0.18
Dead+Wind 225 deg - Service	3.17	-1.71	1.78	42.29	41.19	0.36
Dead+Wind 240 deg - Service	3.17	-2.20	1.32	30.72	52.50	0.55
Dead+Wind 270 deg - Service	3.17	-2.44	0.00	-1.10	58.73	0.72
Dead+Wind 300 deg - Service	3.17	-2.09	-1.25	-31.62	50.25	0.71
Dead+Wind 315 deg - Service	3.17	-1.71	-1.78	-44.49	41.19	0.65
Dead+Wind 330 deg - Service	3.17	-1.22	-2.20	-54.53	29.19	0.54

Solution Summary

Load Comb.	Sum of Applied Forces			Sum of Reactions			% Error
	PX K	PY K	PZ K	PX K	PY K	PZ K	
1	0.00	-3.17	0.00	0.00	3.17	0.00	0.000%
2	0.00	-3.17	-6.74	-0.00	3.17	6.74	0.000%
3	3.12	-3.17	-5.62	-3.12	3.17	5.62	0.000%
4	4.39	-3.17	-4.56	-4.39	3.17	4.56	0.000%
5	5.34	-3.17	-3.20	-5.34	3.17	3.20	0.000%
6	6.25	-3.17	0.00	-6.25	3.17	0.00	0.000%
7	5.63	-3.17	3.37	-5.63	3.17	-3.37	0.000%
8	4.39	-3.17	4.56	-4.39	3.17	-4.56	0.000%
9	3.12	-3.17	5.62	-3.12	3.17	-5.62	0.000%
10	0.00	-3.17	6.41	-0.00	3.17	-6.41	0.000%
11	-3.12	-3.17	5.62	3.12	3.17	-5.62	0.000%
12	-4.39	-3.17	4.56	4.39	3.17	-4.56	0.000%
13	-5.63	-3.17	3.37	5.63	3.17	-3.37	0.000%
14	-6.25	-3.17	0.00	6.25	3.17	0.00	0.000%
15	-5.34	-3.17	-3.20	5.34	3.17	3.20	0.000%
16	-4.39	-3.17	-4.56	4.39	3.17	4.56	0.000%
17	-3.12	-3.17	-5.62	3.12	3.17	5.62	0.000%
18	0.00	-5.97	0.00	0.00	5.97	-0.00	0.000%
19	0.00	-5.97	-6.66	-0.00	5.97	6.66	0.000%
20	3.04	-5.97	-5.43	-3.04	5.97	5.43	0.000%
21	4.25	-5.97	-4.38	-4.25	5.97	4.38	0.000%
22	5.15	-5.97	-3.07	-5.15	5.97	3.07	0.000%
23	6.08	-5.97	0.00	-6.08	5.97	-0.00	0.000%
24	5.61	-5.97	3.33	-5.61	5.97	-3.33	0.000%




TECTONIC
CB
8814.27

GENERATOR PLATFORM

8814.27 - Generator Platform.r3d



TOWER REACTIONS TAKEN FROM STRUCTURAL ANALYSIS BY CENTEK ENGINEERING DATED 6/7/12 AND HAVE BEEN CONVERTED FROM REV F (FASTEST MILE) TO REV G (3 SECOND GUST)



Loads: BLC 1, DL

TECTONIC


CB

8814.27

GENERATOR PLATFORM

DEAD LOAD

8814.27 - Generator Platform.r3d



Loads: BLC 1, DL


TECTONIC

CB

8814.27

GENERATOR PLATFORM
EXISTING GENERATOR LOAD

8814.27 - Generator Platform EXIS...



Loads: RLC 2 LL


TECTONIC

CB

8814.27

GENERATOR PLATFORM
LIVE LOAD

8814.27 - Generator Platform.r3d



Loads: BLC 3, SL


TECTONIC

CB

8814.27

GENERATOR PLATFORM
SNOW LOAD

8814.27 - Generator Platform.r3d



Loads: BLC 4, WLX


TECTONIC

CB

8814.27

GENERATOR PLATFORM
WIND LOAD IN X DIRECTION

8814.27 - Generator Platform.r3d



Loads: BLC 5, WLZ


TECTONIC

CB

8814.27

GENERATOR PLATFORM
WIND LOAD IN Z DIRECTION

8814.27 - Generator Platform.r3d



Loads: BLC 6, WL-X


TECTONIC

CB

8814.27

GENERATOR PLATFORM
WIND LOAD IN -X DIRECTION

8814.27 - Generator Platform.r3d



Loade BLC 7. WL-Z


TECTONIC

CB

8814.27


GENERATOR PLATFORM WIND LOAD IN -Z DIRECTION

8814.27 - Generator Platform.r3d



MEMBER NOT AFFECTED BY THE PROPOSED SCOPE OF WORK AND THEREFORE HAS NOT BE INCLUDED IN THE ANALYSIS

MAX MEMBER STRESS DOES NOT EXCEED 95.4% THEREFORE THE PROPOSED MEMBER SIZES ARE ADEQUATE



Member Code Checks Displayed (Enveloped)
Envelope Dirty Solution

TECTONIC	GENERATOR PLATFORM BENDING STRESS	
CB		
8814.27		8814.27 - Generator Platform.r3d



Company : TECTONIC
 Designer : CB
 Job Number : 8814.27
 Model Name : GENERATOR PLATFORM

Checked By: _____

Hot Rolled Steel Properties

	Label	E [ksi]	G [ksj]	Nu	Therm (1E...	Density[k/ft...	Yield[ksi]	Ry	Fu[ksi]	Rt
1	A36	29000	11154	.3	.65	.49	36	1.5	58	1.2
2	A572Grade50	29000	11154	.3	.65	.49	50	1.5	58	1.2
3	A992	29000	11154	.3	.65	.49	50	1.5	58	1.2
4	A500 42	29000	11154	.3	.65	.49	42	1.5	58	1.2
5	A500 46	29000	11154	.3	.65	.49	46	1.5	58	1.2

Hot Rolled Steel Section Sets

	Label	Shape	Type	Design List	Material	Design ...	A [in2]	Iyy [in4]	Izz [in4]	J [in4]
1	W12x35	W12x35	Beam	Wide Flange	A36	Typical	10.3	24.5	285	.741
2	W8x31	W8x31	Beam	Wide Flange	A36	Typical	9.13	37.1	110	.536
3	W6x12	W6x12	Beam	Wide Flange	A36	Typical	3.55	2.99	22.1	.09
4	C12x20.7	C12x20.7	Beam	Channel	A36	Typical	6.08	3.86	129	.369

Basic Load Cases

	BLC Description	Category	X Gravity	Y Gravity	Z Gravity	Joint	Point	Distributed Area(Me...	Surface(...
1	DL	DL		-1.05		3		2	6
2	LL	LL							6
3	SL	SL				3			1
4	WLX	WLX				7		15	
5	WLZ	WLZ				6		20	
6	WL-X	WL-X				7		15	
7	WL-Z	WL-Z				6		20	
8	BLC 1 Transient Area Loads	None						25	
9	BLC 2 Transient Area Loads	None						25	
10	BLC 3 Transient Area Loads	None						15	

Load Combinations

	Description	S...	P...	S...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...	Fa...	B...				
1	DL + LL	Yes	Y	DL	1	LL	1	SL	W...	W...																											
2	DL + SL	Yes	Y	DL	1	LL	1	SL	1	W...	W...																										
3	DL + WLX	Yes	Y	DL	1	LL	1	SL	W...	1	W...																										
4	DL + WLZ	Yes	Y	DL	1	LL	1	SL	W...	W...	1																										
5	DL + WL-X	Yes	Y	DL	1	LL	1	SL	W...	-1																											
6	DL + WL-Z	Yes	Y	DL	1	LL	1	SL		W...	-1																										
7	DL + 0.75(LL + SL + WLX)	Yes	Y	DL	1	LL	.75	SL	.75	W...	.75	W...																									
8	DL + 0.75(LL + SL + WLZ)	Yes	Y	DL	1	LL	.75	SL	.75	W...	.75	W...																									
9	DL + 0.75(LL + SL + WL-X)	Yes	Y	DL	1	LL	.75	SL	.75	W...	.75	W...																									
10	DL + 0.75(LL + SL + WL-Z)	Yes	Y	DL	1	LL	.75	SL	.75	W...	.75	W...																									
11	DL		Y	DL	1	LL		SL	W...	W...																											
12	SL		Y	DL		LL		SL	1	W...	W...																										
13	LL		Y	DL		LL	1	SL	W...	W...																											
14	WLX		Y	DL		LL		SL	W...	1	W...																										
15	WLZ		Y	DL		LL		SL	W...	W...	1																										
16	WL-X		Y	DL		LL		SL	W...	1																											
17	WL-Z		Y	DL		LL		SL		W...	1																										



Envelope Joint Reactions

	Joint		X [k]	LC	Y [k]	LC	Z [k]	LC	MX [k-ft]	LC	MY [k-ft]	LC	MZ [k-ft]	LC
1	N6	max	5.24	8	15.604	9	- .854	4	0	1	.011	6	0	1
2		min	.235	10	-7.15	3	-2.502	7	0	1	-.008	10	0	1
3	N5	max	6.919	9	15.824	10	8.618	10	0	1	.007	6	0	1
4		min	.247	3	-3.658	6	-7.262	6	0	1	-.006	10	0	1
5	N8	max	5.55	9	14.794	3	1.598	10	0	1	.004	10	0	1
6		min	-12.824	3	-3.904	9	-3.809	6	0	1	-.006	6	0	1
7	N7	max	.844	6	14.416	10	3.903	10	0	1	.012	10	0	1
8		min	-7.746	10	-.559	6	-3.529	6	0	1	-.014	6	0	1
9	N43	max	0	1	1.074	10	0	1	0	1	0	1	0	1
10		min	0	1	-.027	6	0	1	0	1	0	1	0	1
11	N42	max	0	1	1.011	6	0	1	0	1	0	1	0	1
12		min	0	1	-.527	10	0	1	0	1	0	1	0	1
13	Totals:	max	9.83	9	33.537	1	11.657	10						
14		min	-13.294	3	17.909	5	-15.543	6						

Envelope AISC 14th(360-10): ASD Steel Code Checks

Member	Shape	Code Check	Loc...	Shea...	Loc.....	L	Pnc/o...	Pnt/om...	Mnyy/o...	Mnzz/...	Eqn			
1	M1	.912	10	6	.293	17...	y	5	181.067	222.036	20.659	88.273	1	H1-1b
2	M2	.954	8.125	10	.222	4.792	y	10	140.317	222.036	20.659	78.896	1	H1-1b
3	M3	.541	16....	6	.132	7.656	y	6	185.595	222.036	20.659	89.445	1	H1-1b
4	M4	.431	15....	6	.066	16....	y	10	161.44	222.036	20.659	83.584	1	H1-1b
5	M5	.232	1.111	7	.161	1.042	y	8	181.154	196.814	25.329	54.611	1...	H1-1b
6	M6	.302	1.111	6	.392	0	y	3	181.154	196.814	25.329	54.611	1...	H1-1b
7	M7	.352	1.042	10	.238	1.042	y	10	181.154	196.814	25.329	54.611	1...	H1-1b
8	M8	.535	1.042	10	.212	0	y	9	181.154	196.814	25.329	54.611	1...	H1-1b
9	M9	.796	7.656	10	.157	0	y	10	196.766	222.036	20.659	91.976	1...	H1-1b
10	M10	.432	1.25	6	.088	0	z	6	181.067	222.036	20.659	91.976	1...	H1-1b
11	M11	.029	4	8	.020	8	y	1	181.067	222.036	20.659	91.976	1...	H1-1b
12	M13	.060	6	8	.021	12	y	1	140.317	222.036	20.659	89.654	1...	H1-1b
13	M14	.235	5.25	6	.078	0	y	8	140.317	222.036	20.659	91.976	1...	H1-1b
14	M15	.184	5.25	10	.093	0	y	10	140.317	222.036	20.659	91.976	1...	H1-1b
15	M16	.232	3.563	8	.035	0	z	6	47.515	76.527	4.168	14.884	1...	H1-1a
16	M17	.102	0	10	.015	0	z	3	47.515	76.527	4.168	14.884	1...	H1-1b*
17	M18	.499	3.184	3	.038	0	z	6	47.515	76.527	4.168	14.884	1...	H1-1a
18	M19	.151	0	6	.019	0	z	3	47.515	76.527	4.168	14.884	1...	H1-1b*
19	M20	.155	0	10	.017	0	z	3	47.515	76.527	4.168	14.884	1...	H1-1b*
20	M21	.329	3.563	10	.044	0	z	6	47.515	76.527	4.168	14.884	1...	H1-1a
21	M22	.343	3.184	10	.015	0	z	3	47.515	76.527	4.168	14.884	1...	H1-1a
22	M23	.300	3.563	10	.042	0	z	6	47.515	76.527	4.168	14.884	1...	H1-1a
23	M24	.693	12....	6	.020	0	y	10	27.894	131.066	4.949	36.303	1...	H1-1b
24	M25	.775	0	6	.034	0	y	10	27.894	131.066	4.949	45.988	2...	H1-1b
25	M26	.338	0	6	.033	5.25	y	10	94.31	131.066	4.949	45.988	1...	H1-1b
26	M27	.494	5	6	.043	4.375	y	10	97.24	131.066	4.949	45.988	1...	H1-1b
27	M28	.641	5.25	10	.106	5.25	y	10	94.31	131.066	4.949	45.988	1...	H1-1b
28	M30	.508	5.5	10	.091	5.5	y	10	201.629	222.036	20.659	91.976	1...	H1-1b
29	M31	.876	5.5	6	.058	0	z	10	201.629	222.036	20.659	91.976	1...	H1-1b

MAX MEMBER STRESS DOES NOT EXCEED 95.4% THEREFORE THE PROPOSED MEMBER SIZES ARE ADEQUATE



PRACTICAL SOLUTIONS, EXCEPTIONAL SERVICE.

Job No. 8814.27

Calculated By CB Date : 03/14/19

Generator Platform Reaction Comparison

Existing Reactions

Node (Label)	X (kips)	Y (kips)	Z (kips)
N6	5.223	8.000	15.570
N6	0.217	10.000	-7.184
N5	6.857	9.000	15.715
N5	0.185	3.000	-3.765
N8	5.567	9.000	14.769
N8	-12.807	3.000	-3.928
N7	0.906	6.000	14.341
N7	-7.684	10.000	-0.632
N43	0.000	1.000	1.070
N43	0.000	1.000	-0.031
N42	0.000	1.000	1.023
N42	0.000	1.000	-0.516

Proposed Reactions

Node (Label)	X (kips)	Y (kips)	Z (kips)
N6	5.240	8.000	15.604
N6	0.235	10.000	-7.150
N5	6.919	9.000	15.824
N5	0.247	3.000	-3.658
N8	5.550	9.000	14.794
N8	-12.824	3.000	-3.904
N7	0.844	6.000	14.416
N7	-7.746	10.000	-0.559
N43	0.000	1.000	1.074
N43	0.000	1.000	-0.027
N42	0.000	1.000	1.011
N42	0.000	1.000	-0.527

Increase in Load


Node (Label)	X (kips)	Y (kips)	Z (kips)
N6	0.017	0.000	0.034
N6	0.018	0.000	0.034
N5	0.062	0.000	0.109
N5	0.062	0.000	0.107
N8	0.017	0.000	0.025
N8	0.017	0.000	0.024
N7	0.062	0.000	0.075
N7	0.062	0.000	0.073
N43	0.000	0.000	0.004
N43	0.000	0.000	0.004
N42	0.000	0.000	0.012
N42	0.000	0.000	0.011

The maximum increase in load does not exceed 109 lbs which is relatively small in comparison to the existing reactions (15,824 lbs, which is less than a 1% increase in load). Therefore, we believe the existing platform connections and building supporting elements are adequate to support the proposed Verizon Wireless installation.



225 N Main St, Bristol, CT 06010, USA

Latitude, Longitude: 41.6763822, -72.94782609999998




Date	3/8/2019, 10:27:48 AM
Design Code Reference Document	ASCE7-10
Risk Category	IV
Site Class	D - Stiff Soil

Type	Value	Description
S _s	0.185	MCE _R ground motion. (for 0.2 second period)
S ₁	0.064	MCE _R ground motion. (for 1.0s period)
S _{MS}	0.295	Site-modified spectral acceleration value
S _{M1}	0.154	Site-modified spectral acceleration value
S _{DS}	0.197	Numeric seismic design value at 0.2 second SA
S _{D1}	0.103	Numeric seismic design value at 1.0 second SA


Type	Value	Description
SDC	C	Seismic design category
F _a	1.6	Site amplification factor at 0.2 second
F _v	2.4	Site amplification factor at 1.0 second
PGA	0.094	MCE _G peak ground acceleration
F _{PGA}	1.6	Site amplification factor at PGA
PGA _M	0.15	Site modified peak ground acceleration
T _L	6	Long-period transition period in seconds
S _{sRT}	0.185	Probabilistic risk-targeted ground motion. (0.2 second)
S _{sUH}	0.206	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
S _{sD}	1.5	Factored deterministic acceleration value. (0.2 second)
S _{1RT}	0.064	Probabilistic risk-targeted ground motion. (1.0 second)
S _{1UH}	0.071	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
S _{1D}	0.6	Factored deterministic acceleration value. (1.0 second)
PGA _d	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)
C _{RS}	0.897	Mapped value of the risk coefficient at short periods

Type	Value	Description
C _{R1}	0.898	Mapped value of the risk coefficient at a period of 1 s

MCER Response Spectrum



Design Response Spectrum



DISCLAIMER

While the information presented on this website is believed to be correct, SEAOC /OSHPD and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in this web application should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. SEAOC / OSHPD do not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the seismic data provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the search results of this website.

ATTACHMENT 4




City of Bristol, Connecticut Assessment Parcel Map

Parcel: 0026670

Account #: 0026670

Address: 225 NORTH MAIN ST



Approximate Scale: 1 inch = 100 feet

Map Produced March 2018

Disclaimer: This map is for informational purposes only. All information is subject to verification by any user. The City of Bristol and its mapping contractors assume no legal responsibility for the information contained herein.



Property Information


Property Location	225 NORTH MAIN ST
Owner	CARPENTER REALTY COMPANY
Co-Owner	
Mailing Address	PO BOX 176 BRISTOL CT 06011
Land Use	340 Off Bldg
Land Class	C
Zoning Code	BD-1
Census Tract	04061

Neighborhood	
Acreage	3.19
Utilities	All Public
Lot Setting/Desc	Level
Book / Page	0692/0054
Additional Info	

Photo



Sketch



Primary Construction Details

Year Built	1912
Building Desc.	Off Bldg
Building Style	Office Bldg
Building Grade	NA
Stories	5
Occupancy	28.00
Exterior Walls	Brick/Masonry
Exterior Walls 2	NA
Roof Style	Flat
Roof Cover	T+G/Rubber
Interior Walls	Drywall/Sheetr
Interior Walls 2	NA
Interior Floors 1	Carpet
Interior Floors 2	

Heating Fuel	Propane Gas
Heating Type	Forced Air-Duc
AC Type	03
Bedrooms	0
Full Bathrooms	0
Half Bathrooms	0
Extra Fixtures	0
Total Rooms	0
Bath Style	NA
Kitchen Style	NA
Fin Bsmt Area	0
Fin Bsmt Quality	0
Bsmt Gar	0
Fireplaces	0

(*Industrial / Commercial Details)

Building Use	Comm/Ind
Building Condition	A
Sprinkler %	NA
Heat / AC	Heat/AC Pkgs
Frame Type	Masonry
Baths / Plumbing	Average
Ceiling / Wall	Sus-Ceil & WL
Rooms / Prtns	Average
Wall Height	12.00
First Floor Use	NA
Foundation	NA



City of Bristol, CT

Property Listing Report

Map Block Lot **26-21B**

Building # **2** PID **1588** Account **0026670**

Photo



0026670 03/15/2016

Sketch



Primary Construction Details

Year Built	1930
Building Desc.	Comm/Ind
Building Style	Mill Building
Building Grade	NA
Stories	4
Occupancy	7.00
Exterior Walls	Brick/Masonry
Exterior Walls 2	NA
Roof Style	Flat
Roof Cover	T+G/Rubber
Interior Walls	Drywall/Sheetr
Interior Walls 2	NA
Interior Floors 1	Carpet
Interior Floors 2	

Heating Fuel	Propane Gas
Heating Type	Forced Air-Duc
AC Type	03
Bedrooms	0
Full Bathrooms	0
Half Bathrooms	0
Extra Fixtures	0
Total Rooms	0
Bath Style	NA
Kitchen Style	NA
Fin Bsmt Area	0
Fin Bsmt Quality	0
Bsmt Gar	0
Fireplaces	0

(*Industrial / Commercial Details)

Building Use	Off Bldg
Building Condition	A
Sprinkler %	NA
Heat / AC	Heat/AC Pkgs
Frame Type	Masonry
Baths / Plumbing	Average
Ceiling / Wall	Sus-Ceil & WL
Rooms / Prtns	Average
Wall Height	12.00
First Floor Use	NA
Foundation	NA

Sub Areas

Subarea Type	Gross Area (sq ft)	Living Area (sq ft)
Office	102912	102912
First Floor	58649	58649
Canopy	1008	0
Finished Lower Level	54506	54506
Upper Story, Finished	57831	57831
Slab	3913	0

Subarea Type	Gross Area (sq ft)	Living Area (sq ft)
Total Area	278819	273898

ATTACHMENT 5



Certificate of Mailing — Firm

Name and Address of Sender		TOTAL NO. of Pieces Listed by Sender	TOTAL NO. of Pieces Received at Post Office™	Affix Stamp Here Postmark with Date of Receipt.
Kenneth C. Baldwin, Esq. Robinson & Cole LLP 280 Trumbull Street Hartford, CT 06103		3	3	
USPS® Tracking Number Firm-specific Identifier		Address (Name, Street, City, State, and ZIP Code™)		
1.		Ellen Zoppo-Sassu, Mayor City of Bristol 111 North Main Street Bristol, CT 06010		
2.		Robert Flanagan, City Planner City of Bristol 111 North Main Street Bristol, CT 06010		
3.		Carpenter Realty P.O. Box 176 Bristol, CT 06011		
4.				
5.				
6.				

