

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

EM-VER-023-091208

December 8, 2009

ORIGINAL

Via Hand Delivery

S. Derek Phelps
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **Notice of Exempt Modification**
96 Powder Mill Road, Canton, Connecticut

Dear Mr. Phelps:

Cellco Partnership d/b/a Verizon Wireless ("Cellco") maintains a wireless telecommunications facility at the above-referenced location. Cellco intends to install a propane-fueled back-up generator and 1,000 gallon propane tank on the ground adjacent to the tower at 96 Powder Mill Road in Canton, Connecticut.

Please accept this letter as notification pursuant to R.C.S.A. § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to Richard J. Barlow, First Selectman of the Town of Canton. A copy of this letter is also being sent to Properties One, LLC, the owner of the property on which the facility is located.

As shown on the attached plan, Cellco intends to install a propane-fueled back-up generator and a 1,000 gallon propane tank within the fenced compound. Attached to this letter is a Compound Plan showing the location of the proposed generator and 1,000 gallon (vertically-mounted) propane tank.

The planned modifications to the Canton facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).

1. The proposed modification will not increase the overall height of the existing tower.



Law Offices

BOSTON

PROVIDENCE

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY

ALBANY

SARASOTA

www.rc.com

10116189-v1

ROBINSON & COLE_{LLP}

S. Derek Phelps
December 8, 2009
Page 2


2. The proposed installation of a propane-fueled back-up generator and 1,000 gallon propane tank will not require an extension of the fenced compound or site boundary.

3. The proposed installation will not increase the noise levels at the facility by six decibels or more.

4. The proposed modifications will not result in any increase in radio frequency (RF) power density levels at the facility to a level at or above the Federal Communications Commission (FCC) adopted safety standard.

For the foregoing reasons, Cellco respectfully submits that the proposed generator and propane tank installation at the facility constitutes an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,



Kenneth C. Baldwin

Attachments

Copy to:

Richard J. Barlow, Canton First Selectman
Properties One, LLC
Sandy M. Carter
Michelle Kababik



Cellco Partnership

d.b.a. **verizon**wireless

WIRELESS COMMUNICATIONS FACILITY

COLLINSVILLE 2

96 POWDER MILL ROAD


CANTON, CT 06022

PROJECT SUMMARY

SITE NAME: BLOOMFIELD 3
SITE ADDRESS: 96 POWDER MILL ROAD
CANTON, CT 06022
LESSEE/TENANT: CELCO PARTNERSHIP
d.b.a. VERIZON WIRELESS
99 EAST RIVER DRIVE
EAST HARTFORD, CT 06108
CONTACT PERSON: SANDY CARTER
CELCO PARTNERSHIP
(860) 803-8219
TOWER COORDINATES: LATITUDE 41°-50'-2.93"
LONGITUDE 72°-55'-59.24"
COORDINATES ARE BASED ON
CONNECTICUT SITING COUNCIL DATABASE.

SHEET INDEX

SHT. NO.	DESCRIPTION	REV. NO.
T-1	TITLE SHEET	A
C-1	COMPOUND PLAN	A



SITE DIRECTIONS


FROM:	TO:
99 EAST RIVER DRIVE EAST HARTFORD, CONNECTICUT	96 POWDER MILL ROAD CANTON, CT 06022

1. Depart E River Dr
2. Turn left to stay on E River Dr
3. Turn left onto US-44 / Main St
4. At exit 20, take ramp right for US-44 West / US-44 West
5. Keep straight onto US-44 / Main St N West
6. Keep right to stay on US-44 / Main St
7. Keep left to stay on US-202 South
8. Turn right onto Powder Mill Rd, and then turn left onto Ramp Rd
9. Arrive at 96 Powder Mill Rd, Collinsville, CT 06019-3501
10. 0.3 mi
11. 0.1 mi
12. 0.4 mi
13. 0.2 mi
14. 0.1 mi
15. 14.5 mi
16. 0.4 mi
17. 0.1 mi

PROJECT SCOPE

1. THE PROPOSED SCOPE OF WORK GENERALLY INCLUDES THE INSTALLATION OF A PROPEANE FUELED GENERATOR ON A CONCRETE PAD AND A 1,000 GALLON PROPEANE TANK ON A CONCRETE PAD WITHIN THE EXISTING WIRELESS COMMUNICATIONS LEASE AREA.
2. THE PROPEANE SUPPLY LINE WILL BE ROUTED UNDERGROUND FROM THE PROPOSED PROPEANE TANK TO THE PROPOSED GENERATOR. THE PROPEANE SUPPLY CONDUIT WILL BE ROUTED UNDERGROUND FROM THE PROPOSED GENERATOR TO THE EXISTING CELCO PARTNERSHIP EQUIPMENT SHELTER.

DESIGNED BY: CFC	DATE: 12/03/09	REV: A
DRAWN BY: DMD	DATE: 12/03/09	REV: A
CHK'D BY: DMD	DATE: 12/03/09	REV: A
ISSUED FOR CSC-CLIENT REVIEW	DATE: 12/03/09	REV: A



Cellco Partnership d/b/a Verizon Wireless
WIRELESS COMMUNICATIONS FACILITY
96 POWDER MILL ROAD
COLLINSVILLE 2
CANTON, CT 06022

DATE: 12/03/09
SCALE: AS NOTED
JOB NO. 09116

TITLE
SHEET

T-1
Sheet No. 1 of 2

