

From: [Aja Chase](#)
To: [CSC-DL Siting Council](#)
Subject: EM-CING-025B-220609
Date: Monday, November 6, 2023 10:34:01 AM
Attachments: [CT2081 - CBand - FSOSI - 10.31.2023.pdf](#)
[10050935.NYC-NJ_Photos.231006.CTL02081.Post_Construction_Photos-Bulk.\(Not_specified\).jif](#)

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click any links or open any attachments unless you trust the sender and know the content is safe.

Good Morning CSC,

Construction is now complete for the site below. The engineer letter and photo of overall work completed is attached. Please reach out if you need any additional information!

500 HIGHLAND AVENUE	CHESHIRE	6410	EM-CING-025B-220609
---------------------	----------	------	---------------------

Aja Chase

Construction Manager

AT&T NE Market

401-952-6205



Final Report of Special Inspections

Project: CT2081 (FA: 10050935)

Location: 500 Highland Avenue, Cheshire, CT 06410

Owner: AT&T Mobility

Engineer of Record: Daniel P. Hamm, P.E.

Tower Engineering Professionals, LLC (TEP OPCO, LLC)

To the best of my information, knowledge and belief, the Special Inspections required by Chapter 17 for the project have been performed and all discovered discrepancies have been reported and resolved.

Representatives of TEP Northeast performed the Final Inspections after the construction of the telecommunications facility at the above-referenced address. The Final Inspection was performed on October 25, 2023.

Based on my knowledge, information and belief the wireless installation substantially conforms to the approved plans, IBC 2015 with 2018 CT State Building Code Amendments, Structural Standards for Antenna Supporting Structures and Antennas (ANSI/TIA-222-H), and the following:

1. Final Rev. 1 Construction Drawings dated 04/22/2022, prepared by Hudson Design Group LLC, entitled "5G NR 1SR CBAND_BBU ADD_5G NR ACTIVATION_ANTENNA MODIFICATIONS_5G NR 1DR-1 UPGRADE."
2. Final Mount Structural Analysis dated 01/14/2022, prepared by Hudson Design Group LLC.

All deviations from the approved plans do not endanger the intended occupancy of the facility and equipment substitutions are approved as equivalent to the original specifications. This report does not include inspections for the findings of the global stability analysis and modifications to the structure. Those modification inspections, if required, are strictly the responsibility of the tower owner & general contractor performing such design and installation.

Interim reports submitted prior to this final report form a basis for and are to be considered an integral part of this final report.

Respectfully submitted,
Special Inspector

Daniel P. Hamm, P.E.
(Type or print name)

A handwritten signature in blue ink, appearing to read 'D. Hamm', written over a horizontal line.

Signature

10/31/2023

Date

