



🏠 750 W Center Street  
Suite 301  
West Bridgewater, MA 02379  
✉ info@clinellc.com  
☎ 1-(844)-748-8878

**T-Mobile**  
Cullen Morgan  
Site Acquisition Consultant  
750 W Center Street  
Suite 301  
West Bridgewater, MA 02379  
(941) 549-7263  
[cmorgan@clinellc.com](mailto:cmorgan@clinellc.com)

March 15, 2023

ATTN: Melanie A. Bachman, Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, Connecticut 06051

**RE: Commencement of Construction Activity – EM-T-MOBILE-027-211108  
21 E Main Street, Clinton, CT 06413**

Dear Ms. Bachman:

The purpose of this letter is to notify the Siting Council that the construction activity associated with the above-referenced T-Mobile telecommunications facilities has been completed.

If you have any questions or need any additional information regarding these facilities, please do not hesitate to contact me.

Respectfully,

Cullen Morgan  
Site Acquisition Consultant  
Centerline Communications, LLC (Agent to T-Mobile)  
Mobile: (941) 549-7263  
[cmorgan@clinellc.com](mailto:cmorgan@clinellc.com)

## Final Report of Special Inspections

**Project:** CT11031B (T-Mobile Anchor Project)  
**Location:** 21 East Main Street, Clinton, CT  
**Owner:** T-Mobile Northeast LLC

**Date:** March 14, 2023

Engineer of Record: Derek J. Creaser, P.E.  
Centerline Communications, LLC.

To the best of my information, knowledge and belief, the Special Inspections required for this project, and itemized in the *Statement of Special Inspections* submitted for permit, have been performed and all discovered discrepancies have been reported and resolved.

Representatives of Centerline Communications, LLC performed the Final Inspections after the construction of the telecommunications facility at the above-referenced address. The Final Inspection was performed on July 7, 2022.

Based on my knowledge, information, and belief the T-Mobile Installation substantially conforms to the approved plans, IBC 2015, 2018 CT State Building Code, Structural Standards for Antenna Supporting Structures and Antennas (ANSI/TIA-222-G), and the following:

1. Final Construction Drawings dated 11/04/21, prepared by Centerline Communications, LLC.

All deviations from the approved plans do not endanger the intended occupancy of the facility and equipment substitutions are approved as equivalent to the original specifications.

Interim reports submitted prior to this final report form a basis for and are to be considered an integral part of this final report.

Respectfully submitted,  
Special Inspector

Derek Creaser, P.E.  
Director of A&E  
Centerline Communications  
[dcreaser@clinellc.com](mailto:dcreaser@clinellc.com)