



October 2, 2023

VIA ELECTRONIC MAIL

Melanie A. Bachman, Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: CSC Approval EM-AT&T-029-230227 CT1254 Colebrook River Road
Generator Installation 382 Colebrook River Road, Colebrook, Connecticut

Dear Ms. Bachman,

The purpose of this letter is to notify the Siting Council that construction activity associated with the above-referenced decisions has been completed.

If you have any questions or need any additional information regarding this facility, please do not hesitate to contact me.

Sincerely,

Catherine Conklin
Site Acquisition Specialist
General Dynamics Wireless Services
4603 Kemper Street
Rockville, MD 20853
(301) 266-0258
catherine.conklin@gdit.com

GENERAL DYNAMICS
Information Technology

Generator Contractor Notice of Completion

I, Greg Marsh - Site Wireless, confirm that the awarded scope of work at site 10113275 - Colebrook Ct is complete, and all work meets industry standards and jurisdictional code requirements. All required inspections were completed, and all permits are closed. Please find the required notice of completion form with photos, etc. attached for your review and acceptance.

GC Signature Greg Marsh

You MUST copy and paste IDs from OneVizion here
In order for the system to receive this document.

Site Xitor ID 10012102317

Project Xitor ID 10021569823

Workflow ID 521517-B00364

Generator Contractor Notice of Completion

General Site Information	
FA Number	10113275
Address Line 1	
Address Line 2	382 COLEBROOK RIVER ROAD
City, State, Zip	COLEBROOK, CT 06021

Contractor Information	
Contractor Name	Site Wireless
PM or POC	Greg Marsh
Phone Number	860-729-9357
Email Address	gregmarsh@sitewireless.net

Final Accounting	
Base PO Amount	
Approved Work Authorizations	
Total Due at Final Acceptance	
Release of Liens	

Only ONE ITEM per field. PleaseZIP multiple items. Place photo icon directly on the red indicator.

Documentation	
Daily CHA Forms (zipped)	<input type="radio"/>
Permits Closed Out	<input type="radio"/>
Fuel Receipt (if applicable)	<input type="radio"/>
Redline CDs	<input type="radio"/>
Pre-Start Checklist	

Remember to RESIZE large photos. Also, ZIP Multiple Photos! Only one item allowed per field.

Notice of Completion - Photos

General Site Information		
Item #	Description	Photo
C1-GD	ATS installed and Grounded as per CD's	○
C2-GD	All foundations are oriented as per CD's	○
C3-GD	All foundations set, Square, Level & Correct Size as per CD's	○
C4-GD	All Conduits installed as per CD's	○
C5-GD	Automatic Transfer Switch (ATS) Installed (if applicable) / Cam-Lock	○
C6-GD	All wiring from the generator to the ATS correct gauge	
C7-GD	Generator Control & Alarm Wires Installed and Labeled w/66 block	
C8-GD	Generator frame attached to ground system with 2 hole lug	○
C9-GD	Housekeeping: All trash removed	○
C10-GD	Remove construction materials and clean site	○
C11-GD	Generator undamaged & clean	○
C12-GD	Fuel Tank Installed level and as per CD's	○

Item #	Description	Photo
C13-GD	Initial Fueling Complete, filled to 80%	
C14-GD	Individual alarms labeled and run to the 66 alarm block in shelter	
C15-AT&T	All documentation left on site including manual and keys	
C17-AT&T	Install information added to log book in site	o
C18-AT&T	Generator Commissioning Complete	o
C22-AT&T	Signage installed on generator	o
C23-AT&T	Padlocks installed on ATS and fuel door	o
A1	Pre-Construction Photos-General site area	o
A2	Foundation rebar photos, measure rebar size and spacing	o
A3	Generator Anchor Bolts to Slab, 2 each side	o
A4	Trench depth photos	
A5	Conduit installation depth	o
A6	CAD Weld from generator ground to existing ground ring	o

Item #	Description	Photo
A7	Post Construction Photos	<input type="radio"/>
B5	ATS Serial #	<input type="radio"/>
B6	Engine serial #	<input type="radio"/>
B7	Labeling of circuit breakers and panel schedule	<input type="radio"/>
B8	Site signage for compliance	
B9	Daily Logs-Site Log Book Photo Required	<input type="radio"/>

