



August 18, 2023

VIA ELECTRONIC MAIL

Melanie A. Bachman, Executive Director

Connecticut Siting Council

10 Franklin Square

New Britain, CT 06051

RE: CSC Approval EM-AT&T-030-230327 CTL05864 Columbia

Generator Installation 330 Middletown Road, Columbia, Connecticut

Dear Ms. Bachman,

The purpose of this letter is to notify the Siting Council that construction activity associated with the above-referenced decisions has been completed.

If you have any questions or need any additional information regarding this facility, please do not hesitate to contact me.

Sincerely,

Catherine Conklin

Site Acquisition Specialist

General Dynamics Wireless Services

2586 Industry Lane, Ste. 100

Norristown, Pa 19403

(202) 568-0437 phone

catherine.conklin@qdit.com

GENERAL DYNAMICS
Information Technology



GENERAC
INDUSTRIAL
POWER

CAUTION: NO OPEN FLAMES
**NO SMOKING
COMBUSTIBLE
FLAMMABLE
DIESEL FUEL**

190 GALLON
DIESEL FUEL
EMERGENCY
CONTACT
1-800-888-4747
11-300-6800-0001



DIESEL FUEL
COMBUSTIBLE
NO SMOKING
NO OPEN FLAMES

Generator Contractor Notice of Completion

I, Nick Stilwell, confirm that the awarded scope of work at site 10070977 COLUMBIA SOUTH E is complete, and all work meets industry standards and jurisdictional code requirements. All required inspections were completed, and all permits are closed. Please find the required notice of completion form with photos, etc. attached for your review and acceptance.

GC Signature Nick Stilwell

You MUST copy and paste IDs from OneVizion here
In order for the system to receive this document.

Site Xitor ID 10012101951

Project Xitor ID 10022149959

Workflow ID 521517-B00433

Generator Contractor Notice of Completion

General Site Information

FA Number	10070977
Address Line 1	330 MIDDLETOWN ROAD (RT 66 SOUTH)
Address Line 2	
City, State, Zip	COLUMBIA, CT 06237

Contractor Information

Contractor Name	Stilwell Plumbing
PM or POC	Nick Stilwell
Phone Number	443-452-0004
Email Address	Nick@stilwellplumbing.com

Final Accounting

Base PO Amount	
Approved Work Authorizations	
Total Due at Final Acceptance	
Release of Liens	

Only ONE ITEM per field. Please ZIP multiple items. Place photo icon directly on the red indicator.

Documentation	
Daily CHA Forms (zipped)	<input type="radio"/>
Permits Closed Out	<input type="radio"/>
Fuel Receipt (if applicable)	<input type="radio"/>
Redline CDs	<input type="radio"/>
Pre-Start Checklist	<input type="radio"/>

Remember to RESIZE large photos. Also, ZIP Multiple Photos! Only one item allowed per field.

Notice of Completion - Photos

General Site Information		
Item #	Description	Photo
C1-GD	ATS installed and Grounded as per CD's	○
C2-GD	All foundations are oriented as per CD's	○
C3-GD	All foundations set, Square, Level & Correct Size as per CD's	○
C4-GD	All Conduits installed as per CD's	○
C5-GD	Automatic Transfer Switch (ATS) Installed (if applicable) / Cam-Lock	○
C6-GD	All wiring from the generator to the ATS correct gauge	○
C7-GD	Generator Control & Alarm Wires Installed and Labeled w/66 block	○
C8-GD	Generator frame attached to ground system with 2 hole lug	○
C9-GD	Housekeeping: All trash removed	○
C10-GD	Remove construction materials and clean site	○
C11-GD	Generator undamaged & clean	○
C12-GD	Fuel Tank Installed level and as per CD's	○

Item #	Description	Photo
C13-GD	Initial Fueling Complete, filled to 80%	○
C14-GD	Individual alarms labeled and run to the 66 alarm block in shelter	○
C15-AT&T	All documentation left on site including manual and keys	○
C17-AT&T	Install information added to log book in site	○
C18-AT&T	Generator Commissioning Complete	○
C22-AT&T	Signage installed on generator	○
C23-AT&T	Padlocks installed on ATS and fuel door	○
A1	Pre-Construction Photos-General site area	○
A2	Foundation rebar photos, measure rebar size and spacing	○
A3	Generator Anchor Bolts to Slab, 2 each side	○
A4	Trench depth photos	○
A5	Conduit installation depth	○
A6	CAD Weld from generator ground to existing ground ring	○

Item #	Description	Photo
A7	Post Construction Photos	○
B5	ATS Serial #	○
B6	Engine serial #	○
B7	Labeling of circuit breakers and panel schedule	○
B8	Site signage for compliance	○
B9	Daily Logs-Site Log Book Photo Required	○