



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

**VIA ELECTRONIC MAIL**

October 22, 2020

Kenneth C. Baldwin, Esq.  
Robinson & Cole LLP  
280 Trumbull Street  
Hartford, CT 06103-3597

RE: **TS-VER-031-200619** – Cellco Partnership d/b/a Verizon Wireless request for an order to approve tower sharing at an existing telecommunications facility located at 16 Bell Road Extension, Cornwall, Connecticut.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated October 20, 2020 regarding the proposed project changes to the above-referenced tower share that was approved by the Council on July 17, 2020.

Pursuant to Condition No. 1 of the Council's Decision on July 17, 2020, your request to increase the capacity of the approved emergency backup generator from 20-kilowatts to 30-kilowatts is hereby approved.

This approval applies only to the above referenced project changes dated October 20, 2020. Any significant changes to the project require advance Council notification and approval.

Thank you for your attention and cooperation.

Sincerely,

*s/ Melanie A. Bachman*

Melanie Bachman  
Executive Director

MAB/IN/emr

KENNETH C. BALDWIN

280 Trumbull Street  
Hartford, CT 06103-3597  
Main (860) 275-8200  
Fax (860) 275-8299  
kbaldwin@rc.com  
Direct (860) 275-8345

Also admitted in Massachusetts  
and New York

October 20, 2020

*Via Electronic Mail*

Melanie A. Bachman, Esq.  
Executive Director/Staff Attorney  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: **TS-VER-031-200619 – Cellco Partnership d/b/a Verizon Wireless request for an order to approve tower sharing at an existing telecommunications facility located at 16 Bell Road Extension, Cornwall, Connecticut.**

**Request for Staff Approval of Minor Project Changes**

Dear Attorney Bachman:

I write, on behalf of Cellco Partnership d/b/a Verizon Wireless (“Cellco”), to request the approval of a minor project modification involving its approved shared use of the telecommunications facility approved in TS-VER-031-200619.

Since receiving the Council’s approval, Cellco has decided to increase the size of its back-up generator at this site from 20 kW to 30 kW. (Generator Specification attached). No other facility modifications are required to accommodate the larger generator, which will fit on the approved concrete pad within the facility compound.

Please feel free to contact me if you have any questions or need any additional information. Thank you in advance for your cooperation.

Sincerely,



Kenneth C. Baldwin

# 30RE0ZK

30 kW Generator



**KOHLER**<sup>®</sup>  
IN POWER. SINCE 1920.

# LEGENDARY KOHLER QUALITY

## FOR SMALL SPACES

### COMPACT FOOTPRINT

Our 76.5" x 32" rectangular footprint is specially designed for cell tower site applications.

### QUIET PERFORMANCE

Our sound enclosure delivers a sound performance of 65 dBA— which is among the quietest available.

### RELIABLE POWER


Our direct engine/alternator design eliminates the possibility of generator failure due to improper adjustment or belt breakdowns.

### SINGLE-SIDE SERVICE


Maintenance is easy. All frequently serviced touch points are located on a single side and accessible by an easy-to-remove lift off door.

## 30RE0ZK

Front View



Top View



MODEL	30RE0ZK
FUEL TYPE	Diesel
ENGINE MAKER	Kohler KDI
OPERATING SPEED (rpm)	1800
CONTROLLER	Kohler Decision-Maker 3000
VOLTAGE	120/240 1 Phase
TANK GALLON/48 HRS @ FULL LOAD	203
TANK*	Standard, Double Wall
OVERALL DIMENSIONS L x W x H in	76.5 x 32.0 x 47.0
WEIGHT lbs	1130
PEOPLESOFT NUMBER	21099077

\*Alternative tank sizes, state tanks and 3 phase models available.