

May 12, 2016

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-033-150327 – Cellco Partnership d/b/a Verizon Wireless
179 Shunpike Road, Cromwell, Connecticut**

Dear Ms. Bachman:

On April 26, 2015, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 179 Shunpike Road in Cromwell, Connecticut. The modifications involved the replacement of its existing antennas with newer model antennas.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter confirming that it has complied with the recommendations made in the structural report included with its filing. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to the structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment
Copy to:
Tim Parks

May 11, 2016

Mr. Tim Parks
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Cromwell North
179 Shunpike Road, Cromwell, CT

Tower Owner: Cromwell Fire Department
82 Court Street, Cromwell, CT

Engineer: URS Coporation
500 Enterprise Drive, Suite 3B, Rocky Hill, CT

Centek Project No.: 15003.023

CSC Exempt Mod Reference No.: EM-VER-033-150327

Dear Mr. Parks,


We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by URS Coporation (URS Project Number: 36928711.00000 VZ5-192):

- ❑ Review of the URS Coporation Structural Analysis dated 01/07/2015.
- ❑ Review of the URS Modification Drawing SK-1 dated 09/22/2014.
- ❑ Field observations by Centek Engineering personnel on 10/30/2015 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the structural analysis report prepared by URS Coporation on 01/07/2015.

The modification design prepared by URS Coporation demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,


Carlo F. Centore, PE
Principal - Structural

