

**From:** Mayo, Rachel <rmayo@RC.com>  
**Sent:** Friday, October 1, 2021 9:29 AM  
**To:** Bachman, Melanie <Melanie.Bachman@ct.gov>; CSC-DL Siting Council <Siting.Council@ct.gov>  
**Cc:** Baldwin, Kenneth <KBALDWIN@RC.com>; alex.tyurin@verizonwireless.com; Mayo, Rachel <rmayo@RC.com>  
**Subject:** RE: EM-VER-047-210817 - 50 Plantation Road, East Windsor, CT re Incomplete Exempt Mod Filing

Good morning, Please see the attached Revised Structural Report in response to the council's incomplete letter. This report better clarifies the information needed.

Please let us know if you have any questions or need additional information.

Thank you

**Rachel A. Mayo**  
**Land Use Analyst**

Robinson & Cole LLP  
280 Trumbull Street  
Hartford, CT 06103  
Direct 860.275.8213 | Fax 860.275.8299  
[rmayo@rc.com](mailto:rmayo@rc.com) | [Bio](#) | [V-Card](#)

---



September 30, 2021 (Rev 1)

Verizon Wireless  
20 Alexander Drive  
Wallingford, CT 06492

Attn: Mr. David Vivian

Re: Structural Analysis Report  
Verizon Site I.D.: South Windsor North CT - LSub6 - Carrier Add  
50 Plantation Road  
East Windsor, CT 06016

Project/Location Code: 20171646071/469756  
VZW FUZE I.D.: 16560063  
APT Filing No. CT141\_12500

Dear Mr. Vivian,

All-Points Technology Corp. (APT), a professional engineering corporation licensed in the State of Connecticut, performed a structural analysis of the above existing 133-ft $\pm$  high elevated water reservoir to support a proposed antenna and appurtenance modification.

Details of the proposed antenna and appurtenance modification are included within the table on the following page. Reference is made to the Construction Drawings prepared by this office, marked Rev 0, dated 07/07/21.

The following information was utilized in the preparation of this assessment:

- Construction Drawings prepared by APT, marked Rev1, dated 11/06/2020
- Tank Reinforcement Drawings, prepared by APT, marked Rev0, dated 07/09/20.
- Structural Modification Design Report, prepared by APT, dated 07/09/20.
- SK-S1 - Foundation Reinforcement Details, marked Rev1, dated 06/08/21.
- SK-S2 & S3 - Reinforcement Details, marked Rev1, dated 06/30/21.

The structural analysis has been prepared in accordance with the following design standards:

- ASCE/SEI 7-10 - Minimum Design Loads for Buildings and Other Structures
- AISC - American Institute of Steel Construction Manual of Steel Construction, 14<sup>th</sup> Ed.
- IBC 2015 - as amended by the 2018 Connecticut State Building Code.
- ANSI/TIA-222-H - Structural Standard for Antenna Supporting Structures, Antennas and Small Wind Turbine Support Structures

#### Design Criteria:

- Load Case 1: 125 mph (3-sec gust), Ultimate Wind Speed
- Load Case 2: 125 mph (3-sec gust), Ultimate Wind Speed 0.9 x Dead Load
- Structure Class II
- Exposure Category C
- Topographic Category 1

Note: Risk Category II used. (Water tank no longer in service).

The analysis consists was conducted utilizing the following equipment inventory (proposed equipment indicated in **bold** text):

Carrier	Antenna and Appurtenance Make/Model	Elevation	Status	Mount Type	Coax/Feed-Line
Clearwire	(2) 3-ft Dia. Microwave Dishes (Dragonwave A-ANT-23-G-2.5 est.)	125'±	E	(3) Pipe Mounts	(3) 1-1/4" RF Hyrbriflex, (2) 1/2", (2) 2-1/4" Innerduct
Clearwire	(3) Fiber Boxes	124'±	E		
Clearwire	(3) Argus LLPX310R-V4 panel antennas	119'±	E		
Clearwire	(3) Remote Radio Units	116'±	E		
Sprint	(2) RFS APVX9ERR18-C-A20, (1) RFS APVXSPP18-C-A20, (3) ALU 800 MHz 2x50W RRHs & (3) ALU 1900MHz 4x40W RRHs	121'±	E	(3) Pipe Mounts	
Clearwire	(1) Fiber Box	109'±	E	Catwalk Rail	n/a
MetroPCS/ T-Mobile	(3) RFS APVX18-206517S-C panel antennas	119'±	E	(3) Pipe Mounts	(6) 1-5/8
AT&T	(6) Powerwave 7770 panel antennas, (2) Powerwave P65-17-XLH-RR panel antennas, (1) KMW AM-X-CD-16-65-00T-RET panel antenna (12) Powerwave LGP 21401 TMAs, (3) Ericsson RRUS-11, (3) Ericsson RRUS-12 and (3) Raycap DC2 Surge Suppressors (est.)	112 - 113'±	E	(3) Pipe Mounts (shared with Clearwire & MetroPCS/T-Mobile)	(12) 1-5/8", (2) 5/8" & (1) 3/8" fiber/DC cables (est.)
Verizon	(3) Commscope NHSS-65B-R2B, (3) Commscope NHH-65B-R2B panel antennas, (3) Samsung MT6407-77A antennas (3) Samsung B5/B13 RRH-BR04C Remote Radio Heads (RRHs), (3) Samsung B2/B66A RRH-BR049 RRHs, (3) Samsung CBRS RT4401-48A RRHs (3) Raycap RHSDC-3315-PF-48 Over Voltage Protection Boxes (OVPs)	102'94'	P	Custom Pipe Mounts Attached to Exist. Tank Legs	(3) 6x12 Low Inductance Hybrid Fiber Cables (Routed within Southwest Bull-Up Lattice Leg Channels)
Clearwire	One (1) Fiber Box	10'±	E	Leg	n/a

### Analysis Results:

The analysis was conducted in accordance with the criteria outlined above, with the aforementioned existing and proposed equipment loading. The following table summarizes the results of the analysis:

Component	Usage (%)
New Sway Rods	94%
Reinforced Wing Plates	97%
Anchor Bolts	58%

#### Notes:

1. ASTM A36 steel grade used for the basis of the new sway rod design.
2. Existing anchor bolts include 1/8" corrosion allowance.
3. Anchor bolt usage includes (1) new 3/4"dia. anchor bolt per leg.
4. Assumes reservoir no longer used for water storage.
5. Reinforced gusset plates (Pin bearing on plate controls).

**Base Foundation:**

Evaluation of the existing foundation system was limited to a global stability check with the existing and proposed loading. The existing foundation geometry was established through field investigation conducted by APT during May 2017, and during construction of the new build project during June 2021. Subgrade conditions were based on presumptive soil parameters per TIA-222-H Section 9.4, and Table F-1 (Annex F) & IBC 2015.

The calculated leg and base reactions with the above noted loading are as follows:

Load Effect	Calculated Base Reactions	Usage
Axial	74 k	n/a
Shear	70 k	n/a
Overspinning Moment	5291 ft-k	n/a
Leg Uplift	95 k	0.75<1.0 (PASS)

1 kip = 1,000lbs

**Conclusions:**

Successful completion of the reinforcements detailed within the attached drawings, will result in a host structure that meet the requirements of the 2015 International Building Code, as amended by the 2018 Connecticut State Building Code.

Sincerely,  
All-Points Technology Corp., P.C.



Michael S. Trodden, P.E.  
Sr. Structural Engineer

Prepared by:  
All-Points Technology Corp., P.C.



Jason R. Mead  
Department Manager –  
Structural Services



**Limitations:**

This report is based on the following:

1. Tower/structure is properly installed and maintained.
2. All members are in a non-deteriorated condition.
3. All required members are in place.
4. All bolts are in place and are properly tightened.
5. Tower/structure is in plumb condition.
6. All tower members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.

All-Points Technology Corporation, P.C. (APT) is not responsible for any modifications completed prior to or hereafter which APT is not or was not directly involved. Modifications include but are not limited to:

1. Replacing or reinforcing bracing members.
2. Reinforcing members in any manner.
3. Installing antenna mounts.
4. Extending tower/structure.

APT hereby states that this document represents the entire report and that it assumes no liability for any factual changes that may occur after the date of this report. All representations, recommendations, and conclusions are based upon the information contained and set forth herein. If you are aware of any information which is contrary to that which is contained herein, or you are aware of any defects arising from the original design, material, fabrication and erection deficiencies, you should disregard this report and immediately contact APT. APT disclaims all liability for any representation, recommendation, or conclusion not expressly stated herein.

# ***Appendix A***

*Calculations*

(APPENDIX N) MUNICIPALITY - SPECIFIC STRUCTURAL DESIGN PARAMETERS													
Municipality	Ground Snow Load (psf)	Wind Design Parameters											Hurricane-Prone Regions
		MCE Spectral Acceleration s (%g)		Ultimate Design Wind Speeds, $V_{ult}$ (mph)			Nominal Design Wind Speeds, $V_{asd}$ (mph)			Wind-Borne Debris Regions <sup>1</sup>			
		$S_s$	$S_1$	Risk Cat.I	Risk Cat.II	Risk Cat. III-IV	Risk Cat. I	Risk Cat. II	Risk Cat. III-IV	Risk Cat. II & III except Occup I-2	Risk Cat. III Occup I-2 & Risk Cat. IV		
East Hampton	30	0.177	0.062	120	130	140	93	101	108			Yes	
East Hartford	30	0.180	0.064	115	125	135	89	97	105			Yes	
East Haven	30	0.182	0.062	120	130	140	93	101	108		Type B	Yes	
East Lyme	30	0.164	0.059	125	135	145	97	105	112	Type B	Type A	Yes	
Easton	30	0.215	0.066	110	120	130	85	93	101			Yes	
East Windsor	35	0.177	0.064	115	125	135	89	97	105			Yes	
Ellington	35	0.176	0.064	115	125	135	89	97	105			Yes	
Enfield	35	0.176	0.065	110	125	130	85	97	101			Yes	
Essex	30	0.168	0.059	120	135	145	93	105	112	Type A	Type A	Yes	
Fairfield	30	0.215	0.065	115	125	135	89	97	105	Type B	Type B	Yes	
Farmington	35	0.183	0.064	115	125	135	89	97	105			Yes	
Franklin	30	0.171	0.061	120	130	140	93	101	108	Type A	Type A	Yes	
Glastonbury	30	0.180	0.063	115	125	135	89	97	105			Yes	
Goshen	40	0.181	0.065	105	115	125	81	89	97				
Granby	35	0.176	0.065	110	120	130	85	93	101			Yes	
Greenwich	30	0.259	0.070	110	120	130	85	93	101			Yes	
Griswold	30	0.168	0.060	125	135	145	97	105	112	Type A	Type A	Yes	
Groton	30	0.160	0.058	125	135	145	97	105	112	Type B	Type A	Yes	
Guilford	30	0.176	0.061	120	130	140	93	101	108	Type B	Type B	Yes	
Haddam	30	0.175	0.061	120	130	140	93	101	108			Yes	
Hamden	30	0.185	0.063	115	125	135	89	97	105			Yes	
Hampton	35	0.172	0.062	120	130	140	93	101	108			Yes	
Hartford	30	0.181	0.064	115	125	135	89	97	105			Yes	
Hartland	40	0.175	0.065	110	120	125	85	93	97			Yes	
Harwinton	35	0.183	0.065	110	120	130	85	93	101			Yes	
Hebron	30	0.177	0.063	120	130	140	93	101	108			Yes	
Kent	40	0.188	0.065	105	115	120	81	89	93				
Killingly	40	0.171	0.062	120	130	140	93	101	108			Yes	
Killingworth	30	0.173	0.061	120	130	140	93	101	108			Yes	
Lebanon	30	0.173	0.062	120	130	140	93	101	108			Yes	
Ledyard	30	0.163	0.059	125	135	145	97	105	112	Type A	Type A	Yes	
Lisbon	30	0.169	0.061	125	135	145	97	105	112	Type A	Type A	Yes	
Litchfield	40	0.184	0.065	110	120	125	85	93	97			Yes	
Lyme	30	0.164	0.059	125	135	145	97	105	112	Type A	Type A	Yes	
Madison	30	0.173	0.060	120	130	140	93	101	108	Type B	Type B	Yes	
Manchester	30	0.178	0.064	115	125	135	89	97	105			Yes	
Mansfield	35	0.173	0.062	120	130	140	93	101	108			Yes	
Marlborough	30	0.177	0.062	120	130	140	93	101	108			Yes	
Meriden	30	0.183	0.063	115	125	135	89	97	105			Yes	
Middlebury	35	0.191	0.064	110	120	130	85	93	101			Yes	
Middlefield	30	0.181	0.063	115	125	135	89	97	105			Yes	
Middletown	30	0.180	0.063	115	130	135	89	101	105			Yes	
Milford	30	0.194	0.063	115	125	135	89	97	105	Type B	Type B	Yes	
Monroe	30	0.205	0.065	110	120	130	85	93	101			Yes	

# ASCE 7 Hazards Report

**Address:**

50 Plantation Rd  
Broad Brook, Connecticut  
06016



**Standard:** ASCE/SEI 7-10

**Risk Category:** II

**Soil Class:** D - Stiff Soil

**Elevation:** 158.08 ft (NAVD 88)

**Latitude:** 41.87543

**Longitude:** -72.564799


## Wind

**Results:**

Wind Speed:	122 Vmph
10-year MRI	76 Vmph
25-year MRI	86 Vmph
50-year MRI	93 Vmph
100-year MRI	100 Vmph

**Data Source:**

ASCE/SEI 7-10, Fig. 26.5-1A and Figs. CC-1–CC-4, and Section 26.5.2, incorporating errata of March 12, 2014

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-10 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).

Site is in a hurricane-prone region as defined in ASCE/SEI 7-10 Section 26.2. Glazed openings need not be protected against wind-borne debris.



## Seismic

**Site Soil Class:** D - Stiff Soil

**Results:**

$S_s$ :	0.177	$S_{DS}$ :	0.189
$S_1$ :	0.064	$S_{D1}$ :	0.103
$F_a$ :	1.6	$T_L$ :	6
$F_v$ :	2.4	PGA :	0.088
$S_{MS}$ :	0.284	PGA <sub>M</sub> :	0.141
$S_{M1}$ :	0.154	$F_{PGA}$ :	1.6
		$I_e$ :	1

**Seismic Design Category** B



**Data Accessed:**

Wed Jul 14 2021

**Date Source:**

USGS Seismic Design Maps based on ASCE/SEI 7-10, incorporating Supplement 1 and errata of March 31, 2013, and ASCE/SEI 7-10 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-10 Ch. 21 are available from USGS.

## All-Points Technology Corporation

Consulting Engineers  
3 Saddlebrook Drive,  
Killingworth, CT 06419  
Ph. 860-663-1697  
Fax. 860-663-0935

Subject: **Antenna & Appurtenance Area Calculations**  
Project: **Verizon - South Windsor North CT - LSub6**  
Prepared: **07.09.21**

Revised:

APT Job No.

**CT141\_12500**

Antenna and Appurtenance Area Calculations																
Height	Carrier/Equipment	Item Quantity	Dimensions			Item Area (ft <sup>2</sup> ) (ea)	Aspect Ratio	Flat or Round	Cf	CfAa	Shielding Factor	Rotational Area Factor	Total CfAa (ft <sup>2</sup> )	Adjusted Net CfAa (ft <sup>2</sup> )	Weight (ea) (lbs)	Weight (Total) (lbs)
			H (in)	W (in)	D (in)											
94.00	Prop. Verizon LSub6 Antennas	2.00	35.1	16.1	5.5	3.92	2.18	FLAT	1.32	5.18	1.00	0.70	10.36	7.25	87.1	174.20
94.00	Prop. Verizon LSub6 Antennas	1.00	35.1	16.1	5.5	3.92	2.18	FLAT	1.32	5.18	1.00	1.00	5.18	5.18	87.1	87.10
102.00	Prop. Verizon Panel Antennas	4.00	72.0	11.9	7.1	5.95	6.05	FLAT	1.38	8.24	1.00	0.70	32.94	23.06	60.0	240.00
102.00	Prop. Verizon Panel Antennas	2.00	72.0	11.9	7.1	5.95	6.05	FLAT	1.38	8.24	1.00	1.00	16.47	16.47	60.0	120.00
94.00	Prop. Verizon B2/B66A RRH BR049	2.00	15.0	15.0	10.0	1.56	1.00	FLAT	1.30	2.03	1.00	0.70	4.06	2.84	97.5	195.00
94.00	Prop. Verizon B2/B66A RRH BR049	1.00	15.0	15.0	10.0	1.56	1.00	FLAT	1.30	2.03	1.00	1.00	2.03	2.03	97.5	97.50
94.00	Prop. Verizon B5/B13 RRH BR04C	2.00	15.0	15.0	8.1	1.56	1.00	FLAT	1.30	2.03	1.00	0.70	4.06	2.84	82.0	164.00
94.00	Prop. Verizon B5/B13 RRH BR04C	1.00	15.0	15.0	8.1	1.56	1.00	FLAT	1.30	2.03	1.00	1.00	2.03	2.03	82.0	82.00
94.00	Prop. Verizon Samsung CBRS RT44001-48A RRH	2.00	10.6	8.9	3.0	0.66	1.19	FLAT	1.30	0.85	1.00	0.70	1.71	1.20	11.0	22.00
94.00	Prop. Verizon Samsung CBRS RT44001-48A RRH	1.00	1.0	1.0	1.0	0.01	1.00	FLAT	1.30	0.01	1.00	1.00	0.01	0.01	11.0	11.00
102.00	Prop. Verizon 6OVP	2.00	29.5	16.5	12.6	3.38	1.79	FLAT	1.31	4.44	1.00	0.70	8.88	6.21	32.0	64.00
102.00	Prop. Verizon 6OVP	1.00	29.5	16.5	12.6	3.38	1.79	FLAT	1.31	4.44	1.00	1.00	4.44	4.44	32.0	32.00
98.00	Prop. Verizon Pipe Mounts (For Ant + RRHs)	6.00	180.0	3.5	3.5	4.38	51.43	ROUND	1.20	5.25	1.00	1.00	31.50	31.50	115.0	690.00
98.00	Prop. Verizon Mounts	3.00				3.00			1.40	4.20	1.00	1.00	12.60	12.60	80.0	240.00
													<b>Subtotal</b>	<b>136.27</b>	<b>117.67</b>	<b>2218.80</b>
112.00	Exist. AT&T Panel Antennas (KMW AM-X-CD-16-65-00T-RET)	1.00	72.0	11.8	5.9	5.90	6.10	FLAT	1.39	8.17	1.00	0.70	8.17	5.72	48.5	48.50
112.00	Exist. AT&T Panel Antennas (Powerwave P65-17-XLH-RR)	1.00	96.0	12.0	6.0	8.00	8.00	FLAT	1.43	11.47	1.00	1.00	11.47	11.47	62.0	62.00
112.00	Exist. AT&T Panel Antennas (Powerwave P65-17-XLH-RR)	1.00	96.0	12.0	6.0	8.00	8.00	FLAT	1.43	11.47	1.00	0.70	11.47	8.03	62.0	62.00
112.50	Exist. AT&T Panel Antennas (Powerwave 7770)	4.00	55.0	11.0	5.0	4.20	5.00	FLAT	1.37	5.74	1.00	0.70	22.97	16.08	39.0	156.00
112.50	Exist. AT&T Panel Antennas (Powerwave 7770)	2.00	55.0	11.0	5.0	4.20	5.00	FLAT	1.37	5.74	1.00	1.00	11.48	11.48	39.0	78.00
113.50	Exist. AT&T TMA (Powerwave LGP21401)	4.00	14.4	9.2	2.6	0.92	1.57	FLAT	1.31	1.20	1.00	1.00	4.82	4.82	14.1	56.40
113.50	Exist. AT&T TMA (Powerwave LGP21401)	8.00	14.4	9.2	2.6	0.92	1.57	FLAT	1.31	1.20	1.00	0.70	9.64	6.75	14.1	112.80
113.50	Exist. AT&T RRUs (Ericsson RRUS 11)	2.00	19.7	17.0	7.2	2.33	1.16	FLAT	1.30	3.03	1.00	0.70	6.06	4.24	50.0	100.00
113.50	Exist. AT&T RRUs (Ericsson RRUS 11)	1.00	19.7	17.0	7.2	2.33	1.16	FLAT	1.30	3.03	1.00	1.00	3.03	3.03	50.0	50.00
113.50	Exist. AT&T RRUs (Ericsson RRUS 12)	2.00	20.4	18.5	7.5	2.62	1.10	FLAT	1.30	3.41	1.00	0.70	6.82	4.78	50.0	100.00
113.50	Exist. AT&T RRUs (Ericsson RRUS 12)	1.00	20.4	18.5	7.5	2.62	1.10	FLAT	1.30	3.41	1.00	1.00	3.41	3.41	50.0	50.00
113.50	Exist. AT&T SA (DC2-48-60-09E, est.)	2.00	10.4	6.3	10.8	0.46	1.65	ROUND	1.31	0.60	1.00	0.70	1.19	0.84	16.0	32.00
113.50	Exist. AT&T SA (DC2-48-60-09E, est.)	1.00	10.4	6.3	10.8	0.46	1.65	ROUND	1.31	0.60	1.00	1.00	0.60	0.60	16.0	16.00
													<b>Subtotal</b>	<b>101.13</b>	<b>81.23</b>	<b>923.70</b>
119.00	MetroPCS/T-Mobile Panel Antennas (RFS APXV18-206517S-C)	2.00	72.0	6.8	3.2	3.40	10.59	FLAT	1.52	5.17	1.00	0.70	10.33	7.23	26.4	52.80
119.00	MetroPCS/T-Mobile Panel Antennas (RFS APXV18-206517S-C)	1.00	72.0	6.8	3.2	3.40	10.59	FLAT	1.52	5.17	1.00	1.00	5.17	5.17	26.4	26.40
													<b>Subtotal</b>	<b>15.50</b>	<b>12.40</b>	<b>79.20</b>
121.00	Exist. Sprint Panel Antennas (RFS APXV Series)	2.00	72.0	11.8	7.0	5.90	6.10	FLAT	1.39	8.17	1.00	0.70	16.34	11.44	57.0	114.00
121.00	Exist. Sprint Panel Antennas (RFS APXV Series)	1.00	72.0	11.8	7.0	5.90	6.10	FLAT	1.39	8.17	1.00	1.00	8.17	8.17	57.0	57.00
115.50	Exist. Sprint RRHs (800 MHz RRH)	2.00	15.7	13.0	9.8	1.42	1.21	FLAT	1.30	1.85	1.00	0.70	3.70	2.59	53.0	106.00
115.50	Exist. Sprint RRHs (800 MHz RRH)	1.00	15.7	13.0	9.8	1.42	1.21	FLAT	1.30	1.85	1.00	1.00	1.85	1.85	53.0	53.00
112.50	Exist. Sprint RRHs (1900 MHz RRH)	2.00	25.0	11.1	11.4	1.93	2.25	FLAT	1.32	2.55	1.00	0.70	5.09	3.56	60.0	120.00
112.50	Exist. Sprint RRHs (1900 MHz RRH)	1.00	25.0	11.1	11.4	1.93	2.25	FLAT	1.32	2.55	1.00	1.00	2.55	2.55	60.0	60.00
													<b>Subtotal</b>	<b>37.70</b>	<b>30.16</b>	<b>510.00</b>
10.00	Exist. CW Fiber Box (1															

Consulting Engineers 3 Saddlebrook Drive, Killingworth, CT 06419 Ph. 860-663-1697 Fax. 860-663-0935	Subject: <b>Water Reservoir Wind Load Calculations</b>
Project: <b>Verizon - South Windsor North CT - LSub6</b>	
Prepared: <b>07.09.21</b>	Revised:
	CT141_12500

**1k Wind Load Distribution (ASCE 7-10) Tank Empty****Due to the height of the structure, the analytical method is required.**

Ultimate Wind Speed (3 Sec Gust), V =  
Risk Category =  
Exposure Category =  
Base Tower Cross-Section =



Appendix N 2018 CSBC  
Note: Structure no longer utilized as a water tank and is empty.  
2015 IBC Section 1609.4.3  
Enter 'SQ' for Square, 'T' for Triangle)

**Terrain Exposure Constants:**

Topographic Factor, Kz = 1.00 ASCE 7-10 Sec. 26.8.2  
Wind Directionality Factor, Kd = 0.85 Tower ASCE 7-10 Table 26.6-1  
0.95 Standpipe/Reservoir

3-Sec Gust Speed Power Law Exponent  $\alpha$  = 9.5 ASCE 7-10 Table 26.9-1  
Nominal Height of the Atmospheric Boundary Layer (zg) = 900 ASCE 7-10 Table 26.9-1  
Gust Response Factor, G (Tank) = 0.85 ASCE 7-10 Sec. 26.9.1

$K_{zmin} = 0.85$  ASCE 7-10  
Velocity Pressure at height z, qz =  $qz = 0.00256 Kz Kd V^2$  ASCE 7-10 [Eq. 29.3-1] Sec. 29.3.2  
Design Wind Load, P =  $F = qz G C_f A_f \geq 10 \text{ psf}$  ASCE 7-10 [Eq. 29.5-1] Sec. 29.8

**Water Tower Wind Load Calculation - Support Tower**

Component	Top of Section Elevation (ft)	Bottom of Section Elevation (ft)	$\Delta h$ (ft)	Outside Width at Top (ft)	Outside Width at Bottom (ft)	Aleg (ft <sup>2</sup> )	Agirts (ft <sup>2</sup> )	Ar (ft <sup>2</sup> )	AR (Sway Rods) (ft <sup>2</sup> )	AG (ft <sup>2</sup> )
Support Tower	109	74	35	14.85	21.77	100.00	0.00	100.00	9.13	640.85
Support Tower	74	37	37	21.77	29.09	104.65	14.02	118.67	10.45	940.91
Support Tower	37	0	37	29.09	36.41	104.65	18.83	123.48	11.61	1211.75

z bar (ft)	Kz	qz	e	CF	RR	DF	DR	DFAF	DRARRR	AE (ft <sup>2</sup> )	F (kips)	OTM (ft-kips)
91.5	1.24	42.23	0.170	3.111	0.585	1.00	1.00	100.00	5.34	105.34	11.77	1076.52
55.5	1.12	38.01	0.137	3.266	0.580	1.00	1.00	118.67	6.06	124.73	13.16	730.46
18.5	0.89	30.16	0.111	3.392	0.576	1.00	1.00	123.48	6.69	130.17	11.32	209.44
										36	2016	

**Water Tower Wind Load Calculation - Stand Pipe, Reservoir and Appurtenances**

Component	Top of Section Elevation (ft)	Bottom of Section Elevation (ft)	$\Delta h$ (ft)	Depth (ft)	Diameter (ft <sup>2</sup> )	Ar (ft <sup>2</sup> )	z bar (ft)	Kz	qz	CF	F (kips)	OTM (ft-kips)	
Stand-Pipe	100	74	26		3.00		78.00	87.0	1.23	46.70	0.70	2.17	188.58
Stand-Pipe	74	37	37		3.00		111.00	55.5	1.12	42.49	0.70	2.81	155.74
Stand-Pipe	37	0	37		3.00		111.00	18.5	0.89	33.71	0.70	2.23	41.19
Ladder	112.5	74	38.5	0.2		7.70		93.3	1.25	42.40	2.00	0.56	51.76
Ladder	74	37	37	0.2		7.40		55.5	1.12	38.01	2.00	0.48	26.54
Ladder	37	0	37	0.2		7.40		18.5	0.89	30.16	2.00	0.38	7.02
Dome Bulb	109	100	9			133.00	104.5	1.28	48.54	0.50	2.74	286.73	
Reservoir Cylinder	127	109	18		19.00		342.00	118.0	1.31	49.80	0.50	7.24	854.12
Reservoir Ladder	129	109	20	0.2		4.00		119.0	1.31	44.64	2.00	0.30	36.12
Exposed Catwalk	112	109	3			4.00		110.5	1.29	43.95	2.00	0.30	33.02
Cone Roof	132.5	125.67	6.83			88.20	129.1	1.34	50.75	0.50	1.90	245.56	
Finial	134.3	133.3	1		0.67		0.67	133.8	1.35	45.75	0.50	0.01	1.74

**Water Tower Wind Load Calculation - Antennas & Appurtenances**

Component	Top of Section Elevation (ft)	Bottom of Section Elevation (ft)	z bar (ft)	Kz	qz	CFaa (from Equip. Worksheet) (ft <sup>2</sup> )	F (kips)	OTM (ft-kips)
Exposed Coaxial Cables	112	74	93.0	1.25	47.36	15.05	0.61	56.34
Exposed Coaxial Cables	74	37	55.5	1.12	42.49	14.65	0.53	29.37
Exposed Coaxial Cables	37	10	23.5	0.93	35.46	10.69	0.32	7.57
CW MW Dishes	125	125	125.0	1.33	45.10	18.80	0.72	90.09
CW Fiber Boxes	124	124	124.0	1.32	45.02	1.58	0.06	7.50
Sprint Panels	121	121	121.0	1.32	44.79	19.61	0.75	90.35
CW Panels	119	119	119.0	1.31	44.64	11.14	0.42	50.27
MetroPCS/T-Mobile Panels	119	119	119.0	1.31	44.64	12.40	0.47	55.99
Exposed Pipe Mounts	117	117	117.0	1.31	49.71	20.69	0.87	102.29
CW RRHs	116	116	116.0	1.31	44.40	5.17	0.20	22.64
Sprint 800 MHz RRHs	115.5	115.5	115.5	1.30	44.36	4.44	0.17	19.34
Sprint 1900 MHz RRHs	112.5	112.5	112.5	1.30	44.11	6.11	0.23	25.77
AT&T RRUs, TMAs & SA	113.5	113.5	113.5	1.30	44.19	28.45	1.07	121.32
AT&T Panels	112.5	112.5	112.5	1.30	44.11	27.56	1.03	116.26
AT&T Panels	112	112	112.0	1.30	44.07	25.21	0.94	105.78
CW Fiber Boxes	109	109	109.0	1.29	43.82	1.77	0.07	7.18
Prop. Verizon Pipe Mounts	98	98	98.0	1.26	47.89	31.50	1.28	125.66
Prop. Verizon Mounts	98	98	98.0	1.26	42.85	12.60	0.46	44.97
Prop. Verizon Panels & OVPs	102	102	102.0	1.27	43.21	50.18	1.84	187.99
Prop. Verizon Panels & RRHs	94	94	94.0	1.25	42.47	23.37	0.84	79.31
CW Fiber Box	10	10	10.0	0.85	28.90	1.02	0.03	0.25
					342.00	12.91		1346.25

Total Axial Force Above Grade (P) = **74.3** kips (Gross tank material weight minus stand pipe & 1/2 spider rods + equipment weight used for foundation analysis)Horizontal Force at Level 3 without Antennas **19.7**Horizontal Force at Level 3 with Antennas **31.5**Horizontal Force at Level 2 Girts without Antennas **35.2**Horizontal Force at Level 2 Girts with Antennas **47.5**Horizontal Force at Level 1 Girts without Antennas **50.4**Horizontal Force at Level 1 Girts with Antennas **63.1**

All-Points Technology Corporation

Consulting Engineers  
3 Saddlesbrook Drive,  
Killingworth, CT 06419  
Ph. 860-663-1697  
Fax. 860-663-0935

Subject: **Sway Bracing & Anchor Bolt Analysis**  
Project: **Verizon - South Windsor North CT - LSub6**  
Prepared: **07.09.21**

Revised:

APT Job No.

**CT141\_12500**

**Sway Rod X - Bracing Analysis at Level 1 (0 to 37-ft ± AGL)**

X Bracing Rod Dia. (in)	1.5	New
Rod Yield Stress, Fy (psi)	36,000	ASTM A307 USED
Rod Tensile Stress, Fu (psi)	60,000	ASTM A307 USED
Angle of Sway Rod From Ground Plane (degrees)	50	
Un-threaded Portion Area (in <sup>2</sup> )	1.767	(Nominal area, Ag)
Available Tension Strength (Tumbuckle)	52.50	kips (1 1/2" dia. UNC/4UN Class 2B)
Available Tension Strength (Clevis)	52.50	kips (#4, UNC Class 2B)
Available Tension Strength in Un-threaded Rod	57.26	(0.90*Fy*Ag)
Available Tension Strength in Threaded Rod	59.64	(0.75*75*Fu*Ag)
Net Ultimate Shear Force (one side)	63.12	kips
Ultimate Tension Force in Sway Rod	49.10	kips
Usage (Tension)	0.94	<1.0 OK

Assumes only one sway rod is engaged per side.

**Sway Rod X - Bracing Analysis at Level 2 (37 to 74-ft ± AGL)**

X Bracing Rod Dia. (in)	1.5	New
Rod Yield Stress, Fy (psi)	36,000	ASTM A307 USED
Rod Tensile Stress, Fu (psi)	60,000	ASTM A307 USED
Angle of Sway Rod From Ground Plane (degrees)	59	
Un-threaded Portion Area (in <sup>2</sup> )	1.767	(Nominal area, Ag)
Available Tension Strength (Tumbuckle)	52.50	kips (1 1/2" dia. UNC/4UN Class 2B)
Available Tension Strength (Clevis)	52.50	kips (#4, UNC Class 2B)
Available Tension Strength in Un-threaded Rod	57.26	(0.90*Fy*Ag)
Available Tension Strength in Threaded Rod	59.64	(0.75*75*Fu*Ag)
Net Ultimate Shear Force	47.51	kips
Ultimate Tension Force in Sway Rod	46.12	kips
Usage (Tension)	0.88	<1.0 OK

Assumes only one sway rod is engaged per side.

**Sway Rod X - Bracing Analysis at Level 3 (74 to 109-ft ± AGL)**

X Bracing Rod Dia. (in)	1.375	New
Rod Yield Stress, Fy (psi)	36,000	ASTM A307 USED
Rod Tensile Stress, Fu (psi)	60,000	ASTM A307 USED
Angle of Sway Rod From Ground Plane (degrees)	66	
Un-threaded Portion Area (in <sup>2</sup> )	1.485	(Nominal area, Ag)
Available Tension Strength (Tumbuckle)	43.50	kips (1 3/8" dia. UNC/4UN Class 2B)
Available Tension Strength (Clevis)	45.00	kips (#3-1/2, UNC Class 2B)
Available Tension Strength in Un-threaded Rod	48.11	(0.90*Fy*Ag)
Available Tension Strength in Threaded Rod	50.12	(0.75*75*Fu*Ag)
Net Ultimate Shear Force	31.47	kips
Ultimate Tension Force in Sway Rod	38.69	kips
Usage (Tension)	0.89	<1.0 OK

Assumes only one sway rod is engaged per side.

**Anchor Bolt Analysis**

Anchor Rod Dia. (in)	1.375	1.5" dia. Bolts. 1/8" corrosion allowance used
Number of Exist. Anchor Bolts Per Leg	2	(Net Area, Ar)
Number of Legs	4	(Assumes central standpipe takes no shell DL)
Leg Circle Diameter (in)	594	Field verified
Bolt Tensile Stress (psi)	60,000	ASTM A7-39 used (tank built circa 1946)
Number of Threads per Inch	6	
Bolt Area (in <sup>2</sup> )	1.485	(Gross area, Ag)
Net Bolt Area (in <sup>2</sup> )	1.155	(Net Area, Ar)
Net Ultimate Uplift Tension Force Per Bolt	45.08	kips. (0.9DL + 1.0WL)
Total Ultimate Base Wind Shear	70.27	kips. (x1.0WL)
Ultimate Shear Per Leg	17.57	kips. (x1.0 WL)
Shear Per Anchor Bolt	8.78	kips. (x1.0 WL)
Available Bolt Tension Strength	50.19	kips
Available Bolt Shear Strength	30.14	kips
Additional Anchor Tension Strength	10.51	kips
Additional Anchor Shear Strength	19.02	kips
Usage	0.58	<1.0 OK

Note: Anchor bolt usage includes installation of (1) new 3/4" dia. anchor bolt per leg.

**Sway Rod X - Base Wing Plate Connection Analysis (AISC 14th Ed. Sec D5)**

Gusset Plate Thickness	0.375	Existing
Plate Yield Stress, Fy (psi)	33,000	ASTM A7-39 used (tank built circa 1946)
Plate Tensile Stress, Fu (psi)	60,000	ASTM A7-39 used (tank built circa 1946)
beff	1.380	in
b	1.950	in
Asf	2.488	in <sup>2</sup>
a	2.380	in
d	1.875	in
Apb	0.703	in <sup>2</sup>
Ultimate Force in Direction of Rod	49.10	kips
Available Tension Strength at Pin (Net)	46.58	kips
Available Long Shear Strength at Pin	67.18	kips
Available Bearing Strength at Pin	31.32	kips
Available Tension Strength (Gross area)	84.87	kips
Usage	1.57	>1.0 BEARING CONTROLS. ADD 1/4" THK. REINF. PLATE
Reinf Usage	0.97	<1.0 OK

**Sway Rod X - Gusset Plate Connection Analysis (37 ± AGL) (AISC 14th Ed. Sec D5)**

Gusset Plate Thickness	0.375	Existing (Assumed, V.I.F.)
Plate Yield Stress, Fy (psi)	33,000	ASTM A7-39 used (tank built circa 1946)
Plate Tensile Stress, Fu (psi)	60,000	ASTM A7-39 used (tank built circa 1946)
beff	1.380	in
b	2.960	in
Asf	2.511	in <sup>2</sup>
a	2.410	in
d	1.875	in
Apb	0.703	in <sup>2</sup>
Ultimate Force in Direction of Rod	49.10	kips
Available Tension Strength at Pin (Net)	46.58	kips
Available Long Shear Strength at Pin	67.79	kips
Available Bearing Strength at Pin	31.32	kips
Available Tension Strength (Gross area)	95.78	kips
Usage	1.57	>1.0 BEARING CONTROLS. ADD 1/4" THK. REINF. PLATE
Reinf Usage	0.97	<1.0 OK

**Sway Rod X - Gusset Plate Connection Analysis (74 ± AGL) (AISC 14th Ed. Sec D5)**

Gusset Plate Thickness	0.375	Existing (Assumed, V.I.F.)
Plate Yield Stress, Fy (psi)	33,000	ASTM A7-39 used (tank built circa 1946)
Plate Tensile Stress, Fu (psi)	60,000	ASTM A7-39 used (tank built circa 1946)
beff	1.380	in
b	2.380	in
Asf	2.488	in <sup>2</sup>
a	2.380	in
d	1.875	in
Apb	0.703	in <sup>2</sup>
Ultimate Force in Direction of Rod	46.12	kips
Available Tension Strength at Pin (Net)	46.58	kips
Available Long Shear Strength at Pin	67.79	kips
Available Bearing Strength at Pin	31.32	kips
Available Tension Strength (Gross area)	80.75	kips
Usage	1.47	>1.0 BEARING CONTROLS. ADD 1/4" THK. REINF. PLATE
Reinf Usage	0.92	<1.0 OK

**Sway Rod X - Gusset Plate Connection Analysis (109 ± AGL) (AISC 14th Ed. Sec D5)**

Gusset Plate Thickness	0.375	Existing (Assumed, V.I.F.)
Plate Yield Stress, Fy (psi)	33,000	ASTM A7-39 used (tank built circa 1946)
Plate Tensile Stress, Fu (psi)	60,000	ASTM A7-39 used (tank built circa 1946)
beff	1.380	in
b	2.060	in
Asf	2.376	in <sup>2</sup>
a	2.230	in
d	1.875	in
Apb	0.703	in <sup>2</sup>
Ultimate Force in Direction of Rod	38.69	kips
Available Tension Strength at Pin (Net)	46.58	kips
Available Long Shear Strength at Pin	64.14	kips
Available Bearing Strength at Pin	31.32	kips
Available Tension Strength (Gross area)	90.10	kips
Usage	1.24	>1.0 BEARING CONTROLS. ADD 1/4" THK. REINF. PLATE
Reinf Usage	0.79	<1.0 OK

**All-Points Technology Corporation**

Consulting Engineers  
3 Saddlebrook Drive,  
Killingworth, CT 06419  
Ph. 860-663-1697  
Fax. 860-663-0935

Subject: Existing Built-Up Column, Lacing Bar and Girt Analysis  
Project: Verizon - South Windsor North CT - LSub6  
Prepared: 07.09.21 Revised: APT Job No. CT141\_12500

**Lattice Column & Lacing Bar Analysis**

Column Steel Yield Strength	33	ksi, ASTM A7-39 (tank built circa 1946)
Column Area	12.095	in <sup>2</sup>
Lacing Bar Thickness	0.375	in
Lacing Bar Depth	2.25	in
Column Moment of Inertia, I <sub>xx</sub>	257.41	in <sup>4</sup> (Calculated Externally)
Column Moment of Inertia, I <sub>yy</sub>	286.94	in <sup>4</sup> (Calculated Externally)
Column Radius of Gyration, r <sub>xx</sub>	4.613	in (Calculated Externally)
Column Radius of Gyration, r <sub>yy</sub>	4.871	in (Calculated Externally)
Column Unbraced Length	445.200	in
Column Effective Length Factor, K	1.000	(Calculated Externally)
Channel Flange Slenderness Ratio	5.868	(Calculated Externally)
Channel Web Slenderness Ratio	34.57	(Calculated Externally)
Lacing Plate Slenderness Ratio	6.00	(Calculated Externally)
Slenderness Parameters		
b/t ≤ 0.56(E/Fy) <sup>1/2</sup>	16.60	Channel Flange - Unstiffened Element
h/tw ≤ 1.49(E/Fy) <sup>1/2</sup>	44.17	Channel Web - Stiffened Element
b/t ≤ 0.45(E/Fy) <sup>1/2</sup>	13.34	Lacing Plate - Unstiffened Element
Column Slenderness Ratio, KL/r	96.51	if < 200, OK
Column Elastic Buckling Stress, F <sub>e</sub>	30.73	ksi
F <sub>c</sub>	21.05	ksi
Column Design	229.17	kips
Compressive Strength, $\phi P_n$	129.17	kips, (1.2DL + 1.0WL) Tank Empty No longer used to store water.
<b>Built-Up Column Usage</b>		
	0.56	if <=1.0, OK
Length of Angle Chord		
Between Lacing Bars, I <sub>a</sub>	16.38	in
Channel, r <sub>yy</sub>	0.797	in (Calculated Externally)
75% of Column KL/r	72.38	
L <sub>a</sub> /r <sub>z</sub>	20.55	< 75% Column KL/r, OK
Length of Lacing Between	11.31	
Channel Chords, L <sub>b</sub>		
Radius of Gyration of Bar, r <sub>b</sub>	0.108	
lb/r <sub>b</sub>	104.51	if < 140, OK
Bar Elastic Buckling Stress, F <sub>e</sub>	26.20	ksi
F <sub>c</sub>	19.48	ksi
Lacing Bar Design Compressive	16.44	
Strength, $\phi P_n$ bar		
Required Shearing Strength on	2.29	kips, (2% Built-Up Column
Each Face of Latticed Column		Compression Strength)
Axial Force in Lacing Bar	3.24	kips, if < Lacing Bar
<b>Lacing Bar Usage</b>		
	0.20	if <=1.0, OK

**Built-Up Girt Analysis - Level 1 - 37-ft+/- (C7x9.8 Toe Up Over C6x8.2 Vert, est.)**

Girt Steel Yield Strength	33	ksi, ASTM A7-39 (tank built circa 1946)
Built-Up Girt Area	5.226	in <sup>2</sup>
Moment of Inertia, I <sub>xx</sub>	30.86	in <sup>4</sup> (Calculated Externally)
Moment of Inertia, I <sub>yy</sub>	22.01	in <sup>4</sup> (Calculated Externally)
Radius of Gyration, r <sub>xx</sub>	2.430	in (Calculated Externally)
Radius of Gyration, r <sub>yy</sub>	2.052	in (Calculated Externally)
Unbraced Length	332.180	in
Effective Length Factor, K	1.000	
Lower Channel Flange Slenderness Ratio	5.598	(Calculated Externally)
Lower Channel Web Slenderness Ratio	21.88	(Calculated Externally)
Upper Channel Flange Slenderness Ratio	5.710	(Calculated Externally)
Upper Channel Web Slenderness Ratio	25.00	(Calculated Externally)
Slenderness Parameters		
b/t ≤ 0.56(E/Fy) <sup>1/2</sup>	16.60	Channel Flange - Unstiffened Element
h/tw ≤ 1.49(E/Fy) <sup>1/2</sup>	44.17	Channel Web - Stiffened Element
Slenderness Ratio, KL/r	161.88	if < 200, OK
Elastic Buckling Stress, F <sub>e</sub>	10.92	ksi
F <sub>c</sub>	9.58	ksi
Design	45.05	kips
Compressive Strength, $\phi P_n$	31.56	kips, (1.0WL)/Two Sides - Tank Empty No longer used to store water.
<b>Lower Built-Up Girt Usage</b>		
	0.70	if <=1.0, OK

**Built-Up Girt Analysis - Level 2 - 74-ft+/- (C6x8.2 Toe Up Over C6x8.2 Vert, est.)**

Girt Steel Yield Strength	33	ksi, ASTM A7-39 (tank built circa 1946)
Built-Up Girt Area	4.76	in <sup>2</sup>
Moment of Inertia, I <sub>xx</sub>	29.11	in <sup>4</sup> (Calculated Externally)
Moment of Inertia, I <sub>yy</sub>	13.90	in <sup>4</sup> (Calculated Externally)
Radius of Gyration, r <sub>xx</sub>	2.473	in (Calculated Externally)
Radius of Gyration, r <sub>yy</sub>	1.709	in (Calculated Externally)
Unbraced Length	244.300	in
Effective Length Factor, K	1.000	
Lower Channel Flange Slenderness Ratio	5.710	(Calculated Externally)
Lower Channel Web Slenderness Ratio	25.00	(Calculated Externally)
Upper Channel Flange Slenderness Ratio	5.710	(Calculated Externally)
Upper Channel Web Slenderness Ratio	25.00	(Calculated Externally)
Slenderness Parameters		
b/t ≤ 0.56(E/Fy) <sup>1/2</sup>	16.60	Channel Flange - Unstiffened Element
h/tw ≤ 1.49(E/Fy) <sup>1/2</sup>	44.17	Channel Web - Stiffened Element
Slenderness Ratio, KL/r	142.95	if < 200, OK
Elastic Buckling Stress, F <sub>e</sub>	14.01	ksi
F <sub>c</sub>	12.28	ksi
Design	52.62	kips
Compressive Strength, $\phi P_n$	23.75	kips, (1.0WL)/Two Sides - Tank Empty No longer used to store water.
<b>Lower Built-Up Girt Usage</b>		
	0.45	if <=1.0, OK



Project ID: CT141\_12500  
Site Name: South Windsor North CT  
Date: 07.09.21

---

Use (1) 3/4" DIA. Threaded Rod set in Hilti RE-500 Epoxy w/ 12" min. embedment

$T_{allow} =$	23070	lbs
$V_{allow} =$	49690	lbs
Anchor Quantity =	1.0	
$f_{AN} =$	0.69	<i>&lt;&lt; Spacing Reduction Factor, 10"</i>
$f_{RN} =$	0.66	<i>&lt;&lt; Edge Distance Reduction Factor, 18"</i>
$f_{Av} =$	0.58	<i>&lt;&lt; Spacing Reduction Factor, 10"</i>
$f_{RV} =$	0.66	<i>&lt;&lt; Edge Distance Reduction Factor, 18" (Parallel)</i>
$f_{RV} =$	0.74	<i>&lt;&lt; Edge Distance Reduction Factor, 18" (Perpendicular)</i>
$f_{HV} =$	1.00	<i>&lt;&lt; Concrete Thickness Reduction Factor</i>
LRFD Factor =	1	

Capacities:

$T_{allow} =$	10506.1	lbs
$V_{allow} =$	19021.3	lbs <i>(Parallel)</i>
$V_{allow} =$	21326.9	lbs <i>(Perpendicular)</i>



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.  
Title Block Line 6

Project Title:  
Engineer:  
Project ID:  
Project Descr:

Printed: 9 JUL 2020, 10:23PM

File: Lattice Column & Girt Section Properties.ec6  
Software copyright ENERCALC, INC. 1983-2020, Build:12.20.5.31  
ALL-POINTS TECHNOLOGY CORP.

## General Section Property Calculator


Lic. #: KW-06006315

DESCRIPTION: Built -Up Lattice Column Section Properties

### Final Section Properties

Total Area	:	12.095 in <sup>2</sup>	I <sub>xx</sub>	:	257.406 in <sup>4</sup>	S <sub>xx</sub> : -Y	:	42.901 in <sup>3</sup>
Calculated final C.G. distance from Datum :			I <sub>yy</sub>	:	286.937 in <sup>4</sup>	S <sub>xx</sub> : +Y	:	42.901 in <sup>3</sup>
X cg Dist.	:	0.0 in	Z <sub>xx</sub>	:	50.929 in <sup>3</sup>	S <sub>yy</sub> : -X	:	41.345 in <sup>3</sup>
Y cg Dist.	:	0.0 in	Z <sub>yy</sub>	:	57.914 in <sup>3</sup>	S <sub>yy</sub> : +X	:	41.345 in <sup>3</sup>
Edge Distances from CG. :						r <sub>xx</sub>	:	4.613 in
+X	:	6.940 in	+Y	:	6.0 in	r <sub>yy</sub>	:	4.871 in
-X	:	-6.940 in	-Y	:	in			

Rotation of All Components @ Angle : 0.00 deg CCW



### Rectangular & Circular Shapes

Rectangular Shape : 1	Height =	0.000 in	Width =	0.000 in	Rotation =	0 deg CCW
	Area =	0.000 in <sup>2</sup>	X <sub>cg</sub> =	0.000 in		
			Y <sub>cg</sub> =	0.000 in		



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.  
Title Block Line 6

Project Title:  
Engineer:  
Project ID:  
Project Descr:

Printed: 9 JUL 2020, 10:23PM

File: Lattice Column & Girt Section Properties.ec6  
Software copyright ENERCALC, INC. 1983-2020, Build:12.20.5.31  
ALL-POINTS TECHNOLOGY CORP.

## General Section Property Calculator

Lic. #: KW-06006315

DESCRIPTION: Built -Up Latticed Column Section Properties

Rectangular Shape : 2	Height =	0.000 in	Width =	0.000 in	Rotation =	0 deg CCW
	Area =	0.000 in <sup>2</sup>	Xcg =	0.000 in		
<hr/>						
C12x20.7 : 1	Area =	6.047 in <sup>2</sup>	Rotation =	180 deg CCW		
			Xcg =	-4.698 in		
			Ycg =	0.000 in		
C12x20.7 : 2	Area =	6.047 in <sup>2</sup>	Rotation =	0 deg CCW		
			Xcg =	4.698 in		
			Ycg =	0.000 in		

### Steel Shapes

---



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.  
Title Block Line 6

Project Title:  
Engineer:  
Project ID:  
Project Descr:

Printed: 9 JUL 2020, 10:22PM

File: Lattice Column & Girt Section Properties.ec6  
Software copyright ENERCALC, INC. 1983-2020, Build:12.20.5.31  
ALL-POINTS TECHNOLOGY CORP.

## General Section Property Calculator


Lic. #: KW-06006315

DESCRIPTION: Existing Level 1 Horz Girt Section Properties

### Final Section Properties

Total Area	:	5.226 in <sup>2</sup>	I <sub>xx</sub>	:	30.862 in <sup>4</sup>	S <sub>xx</sub> : -Y	:	6.234 in <sup>3</sup>
Calculated final C.G. distance from Datum :			I <sub>yy</sub>	:	22.007 in <sup>4</sup>	S <sub>xx</sub> : +Y	:	9.952 in <sup>3</sup>
X cg Dist.	:	0.02912 in	Z <sub>xx</sub>	:	8.80 in <sup>3</sup>	S <sub>yy</sub> : -X	:	6.219 in <sup>3</sup>
Y cg Dist.	:	1.950 in	Z <sub>yy</sub>	:	8.289 in <sup>3</sup>	S <sub>yy</sub> : +X	:	6.323 in <sup>3</sup>
Edge Distances from CG. :						r <sub>xx</sub>	:	2.430 in
+X	:	3.480 in	+Y	:	3.101 in	r <sub>yy</sub>	:	2.052 in
-X	:	-3.539 in	-Y	:	in			

Rotation of All Components @ Angle : 0.00 deg CCW



### Steel Shapes

	C6x8.2 : 1	Area =	2.380 in <sup>2</sup>	Rotation =	0 deg CCW
				X <sub>cg</sub> =	0.000 in
				Y <sub>cg</sub> =	0.000 in
	C7x9.8 : 2	Area =	2.846 in <sup>2</sup>	Rotation =	90 deg CCW
				X <sub>cg</sub> =	0.000 in
				Y <sub>cg</sub> =	3.512 in



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.  
Title Block Line 6

Project Title:  
Engineer:  
Project ID:  
Project Descr:

Printed: 9 JUL 2020, 10:23PM

File: Lattice Column & Girt Section Properties.ec6  
Software copyright ENERCALC, INC. 1983-2020, Build:12.20.5.31  
ALL-POINTS TECHNOLOGY CORP.

## General Section Property Calculator


Lic. #: KW-06006315

DESCRIPTION: Existing Level 2 Horz Girt Section Properties

### Final Section Properties

Total Area :	4.760 in <sup>2</sup>	I <sub>xx</sub> :	29.111 in <sup>4</sup>	S <sub>xx</sub> : -Y	:	6.080 in <sup>3</sup>
Calculated final C.G. distance from Datum :		I <sub>yy</sub> :	13.899 in <sup>4</sup>	S <sub>xx</sub> : +Y	:	9.324 in <sup>3</sup>
X cg Dist. :	0.03198 in	Z <sub>xx</sub> :	8.510 in <sup>3</sup>	S <sub>yy</sub> : -X	:	4.570 in <sup>3</sup>
Y cg Dist. :	1.788 in	Z <sub>yy</sub> :	6.288 in <sup>3</sup>	S <sub>yy</sub> : +X	:	4.668 in <sup>3</sup>
Edge Distances from CG. :				r <sub>xx</sub>	:	2.473 in
+X :	2.978 in	+Y :	3.122 in	r <sub>yy</sub>	:	1.709 in
-X :	-3.042 in	-Y :	in			

Rotation of All Components @ Angle : 0.00 deg CCW



### Steel Shapes

	C6x8.2 : 1	Area =	2.380 in <sup>2</sup>	Rotation =	0 deg CCW
				X <sub>cg</sub> =	0.000 in
				Y <sub>cg</sub> =	0.000 in
	C6x8.2 : 2	Area =	2.380 in <sup>2</sup>	Rotation =	90 deg CCW
				X <sub>cg</sub> =	0.000 in
				Y <sub>cg</sub> =	3.512 in



Project ID: CT141NB7760  
Site Name: South Windsor North CT  
Date: 7/10/2020  
Sheet: of

Use (1) 3/4" DIA. Threaded Rod set in Hilti RE-500 Epoxy w/ 12" min. embedment

$T_{allow}$  = 23070 lbs  
 $V_{allow}$  = 49690 lbs  
Anchor Quantity = 1.0

$f_{AN}$  = 0.69 << Spacing Reduction Factor, 10"  
 $f_{RN}$  = 0.66 << Edge Distance Reduction Factor, 18"  
 $f_{AV}$  = 0.58 << Spacing Reduction Factor, 10"  
 $f_{RV}$  = 0.66 << Edge Distance Reduction Factor, 18" (Parallel)  
 $f_{RV}$  = 0.74 << Edge Distance Reduction Factor, 18" (Perpendicular)  
 $f_{HV}$  = 1.00 << Concrete Thickness Reduction Factor  
LRFD Factor 1

Reductions per Table 36 Hilti  
Anchor Fastening Technical  
Guide (19th edition)

Capacities:

$T_{allow}$  = 10506.1 lbs  
 $V_{allow}$  = 19021.3 lbs (Parallel)  
 $V_{allow}$  = 21326.9 lbs (Perpendicular)



3 Saddlebrook Drive,  
Killingworth, CT 06419  
PH: 860-663-1697; FAX: 860-663-0935

Verizon - South Windsor North CT

Foundation Analysis

50 Plantation Road, East Windsor, CT 06016

Prepared by: JRM.

APT FILING No. CT141\_12500

Checked by: MST, P.E.

Date/Rev: 07.09.21

### Elevated Reservoir Foundation Analysis:

Note: Structure no longer utilized as a water tank and is empty.

#### Max Reactions:

Un-factored Base Axial Load =	$P := 74.3 \cdot \text{kip}$	(User Input)	(Un-factored Axial Load = Tank Self Weight + Wireless Equip DL - Stand Pipe & 1/2 x Spider Rod DL )
Ultimate Base Shear Load =	$V := 70.3 \cdot \text{kip}$	(User Input)	
Ultimate Base Moment =	$M := 5291 \cdot \text{ft.kip}$	(User Input)	

#### Load Factors:

Dead Load Factor =	$DL_{f1} := 0.9$
Dead Load Factor =	$DL_{f2} := 1.2$
Wind Load Factor =	$WL_f := 1.0$

#### Foundation Data:

Foundation data obtained by field investigation during June 2017 and June 2021.

Top Width of Frustum Pyramid =	$W_{top} := 67.3 \text{ in}$	(User Input)
Bot Width of Frustum Pyramid =	$W_{bot} := 127.43 \text{ in}$	(User Input)
Top Area of Frustum Pyramid =	$B_{1top} := 4509.5 \text{ in}^2$	(User Input)
Bot Area of Frustum Pyramid =	$B_{2bot} := 16396 \text{ in}^2$	(User Input)
Overall Depth of Pyramid =	$D_f := 74 \text{ in}$	(User Input)
Base Thickness =	$T_{base} := 0.00 \cdot \text{in}$	(User Input)
Base Width =	$W_{base} := 0.00 \cdot \text{in}$	(User Input)
Height of Foundation Above Grade =	$T_{ext} := 4.00 \cdot \text{in}$	(User Input)
Depth to Water Table =	$D_{wt} := 99 \cdot \text{ft}$	(User Input)
Water Tank Leg Circle Diameter =	$D_{circle} := 594.00 \cdot \text{in}$	(User Input)
Number of Legs =	$N_{leg} := 4.00$	(User Input)
Depth to Base of Foundation from Grade =	$D_{base} := D_f + T_{base} - T_{ext} = 5.833 \text{ ft}$	<i>Note: Set Dwt to a value greater than total depth of footing if water table does not affect footing.</i>

#### Material Data:

Concrete Compressive Strength =	$f_c := 3000 \cdot \text{psi}$	(User Input)
Steel Reinforcement Yield Strength =	$F_y := 40000 \text{ psi}$	(User Input)
Internal Friction Angle of Soil =	$\phi_s := 30 \cdot \text{deg}$	(User Input)
Ultimate Soil Bearing Capacity =	$q_s := 8000 \cdot \text{psf}$	(User Input)
Unit Weight of Soil =	$\gamma_{soil} := 110 \cdot \text{pcf}$	(User Input)
Unit Weight of Concrete =	$\gamma_{conc} := 150 \cdot \text{pcf}$	(User Input)
Foundation Bouyancy =	$Bouyancy := 0$	(User Input) (Yes=1 / No=0)
Depth to Neglect =	$D_n := 6 \text{ in}$	(User Input)
Cohesion of Clay Type Soil =	$c := 0 \cdot \text{ksf}$	(User Input) (Use 0 for Sandy Soil)
Coefficient of Friction Between Concrete =	$\mu := 0.45$	(User Input)
Coefficient of Lateral Soil Pressure =	$K_p := \frac{1 + \sin(\phi_s)}{1 - \sin(\phi_s)} = 3$	
Adjusted Concrete Unit Weight =	$\gamma_c = 150 \text{ pcf}$	
Adjusted Soil Unit Weight =	$\gamma_s = 110 \text{ pcf}$	



3 Saddlebrook Drive,  
Killingworth, CT 06419  
PH: 860-663-1697; FAX: 860-663-0935

Verizon - South Windsor North CT

50 Plantation Road, East Windsor, CT 06016

APT FILING No. CT141\_12500

Date/Rev: 07.09.21

Foundation Analysis

Prepared by: JRM.

Checked by: MST, P.E.

### Determine Maximum Uplift and Compression Forces at Leg:

Factored Shear Force per Leg =  $V_{leg} := \left( \frac{V \cdot WL_f}{N_{leg}} \right) = 17.575 \text{ kip}$

Factored Max Leg Uplift Force =  $U_{plift} := \left( \frac{WL_f \cdot (4 \cdot M)}{N_{leg} \cdot D_{circle}} \right) - \left( \frac{DL_{f1} \cdot P}{N_{leg}} \right) = 90.17 \text{ kip}$

Factored Max Leg Compression Force =  $C_{compression} := \left( \frac{WL_f \cdot (4 \cdot M)}{N_{leg} \cdot D_{circle}} \right) + \left( \frac{DL_{f2} \cdot P}{N_{leg}} \right) = 129.18 \text{ kip}$

### Calculate Foundation Volume:

Volume of Frustum Pyramid Concrete Foundation =  $V_{Frustum} := \frac{1}{3} \cdot D_f \cdot (B_{1top} + B_{2bot} + \sqrt{B_{1top} \cdot B_{2bot}}) = 421.16 \text{ ft}^3$

Gross Volume of Conc =  $V_{conc} := V_{Frustum} = 421.16 \text{ ft}^3$

Volume of Frustum Pyramid Below Grade (Minus Depth to Neglect) =  $V_{FrustumNet} := \frac{1}{3} \cdot (D_{base}) \cdot (B_{1top} + B_{2bot} + \sqrt{B_{1top} \cdot B_{2bot}}) = 398.4 \text{ ft}^3$

Net Volume of Conc =  $V_{concrete} := V_{FrustumNet} = 398.4 \text{ ft}^3$

### Stability of Footing:

Cross-Sectional Area of Resisting Soil at Base of Foundation =  $B_1 := B_{2bot} = 113.861 \text{ ft}^2$

Cross-Sectional Area of Resisting Soil at Top of Foundation (Minus Depth to Neglect) =  $B_2 := 302.98 \text{ ft}^2$

Volume of Resisting Soil =  $V_{Soil} := \frac{1}{3} \cdot ((D_{base}) \cdot (B_1 + B_2 + \sqrt{B_1 \cdot B_2})) - V_{concrete} = 773.28 \text{ ft}^3$

Weight of Concrete =  $Wt_{conc} := V_{conc} \cdot \gamma_c = 63.17 \text{ kip}$

Weight of Resisting Soil =  $Wt_{soil} := V_{Soil} \cdot \gamma_s = 85.06 \text{ kip}$

Total Resisting Weight of Soil & Conc =  $Wt_{Total} := (DL_{f1} \cdot Wt_{conc} + 0.75 \cdot Wt_{soil}) = 120.65 \text{ kip}$

Uplift Interaction Ratio =  $Usage := \left( \frac{U_{plift}}{Wt_{Total}} \right) = 0.75$

$UsageCheck := \text{If} \left( \frac{U_{plift}}{Wt_{Total}} \leq 1.05, \text{"Okay"}, \text{"No Good"} \right)$

**UsageCheck = "Okay"**

## ***Appendix B***

*Reference Information*

### Project Details

**Carrier Aggregation:** false

**MPT Id:**
**eCIP-O:** false

**Project Name:** 5G L-Sub6 - Carrier Add

**FUZE Project ID:** 16560063

**Designed Sector Carrier 4G:** 15

**Designed Sector Carrier 5G:** 3

**Additional Sector Carrier 4G:** N/A

**Additional Sector Carrier 5G:** N/A

**SiteTraker Project Id:**
**FP Solution Type & Tech Type:** MODIFICATION;5G\_L-Sub6-Prep

**Suffix:**
**RFDS Project Scope:** Sub 6 add  
CBRS add

### Location Information

**Site ID:** 2578557

**E-NodeB ID:** 0068554,068554

**PSLC:** 469756

**Switch Name:**
**Tower Owner:**
**Tower Type:**
**Site Type:** MACRO

**Street Address:** 50 Plantation road

**City:** East Windsor

**State:** CT

**Zip Code:** 06016

**County:** Hartford

**Latitude:** 41.87565194 / 41° 52' 32.347" N

**Longitude:** -72.56482972 / 72° 33' 53.387" W

## Antenna Summary

Added																		
700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Centerline	Tip Height	Azimuth	RET	4xRx	Inst. Type	Quantity				
LTE	5G	LTE			COMMSCOPE	COMMSCOPE	NHH-65B-R2B	102	105	20(A) 140(B) 260(C)	true	true	PHYSICAL	3				
LTE	5G		LTE	5G	COMMSCOPE	COMMSCOPE	NHHSS-65B-R2B	102	105	20(A) 140(B) 260(C)	true	true	PHYSICAL	3				
				5G	Samsung	MT6407-77A	94	95.5	20(A) 140(B) 260(C)	false	false	PHYSICAL	3					
Removed																		
700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Centerline	Tip Height	Azimuth	RET	4xRx	Inst. Type	Quantity				
LTE	5G		LTE		COMMSCOPE	COMMSCOPE	NNHH-65B-R4	102	105	20(A) 140(B) 260(C)	false	false	PHYSICAL	3				
		LTE			COMMSCOPE	COMMSCOPE	NNHH-65B-R4	94	97	20(A) 140(B) 260(C)	false	false	PHYSICAL	3				
Retained																		
700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Centerline	Tip Height	Azimuth	RET	4xRx	Inst. Type	Quantity				
No data available.																		

Added: 9

Removed: 6

Retained: 0

## Equipment Summary

### Added

Equipment Type	Location	700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Cable Length	Cable Size	Install Type	Quantity	
Mount	Tower							Commscope	BASMNT-SBS-1-2			PHYSICAL	3	
RRU	Tower					LTE		Samsung	CBRS RRH - RT4401-48A			PHYSICAL	3	
RRU	Tower						5G	Samsung	MT6407-77A			PHYSICAL	3	

### Removed

Equipment Type	Location	700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Cable Length	Cable Size	Install Type	Quantity	
No data available.														

### Retained

Equipment Type	Location	700	850	1900	AWS	CBRS	L-Sub6	Make	Model	Cable Length	Cable Size	Install Type	Quantity	
RRU	Tower			LTE	LTE			Samsung	B2/B66A RRH-BR049 (RFV01U-D1A)			PHYSICAL	3	
RRU	Tower	LTE	5G					Samsung	B5/B13 RRH-BR04C (RFV01U-D2A)			PHYSICAL	3	
Hybrid Cable	Tower											PHYSICAL	3	
OVP Box	Tower											PHYSICAL	3	

## Service Info

700 MHz LTE						
0002			5GLS			
<b>Sector</b>	<b>01</b>	<b>02</b>	<b>03</b>	<b>01</b>	<b>02</b>	<b>03</b>
<b>Azimuth</b>	20	140	260	20	140	260
<b>Cell / ENode B ID</b>	068554	068554	068554	068554	068554	068554
<b>Antenna Model</b>	NNHH-65B-R4	NNHH-65B-R4	NNHH-65B-R4	NHH-65B-R2B	NHH-65B-R2B	NHH-65B-R2B
<b>Antenna Make</b>	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE
<b>Antenna Centerline(Ft)</b>	102	102	102	102	102	102
<b>Mechanical Down-Tilt(Deg.)</b>	0	0	0	0	0	0
<b>Electrical Down-Tilt</b>	4	2	4	4	2	4
<b>Tip Height</b>	105	105	105	105	105	105
<b>Regulatory Power</b>	68.01	65.85	68.01	73.6	71.26	73.6
<b>Total ERP (W)</b>						
<b>TMA Make</b>						
<b>TMA Model</b>						
<b>RRU Make</b>	Samsung	Samsung	Samsung	Samsung	Samsung	Samsung
<b>RRU Model</b>	B5/B13 RRH-BR04C (RFV01U-D2A)					
<b>Number of Tx, Rx Lines</b>	4,4	4,4	4,4	4,4	4,4	4,4
<b>Position</b>						
<b>Transmitter Id</b>	1967093	1967283	1967288	10225856	10225859	10225862
<b>Source</b>	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API
850 MHz 5GNR						
0002			5GLS			
<b>Sector</b>	<b>0001</b>	<b>0002</b>	<b>0003</b>	<b>0001</b>	<b>0002</b>	<b>0003</b>
<b>Azimuth</b>	20	140	260	20	140	260
<b>Cell / ENode B ID</b>	0068554	0068554	0068554	0068554	0068554	0068554
<b>Antenna Model</b>	NNHH-65B-R4	NNHH-65B-R4	NNHH-65B-R4	NHH-65B-R2B	NHH-65B-R2B	NHH-65B-R2B
<b>Antenna Make</b>	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE
<b>Antenna Centerline(Ft)</b>	102	102	102	102	102	102
<b>Mechanical Down-Tilt(Deg.)</b>	0	0	0	0	0	0
<b>Electrical Down-Tilt</b>	4	2	4	4	2	4
<b>Tip Height</b>	105	105	105	105	105	105
<b>Regulatory Power</b>	324.8	316.68	324.8	306.07	290.63	289.96
<b>Total ERP (W)</b>						
<b>TMA Make</b>						
<b>TMA Model</b>						
<b>RRU Make</b>	Samsung	Samsung	Samsung	Samsung	Samsung	Samsung
<b>RRU Model</b>	B5/B13 RRH-BR04C (RFV01U-D2A)					
<b>Number of Tx, Rx Lines</b>	4,4	4,4	4,4	4,4	4,4	4,4
<b>Position</b>						
<b>Transmitter Id</b>	10225644	10225645	10225646	10225853	10225854	10225855
<b>Source</b>	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API
1900 MHz LTE						
0002			5GLS			
<b>Sector</b>	<b>01</b>	<b>02</b>	<b>03</b>	<b>01</b>	<b>02</b>	<b>03</b>
<b>Azimuth</b>	20	140	260	20	140	260
<b>Cell / ENode B ID</b>	068554	068554	068554	068554	068554	068554
<b>Antenna Model</b>	NNHH-65B-R4	NNHH-65B-R4	NNHH-65B-R4	NHH-65B-R2B	NHH-65B-R2B	NHH-65B-R2B
<b>Antenna Make</b>	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE
<b>Antenna Centerline(Ft)</b>	94	94	94	102	102	102
<b>Mechanical Down-Tilt(Deg.)</b>	0	0	0	0	0	0
<b>Electrical Down-Tilt</b>	2	2	2	2	2	2
<b>Tip Height</b>	97	97	97	105	105	105
<b>Regulatory Power</b>	224.16	224.16	224.16	267.15	267.15	267.15
<b>Total ERP (W)</b>						
<b>TMA Make</b>						
<b>TMA Model</b>						
<b>RRU Make</b>	Samsung	Samsung	Samsung	Samsung	Samsung	Samsung
<b>RRU Model</b>	B2/B66A RRH-BR049 (RFV01U-D1A)					
<b>Number of Tx, Rx Lines</b>	4,4	4,4	4,4	4,4	4,4	4,4
<b>Position</b>						
<b>Transmitter Id</b>	1967095	1967285	1967290	10225857	10225860	10225863
<b>Source</b>	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API

2100 MHz LTE						
	0002			5GLS		
Sector	01	02	03	01	02	03
Azimuth	20	140	260	20	140	260
Cell / ENode B ID	068554	068554	068554	068554	068554	068554
Antenna Model	NNHH-65B-R4	NNHH-65B-R4	NNHH-65B-R4	NHHSS-65B-R2B	NHHSS-65B-R2B	NHHSS-65B-R2B
Antenna Make	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE	COMMSCOPE
Antenna Centerline(Ft)	102	102	102	102	102	102
Mechanical Down-Tilt(Deg.)	0	0	0	0	0	0
Electrical Down-Tilt	2	2	2	0	0	0
Tip Height	105	105	105	105	105	105
Regulatory Power	103.64	103.64	103.64	143.06	143.06	143.06
Total ERP (W)						
TMA Make						
TMA Model						
RRU Make	Samsung	Samsung	Samsung	Samsung	Samsung	Samsung
RRU Model	B2/B66A RRH-BR049 (RFV01U-D1A)					
Number of Tx, Rx Lines	4,4	4,4	4,4	4,4	4,4	4,4
Position						
Transmitter Id	1967233	1967286	1967291	10225858	10225861	10225864
Source	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API	ATOLL_API
CBRS 3.5 GHz						
	5GLS			5GLS		
Sector	19	20	21	19	20	21
Azimuth	20	140	260	20	140	260
Cell / ENode B ID	068554	068554	068554	068554	068554	068554
Antenna Model	NHHSS-65B-R2BT4	NHHSS-65B-R2BT4	NHHSS-65B-R2BT4	NHHSS-65B-R2BT4	NHHSS-65B-R2BT4	NHHSS-65B-R2BT4
Antenna Make				CommScope	CommScope	CommScope
Antenna Centerline(Ft)				102	102	102
Mechanical Down-Tilt(Deg.)				0	0	0
Electrical Down-Tilt				4	4	4
Tip Height				105	105	105
Regulatory Power				12.78	12.78	12.78
Total ERP (W)						
TMA Make						
TMA Model						
RRU Make				Samsung	Samsung	Samsung
RRU Model				CBRS RRH - RT4401-48A	CBRS RRH - RT4401-48A	CBRS RRH - RT4401-48A
Number of Tx, Rx Lines				4,4	4,4	4,4
Position						
Transmitter Id				10225935	10225936	10225937
Source				ATOLL_API	ATOLL_API	ATOLL_API
nL-Sub6						
	5GLS			5GLS		
Sector	0001	0002	0003	0001	0002	0003
Azimuth	20	140	260	20	140	260
Cell / ENode B ID	0068554	0068554	0068554	0068554	0068554	0068554
Antenna Model	MT6407-77A	MT6407-77A	MT6407-77A	MT6407-77A	MT6407-77A	MT6407-77A
Antenna Make				Samsung	Samsung	Samsung
Antenna Centerline(Ft)				94	94	94
Mechanical Down-Tilt(Deg.)				0	0	0
Electrical Down-Tilt				6	6	6
Tip Height				95.5	95.5	95.5
Regulatory Power				751.94	751.94	751.94
Total ERP (W)						
TMA Make						
TMA Model						
RRU Make				Samsung	Samsung	Samsung
RRU Model				MT6407-77A	MT6407-77A	MT6407-77A
Number of Tx, Rx Lines				4,4	4,4	4,4
Position						
Transmitter Id				10225971	10225972	10225973
Source				ATOLL_API	ATOLL_API	ATOLL_API
Service Comments						


### Callsigns Per Antenna


Sector	Antenna Ma	Antenna Mc	Ant CL Height AGL	Tip Height	Azimuth (T)	Electrical Tilt	Mechanical Tilt	Gain	Beamwidth	Regulatory Power	Callsigns					
											700	850	1900	2100	28 GHz	31 GHz
No data available.																


Callsigns																					
Callsign	Market	Radio Code	Market Number	Block	State	County	Licensee Name	Wholly Owned	Total MHZ	Freq Range 1	Freq Range 2	Freq Range 3	Freq Range 4	Regulatory Power	Threshold (W)	POPs/Sq Mi	Status	Action	Approved for Insvc		
WQJQ689	Northeast	WU	REA001	C	CT	Hartford	Cellco Partnership	Yes	22.000	746.000-757.000	776.000-787.000	.000-.000	.000-.000	73.6	1000	1216.19	Active	added	Yes		
KNKA404	Hartford-New Britain-Bristol, CT	CL	CMA032	A	CT	Hartford	Cellco Partnership	Yes	25.000	824.000-835.000	869.000-880.000	845.000-846.500	890.000-891.500	306.07	400	1216.19	Active	added	Yes		
WPOJ730	Hartford, CT	CW	BTA184	C	CT	Hartford	Cellco Partnership	Yes	15.000	1895.000-1902.500	1975.000-1982.500	.000-.000	.000-.000	267.15	1640	1216.19	Active	added	Yes		
KNLH251	Hartford, CT	CW	BTA184	F	CT	Hartford	Cellco Partnership	Yes	10.000	1890.000-1895.000	1970.000-1975.000	.000-.000	.000-.000	267.15	1640	1216.19	Active	added	Yes		
CBRS_CALL	UNLICENSE	3.5 GHz	UNLICENSE	UNLICENSE	CT	Hartford	UNLICENSE	UNLICENSE	UNLICENSE	UNLICENSED-UNLIC	UNLICENSED-UNLIC	UNLICENSED-UNLIC	UNLICENSED-UNLIC	12.78		1216.19	Active	added	No		
WRLD515	D09003 - Hartford, CT	PL	D09003	0	CT	Hartford	Verizon Wireless Network Procure LP	Yes	100.000	3550.000-3650.000	.000-.000	.000-.000	.000-.000	12.78		.00	Active	added	Yes		
WRLD514	D09003 - Hartford, CT	PL	D09003	0	CT	Hartford															
WRLD513	D09003 - Hartford, CT	PL	D09003	0	CT	Hartford	Verizon Wireless Network Procure LP	Yes	100.000	3550.000-3650.000	.000-.000	.000-.000	.000-.000	12.78		.00	Active	added	Yes		
WQGB276	Hartford-New Britain-Bristol, CT	AW	CMA032	A	CT	Hartford															
WQGA906	New York-No. New Jer.-Long Island, NY-NJ-CT-PA-MA-	AW	BEA010	B	CT	Hartford	Cellco Partnership	Yes	20.000	1710.000-1720.000	2110.000-2120.000	.000-.000	.000-.000	143.06	1640	1216.19	Active	added	Yes		
WPOH943	Hartford, CT	LD	BTA184	A	CT	Hartford	Cellco Partnership	Yes	300.000	29100.000-29250.000	31075.000-31225.000	.000-.000	.000-.000			1216.19	Active		No		
WPLM398	Hartford, CT	LD	BTA184	B	CT	Hartford	Cellco Partnership	Yes	150.000	31000.000-31075.000	31225.000-31300.000	.000-.000	.000-.000			1216.19	Active		No		
WRBA708	Hartford, CT	UU	BTA184	L1	CT	Hartford	Cellco Partnership	Yes	325.000	27500.000-27600.000	27700.000-27925.000	.000-.000	.000-.000			1216.19	Active		Yes		
WRBA709	Hartford, CT	UU	BTA184	L2	CT	Hartford	Cellco Partnership	Yes	325.000	27925.000-28050.000	28150.000-28350.000	.000-.000	.000-.000			1216.19	Active		Yes		

WRHD609	New York, NY	UU	PEA001	M1	CT	Hartford	Straight Path um, LLC	Yes	100.000	37600.000-37700.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD610	New York, NY	UU	PEA001	M10	CT	Hartford	Straight Path um, LLC	Yes	100.000	38500.000-38600.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD611	New York, NY	UU	PEA001	M2	CT	Hartford	Straight Path um, LLC	Yes	100.000	37700.000-37800.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD612	New York, NY	UU	PEA001	M3	CT	Hartford	Straight Path um, LLC	Yes	100.000	37800.000-37900.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD613	New York, NY	UU	PEA001	M4	CT	Hartford	Straight Path um, LLC	Yes	100.000	37900.000-38000.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD614	New York, NY	UU	PEA001	M5	CT	Hartford	Straight Path um, LLC	Yes	100.000	38000.000-38100.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD615	New York, NY	UU	PEA001	M6	CT	Hartford	Straight Path um, LLC	Yes	100.000	38100.000-38200.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD616	New York, NY	UU	PEA001	M7	CT	Hartford	Straight Path um, LLC	Yes	100.000	38200.000-38300.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD617	New York, NY	UU	PEA001	M8	CT	Hartford	Straight Path um, LLC	Yes	100.000	38300.000-38400.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD618	New York, NY	UU	PEA001	M9	CT	Hartford	Straight Path um, LLC	Yes	100.000	38400.000-38500.00	.000-000	.000-000	.000-000				1216.19	Active		Yes
WRHD619	New York, NY	UU	PEA001	N1	CT	Hartford	Straight Path um, LLC	Yes	100.000	38600.000-38700.00	.000-000	.000-000	.000-000				1216.19	Active		No
PEND1050	Northeast	CC	REA001	A	CT	Hartford	Celco Partnership	Yes	100.000	3700.000-3800.00	.000-000	.000-000	.000-000				1216.19	Active		No

Upper level with SBS bracket










NOTES:

1. REFER TO REINFORCEMENT DESIGN DRAWINGS PREPARED BY ALL-POINTS TECHNOLOGY, P.C. MARKED REV0, DATED JULY 09, 2020 FOR ADDITIONAL INFORMATION PERTAINING TO NEW SWAY ROD HARDWARE NOT SHOWN HEREIN.
2. VERIFY ALL DIMENSIONS IN FIELD PRIOR TO FABRICATION.
3. CUT & REMOVE PORTION OF EXIST. CORRODED  $\frac{3}{8}$ " WING PLATE AS SHOWN (VERIFY EXTENT OF CORROSION AT EXIST. PIN CONNECTION W/ EOR PRIOR TO CUTTING).
4. ALL WELDS SHALL BE INSPECTED PER AWS D1.1/D1.1M.
5. ALL CJP WELDS SHALL BE INSPECTED PER AWS D1.1/D1.1M UTILIZING RADIOGRAPHIC TESTING (RT), OR ULTRASONIC TESTING (UT) PROCEDURES.



REVISIONS:

- REV0: 06/30/21: FOR CONSTRUCTION: JRM
- REV1:
- REV2:
- REV3:
- REV4:
- REV5:

**Verizon**

**SK-S2**

**SHEET NUMBER:**

**ALL-POINTS**  
TECHNOLOGY CORPORATION  
567 VAUXHALL STREET EXTENSION - SUITE 311  
WATERFORD, CT 06385  
PH: (860)-663-1697  
FAX: (860)-663-0935  
WWW.ALLPOINTSTECH.COM


**SOUTH WINDSOR NORTH CT**  
50 PLANTATION ROAD  
EAST WINDSOR, CT 06016

**VZW**  
PROJECT CODE: 20171645681 LC: 469756 CM: BM

DATE OF DV: N/A	DRAWN BY: JRM
DATE: 04/26/21	CHECKED BY: MST

**NOTES:**

1. REFER TO REINFORCEMENT DESIGN DRAWINGS PREPARED BY ALL-POINTS TECHNOLOGY, P.C. MARKED REV0, DATED JULY 09, 2020 FOR ADDITIONAL INFORMATION PERTAINING TO NEW SWAY ROD HARDWARE NOT SHOWN HEREIN.
2. VERIFY ALL DIMENSIONS IN FIELD PRIOR TO FABRICATION.
3. BORING OF THE EXIST. PIN HOLES MAY BE REQUIRED TO ACCOMMODATE NEW PINS. CONTRACTOR TO VERIFY IN FIELD.
4. ALL WELDS SHALL BE INSPECTED PER AWS D1.1/D1.1M.
5. ALL CJP WELDS SHALL BE INSPECTED PER AWS D1.1/D1.1M UTILIZING RADIOGRAPHIC TESTING (RT), OR ULTRASONIC TESTING (UT) PROCEDURES.



ROD REPLACEMENT SCHEDULE:


SECTION	OVERALL ROD LENGTH (PIN TO PIN)	TURNBUCKLE (CL TO CL PIN AT BOT)	TOTAL LENGTH	ROD SIZE	CLEVIS	GRIP	TURNBUCKLE SIZE	PIN SIZE	QTY
S3	37'-0"±	5'-1½"	296'±	1 3/8"	#3½	1"	1 3/8"	2"	8
S2	41'-9½"±	5'-1½"	334.4'±	1 1/2"	#4	1"	1 1/2"	2"	8
S1	45'-11"±	6'-1"	367.4'±	1 1/2"	#4	1"	1 1/2"	2"	8

\* SWAY ROD LENGTHS NOTED ABOVE ARE ESTIMATED. CONTRACTOR SHALL VERIFY IN FIELD.

POTENTIAL SOURCES / MANUFACTURERS  
 PORTLAND BOLT (OR) [PORTLANDBOLTING.COM]  
 CLEVELAND CITY FORGE (OH) [CLEVELANDCITYFORGE.COM]  
 FABSCO CORP. (IL) [FABSCOCORP.COM]  
 ATLANTIC BOLT INC. (NC) [ATLANTICBOLTING.COM]


**2 SWAY ROD DETAIL**

SK-S3 SCALE : 1½" = 1'-0"



**TYP. UPPER WING PLATE  
REINF. DETAIL (24PL)**

1 SK-S3 SCALE : 1½" = 1'-0"



**REVISIONS:**

- REV0: 06/30/21: FOR CONSTRUCTION: JRM
- REV1:
- REV2:
- REV3:
- REV4:
- REV5:

**ALL-POINTS**  
TECHNOLOGY CORPORATION  
567 VAUXHALL STREET EXTENSION - SUITE 311  
WATERFORD, CT 06385  
WWW.ALLPOINTSTECH.COM

**SK-S3**

**SOUTH WINDSOR NORTH CT**  
50 PLANTATION ROAD  
EAST WINDSOR, CT 06016

DATE OF DV: N/A	DRAWN BY: JRM
DATE: 04/26/21	CHECKED BY: MST

**Verizon**  
Cellco Partnership d/b/a

APT FILING NUMBER: CT141NB7760	SHEET NUMBER: SK-S3
VZW FUZE ID: 2132728	VZW PROJECT CODE: 20171645681 LC: 469756 CM: BM

567 VAUXHALL STREET EXTENSION - SUITE 311  
WATERFORD, CT 06385  
WWW.ALLPOINTSTECH.COM

20 ALEXANDER DRIVE  
WALLINGFORD, CT 06492

## CONSTRUCTION DOCUMENTS

NO	DATE	REVISION
0	07/09/20	FOR REVIEW: JRM
1		
2		
3		
4		
5		
6		



## DESIGN PROFESSIONALS OF RECORD

PROF: MICHAEL S. TRODDEN P.E.  
COMP: ALL-POINTS TECHNOLOGY  
CORPORATION  
ADD: 567 VAUXHALL STREET EXT.  
SUITE 311  
WATERFORD, CT 06385

OWNER: PLANTATION PROPERTIES, LLC  
ADDRESS: P.O. BOX 542  
BROAD BROOK, CT 06016-0542



## SOUTH WINDSOR NORTH CT

SITE 50 PLANTATION ROAD  
ADDRESS: EAST WINDSOR, CT 06016  
APT FILING NUMBER: CT141NB7760  
DRAWN BY: DRA  
DATE: 07/09/20 CHECKED BY: JRM  
VZW PROJECT CODE: 20171645681  
VZW LOCATION CODE: 469756  
VZW FUZE ID: 2132728

## SHEET TITLE:

**TANK REINFORCEMENT  
PLAN, DETAILS &  
NOTES**


SHEET NUMBER:

**S-1**

**3 CONNECTION DETAIL**  
S-1 SCALE: 1 1/2" = 1'-0"

**EXCAVATION & TRENCHING NOTES:**

1. CONTRACTOR SHALL ENGAGE THE SERVICES OF AN UNDERGROUND UTILITY LOCATING COMPANY TO LOCATE ALL UNDERGROUND CONDUITS & EQUIPMENT IN THE TRENCHING AREA TO AVOID ANY DAMAGE.
2. HAND EXCAVATE WITHIN 5' OF EXIST. UNDERGROUND UTILITIES (V.I.F.) MAINTAIN 18" MIN. CLEARANCE.
3. CONTRACTOR TO COORDINATE TRENCHING OPERATIONS w/ OWNER AND/OR MANAGEMENT COMPANY SO AS TO MINIMIZE DISRUPTIONS TO THE EXIST. PROPERTY OPERATIONS.



**1 TANK PLAN**  
S-1 SCALE: 1" = 10'-0"

## GENERAL NOTES:

1. COORDINATE WORK TO MINIMIZE DISRUPTION OF EXISTING FACILITIES.
2. WORK MUST BE PERFORMED BY COMPETENT AND QUALIFIED WORKERS WITH EXPERIENCE PERTINENT TO THE TASKS INDICATED HEREIN.
3. WORK TO BE ACCOMPLISHED ON ONE BRACING BAY AT A TIME, REPLACING DIAGONAL SWAY BRACING ONE MEMBER AT A TIME IN 15-MPH OR LESS WIND CONDITIONS. PROVIDE SHORING OR TEMPORARY BRACING AS REQUIRED TO COMPLETE THE WORK.
4. WORK MAY REQUIRE TEMPORARY RELOCATION OF UTILITIES/HANGERS.
5. VERIFY ALL DIMENSIONS AND EXISTING CONDITIONS PRIOR TO FABRICATION. BRING ANY DISCREPANCIES TO THE ATTENTION OF THE ENGINEER BEFORE PROCEEDING WITH THE AFFECTED PORTION OF THE WORK.
6. CONTRACTOR SHALL BE RESPONSIBLE FOR CONSTRUCTION MEANS & METHODS AS WELL AS PROTECTING EXISTING LINES AND FACILITIES FROM WELDING AND CONSTRUCTION DAMAGE.
7. DETAILS SHOWN ON ANY DRAWING ARE CONSIDERED TYPICAL FOR ALL SIMILAR CONDITIONS UNLESS OTHERWISE NOTED.

## STRUCTURAL STEEL:

1. ALL STRUCTURAL STEEL WORK SHALL CONFORM TO THE REQUIREMENTS OF THE AMERICAN INSTITUTE OF STEEL CONSTRUCTION AND ALL APPLICABLE BUILDING CODES.
2. WELD IN ACCORDANCE WITH AWS D1.1 USING CERTIFIED WELDERS AND E70XX ELECTRODES.
3. MATERIALS:
  - SWAY ROD
  - ASTM A307
  - CLEVIS
  - ASTM A668 CLASS A
  - TURNBUCKLES
  - ASTM A668 CLASS C
4. BOLTS SHALL HAVE GALVANIZED LOCK WASHER OR PAL NUT; ANCO NUTS ARE NOT PERMITTED.
5. ANCHOR BOLTS SHALL BE TIGHTENED USING THE 'TURN OF THE NUT' METHOD SPECIFIED BY AISC.
6. HOT-DIP GALVANIZE STEEL MEMBERS AND WELDMENTS PER ASTM D123 AFTER FABRICATION.
7. COLD GALVANIZE ANY FIELD CUT, WELDED, OR DRILLED SURFACES. TOUCH-UP ALL DAMAGED GALVANIZED STEEL WITH ZINC RICH/COLD GALV. (ZINGA®, ZRCO®) OR APPROVED EQUAL, IN ACCORDANCE WITH MANUFACTURER'S GUIDELINES. TOUCH-UP DAMAGED NON-GALVANIZED STEEL WITH SAME PAINT APPLIED IN SHOP OR FIELD.
8. EXERCISE EXTREME CAUTION DURING FIELD WELDING OPERATIONS. THOROUGHLY PROTECT EXISTING EQUIPMENT AND FEED LINES PRIOR TO WELDING.
9. ALL SWAY RODS SHALL BE SNUG TIGHT.

