

EM-CING-046-110614



cingular
raising the bar™

New Cingular Wireless PCS, LLC
500 Enterprise Drive
Rocky Hill, Connecticut 06067-3900
Phone: (860) 463-5511
Fax: (860) 513-7190

Douglas L. Culp
Real Estate Consultant

HAND DELIVERED

June 14, 2011

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, Connecticut 06051

RECEIVED
JUN 14 2011

CONNECTICUT
SITING COUNCIL

Re: New Cingular Wireless PCS, LLC notice of intent to modify an existing telecommunications facility located at 275 North Street Easton, CT (owner SBA).

Dear Ms. Roberts:

In order to accommodate technological changes, implement Uniform Mobile Telecommunications System ("UMTS") and/or Long Term Evolution ("LTE") capabilities, and enhance system performance in the State of Connecticut, New Cingular Wireless PCS, LLC ("AT&T") plans to modify the equipment configurations at many of its existing cell sites. Please accept this letter and attachments as notification, pursuant to R.C.S.A. Section 16-50j-73, of construction which constitutes an exempt modification pursuant to R.C.S.A. Section 16-50j-72(b)(2). In compliance with R.C.S.A. Section 16-50j-73, a copy of this letter and attachments is being sent to the chief elected official of the municipality in which the affected cell site is located.

UMTS technology offers services to mobile computer and phone users anywhere in the world. Based on the Global System for Mobile ("GSM") communication standard, UMTS is the planned worldwide standard for mobile users. UMTS, fully implemented, gives computer and phone users high-speed access to the Internet as they travel. They have the same capabilities even when they roam, through both terrestrial wireless and satellite transmissions.

LTE is a new high-performance air interface for cellular mobile communications. It is designed to increase the capacity and speed of mobile telephone networks.

Attached is a summary of the planned modifications, including power density calculations reflecting the change in AT&T's operations at the site. Also included is documentation of the structural sufficiency of the tower to accommodate the revised antenna configuration.


The changes to the facility do not constitute modifications as defined in Connecticut General Statutes ("C.G.S.") Section 16-50i(d) because the general physical characteristics of the facility will not be significantly changed or altered. Rather, the planned changes to the facility fall squarely within those activities explicitly provided for in R.C.S.A. Section 16-50j-72(b)(2).

1. The height of the overall structure will be unaffected.
2. The proposed changes will not extend the site boundaries. There will be no effect on the site compound other than some enlarged equipment pads as may be noted in the attachments.
3. The proposed changes will not increase the noise level at the existing facility by six decibels or more.
4. Radio frequency power density may increase due to use of one or more GSM channel for UMTS transmissions. Moreover, LTE will utilize additional radio frequencies newly-licensed by the FCC for cellular mobile communications. However, the changes will not increase the calculated "worst case" power density for the combined operations at the site to a level at or above the applicable standard for uncontrolled environments as calculated for a mixed frequency site.

For the foregoing reasons, New Cingular Wireless respectfully submits that the proposed changes at the referenced site constitute exempt modifications under R.C.S.A. Section 16-50j-72(b)(2).

Please feel free to call me at (860) 463-5511 with questions concerning this matter. Thank you for your consideration.

Sincerely,



Douglas L. Culp
Real Estate Consultant

Attachments

**NEW CINGULAR WIRELESS PCS, LLC
Equipment Modification**

275 North Street Easton, CT
Site Number CT5050
Exempt Mod

Tower Owner/Manager: SBA Network Services, Inc

Equipment configuration: Monopole

Current and/or approved: Six PowerWave antennas @ 155 ft
Six PowerWave TMA's and Six PowerWave Diplexers @ 155 ft
Twelve runs 1 5/8 inch coax to 155 ft
Equipment on Concrete Pad

Planned Modifications: Retain existing PowerWave Antenna's, TMA's and Diplexers at 155 ft
Retain all Coax Cabling
Install three PowerWave P65-16 antennas or equivalent @ 155 ft
Install six remote radio heads and surge arrestor @ 155 ft
Install one fiber and two DC power cables to 155 ft

Power Density:

Worst-case calculations for existing wireless operations at the site, using standard parameters for other carriers, indicate a radio frequency electromagnetic radiation power density, measured at ground level beside the Tower, of 16.3 % of the standard adopted by the FCC. As depicted in the second table below, the total radio frequency electromagnetic radiation power density following proposed modifications would be approximately 17.8 % of the standard.

Existing

Company	Centerline Ht (feet)	Frequency (MHz)	Number of Channels	Power Per Channel (Watts)	Power Density (mW/cm ²)	Standard Limits (mW/cm ²)	Percent of Limit
Other Users							7.79
AT&T UMTS	155	1900 Band	1	500	0.0075	1.0000	0.75
AT&T UMTS	155	800 Band	1	500	0.0075	0.5867	1.28
AT&T GSM	155	800Band	6	296	0.0266	0.5867	4.53
AT&T UMTS	155	1900 Band	3	427	0.0192	1.0000	1.92
Total							16.3%

* Data for other users are from Siting Council records.

Proposed

Company	Centerline Ht (feet)	Frequency (MHz)	Number of Channels	Power Per Channel (Watts)	Power Density (mW/cm ²)	Standard Limits (mW/cm ²)	Percent of Limit
Other Users							7.79
AT&T UMTS	155	800 Band	1	500	0.0075	0.5867	1.28
AT&T UMTS	155	1900 Band	1	500	0.0075	1.0000	0.75
AT&T GSM	155	880 - 894	6	296	0.0266	0.5867	4.53
AT&T GSM	155	1900 Band	3	427	0.0192	1.0000	1.92
AT&T LTE	155	740 - 746	1	500	0.0075	0.4933	1.52
Total							17.8%

* Data for other users are from Siting Council records

Structural information:

The attached structural analysis demonstrates that the monopole and foundation have adequate structural capacity to accommodate the proposed modifications. (FDH Engineering dated 6-2-11).



REQUIRED 3'-0" CLEARANCE PER NEC

EXISTING AT&T POWER PANEL

3'-0" (TYP.)

REMOVE EXISTING NOKIA NUSS CABINET AFTER INSTALLATION OF NEW EMERSON POWER CABINET

PROPOSED POWER CONDUIT FROM AC PANEL TO EMERSON POWER CABINET

EXISTING CONCRETE PAD

PROPOSED EMERSON POWER CABINET ON EXISTING CONCRETE PAD

EXISTING AT&T TELCO PANEL

EXISTING AT&T GPS ANTENNA MOUNTED CABLE BRIDGE TO BE MOVED 10' MIN FROM PROPOSED AT&T LTE GPS

EXISTING NOKIA NUSS CABINET

EXISTING NOKIA GSM CABINET

EXISTING EMERSON GSM 3106 UNITS CABINET

3'-8"

EXISTING CONCRETE PAD-7

PROPOSED LTE FLYING PURCELL CABINET AND DC8-86-60-0-1B SURGE SUPPRESSOR (BELOW) MOUNTED ON PROPOSED H-FRAME ON EXISTING CONCRETE PAD

EXISTING 190'-0" MONOPOLE
DC POWER AND FIBER CABLES TO TRANSITION OUT OF 3" FLEX CONDUIT AND INTO MONOPOLE

ATTACH DC POWER AND FIBER CABLES IN 3" FLEX CONDUIT TO EXISTING CABLES UNDER EXISTING CABLE BRIDGE

1'-7"

EXISTING AT&T DIPLEXER RACK MOUNTED TO EXISTING CABLE BRIDGE SUPPORTS WITH (12) POWERWAVE DIPLEXERS

EXISTING AT&T CABLE BRIDGE WITH (12) 1-5/8" COAX CABLES

PROPOSED 1/2" COAX FOR AT&T LTE GPS

PROPOSED AT&T LTE GPS ANTENNA MOUNTED TO EXISTING CABLE BRIDGE SUPPORT 10' MIN FROM EXISTING AT&T GPS

EQUIPMENT PLAN

GRAPHIC SCALE 0 1 2 FEET

1

CO2



3


COB

4


CO5

1

CO5



NO.	REVISION	DATE	BY
1	REVISED	10/10/07	SPS
2	REVISED	10/10/07	SPS



PROJECT NO. CT15050
SITE ADDRESS: HIGH RIDGE, 275 NORTH STREET EASTON, CT 08612
COUNTY: FAIRFIELD COUNTY

EQUIPMENT PLAN


SHEET NUMBER CO2



NEW CONSUMERS WIRELESS, INC. LLC
200 ENTERPRISE DRIVE
ROCKY HILL, CT 06867




NO.	DESCRIPTION	DATE
0	ISSUED FOR REVIEW	05/05/03
1	ISSUED FOR CONSTRUCTION	05/05/03
2	ISSUED FOR CONSTRUCTION	05/05/03




IT IS A VIOLATION BY LAW FOR ANY PERSON UNLICENSED HEREIN TO REPRODUCE OR TO ALTER THIS DOCUMENT.

SITE ID: CT15050
SITE NAME: HIGH RIDGE
SITE ADDRESS: 275 NORTH STREET EASTON, CT 06612
FAIRFIELD COUNTY

SHEET TITLE: ELEVATION AND ANTENNA PLAN
SHEET NUMBER: C03



NOTE: SYNTHETIC PINE TREE BRANCHES NOT SHOWN FOR CLARITY




NOTE: SYNTHETIC PINE TREE BRANCHES NOT SHOWN FOR CLARITY

NOTE: REFER TO FINAL RFDS FOR FINAL SECTOR CONFIGURATIONS.

2 ANTENNA PLANS
C03 SCALE: N.T.S.

NOTE: PAINT ALL TOWER MOUNTED EQUIPMENT TO MATCH TOWER



NOTE: A STRUCTURAL ANALYSIS OF THE EXISTING TOWER HAS NOT BEEN PERFORMED. AN ANALYSIS OF THE EXISTING STRUCTURE MUST BE PERFORMED PRIOR TO CONSTRUCTION TO CONFIRM STRUCTURE IS CAPABLE OF SUPPORTING PROPOSED LOADS.

TOP OF MONOPOLE AT 190'-0" AGL



Your world. Delivered.


NEW CONULAR WIRELESS PCS, LLC
530 ENTERPRISE DRIVE
ROCKY HILL, CT 06867



239 Main Street, Rocky Hill, CT 06867
Tel: 860-262-8877
Fax: 860-262-8877
www.cha.com

CHA PROJECT NO.
2702 - 1018 - 43009


NO.	DATE	DESCRIPTION
0	02/27/11	ISSUED FOR PERMIT
1	04/27/11	ISSUED FOR CONSTRUCTION
2	07/27/11	ISSUED FOR PERMIT



STATE OF CONNECTICUT
JOHN P. SOBIEAJ
No. 17827
LICENSED PROFESSIONAL ENGINEER
I AM NOT PROVIDING ANY PROFESSIONAL SERVICES TO ANY PERSON OR ENTITY UNLESS I AM SPECIFICALLY AUTHORIZED TO DO SO BY THIS DOCUMENT.


SITE ID:
C15050
SITE NAME:
HIGH RIDGE
SITE ADDRESS:
275 NORTH STREET
EASTON, CT
06812
FAIRFIELD COUNTY

SHEET TITLE
STRUCTURAL DETAILS
SHEET NUMBER
C04




NOTE:
1. THE WEIGHT OF THE ANTENNA MOUNT IS 6.5 LBS.

4 GPS MOUNTING DETAIL
C04 SCALE: NTS




NOTE:
1. THE WEIGHT OF THE ANTENNA MOUNT IS 6.5 LBS.

3 FLEX CONDUIT DETAIL
C04 SCALE: NTS




NOTE:
1. THE WEIGHT OF THE ANTENNA MOUNT IS 6.5 LBS.

2 RRH MOUNTING DETAIL
C04 SCALE: NTS




NOTE:
1. MOUNT ANTENNA IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDED PROCEDURE.

6 TYPICAL ANTENNA MOUNTING DETAIL
C04 SCALE: NTS




NOTE:
1. SURGE ARRESTOR MOUNTING BRACKET AND HARDWARE TO BE PROVIDED BY MANUFACTURER.

5 SURGE ARRESTOR MOUNTING DETAIL
C04 SCALE: NTS



1 PLAN



1 ELEVATION

NOTE:
1. CONTRACTOR TO ENSURE THAT RRH AND SURGE ARRESTOR MOUNTING DOES NOT OBSTRUCT ACCESS TO CLIMBING LADDERS.
2. INSTALL RRH WITH ADEQUATE CLEARANCE FROM AT&T PLATFORM TO ALLOW ROOM FOR ACCESS.

1 RRH/SURGE ARRESTOR MOUNTING DETAIL
C04 SCALE: NTS




Your work. Delivered.

INEM CIRCULAR WIRELESS, INC. LLC
500 ENTERPRISE DRIVE
ROCKY HILL, CT 06867



CHA, INC. PRO. REG. U.S.
27202 - 1019 - 43000

NO.	DATE	DESCRIPTION
0	03/27/13	ISSUED FOR PERMIT
1	04/22/13	ISSUED FOR CONSTRUCTION
2	08/20/13	ISSUED FOR CONSTRUCTION




IT IS A VIOLATION OF LAW FOR ANY PERSON, OTHER THAN THE LICENSEE, TO SIGN ANY DOCUMENT OF A LICENSED PROFESSIONAL ENGINEER, WITHOUT HIS OR HER SIGNATURE TO ALIAS HIS DOCUMENT.


SITE ID:
CT15050
SITE NAME:
HIGH RIDGE
SITE ADDRESS:
275 NORTH STREET
EASTON, CT
FAIRFIELD COUNTY
06612

STRUCTURAL DETAILS


SHEET NUMBER
C05



1 PURCELL AND SURGE ARRESTOR MOUNTING DETAIL
SCALE: NTS



2 FLEX CONDUIT DETAIL
SCALE: NTS




3 CONCRETE MOUNTED CONDUIT
SCALE: NTS

NOTES:

- REPLACE EXISTING SURFACE CONDITIONS IN KIND TO INCLUDE, BUT NOT LIMITED TO, CONCRET, UNFINISHED STONE, SELECT GRAVEL, ASPHALT, TOPSOIL AND GRASS.
- $3/8"$ MIN. COVER.

4 UNDERGROUND CONDUITS
SCALE: NTS





NEW CONSUMER WIRELESS, INC. LLC
 1000 ROCKY HILL, CT 06067

2020 New Haven Planning, Suite 210, 1400 N. 17th Street, Easton, CT 06120
CHA
 COMMUNICATIONS CONTRACTORS ASSOCIATION
 2020 New Haven Planning, Suite 210, 1400 N. 17th Street, Easton, CT 06120
 2020 New Haven Planning, Suite 210, 1400 N. 17th Street, Easton, CT 06120


NO.	REVISION	DATE	BY	CHKD.
0	ISSUED FOR REVIEW	05/22/11	ED	ED
1	ISSUED FOR CONSTRUCTION	05/22/11	ED	ED



IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE LICENSED UNDER THE JURISDICTION OF A STATE, TO SEAL THIS DOCUMENT.


SITE ID: CT5050
 SITE NAME: HIGH RIDGE
 SITE ADDRESS: 275 NORTH STREET EASTON, CT 06121
 FAIRFIELD COUNTY

SHEET TITLE: GROUNDING & PLUMBING DIAGRAM
 SHEET NUMBER: E.01




- LEGEND**
- 1 - COPPER GROUND BAR. HOLE CENTERS TO MATCH NEMA DOUBLE LUG CONFIGURATION.
 - 2 - INSULATORS, NEWTON INSTRUMENT CAT. NO. 3061-4. (NOT TO BE USED ON BARS PHYSICALLY ATTACHED TO TOWER.)
 - 3 - 5/8" LOCKWASHERS, NEWTON INSTRUMENT CO. CAT. NO. 3015-B
 - 4 - WALL MOUNTING BRACKET, NEWTON INSTRUMENT CO. CAT. NO. A-6056
 - 5 - 5/8-11 X 1" 4H.C.S.BOLTS, NEWTON INSTRUMENT CO. CAT. NO. 3012-1

2 GROUND BAR
 NO SCALE




1 GROUND WIRE INSTALLATION TO GROUND BAR
 NO SCALE




- NOTE:**
- DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO CABLE.

3 GROUND WIRE TO GROUND BAR CONNECTION DETAIL
 NO SCALE



4 GROUNDING RISER DIAGRAM
 NO SCALE



- NOTES:**
- CONTRACTOR TO CONFIRM ALL PARTS.
 - INSTALL ALL EQUIPMENT TO MANUFACTURER'S RECOMMENDATIONS.

5 PLUMBING DIAGRAM
 NO SCALE

GROUNDING SYSTEM NOTES:

- CONDUCTOR USED FOR CELLULAR GROUNDING SYSTEM. INTER-LEG EXTENSION (FROM IOR TO EGR) - #2 AWG ANNEALED SOLID TINNED BARE COPPER. EXTERIOR BOND CONNECTIONS TO EGR - #2 AWG ANNEALED SOLID TINNED BARE COPPER. INTERIOR BOND CONNECTIONS TO EGR - #2 AWG SOLID COPPER.
- MINIMUM BENDING RADIUS FOR CELLULAR GROUNDING CONDUCTOR SHALL BE AS STRAIGHT AS POSSIBLE WITH MINIMUM 8" RADIUS.
- CONNECTIONS (MECHANICAL) COMPRESSION LUG CONNECTOR - 15 TON COMPRESSION, 2-HOLE, LONG BARREL, ELECTRO TINNED PLATED, HIGH CONDUCTIVITY COPPER, BODY RATED, USE 1/4" DIA. BOLT, 3/4" SPACING LUGS TO BOND OBJECTS FROM IOR. CONNECTOR SHALL BE BURNDY "HPLUG" SERIES OR EQUAL.
- EXOTHERMIC WELD LUG CONNECTOR - 2 HOLE OFFSET, ELECTRO TINNED PLATED, HIGH CONDUCTIVITY COPPER, BODY USE 1/4" DIA. BOLT, 1/2" SPACING LUGS TO BOND OBJECTS FROM IOR. CONNECTOR SHALL BE CADWELD CONNECTION STYLE (CABLE TO SURFACE) TYPE "A". EXOTHERMIC WELD TO LUG AS REQUIRED.
- "C" TAP COMPRESSION CONNECTOR - HIGH CONDUCTIVITY COPPER FOR MAIN-BRANCH TAPPING. CONNECTOR SHALL BE BURNDY "HITAP" SERIES OR EQUAL. USE MATCHING MANUFACTURER TOOL AND DIE FOR COMPRESSION CONNECTION. APPLY ANTI-OXIDANT CONDUCTIVITY ENHANCER COMPOUND ON SURFACES THAT ARE COMPRESSED. SURFACES INTENDED TO BE CONNECTED WITH MECHANICAL CONNECTIONS SHALL BE BARE METAL TO BARE METAL. PRIME AND PAINT OVER BONDING AREA TO PREVENT CORROSION.
- CONNECTIONS - BELOW GRADE (EXOTHERMIC) PROVIDE CADWELD CONNECTIONS - STYLE AND TYPE AS REQUIRED.
- WHEN BONDING #2 TO #2 EXTERIOR OF SHELTER - USE EXOTHERMIC WELD CONNECTION.
- WHEN BONDING #2 TO FENCE POST SURFACE - TEST WELD FOR FUSIBLE BOND. CONNECTION TO FENCE POST STEEL SURFACE SHALL BE WELDED TOGETHER WITH GALVANIZED COATING AS REQUIRED FOR PROPER WELDED PERMANENT BOND. REFER TO MANUFACTURER'S REQUIREMENTS FOR DETAILS.

SECTION 16050 GROUNDING

- 1.01 ALL NON-CURRENT CARRYING PARTS OF THE ELECTRICAL SYSTEM AND TELEPHONE CONDUIT SYSTEMS SHALL BE MECHANICALLY AND ELECTRICALLY CONNECTED TO PROVIDE AN INDEPENDENT RETURN PATH TO THE EQUIPMENT GROUNDING SOURCES.
- 1.02 GROUNDING SYSTEM WILL BE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND LOCAL INSPECTOR HAVING JURISDICTION.
- 1.03 ELECTRICAL AC SERVICE GROUNDING SYSTEM - GROUNDING AT MAIN SERVICE OVERCURRENT PROTECTION DEVICE.
 - THE GROUNDING CONDUCTOR (NEUTRAL) OF THE INCOMING SERVICE FEEDERS (LINE SIDE OF THE METER SOCKET) SHALL TERMINATE INTO THE MAIN OVERCURRENT DEVICE ENCLOSURE SOLID NEUTRAL BAR WHICH IS INSULATED FROM THE ENCLOSURE.
 - THE GROUNDING ELECTRODE CONDUCTOR SHALL EXTEND CONTINUOUSLY WITHOUT SPLICES OR JOINTS FROM THE MAIN SWITCHBOARD GROUND TERMINAL NEUTRAL BAR TO THE MAIN SWITCHBOARD GROUND TERMINAL.
 - THE MAIN SERVICE OVERCURRENT PROTECTION DEVICE ENCLOSURE'S SURFACES BETWEEN THE MAIN NEUTRAL BAR AND SOLID NEUTRAL BONDING JUMPER BETWEEN EQUIPMENT GROUND BAR AND SOLID NEUTRAL BONDING JUMPER CONDUCTOR SIZE SHALL BE THE SAME AS THE GROUNDING ELECTRODE CONDUCTOR. CONDUITS TERMINATING INTO THE MAIN OVERCURRENT DEVICE ENCLOSURE SHALL BE BARE METAL TO BARE METAL. ALL CONNECTIONS SHALL BE BONDED TOGETHER WITH #10 AWG BARE COPPER WHICH IN TURN IS TERMINATED INTO THE EQUIPMENT GROUND BAR MIT.
- 1.04 CELLULAR GROUNDING SYSTEM:
 - PROVIDE THE CELLULAR GROUNDING SYSTEM AS SPECIFIED ON DRAWINGS. INCLUDING BUT NOT LIMITED TO:
 - GROUNDING BONDING RING
 - ANTENNA GROUND CONNECTIONS AND PLATES

SECTION 16120 CONDUCTORS

- 1.01 ALL CONDUCTORS SHALL BE THE TYPE TWIN (EXTERIOR) AND HAWK (EXTERIOR), 75 DEGREES C, 600 VOLT INSULATION, SOFT DRAWN, STRANDED COPPER, #10 AWG AND SMALLER SHALL BE SPICED USING SOLDFLOSS PRESSURE CONNECTORS, ACCEPTABLE. #12 AWG SHALL BE MINIMUM SIZE CONDUCTOR FOR LINE VOLTAGE BRANCH CIRCUITS. REFER TO PANEL SCHEDULE FOR BRANCH CIRCUIT CONDUCTOR SIZES. CONDUCTORS SHALL BE COLOR CODED FOR CONSISTENT PHASE IDENTIFICATION.
 - 120 / 240 VAC - 1 PHASE, 3 WIRE SYSTEM
 - PHASE:
 - A BLACK
 - B RED
 - C CONTINUOUS WHITE
 - G CONTINUOUS GREEN
- 1.02 MINIMUM BENDING RADIUS FOR CONDUCTORS SHALL BE 12 TIMES THE LARGEST DIAMETER OF BRANCH CIRCUIT CONDUCTOR.
- SECTION 16130 RACEWAY
 - 1.01 CONDUIT MATERIAL SHALL BE AS FOLLOWS:
 - GALVANIZED RIGID CONDUIT (GRC) - FEEDERS EXPOSED TO EXTERIOR & UNDERGROUND CONDUIT SNEEPS.
 - PVC CONDUIT - SERVICE CONDUITS AND WHERE SHOWN ON GROUNDING DETAILS.

GENERAL NOTES:

- ALL DIMENSIONS TO FACE AND IN EXISTING STRUCTURES SHALL BE AS SHOWN IN FIELD BY CONTRACTOR WITH ALL DISCREPANCIES REPORTED TO THE ENGINEER. THE APPROVAL OF THE ENGINEER.
- DETAILS SHOWN ARE TYPICAL AND APPLY TO SIMILAR CONDITIONS UNLESS NOTED OTHERWISE.
- THESE DRAWINGS DO NOT INCLUDE NECESSARY COMPONENTS FOR CONSTRUCTION SAFETY.
- BRACE STRUCTURES AS REQUIRED FOR CONSTRUCTION AND WIND LOADS UNTIL ALL STRUCTURAL ELEMENTS NEEDED FOR STABILITY ARE INSTALLED. THESE ELEMENTS ARE AS FOLLOWS: (LATERAL BRACING MEMBERS, ANCHOR BOLTS, ETC.) THE DESIGN IS BASED ON THE 2005 CONNECTICUT STATE BUILDING CODE (BC 2003), 2005 CONNECTICUT SUPPLEMENT AND THE 2009 AMENDMENT TO THE 2005 CONNECTICUT SUPPLEMENT AND TIA/91A-222-G.
- CONTRACTOR SHALL DETERMINE EXACT LOCATION OF EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE OCCASIONED BY HIS FAILURE TO EXACTLY LOCATE AND PRESERVE UNDERGROUND UTILITIES.
- INCORRECTLY FABRICATED, DAMAGED, OR OTHERWISE MISFITTING OR NONCONFORMING MATERIALS OR CONDITIONS SHALL BE REPORTED TO THE OWNER PRIOR TO REMEDIAL OR CORRECTIVE ACTION. ANY SUCH ACTION SHALL REQUIRE ENGINEER'S APPROVAL.
- EACH CONTRACTOR SHALL COOPERATE WITH THE OWNER'S REPRESENTATIVE AND COORDINATE HIS WORK WITH THE WORK OF OTHERS.
- VERIFY SIZE AND LOCATION OF OPENINGS PRIOR TO BEGINNING WORK. FOR DIMENSIONS NOT SHOWN, SEE CIVIL DRAWINGS.
- VERIFY SIZE AND LOCATION OF EQUIPMENT PADS WITH MECHANICAL AND/OR ELECTRICAL CONTRACTOR AND EQUIPMENT MANUFACTURER.
- CONTRACTOR TO FOLLOW ALL STATE, LOCAL AND NATIONAL CODES AS APPLICABLE.

APURTENANCE SUPPORT BRACKET NOTES:

- DESIGN RESPONSIBILITY OF APURTENANCE MOUNTING BRACKETS AND POLES AND ALL COMPONENTS THERE OF AND ATTACHMENT THERE TO SHALL BE THE RESPONSIBILITY OF THE MANUFACTURER. MANUFACTURER SHALL PROVIDE TO THE ENGINEER FOR APPROVAL, DRAWINGS DETAILING ALL COMPONENTS OF THE APURTENANCE SUPPORT BRACKET, DESIGN LOADS, AND ALL OTHER PERTINENT DATA. ALL SUBMISSIONS SHALL BE IN THE FORM OF A PROFESSIONAL ENGINEER REGISTERED IN THE STATE OF CONNECTICUT.
- BRACKETS SHALL BE DESIGNED TO SUPPORT CURRENT AND FUTURE PANEL ANTENNAS, REMOTE RADIO HEADS, SURGE ARRESTORS, AND COAXIAL CABLES AS SHOWN.

STEEL NOTES:

- STRUCTURAL STEEL FABRICATION AND ERECTION SHALL CONFORM TO THE LATEST EDITION OF THE AISC STEEL CONSTRUCTION MANUAL.
- STRUCTURAL STEEL SHALL CONFORM TO THE FOLLOWING:
 - WIDE FLANGE AND CHANNEL SHAPES - A992 GR 50 (50 KSI) UNLESS OTHERWISE NOTED
 - ANGLES AND PLATES - ASTM A36 (36 KSI)
 - STEEL PIPE - ASTM A53, GRADE B A500 GRADE B (35 KSI)
- ALL EXTERIOR STEEL WORK SHALL BE GALVANIZED IN ACCORDANCE WITH ASTM SPECIFICATION A123 UNLESS OTHERWISE NOTED. GALVANIZING SHALL BE PERFORMED AFTER SHOP FABRICATION TO THE GREATEST EXTENT POSSIBLE. ALL DRINGS, SCRAPES, MARKS AND WELDS IN THE GALVANIZED AREAS SHALL BE REPAIRED BY FIELD TOUCHUP PRIOR TO COMPLETION OF THE WORK USING ZRC COAL GALVANIZING COMPOUND OR APPROVED EQUAL.
- CONNECTIONS:
 - ALL BOLTS, NUTS AND WASHERS USED IN EXTERIOR APPLICATIONS SHALL BE GALVANIZED.

DESIGN LOADS:

THE FOLLOWING DESIGN LOADS WERE USED FOR THIS BUILDING BASED ON THE 2005 CONNECTICUT STATE BUILDING CODE (BC 2003), 2005 CONNECTICUT SUPPLEMENT AND THE 2009 AMENDMENT TO THE 2005 CONNECTICUT SUPPLEMENT AND TIA/91A-222-G:

ICE LOAD: 3/4" RADIAL ON ALL COMPONENTS AND CABLE

WIND DESIGN DATA:
 BASIC WIND SPEED (3 SECOND GUST): 110 MPH
 WIND IMPORTANCE FACTOR = 1.0
 WIND EXPOSURE CATEGORY: B


EARTHQUAKE DESIGN DATA:
 SEISMIC IMPORTANCE FACTOR: 1.0
 MAPPED SPECTRAL RESPONSE ACCELERATIONS: SS=0.278 S1=0.065
 SITE CLASS: D
 SEISMIC DESIGN CATEGORY: B



NEW CONSUMER SERVICES, INC. LLC
 500 ENTERPRISE DRIVE
 ROCKY HILL, CT 06067



REVISIONS	
NO.	DESCRIPTION
1	ISSUED FOR PERMIT
2	ISSUED FOR CONSTRUCTION
3	ISSUED FOR CONSTRUCTION
4	ISSUED FOR CONSTRUCTION



IT IS A VIOLATION OF LAW FOR ANY PERSON UNLESS HE BE A LICENSED PROFESSIONAL ENGINEER TO ALTER THIS DOCUMENT.

SITE ID: CT5050
 SITE NAME: HIGH RIDGE
 SITE ADDRESS: 275 NORTH STREET EASTON, CT 06612
 FAIRFIELD COUNTY

SHEET TITLE: GENERAL NOTES

SHEET NUMBER: GNO1



FDH Engineering, Inc., 2730 Rowland Rd. Raleigh, NC 27615, Ph. 919.755.1012, Fax 919.755.1031

**Structural Analysis for
SBA Network Services, Inc.**

185' Monopine

**SBA Site Name: North Easton
SBA Site ID: CT00707-S**

FDH Project Number 11-05207E S1

Prepared By:

Brandon Compton, EI
Project Engineer

Reviewed By:

Christopher M. Murphy, PE
President
CT PE License No. 25842

FDH Engineering, Inc.
2730 Rowland Rd.
Raleigh, NC 27615
(919) 755-1012
info@fdh-inc.com

June 2, 2011



Prepared pursuant to TIA/EIA-222-F June 1996 Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

TABLE OF CONTENTS

EXECUTIVE SUMMARY..... 3
 Conclusions
 Recommendations

APPURTENANCE LISTING..... 4

RESULTS..... 5

GENERAL COMMENTS..... 6

LIMITATIONS..... 6

APPENDIX..... 7

EXECUTIVE SUMMARY

At the request of SBA Network Services, Inc., FDH Engineering, Inc. performed a structural analysis of the monopole located in Easton, CT to determine whether the tower is structurally adequate to support both the existing and proposed loads, pursuant to the *Structural Standards for Steel Antenna Towers and Antenna Supporting Structures, TIA/EIA-222-F*. Information pertaining to the existing/proposed antenna loading, current tower geometry, soil parameters, foundation dimensions, and member sizes was obtained from Paul J. Ford and Company (Job No. 20099-146) original design drawings dated August 10, 1999, Jaworski Geotech, Inc. (Project No. C98404G) Geotechnical Evaluation dated July 30, 1999, and SBA Network Services, Inc.

The *basic design wind speed* per the *TIA/EIA-222-F* standards is 85 mph without ice and 38 mph with 3/4" radial ice. Ice is considered to increase in thickness with height.

Conclusions

With the current and proposed antennas from AT&T in place at 155' (see **Table 1**), the tower meets the requirements of the *TIA/EIA-222-F* standards provided the **Recommendations** listed below are satisfied. Furthermore, provided the foundation was designed and constructed to support the original design reactions (see Paul J. Ford Job No. 20099-146), the foundation should have the necessary capacity to support the existing and proposed loading. For a more detailed description of the analysis of the tower, see the **Results** section of this report.

Our structural analysis has been performed assuming all information provided to FDH Engineering, Inc. is accurate (i.e. the steel data, tower layout, existing antenna loading, and proposed antenna loading) and that the tower has been properly erected and maintained per the original design drawings.

Recommendations

To ensure the requirements of the *TIA/EIA-222-F* standards are met with the existing and proposed loading in place, we have the following recommendations:

1. Proposed coax should be installed inside the monopole's shaft.
2. Existing TMAs should be installed directly behind the proposed and existing antennas.
3. Proposed RRUs should be installed directly behind the proposed and existing antennas.

APPURTENANCE LISTING

The proposed and existing antennas with their corresponding cables/coax lines are shown in **Table 1**. If the actual layout determined in the field deviates from this layout, FDH Engineering, Inc. should be contacted to perform a revised analysis.

Table 1 – Appurtenance Loading

Existing Loading:

Antenna No.	Antenna Elevation (ft)	Description	Coax and Lines ¹	Carrier	Mount Elevation (ft)	Mount Type
1-3	185	(3) EMS-RR90-17-02DP (6) Allen Telecom FE15S01P77/75 TMAs	(6) 1-5/8"	T-Mobile	185	(3) Cobra Arms
---	---	6' Branches	---	---	---	---
---	179.5	6' Branches	---	---	---	---
4-9	175	(6) Decibel DB980H90E-M	(6) 1-5/8"	Sprint	175	(3) Cobra Arms
---	174.5	7' Branches	---	---	---	---
---	196.5	8' Branches	---	---	---	---
10-21	165	(6) Antel LPA-80090/4CF (6) Antel LPA-185090/8CF	(12) 1-5/8"	Verizon	165	(3) Cobra Arms
---	164.5	8' Branches	---	---	---	---
---	159.5	9' Branches	---	---	---	---
22-27	155 ²	(6) Powerwave 7770 (6) Powerwave LGP 21401 TMAs (6) Powerwave LGP 21903 Diplexers	(12) 1-5/8"	AT&T	155	(3) Cobra Arms
---	154.5	9' Branches	---	---	---	---
---	149.5	10' Branches	---	---	---	---
---	144.5	11' Branches	---	---	---	---

1. Coax installed inside the pole's shaft, unless otherwise noted.

2. AT&T's loading will be altered at 155'. See the proposed loading below.

Proposed Loading:

Antenna No.	Antenna Elevation (ft)	Description	Coax and Lines	Carrier	Mount Elevation (ft)	Mount Type
1-9	155 ¹	(6) Powerwave 7770.00 (3) Powerwave P65-16-XLH-RR (6) Powerwave LGP 21401 TMAs (6) Powerwave LGP21903 Diplexers (6) Ericsson RRUS-11 RRUs (1) Raycap DC6-48-60-18-8F Surge Suppressor	(12) 1-5/8" (1) Fiber (2) DC Power	AT&T	155	(3) Cobra Arms

1. This represents the final configuration for AT&T at 155'. According to the information provided by SBA, AT&T will install (3) Powerwave P65-16-XLH-RR antennas, (6) Ericsson RRUS-11 RRUs, (1) Raycap DC6-48-60-18-8F Surge Suppressor, (1) 0.39" fiber cable, and (2) 0.645" DC Power cables in addition to their existing antennas, TMAs, diplexers, and coax at 155'.

RESULTS

Based on information obtained from the original design drawings, the yield strength of steel for individual members was as follows:

Table 2 - Material Strength

Member Type	Yield Strength
Tower Shaft Sections	65 ksi
Base Plate	50 ksi
Anchor Bolts	75 ksi

Table 3 displays the summary of the ratio (as a percentage) of force in the member to their capacities. Values greater than 100% indicate locations where the maximum force in the member exceeds its capacity. *Note: Capacities up to 100% are considered acceptable.* **Table 4** displays the maximum foundation reactions.

If the assumptions outlined in this report differ from actual field conditions, FDH Engineering, Inc. should be contacted to perform a revised analysis. Furthermore, as no information pertaining to the allowable twist and sway requirements for the existing or proposed appurtenances was provided, deflection and rotation were not taken into consideration when performing this analysis.

See the **APPENDIX** for detailed modeling information.

Table 3 - Summary of Working Percentage of Structural Components

Section No.	Elevation ft	Component Type	Size	% Capacity	Pass Fail
L1	185 - 143.75	Pole	TP33.22x21.375x0.1858	97.4	Pass
L2	143.75 - 94.0833	Pole	TP47.108x31.6042x0.375	93.9	Pass
L3	94.0833 - 46.1667	Pole	TP60.118x44.6114x0.4375	90.4	Pass
L4	46.1667 - 0	Pole	TP72.5x56.9936x0.4375	95.4	Pass
		Anchor Bolts	(24) 2.25" ϕ w/ BC = 79.875" BC	88.4	Pass
		Base Plate	79.625' sq. PL x 3.5" thk.	60.6	Pass

*Capacities include 1/3 allowable increase for wind.

Table 4 - Maximum Base Reactions

Base Reactions	Current Analysis (TIA/EIA-222-F)	Original Design (TIA/EIA-222-F)
Axial	57 k*	52 k
Shear	50 k	53 k
Moment	6,975 k-ft	7,275 k-ft

*Given our experience with foundations of a similar nature, the vertical load will not control.

GENERAL COMMENTS


This engineering analysis is based upon the theoretical capacity of the structure. It is not a condition assessment of the tower and its foundation. It is the responsibility of SBA Network Services, Inc. to verify that the tower modeled and analyzed is the correct structure (with accurate antenna loading information) modeled. If there are substantial modifications to be made or the assumptions made in this analysis are not accurate, FDH Engineering, Inc. should be notified immediately to perform a revised analysis.

LIMITATIONS

All opinions and conclusions are considered accurate to a reasonable degree of engineering certainty based upon the evidence available at the time of this report. All opinions and conclusions are subject to revision based upon receipt of new or additional/updated information. All services are provided exercising a level of care and diligence equivalent to the standard and care of our profession. No other warranty or guarantee, expressed or implied, is offered. Our services are confidential in nature and we will not release this report to any other party without the client's consent. The use of this engineering work is limited to the express purpose for which it was commissioned and it may not be reused, copied, or distributed for any other purpose without the written consent of FDH Engineering, Inc.

APPENDIX

Section	11	2	3	4	11
Length (ft)	41.25	54.00	54.00	54.00	40.4
Number of Sides	18	18	18	18	
Thickness (in)	0.1858	0.3750	0.4375	0.4375	
Socket Length (ft)	4.33	6.06	7.83		
Top Dia (in)	21.3750	31.6042	44.6114	56.9936	
Bot Dia (in)	39.2200	47.1080	60.1180	72.5000	
Grade					A572-85
Weight (K)	2.2	8.6	13.2	16.4	



DESIGNED APPURTENANCE LOADING


TYPE	ELEVATION	TYPE	ELEVATION
Lightning Rod	185	(2) LPA-80990/4CF w/Mount Pipe	185
RR90-17-02DP w/Mount Pipe	185	(2) LPA-80990/4CF w/Mount Pipe	185
RR90-17-02DP w/Mount Pipe	185	(2) LPA-185090/6CF w/Mount Pipe	165
RR90-17-02DP w/Mount Pipe	185	8' Branches	164.5
(3) Empty Pipe Mount	185	9' Branches	159.5
(3) Empty Pipe Mount	185	(2) LGP 21401 TMA	155
(3) Empty Pipe Mount	185	(2) LGP 21401 TMA	155
(2) FE15S01P77/75 TMA	185	(2) LGP 21401 TMA	155
(2) FE15S01P77/75 TMA	185	(2) LGP21903 Diplexer	155
(2) FE15S01P77/75 TMA	185	(2) LGP21903 Diplexer	155
(3) Cobra Mounts	185	(2) LGP21903 Diplexer	155
6' Branches	185	(2) RRUS 11 RRU	155
6' Branches	179.5	(2) RRUS 11 RRU	155
(2) DB980H90E-M w/Mount Pipe	175	(2) RRUS 11 RRU	155
(2) Empty Pipe Mount	175	Raycap DC6-48-60-18-8F Surge Suppressor	155
(2) Empty Pipe Mount	175	(3) Cobra Mounts	155
(2) Empty Pipe Mount	175	(2) 7770.00 W/Mount Pipe	155
(3) Cobra Mounts	175	(2) 7770.00 W/Mount Pipe	155
(2) DB980H90E-M w/Mount Pipe	175	(2) 7770.00 W/Mount Pipe	155
(2) DB980H90E-M w/Mount Pipe	175	(2) 7770.00 W/Mount Pipe	155
7' Branches	174.5	P85-16-XLH-RR w/Mount Pipe	165
8' Branches	169.5	P85-16-XLH-RR w/Mount Pipe	155
(2) LPA-185090/6CF w/Mount Pipe	165	P85-16-XLH-RR w/Mount Pipe	155
(2) LPA-185090/6CF w/Mount Pipe	165	9' Branches	154.5
(3) Cobra Mounts	165	10' Branches	149.5
(2) LPA-80090/4CF w/Mount Pipe	165	11' Branches	144.5

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-85	65 ksi	80 ksi			

TOWER DESIGN NOTES

1. Tower is located in Fairfield County, Connecticut.
2. Tower designed for a 85 mph basic wind in accordance with the TIA/EIA-222-F Standard.
3. Tower is also designed for a 38 mph basic wind with 0.75 in ice. Ice is considered to increase in thickness with height.
4. Deflections are based upon a 50 mph wind.
5. TOWER RATING: 97.4%



FDH Engineering, Inc.
 2730 Rowland Road
 Raleigh, North Carolina
 Phone: (919) 755-1012
 FAX: (919) 755-1031

Job: **NORTH EASTON, CT - CT00707-S**
 Project: 11-05207E S1
 Client: SBA Network Services, Inc. Drawn by: Brandon Compton App'd:
 Code: TIA/EIA-222-F Date: 06/02/11 Scale: NTS
 Path: Tower Analysis Dwg No. E-1

P65-16-XLH-RR Dual Broadband Antennas


POLARIZATION: Dual linear $\pm 45^\circ$
 FREQUENCY (MHz): 698-894, 1710-2170
 HORIZONTAL BEAM WIDTH ($^\circ$): 65, 65
 GAIN (dBi/dBd): 15.5/13.4 17.5/15.4
 TILT: 1-12, 0-8
 LENGTH: 72"

ELECTRICAL SPECIFICATIONS*

	698-894		1710-2170		
	698-806	806-894	1710-1880	1850-1990	1900-2170
Frequency range (MHz)					
Frequency band (MHz)	698-806	806-894	1710-1880	1850-1990	1900-2170
Gain (dBi/dBd)	14.8/12.7	15.5/13.4	16.9/14.8	17.2/15.1	17.5/15.4
Polarization	Dual Linear +/- 45		Dual Linear +/- 45		
Nominal Impedance (Ω)	50		50		
VSWR	< 1.5:1		< 1.5:1		
Horizontal beam width, -3 dB ($^\circ$)	66	65	60	63	63
Vertical beam width, -3 dB ($^\circ$)	14.7	12.5	6.8	6.4	5.7
Electrical down tilt ($^\circ$)	1 to 12		0 to 8		
Side lobe suppression, vertical 1st upper (dB)	> 16	> 16	> 16		
	> 16	> 16			
Isolation between inputs (dB)	> 30	> 30	> 30	> 30	
Inter band Isolation (dB)	> 40		> 40		
Tracking, horizontal plane $\pm 60^\circ$ (dB)	< 2		< 2	< 2	< 2
First null fill (dB)			> 20	> 20	> 20
Vertical beam squint ($^\circ$)	< 0.8	< 0.8	< 0.5	< 0.5	< 0.5
Front to back ratio (dB) $180^\circ \pm 30^\circ$ copolar	> 24	> 24	> 30	> 30	> 28
Front to back ratio (dB) $180^\circ \pm 30^\circ$ total power					
Cross polar discrimination (XPD) 0° (dB)	> 15	> 15	> 15	> 15	> 15
Cross polar discrimination (XPD) $\pm 60^\circ$ (dB)	> 10	> 10	> 10	> 10	> 10
Far field coupling					
IM3, 2xTx@43dBm (dBc)	< -153		< -153		
IM7, 2xTx@43dBm (dBc)					
Power handling, average per input (W)	500		250		
Power handling, average total (W)	1000		500		

MECHANICAL SPECIFICATIONS*

Connector	4 X 7/16 DIN Female, IP67
Connector position	Bottom
Dimensions, HxWxD, mm (ft)	72" x 12" x 6" (1829 x 305 x 152)
Mounting	Pre-mounted Tilt Brackets
Weight, with brackets, kg (lbs)	29 (64)
Weight, without brackets, kg (lbs)	24 (53)
Wind load, frontal/lateral/rear side 42 m/s Cd=1.6 (N)	1380
Maximum operational wind speed, m/s (mph)	100 (45)
Survival wind speed, m/s (mph)	150 (67)
Lightning protection	DC Ground
Operating Temperature	-40C to +60C
Radome material	PVC, IP55
Packet size, HxWxD, mm (ft)	87" x 16" x 10" (2225 x 400 x 225)
Radome colour	Light Grey
Shipping weight, kg (lbs)	34 (75)
RET	IRET AISGv1.1, MET and AISGv2.0
Brackets	7256.00, 7454.00A



*All specifications subject to change without notice. Please contact your Powerwave representative for complete performance data.

ANTENNA PATTERNS*

For detailed patterns visit <http://www.powerwave.com/rpa/>.

RRUS 11 – Dual PA RRU.

Technical Data

- > Multi standard
- > RF: 2x30 Watts
- > Carrier BW: 1.4 – 20 MHz
- > Alarms: 2
- > Dimensions (with sunshield):
 - Width: 17.0 in
 - Height: 17.8 in
 - Depth: 7.2 in
 - Weight: 55 lbs (Band 12)
 - Weight: 50 lbs (Band 4)
- > Temperature: –40 to +131 F
- > Cooling: Self convection
- > Power: –48 VDC
- > Rec. fuse size 20 Amp
 - Rec. DC cable:
 - > 6 mm² up to 60 meters
 - > 10 mm² over 60 meters
 - > Shielded
- > Power Cons: 200 Watts typ.




RBS6000



RRUS-11 I/F



RBS6000



Co-site & x-connect ports: SMA

SFP port with LC connector

Ethernet Maintenance port

Protected ground M8 stud

RF feeder 7/16

RET & external alarm ALD connector

-48 V DC Power using 2*6 or 2*10 screw plint

POWER




DC6-48-60-18-8F

DC Surge Suppression Solution

The DC6-48-60-18 is a dual chambered, DC surge suppression system for use in multi-circuit, Distributed Antenna Systems. The system will protect up to 6 Remote Radio Heads from voltage surges and lightning, and connect up to 18 fiber pairs. The system is enclosed in a NEMA 4 rated, waterproof enclosure.

FEATURES

- Protects up to 6 Remote Radio Heads, each with its own protection circuit.
- Flexible design allows for installation at the top of a tower for Remote Radio Head protection.
- Includes fiber connections for up to 18 pairs of fiber.
- LED indicators on individual circuits provide visual indication of suppressor status.
- Form 'C' relays allow for remote monitoring of the suppressor status.
- Patented Strikesorb technology provides over 60 kA of surge current capacity per circuit.
- Strikesorb suppression modules are fully recognized to UL 1449-3rd Edition Safety Standard, meeting all intermediate and high current fault requirements to facilitate use in OEM applications.
- Raycap recommends that DC protection system be installed within 2 meters or 6 feet of the radio.
- Dome design is lightweight and aerodynamic providing maximum flexibility for installation on top of towers.



DC6-48-60-18-8F

DC Power Surge Protection

Electrical Specifications	
Model Number	DC6-48-60-18-8F
Nominal Operating Voltage	48 VDC
Nominal Discharge Current (I_n)	20 kA 8/20 μ s
Maximum Discharge Current (I_{max}) per NEMA LS-1	60 kA 8/20 μ s
Maximum Continuous Operating Voltage (U_c)	75 VDC
Voltage Protection Rating	400 V

Mechanical Specifications	
Suppression Connection Method	Compression lug, #2-#14 AWG Copper, #2-#12 Aluminum
Fiber Connection Method	LC-LC Single mode duplex
Environmental Rating	IP 68, 7m 72hrs
Operating Temperature	-40° C to + 80° C
Storage Temperature	-70° C to + 80° C
Cold Temperature Cycling	IEC 61300-2-22e -30° C to + 60° C 200 hrs @ 5 psi
Resistance to Aggressive Materials	CEI IEC 61073-2 including acids and bases
UV Protection	ISO 4892-2 Method A Xenon-Arc 2160 hrs
Weight	20 lbs without Mounting Bracket

STANDARDS

Strikesorb modules are compliant to the following Surge Protection Device (SPD) Standards:

- ANSI/UL 1449 - 3rd Edition
- IEEE C62.41
- NEMA LS-1, IEC 61643-1:2005 2nd Edition:2005
- IEC 61643-12
- EN 61643-11:2002 (including A11:2007)



Raycap

G02-00-068 REV 050610



GS-07F-0435V



Certified to
ISO 9001:2000



TUV Rheinland
of North America

Raycap, Inc. 806 W. Clearwater Loop • Post Falls • Idaho • 83854 • USA
Phone 208.777.1166 • Toll Free 800.890.2569 • Fax 208.777.4466 • www.raycapsurgeprotection.com



cingular
raising the bar™

New Cingular Wireless PCS, LLC
500 Enterprise Drive
Rocky Hill, Connecticut 06067-3900
Phone: (860) 463-5511
Fax: (860) 513-7190

Douglas L. Culp
Real Estate Consultant

June 14, 2011

Honorable Thomas A. Herrmann
1st Selectman, Town of Easton
Easton Town Hall
225 Center Road
Easton, CT 06612

Re: Telecommunications Facility – 275 North Street Easton, CT

Dear Selectman Herrmann:

In order to accommodate technological changes, implement Uniform Mobile Telecommunications System (“UMTS”) and Long Term Evolution (“LTE”) capabilities, and enhance system performance in the State of Connecticut, New Cingular Wireless PCS, LLC (“AT&T”) will be changing its equipment configuration at certain cell sites.

As required by Regulations of Connecticut State Agencies (“R.C.S.A.”) Section 16-50j-73, the Connecticut Siting Council has been notified of the changes and will review AT&T’s proposal. Please accept this letter as notification under Section 16-50j-73 of construction which constitutes an exempt modification pursuant to R.C.S.A. Section 16-50j-72(b)(2).

The accompanying letter to the Siting Council fully describes Cingular’s proposal for the referenced cell site. However, if you have any questions or require any further information on our plans or the Siting Council’s procedures; please call me at (860) 463-5511 or Ms. Linda Roberts, Executive Director, Connecticut Siting Council at (860) 827-2935.

Sincerely,

Douglas L. Culp
Real Estate Consultant

Enclosure