

Northeast Site Solutions Victoria Masse 420 Main St Unit 1 Box 2 Sturbridge, MA 01566 victoria@northeastsitesolutions.com

July 13, 2023

Members of the Siting Council Connecticut Siting Council Ten Franklin Square New Britain, CT 06051

RE: Tower Share Application 280 Morehouse Drive, Fairfield, CT 06824 Latitude: 41.20998700 N Longitude: -73.26153900 W Site#: CT11317B L600

Dear Ms. Bachman:

T-Mobile currently maintains six (6) antennas at the 95-foot level of the existing 86-foot transmission pole (#876) located at 280 Morehouse Drive, Fairfield CT. The electric transmission pole (#876) is owned by CL&P d/b/a Eversource. The property which holds the utility easement is owned by Zhang Chijian & Hu Yuzhi. T-Mobile now intends to replace three (3) existing antennas with three (3) new 600/700MHz antenna and relocate all existing equipment to the new tower per Petition No. 1549. The new antennas would be installed at the 121-foot level of the new 125-foot transmission pole. This modification includes B2, B5 hardware that is both 4G (LTE), and 5G capable.

T-Mobile Planned Modifications: Remove: N/A

Remove and Replace: (3) Andrew-LNX-6515DS-A1M Antenna (Remove) - (3) RFS APXVAALL24 600/700/1900 MHz Antenna (Replace)

Install New: (6) Smart Bias-T (6) Coax

Existing to Remain: (3) RFS APX16DWV-16DWVS-E-A20 2100 MHz Antenna (Relocate) (18) Coax (Relocate)

Ground Work: (3) RRUS11 B12 Radio (Remove) - (3) Radio 4480 B71+B85 (Replace) This facility was approved by the CT Siting Council Petition No. 1549, dated February 16, 2023. Please see attached.

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies §16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to First Selectwoman, Brenda L. Kupchick and Jim Wendt, Planning Director for the Town of Fairfield, as well as the property owner and the tower owner.

1. The proposed modifications will not result in an increase in the height of the existing structure.

2. The proposed modifications will not require the extension of the site boundary.

3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.

4. The operation of the replacement antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard.

5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.

6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, T-Mobile respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,

Victoria Masse Mobile: 860-306-2326 Fax: 413-521-0558 Office: 420 Main Street, Unit 2, Sturbridge MA 01566 Email: victoria@northeastsitesolutions.com Attachments cc:

The Honorable Brenda Kupchick- First Selectwomen Sullivan Independence Hall, Second Floor 725 Old Post Road Fairfield, CT 06824

Jim Wendt- Planning Director Sullivan Independence Hall 725 Old Post Road Fairfield, CT 06824

CL&P d/b/a Eversource - as tower owner 56 Prospect St., First Floor Hartford, CT 06103

Zhang Chijian & Hu Yuzhi- Utility Easement 280 Morehouse Drive Fairfield, CT 06824

# Exhibit A

**Original Facility Approval** 

# Exhibit B

**Property Card** 



# **280 MOREHOUSE DRIVE**

Location	280 MOREHOUSE DRIVE	Mblu	51/ 51/ / /
Acct#	17416	Owner	ZHANG CHIJIAN & HU YUZHI (SV)
Assessment	\$362,950	Appraisal	\$518,500
PID	5101	<b>Building Count</b>	1

### **Current Value**

Appraisal					
Valuation Year	Improvements	Land	Total		
2017	\$232,900	\$285,600	\$518,500		
Assessment					
Valuation Year	Improvements	Land	Total		
2017	\$163,030	\$199,920	\$362,950		

### **Owner of Record**

Owner	ZHANG CHIJIAN & HU YUZHI (SV)	Sale Price	\$300,000
Co-Owner		Certificate	
Address	280 MOREHOUSE DRIVE	Book & Page	2095/ 192
	FAIRFIELD, CT 06824-2374	Sale Date	03/06/2000
		Instrument	07

# **Ownership History**

Ownership History						
Owner Sale Price Certificate Book & Page Instrument Sale Date						
ZHANG CHIJIAN & HU YUZHI (SV)	\$300,000		2095/ 192	07	03/06/2000	
FLEET BANK,N.A.	\$0		2060/ 112		11/10/1999	
STONE WILLIAM & SANDRA	\$0		620/ 360		08/06/1976	

# **Building Information**

# Building 1 : Section 1

Year Built:	1976
Living Area:	2,172
Replacement Cost:	\$362,258
Building Percent	63
Good:	

### Replacement Cost Less Depreciation:

**n:** \$228,200

Building Attributes			
Field Description			
Style	Colonial		
Stories:	2 Stories		
Occupancy	1		
Exterior Wall 1	Vinyl Siding		
Exterior Wall 2			
Roof Structure:	Gable/Hip		
Roof Cover	Asphalt		
Interior Wall 1	Drywall		
Interior Wall 2			
Interior Flr 1	Linoleum		
Interior Flr 2	Hardwood		
Heat Fuel	Gas		
Heat Type:	Hot Water		
АС Туре:	Central		
Total Bedrooms:	4 Bedrooms		
Total Bthrms:	2		
Total Half Baths:	1		
Total Xtra Fixtrs:			
Total Rooms:	9 Rooms		
Bath Style:	Average		
Kitchen Style:	Average		
FCPZ			

# **Building Photo**



(http://images.vgsi.com/photos2/FairfieldCTPhotos//\02\03\80/6

# **Building Layout**



(http://images.vgsi.com/photos2/FairfieldCTPhotos//Sketches/51

Building Sub-Areas (sq ft)			
Code	Description	Gross Area	Living Area
BAS	First Floor	1,250	1,250
FUS	Upper Story, Finished	922	922
FEP	Porch, Enclosed, Finished	250	0
FRB	Finished Raised Bsmt	384	0
UBM	Basement, Unfinished	534	0
UGR	Garage, Under	528	0
WDK	Deck, Wood	323	0
		4,191	2,172

### **Extra Features**

•

Extra Features					
Code         Description         Size         Value         Bldg #					
FPL3	2.0 STORY FIREPLACE	1 UNITS	\$4,700	1	

### Land

### Land Use

Use Code	1010
Description	Single Fam MDL-01
Zone	R3
Neighborhood	0085
Alt Land Appr	No
Category	

# Land Line Valuation

Size (Acres)	0.79
Depth	0
Assessed Value	\$199,920
Appraised Value	\$285,600

# Outbuildings

Outbuildings	<u>Legend</u>
No Data for Outbuildings	

# Valuation History

Appraisal				
Valuation Year	Improvements	Land	Total	
2018	\$232,900	\$285,600	\$518,500	
2017	\$232,900	\$285,600	\$518,500	
2016	\$232,900	\$285,600	\$518,500	

	Assessment		
Valuation Year	Improvements	Land	Total
2018	\$163,030	\$199,920	\$362,950
2017	\$163,030	\$199,920	\$362,950
2016	\$163,030	\$199,920	\$362,950

(c) 2019 Vision Government Solutions, Inc. All rights reserved.

# Exhibit C

**Construction Drawings** 

# SITE NAME: FAIRFIELD/MP/X44&X42 SITE ID: CT11317B NEW EVERSOURCE STRUCT. #19725 280 MOREHOUSE DR **PROJECT SUMMARY** TELECOMMUNICATIONS FACILITY INCLUDING THE FOLLOWING: FAIRFIELD, CT 06824 REMOVAL OF EXISTING UTILITY TOWER AND INSTALLATION OF NEW TOWER TO BE DONE (BY OTHERS) OF (3)

# T-MOBILE A+L TEMPLATE (PROVIDED BY RFDS)

# 67D94B\_1DP+1QP+1OP

T-MOBILE RAN TEMPLATE (PROVIDED BY RFDS)

# 67D94B\_FLAGPOLE OUTDOOR

# **GENERAL NOTES**

- ALL WORK SHALL BE IN ACCORDANCE WITH THE 2021 INTERNATIONAL BUILDING CODE AS MODIFIED BY THE 2022 CONNECTICUT SUPPLEMENT, INCLUDING THE TIA/EIA-222 REVISION "G" "STRUCTURAL STANDARDS FOR STEEL ANTENNA TOWERS AND SUPPORTING STRUCTURES." 2022 CONNECTICUT FIRE SAFETY CODE, NATIONA ELECTRICAL CODE AND LOCAL CODES.
- SHOULD ANY FIELD CONDITIONS PRECLUDE COMPLIANCE WITH DRAWINGS, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE ENGINEER AND SHALL NOT PROCEED WITH ANY AFFECTED WORK
- CONTRACTOR SHALL REVIEW ALL DRAWINGS AND SPECIFICATIONS IN THE CONTRACT DOCUMENT SET. CONTRACTOR SHALL COORDINATE ALL WORK SHOWN IN THE SET OF DRAWINGS. THE CONTRACTOR SHAL PROVIDE A COMPLETE SET OF DRAWINGS TO ALL SUBCONTRACTORS AND ALL RELATED PARTIES. THE SUBCONTRACTORS SHALL EXAMINE ALL THE DRAWINGS AND SPECIFICATIONS FOR THE INFORMATION THAT AFFECTS THEIR WORK.
- BEFORE BEGINNING THE WORK, THE CONTRACTOR IS RESPONSIBLE FOR MAKING SUCH INVESTIGATIONS CONCERNING PHYSICAL CONDITIONS (SURFACE AND SUBSURFACE) AT OR CONTIGUOUS TO THE SITE, WHICH MAY AFFECT PERFORMANCE AND COST OF THE WORK.
- ALL DIMENSIONS. ELEVATIONS. AND OTHER REFERENCES TO EXISTING STRUCTURES. SURFACE. AND SUBSURFACE CONDITIONS ARE APPROXIMATE. NO GUARANTEE IS MADE FOR THE ACCURACY OR COMPLETENESS OF THE INFORMATION SHOWN. THE CONTRACTOR SHALL VERIFY AND COORDINATE ALL DIMENSIONS, ELEVATIONS AND ANGLES WITH EXISTING CONDITIONS AND WITH ARCHITECTURAL AND SITE DRAWINGS BEFORE PROCEEDING WITH ANY WORK.
- AS THE WORK PROGRESSES, THE CONTRACTOR SHALL NOTIFY THE OWNER OF ANY CONDITIONS WHICH ARE IN CONFLICT OR OTHERWISE NOT CONSISTENT WITH THE CONSTRUCTION DOCUMENTS, AND SHALL NOT PROCEED WITH SUCH WORK UNTIL THE CONFLICT IS SATISFACTORILY RESOLVED.
- CONTRACTOR SHALL PROVIDE A COMPLETE BUILD-OUT WITH ALL FINISHES, STRUCTURAL, MECHANICAL, AND ELECTRICAL COMPONENTS AND PROVIDE ALL ITEMS AS SHOWN OR INDICATED ON THE DRAWINGS OR IN THE WRITTEN SPECIFICATIONS.
- CONTRACTOR SHALL FURNISH ALL MATERIAL, LABOR AND EQUIPMENT TO COMPLETE THE WORK AND FURNISH A COMPLETED JOB ALL IN ACCORDANCE WITH LOCAL AND STATE GOVERNING AUTHORITIES AND OTHER AUTHORITIES HAVING LAWFUL JURISDICTION OVER THE WORK.
- CONTRACTOR SHALL SECURE AND PAY FOR ALL PERMITS AND ALL INSPECTIONS REQUIRED AND SHALL ALSO PAY FEES REQUIRED FOR THE GENERAL CONSTRUCTION, PLUMBING, ELECTRICAL, AND HVAC. PERMITS SHALL BE PAID FOR BY THE RESPECTIVE SUBCONTRACTORS.
- 10. CONTRACTOR SHALL MAINTAIN A CURRENT SET OF DRAWINGS AND SPECIFICATIONS ON SITE AT ALL TIMES AND INSURE DISTRIBUTION OF NEW DRAWINGS TO SUBCONTRACTORS AND OTHER RELEVANT PARTIES AS SOON AS THEY ARE MADE AVAILABLE. ALL OLD DRAWINGS SHALL BE MARKED VOID AND REMOVED FROM THE CONTRACT AREA. THE CONTRACTOR SHALL FURNISH AN 'AS-BUILT' SET OF DRAWINGS TO OWNER UPON COMPLETION OF PROJECT.
- 11. LOCATION OF EQUIPMENT AND WORK SUPPLIED BY OTHERS THAT IS DIAGRAMMATICALLY INDICATED ON THE DRAWINGS. SHALL BE DETERMINED BY THE CONTRACTOR. THE CONTRACTOR SHALL DETERMINE LOCATIONS AND DIMENSIONS SUBJECT TO STRUCTURAL CONDITIONS AND WORK OF THE SUBCONTRACTORS.
- 12. THE CONTRACTOR IS SOLELY RESPONSIBLE TO DETERMINE CONSTRUCTION PROCEDURE AND SEQUENCE AND TO ENSURE THE SAFETY OF THE EXISTING STRUCTURES AND ITS COMPONENT PARTS DURING CONSTRUCTION. THIS INCLUDES THE ADDITION OF WHATEVER SHORING, BRACING, UNDERPINNING, ETC. THAT MAY BE NECESSARY.
- 13. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUB-CONTRACTORS FOR ANY CONDITION PER THE MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.

- SHOULD BE INDICATED TO BE SUBSTANDARD TO ANY ORDINANCES, CODES. RULES. OR REGULATIONS BEARING ON THE WORK. CONTRACTOR SHALL INCLUDE IN HIS WORK AND SHALL EXECUTE TH WORK CORRECTLY IN ACCORDANCE WITH SUCH ORDINANCES. LAWS. CODES. RULES OR REGULATIONS WITH NO INCREASE IN COSTS
- 15. ALL UTILITY WORK SHALL BE IN ACCORDANCE WITH LOCAL UTILITY COMPANY REQUIREMENTS AND SPECIFICATIONS
- 16. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED CONTRACTOR AND ALL APPLICABLE SUBCONTRACTORS FOR ANY CONDITION PER MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.
- 17. ANY AND ALL ERRORS, DISCREPANCIES, AND 'MISSED' ITEMS ARE TO BE BROUGHT TO THE ATTENTION OF THE T-MOBILE CONSTRUCTION MANAGER DURING THE BIDDING PROCESS BY THE CONTRACTOR. ALL THESE ITEMS ARE TO BE INCLUDED IN THE BID. NO 'EXTRA' WILL BE ALLOWED FOR MISSED ITEMS.
- 18. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ON-SITE SAFETY FROM THE TIME THE JOB IS AWARDED UNTIL ALL WORK IS COMPLETE AND ACCEPTED BY THE OWNER.
- 19. CONTRACTOR TO REVIEW ALL SHOP DRAWINGS AND SUBMIT COPY TO ENGINEER FOR APPROVAL. DRAWINGS MUST BEAR THE CHECKER'S INITIALS BEFORE SUBMITTING TO THE CONSTRUCTION MANAGER FOR **REVIEW.**
- 20. THE CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS, ELEVATIONS, ANGLES AND EXISTING CONDITIONS AT THE SITE, PRIOR TO FABRICATION AND/OR INSTALLATION OF ANY WORK IN THE CONTRACT AREA.
- 21. COORDINATION, LAYOUT, FURNISHING AND INSTALLATION OF CONDUITS AND ALL APPURTENANCES REQUIRED FOR PROPER INSTALLATION OF ELECTRICAL AND TELECOMMUNICATION SERVICE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR AND CONFIRMED WITH THE PROJECT MANAGER AND OWNER PRIOR TO THE COMMENCEMENT OF ANY WORK
- 22. ALL DAMAGE CAUSED TO ANY EXISTING STRUCTURE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR WILL BE HELD LIABLE FOR ALL REPAIRS REQUIRED FOR EXISTING STRUCTURES IF DAMAGED DURING CONSTRUCTION ACTIVITIES.
- 23. THE CONTRACTOR SHALL CONTACT 'CALL BEFORE YOU DIG' AT LEAST 48 HOURS PRIOR TO ANY EXCAVATIONS AT 1-800-922-4455. ALL UTILITIES SHALL BE IDENTIFIED AND CLEARLY MARKED. CONTRACTOR SHALL MAINTAIN AND PROTECT MARKED UTILITIES THROUGHOUT PROJECT COMPLETION.
- 24. CONTRACTOR SHALL COMPLY WITH THE OWNER'S ENVIRONMENTAL ENGINEER ON ALL METHODS AND PROVISIONS FOR ALL EXCAVATION ACTIVITIES INCLUDING SOIL DISPOSAL. ALL BACKFILL MATERIALS TO BE PROVIDED BY THE CONTRACTOR.
- 25. THE COUNTY/CITY/TOWN MAY MAKE PERIODIC FIELD INSPECTIONS TO ENSURE COMPLIANCE WITH THE DESIGN PLANS, SPECIFICATIONS, AND CONTRACT DOCUMENTS.
- 26. THE COUNTY/CITY/TOWN MUST BE NOTIFIED (2) WORKING DAYS PRIOR TO CONCEALMENT/BURIAL OF ANY SYSTEM OR MATERIAL THAT WILL PREVENT THE DIRECT INSPECTION OF MATERIALS, METHODS OR WORKMANSHIP. EXAMPLES OF THESE PROCESSES ARE BACKFILLING A GROUND RING OR TOWER FOUNDATION, POURING TOWER FOUNDATIONS, BURYING GROUND RODS, PLATES OR GRIDS, ETC. THE CONTRACTOR MAY PROCEED WITH THE SCHEDULED PROCESS (2) WORKING DAYS AFTER PROVIDING NOTICE UNLESS NOTIFIED OTHERWISE BY THE COUNTY/CITY/TOWN.
- 27. PRIOR TO THE SUBMISSION OF BIDS, THE CONTRACTOR SHALL VISIT THE SITE TO FAMILIARIZE WITH THE EXISTING CONDITIONS AND TO CONFIRM THAT THE WORK CAN BE ACCOMPLISHED AS SHOWN ON THE CONSTRUCTION DRAWINGS. ANY DISCREPANCY FOUND SHALL BE BROUGHT TO THE ATTENTION OF ENGINEER ON RECORD, PRIOR TO THE COMMENCEMENT OF ANY WORK.







THE PROPOSED SCOPE OF WORK CONSISTS OF A MODIFICATION TO THE EXISTING UNMANNED

- REMOVE EXISTING ANDREW: LNX-6515DS-A1M ANTENNAS, TYP. (1) PER SECTOR; TOTAL
- 3. REMOVE EXISTING TMAs
- 4. RELOCATE EXISTING T-MOBILE RFS: APX16DWV-16DWV-S-E-A20 ANTENNAS TO NEW ANTENNA FRAME, TYP (1) PER SECTOR; TOTAL OF (3)
- 5. INSTALL RADIO 4480 AT GRADE, TYP. (1) PER SECTOR; TOTAL OF (3)
- 6. INSTALL (1) BB6648 FOR L600/L700/5G N600
- 7. INSTALL (6) 1-1/4" COAX CABLES PER SECTOR FOR NEW TOTAL OF (24)
- 8. INSTALL RFS: APXVAALL24\_43-U-NA20 ANTENNA, TYP. (1) PER SECTOR; TOTAL OF (3)
- 9. INSTALL SMART BIAS-T: ATSBT-TOP-MF-4G TMA, TYP. (2) PER SECTOR; TOTAL OF (6)
- 10. INSTALL NEW ANTENNA MOUNT PLATFORM SITE PRO: RMQLP-496-HK
- 11. INSTALL NEW ANTENNA ICE-BRIDGE AS SHOWN HEREIN.

	PROJECT INFORMATION
SITE NAME:	FAIRFIELD/MP/X44&X42
SITE ID:	CT11317B
SITE ADDRESS:	280 MOREHOUSE DR FAIRFIELD, CT 06824
APPLICANT:	T-MOBILE NORTHEAST, LLC 35 GRIFFIN ROAD SOUTH BLOOMFIELD, CT. 06002
CONTACT PERSON:	MATT BANDLE (PROJECT MANAGER) NORTHEAST SITE SOLUTIONS (508) 642–8801
ENGINEER OF RECORD:	CENTEK ENGINEERING, INC. 63–2 NORTH BRANFORD ROAD BRANFORD, CT. 06405
	CARLO F. CENTORE, PE (203) 488–0580 EXT. 122
SITE COORDINATES:	LATITUDE: 41°–12'–35" N LONGITUDE: 73°–15'–41" W GROUND ELEVATION: ±223' AMSL
	SITE COORDINATES AND GROUND ELEVATION REFERENCED FROM GOOGLE EARTH.

	SHEET INDEX	
SHEET. NO.	DESCRIPTION	REV.
T-1	TITLE SHEET	1
N-1	SPECIFICATIONS, NOTES, AND ANT. SCHEDULE	1
C-1	COMPOUND AND EQUIPMENT PLANS	1
C-2	ANTENNA PLANS AND ELEVATIONS	1
C-3	TYPICAL EQUIPMENT DETAILS	1
E-1	ELECTRICAL COMPOUND PLAN	1
E-2	ELECTRICAL SCHEMATIC DIAGRAM	1
E-3	ELECTRICAL GROUNDING PLANS	1
E-4	TYPICAL ELECTRICAL DETAILS	1
E-5	TYPICAL ELECTRICAL DETAILS	1
E-6	TYPICAL ELECTRICAL DETAILS	1
E-7	ELECTRICAL SPECIFICATIONS	1



# **NOTES AND SPECIFICATIONS:**

# DESIGN BASIS:

GOVERNING CODE: 2021 INTERNATIONAL BUILDING (IBC) AS MODIFIED BY THE 2022 CONNECTICUT STATE BUILDING CODE.

- 1. DESIGN CRITERIA:
- ٠ NOMINAL DESIGN SPEED: 97 MPH (Vult) •

# SITE NOTES

- CONSTRUCTION.
- DOCUMENTS.
- RETURNED TO THEIR ORIGINAL CONDITION.
- RESOLVED.

				A	NTEN	NA/APPURTENANCE SCHEDULE	
SECTOR	EXISTING/PROPOSED	ANTENNA – AT TOWER	SIZE (INCHES) (L × W × D)	ANTENNA & HEIGHT	AZIMUTH	(E/P) RRU (QTY) – AT CABINET	(E/P) TMA (QTY) – AT TOWER
A1	EXISTING	RFS (APX16DWV-16DWV-S-E-A20)	55.9 x 13 x 3.15	121'	60*		(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)
A2	PROPOSED	RFS (APXVAALL24_43-U_NA20)	95.9 x 24 x 8.5	121'	60 <b>°</b>	(r) (ADIO 4400 B) (T)	(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)
B1	EXISTING	RFS (APX16DWV-16DWV-S-E-A20)	55.9 x 13 x 3.15	121'	180°	(P) RADIO 4480 B71+B85 (1)	(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)
B2	PROPOSED	RFS (APXVAALL24_43-U_NA20)	95.9 x 24 x 8.5	121'	180°		(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)
	•						
C1	EXISTING	RFS (APX16DWV-16DWV-S-E-A20)	55.9 x 13 x 3.15	121'	300*	(P) RADIO 4480 B71+B85 (1)	(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)
C2	PROPOSED	RFS (APXVAALL24_43-U_NA20)	95.9 x 24 x 8.5	121'	300*		(P) (SMART BIAST-ATSBT-TOP-MF-4G) (1)

RISK CATEGORY II (BASED ON IBC TABLE 1604.5)

(EXPOSURE B/ IMPORTANCE FACTOR 1.0 BASED ON ASCE 7-10).

1. THE CONTRACTOR SHALL CALL UTILITIES PRIOR TO THE START OF

2. ACTIVE EXISTING UTILITIES, WHERE ENCOUNTERED IN THE WORK, SHALL BE PROTECTED AT ALL TIMES. THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY, PRIOR TO PROCEEDING, SHOULD ANY UNCOVERED EXISTING UTILITY PRECLUDE COMPLETION OF THE WORK IN ACCORDANCE WITH THE CONTRACT

3. THE AREAS OF THE COMPOUND DISTURBED BY THE WORK SHALL BE

4. CONTRACTOR SHALL MINIMIZE DISTURBANCE TO EXISTING SITE DURING CONSTRUCTION. EROSION CONTROL MEASURES, SHALL BE IN CONFORMANCE WITH THE LOCAL GUIDELINES FOR EROSION AND SEDIMENT CONTROL.

5. IF ANY FIELD CONDITIONS EXIST WHICH PRECLUDE COMPLIANCE WITH THE DRAWINGS, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE ENGINEER AND SHALL PROCEED WITH AFFECTED WORK AFTER CONFLICT IS SATISFACTORILY

# **GENERAL NOTES**

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE 2021 INTERNATIONAL BUILDING CODE AS MODIFIED BY THE 2022 CONNECTICUT SUPPLEMENT, INCLUDING THE TIA/EIA-222 REVISION "G" "STRUCTURAL STANDARDS FOR STEEL ANTENNA TOWERS AND SUPPORTING STRUCTURES." 2022 CONNECTICUT FIRE SAFETY CODE, NATIONAL ELECTRICAL CODE AND LOCAL CODES.
- 2. SHOULD ANY FIELD CONDITIONS PRECLUDE COMPLIANCE WITH THE DRAWINGS, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE ENGINEER AND SHALL NOT PROCEED WITH ANY AFFECTED WORK.
- 3. CONTRACTOR SHALL REVIEW ALL DRAWINGS AND SPECIFICATIONS IN THE CONTRACT DOCUMENT SET. CONTRACTOR SHALL COORDINATE ALL WORK SHOWN IN THE SET OF DRAWINGS. THE CONTRACTOR SHALL PROVIDE A COMPLETE SET OF DRAWINGS TO ALL SUBCONTRACTORS AND ALL RELATED PARTIES. THE SUBCONTRACTORS SHALL EXAMINE ALL THE DRAWINGS AND SPECIFICATIONS FOR THE INFORMATION THAT AFFECTS THEIR WORK.
- 4. BEFORE BEGINNING THE WORK, THE CONTRACTOR IS RESPONSIBLE FOR MAKING SUCH INVESTIGATIONS CONCERNING PHYSICAL CONDITIONS (SURFACE AND SUBSURFACE) AT OR CONTIGUOUS TO THE SITE, WHICH MAY AFFECT PERFORMANCE AND COST OF THE WORK.
- 5. ALL DIMENSIONS, ELEVATIONS, AND OTHER REFERENCES TO EXISTING STRUCTURES. SURFACE. AND SUBSURFACE CONDITIONS ARE APPROXIMATE. NO GUARANTEE IS MADE FOR THE ACCURACY OR COMPLETENESS OF THE INFORMATION SHOWN. THE CONTRACTOR SHALL VERIFY AND COORDINATE ALL DIMENSIONS, ELEVATIONS AND ANGLES WITH EXISTING CONDITIONS AND WITH ARCHITECTURAL AND SITE DRAWINGS BEFORE PROCEEDING WITH ANY WORK.
- 6. AS THE WORK PROGRESSES, THE CONTRACTOR SHALL NOTIFY THE OWNER OF ANY CONDITIONS WHICH ARE IN CONFLICT OR OTHERWISE NOT CONSISTENT WITH THE CONSTRUCTION DOCUMENTS, AND SHALL NOT PROCEED WITH SUCH WORK UNTIL THE CONFLICT IS SATISFACTORILY RESOLVED.
- CONTRACTOR SHALL PROVIDE A COMPLETE BUILD-OUT WITH ALL FINISHES, STRUCTURAL, 7. MECHANICAL, AND ELECTRICAL COMPONENTS AND PROVIDE ALL ITEMS AS SHOWN OR INDICATED ON THE DRAWINGS OR IN THE WRITTEN SPECIFICATIONS.
- 8. CONTRACTOR SHALL FURNISH ALL MATERIAL, LABOR AND EQUIPMENT TO COMPLETE THE WORK AND FURNISH A COMPLETED JOB ALL IN ACCORDANCE WITH LOCAL AND STATE GOVERNING AUTHORITIES AND OTHER AUTHORITIES HAVING LAWFUL JURISDICTION OVER THE WORK.
- 9. CONTRACTOR SHALL SECURE AND PAY FOR ALL PERMITS AND ALL INSPECTIONS REQUIRED AND SHALL ALSO PAY FEES REQUIRED FOR THE GENERAL CONSTRUCTION, PLUMBING, ELECTRICAL, AND HVAC. PERMITS SHALL BE PAID FOR BY THE RESPECTIVE SUBCONTRACTORS.
- 10. CONTRACTOR SHALL MAINTAIN A CURRENT SET OF DRAWINGS AND SPECIFICATIONS ON SITE AT ALL TIMES AND INSURE DISTRIBUTION OF NEW DRAWINGS TO SUBCONTRACTORS AND OTHER RELEVANT PARTIES AS SOON AS THEY ARE MADE AVAILABLE. ALL OLD DRAWINGS SHALL BE MARKED VOID AND REMOVED FROM THE CONTRACT AREA. THE CONTRACTOR SHALL FURNISH AN 'AS-BUILT' SET OF DRAWINGS TO OWNER UPON COMPLETION OF PROJECT.
- 11. LOCATION OF EQUIPMENT AND WORK SUPPLIED BY OTHERS THAT IS DIAGRAMMATICALLY INDICATED ON THE DRAWINGS, SHALL BE DETERMINED BY THE CONTRACTOR. THE CONTRACTOR SHALL DETERMINE LOCATIONS AND DIMENSIONS SUBJECT TO STRUCTURAL CONDITIONS AND WORK OF THE SUBCONTRACTORS.
- 12. THE CONTRACTOR IS SOLELY RESPONSIBLE TO DETERMINE CONSTRUCTION PROCEDURE AND SEQUENCE AND TO ENSURE THE SAFETY OF THE EXISTING STRUCTURES AND ITS COMPONENT PARTS DURING CONSTRUCTION. THIS INCLUDES THE ADDITION OF WHATEVER SHORING, BRACING, UNDERPINNING, ETC. THAT MAY BE NECESSARY.
- 13. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUB-CONTRACTORS FOR ANY CONDITION PER THE MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.

# 

- 14. DRAWINGS INDICATE THE MINIMUM STANDARDS, BUT IF ANY WORK SHOULD BE INDICATED TO BE SUBSTANDARD TO ANY ORDINANCES, LAWS, CODES, RULES, OR REGULATIONS BEARING ON THE WORK, THE CONTRACTOR SHALL INCLUDE IN HIS WORK AND SHALL EXECUTE THE WORK CORRECTLY IN ACCORDANCE WITH SUCH ORDINANCES, LAWS, CODES, RULES OR REGULATIONS WITH NO INCREASE IN COSTS. 15. ALL UTILITY WORK SHALL BE IN ACCORDANCE WITH LOCAL UTILITY COMPANY REQUIREMENTS AND SPECIFICATIONS. 16. ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUBCONTRACTORS FOR ANY CONDITION PER MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.
- 17. ANY AND ALL ERRORS, DISCREPANCIES, AND 'MISSED' ITEMS ARE TO BE BROUGHT TO THE ATTENTION OF THE T-MOBILE CONSTRUCTION MANAGER DURING THE BIDDING PROCESS BY THE CONTRACTOR. ALL THESE ITEMS ARE TO BE INCLUDED IN THE BID. NO 'EXTRA' WILL BE ALLOWED FOR MISSED ITEMS.
- 18. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ON-SITE SAFETY FROM THE TIME THE JOB IS AWARDED UNTIL ALL WORK IS COMPLETE AND ACCEPTED BY THE OWNER.
- 19. CONTRACTOR TO REVIEW ALL SHOP DRAWINGS AND SUBMIT COPY TO ENGINEER FOR APPROVAL. DRAWINGS MUST BEAR THE CHECKER'S INITIALS BEFORE SUBMITTING TO THE CONSTRUCTION MANAGER FOR REVIEW.
- 20. THE CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS, ELEVATIONS, ANGLES AND EXISTING CONDITIONS AT THE SITE, PRIOR TO FABRICATION AND/OR INSTALLATION OF ANY WORK IN THE CONTRACT AREA.
- 21. COORDINATION, LAYOUT, FURNISHING AND INSTALLATION OF CONDUITS AND ALL APPURTENANCES REQUIRED FOR PROPER INSTALLATION OF ELECTRICAL AND TELECOMMUNICATION SERVICE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR AND CONFIRMED WITH THE PROJECT MANAGER AND OWNER PRIOR TO THE COMMENCEMENT OF ANY WORK
- 22. ALL DAMAGE CAUSED TO ANY EXISTING STRUCTURE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR WILL BE HELD LIABLE FOR ALL REPAIRS REQUIRED FOR EXISTING STRUCTURES IF DAMAGED DURING CONSTRUCTION ACTIVITIES.
- 23. THE CONTRACTOR SHALL CONTACT 'CALL BEFORE YOU DIG' AT LEAST 48 HOURS PRIOR TO ANY EXCAVATIONS AT 1-800-922-4455. ALL UTILITIES SHALL BE IDENTIFIED AND CLEARLY MARKED. CONTRACTOR SHALL MAINTAIN AND PROTECT MARKED UTILITIES THROUGHOUT PROJECT COMPLETION.
- 24. CONTRACTOR SHALL COMPLY WITH THE OWNER'S ENVIRONMENTAL ENGINEER ON ALL METHODS AND PROVISIONS FOR ALL EXCAVATION ACTIVITIES INCLUDING SOIL DISPOSAL. ALL BACKFILL MATERIALS TO BE PROVIDED BY THE CONTRACTOR.
- 25. THE COUNTY/CITY/TOWN MAY MAKE PERIODIC FIELD INSPECTIONS TO ENSURE COMPLIANCE WITH THE DESIGN PLANS, SPECIFICATIONS, AND CONTRACT DOCUMENTS.
- 26. THE COUNTY/CITY/TOWN MUST BE NOTIFIED (2) WORKING DAYS PRIOR TO CONCEALMENT/BURIAL OF ANY SYSTEM OR MATERIAL THAT WILL PREVENT THE DIRECT INSPECTION OF MATERIALS, METHODS OR WORKMANSHIP. EXAMPLES OF THESE PROCESSES ARE BACKFILLING A GROUND RING OR TOWER FOUNDATION, POURING TOWER FOUNDATIONS, BURYING GROUND RODS, PLATES OR GRIDS, ETC. THE CONTRACTOR MAY PROCEED WITH THE SCHEDULED PROCESS (2) WORKING DAYS AFTER PROVIDING NOTICE UNLESS NOTIFIED OTHERWISE BY THE COUNTY/CITY/TOWN.
- 27. PRIOR TO THE SUBMISSION OF BIDS, THE CONTRACTOR SHALL VISIT THE SITE TO FAMILIARIZE WITH THE EXISTING CONDITIONS AND TO CONFIRM THAT THE WORK CAN BE ACCOMPLISHED AS SHOWN ON THE CONSTRUCTION DRAWINGS. ANY DISCREPANCY FOUND SHALL BE BROUGHT TO THE ATTENTION OF ENGINEER ON RECORD, PRIOR TO THE COMMENCEMENT OF ANY WORK.

(QTY) PROPOSED HYBRID/COAX
(2) 1–1/4" COAX CABLES (TOWER)
(2) 1-1/4" COAX CABLES (TOWER)
(2) 1–1/4" COAX CABLES (TOWER)

NOTE: ALL HYBRID/COAX LENGTHS TO BE MEASURED AND VERIFIÉD IN FIELD BEFORE ORDERING

EAL EAL				1   06/21/23   asc   tjr  construction drawings – revised per client comments	0 06/05/23 ASC 7JR CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION	C 05/24/23 ASC TJR CONSTRUCTION DRAWINGS - REVISED PER CLIENT COMMENTS	P-04/14/23 ASC TJR CONSTRUCTION DRAWINGS - ISSUED FOR CLIENT REVIEW	A 07/28/22 JLD TJR CONSTRUCTION DRAWINGS - ISSUED FOR CLIENT REVIEW	REV. DATE DRAWN BY CHECKED BY DESCRIPTION
PROFESSIONAL ENGINEER S		A A A A A A A A A A A A A A A A A A A		031 488-8587 Fox	-2 North Branford Road	anford, CT 06405		SITE SOLUTIONS	
SC JC		». СІ СТС ·	IFI S	AS 22 C, C, C,			ED 3 DN ND U		,







PROPOSED T-MOBILE RADIO TOTAL OF (3) MODEL: ERICSSON: RADIO 4480 B71+B85







lon lon lon

ALPHA/BET/	A/GAMMA ANTENNA									
EQUIPMENT	EQUIPMENT DIMENSIONS WEIGHT									
MAKE: RFS MODEL: APXVAALL24_43-U-NA20 95.9"L x 24.0"W x 8.5"D ±150 LBS.										
NOTES: 1. CONTRACTOR TO COORDINATE FINAL EC CONSTRUCTION MANAGER PRIOR TO OF	QUIPMENT MODEL SELECTION RDERING.	WITH T-MOBILE								







SHEET NO. <u>5</u> OF <u>12</u>



SF	El	DA SC JO	U I LOVINI I NOVV-L			PROFESSIONAL ENGINEER SEAL						
IEE	_E D 10	ATE: AL										
T		E: NC		Centered on Solutions <sup>344</sup>		ANNUMBER OF STREET						
E NO.	TR \Gl )U	).	SITE NAME: FAIRFIEL D/MP/X44+X49			1 11 10 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0						
6	R/ R/			12031 488_0580		1 - Contractor						
• •		07 AS 22		(203) 400-0300 (203) 488-8587 Fax			1 06/21/23	ASC T.	JR CC	<b>DNSTRUCTION DRAWINGS</b> -	REVISED PER CLIENT COMMENTS	
C	رل ا R	/2 N		63-2 North Branford Road			0 06/05/23	ASC T.	JR CC	<b>DNSTRUCTION DRAWINGS</b> -	ISSUED FOR CONSTRUCTION	
1	F A DL	8/ OT 3.0		Branford, CT 06405	NON N	THE PERSON AND THE SAME	C 05/24/23	ASC T.	JR CC	<b>DNSTRUCTION DRAWINGS</b> -	REVISED PER CLIENT COMMENTS	
_1	RIS NI JT	22 ED				No. And Store	B-04/14/23	ASC T.	JR CC	<b>DNSTRUCTION DRAWINGS</b> -	ISSUED FOR CLIENT REVIEW	
2	SE D TIN			- - -		STONAL EN STONAL	A 07/28/22		JR CC	<b>DNSTRUCTION DRAWINGS</b> -	ISSUED FOR CLIENT REVIEW	
	R G			www.Centekeng.com	1 arrely Heriton Development	**************************************	REV. DATE	DRAWN BY CHECK	KED BY DE	SCRIPTION		

- NEW MONOPOLE TOWER STRUCTURE

- NEW ANTENNA ICE-BRIDGE



# GROUNDING SCHEMATIC NOTES #2/0 GREEN INSULATED 2 #6 AWG GENERAL NOTES: 1. ALL SURGE SUPPRESSION EQUIPMENT SHALL BE BONDED TO GROUND PER MANUFACTURER'S SPECIFICATIONS 2. UNLESS OTHERWISE NOTED OR REQUIRED BY CODE, GROUND CONDUCTORS SHOWN SHALL BE #2 AWG (SOLID TINNED BCW – EXTERIOR; STRANDED GREEN INSULATED - INTERIOR). 3. BOND CABLE TRAY AND ICE BRIDGE SECTIONS TOGETHER WITH #6 AWG STRANDED GREEN INSULATED JUMPERS. 4. ALL SECTOR GROUND BARS SHALL BE BONDED TOGETHER WITH #2 AWG SOLID TINNED BCW. 5. BOND ALL EQUIPMENT CABINETS AND BATTERY CABINETS TO GROUND PER MANUFACTURER'S SPECIFICATIONS. 6. ALL BONDS TO TOWER SHALL BE MADE IN STRICT ACCORDANCE WITH SPECIFICATIONS OF TOWER MANUFACTURER OR STRUCTURAL ENGINEER. 7. REFER TO GROUNDING PLAN FOR LOCATION OF GROUNDING DEVICES. 8. REFER TO ALL ELECTRICAL AND GROUNDING DETAILS. 9. COORDINATE ALL TOWER MOUNTED EQUIPMENT WITH OWNER. 10. ALL TOWER MOUNTED AMPLIFIERS AND ASSOCIATED EQUIPMENT SHALL BE BONDED TO THE SECTOR GROUND BAR PER MANUFACTURER'S SPECIFICATIONS.

11. ALL GROUNDING SHALL BE IN ACCORDANCE WITH NEC AND OWNER'S REQUIREMENTS.

D     D <thd< th="">     D     <thd< th=""> <thd< th="">     D     D     D</thd<></thd<></thd<>	BIE ID: CT137B SIE ID	MODILE
---	--	--------







E-3/

GR	OUNDING PLAN NOTES
(1)	LOWER TOWER MOUNTED GROUND BAR.
$\overline{(2)}$	UPPER TOWER MOUNTED GROUND BAR.
3	BOND UPPER TOWER MOUNTED GROUND BAR TO LOWER TOWER MOUNTED GROUND BAR (2) $\#$ 2/0 GROUND LEADS.
4	BOND UPPER TOWER MOUNTED GROUND BAR TO SECTOR GROUND BAR TYP.
5	BOND GROUND BAR TO ICE-BRIDGE TYP.
6	BOND GROUND RING TO EXISTING TOWER GROUND RING. VERIFY LOCATION OF EXISTING GROUND RING IN FIELD.
7	ICE BRIDGE POST AND COVER. BOND EACH SECTION AND SUPPORT TO GROUND RING.
8	BOND LOWER TOWER MOUNTED GROUND BAR TO GROUND RING TYP 2 PLACES.
(9)	GROUNDING ROD TYP.
10	BOND GROUND RING TO EXISTING COMPOUND GROUND RING. VERIFY LOCATION OF EXISTING GROUND RING IN FIELD.
(11)	SECTOR GROUND BAR TYP.
(12)	BOND ANTENNA MOUNTING PIPES TO SECTOR GROUND BAR. (TYPICAL)
(13)	BOND SECTOR GROUND BAR TO TOWER STEEL.
14	ALL SECTOR GROUND BARS SHALL BE BONDED TOGETHER WITH $#2$ AWG SOLID TINNED BCW.



sional engineer seal			OF OCTOBER OF	CF. CF. CF.	K XX 2 2 1 06/21/23 ASC TJR CONSTRUCTION DRAWINGS - REVISED PER CLIENT COMMENTS	- CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION	Construction drawings - revised per client comments	CONSTRUCTION DRAWINGS - ISSUED FOR CLIENT REVIEW	CONALET A 07/28/22 JLD TJR CONSTRUCTION DRAWINGS - ISSUED FOR CLIENT REVIEW	REV. DATE DRAWN BY CHECKED BY DESCRIPTION
PROF						T				4 umbry Meterics Development
		Centered on Solutions <sup>34</sup>		1203) 188 0580	(203) 488-0300 (203) 488-8587 Fax	63-2 North Branford Road	Branford, CT 06405		- - (	www.CentekEng.com
			CITE NAME: EAIDEIEI D'AJD/VALVAD							
D/ SC JC	ATE: CALI DB	E: NC	). E	EC	07 AS 22 TF	2/2 N 207	8/ 0T 3.0	22 ED 03		
		G	R( F		J N _AI				2	



![](_page_18_Figure_1.jpeg)

# NOTES:

1. DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO CIGBE

# CONNECTION OF GROUND WIRES TO GROUND BAR SCALE: NOT TO SCALE

					DRAWINGS - REVISED PER CLIENT COMMENTS	DRAWINGS - ISSUED FOR CONSTRUCTION	DRAWINGS - REVISED PER CLIENT COMMENTS	DRAWINGS - ISSUED FOR CLIENT REVIEW	DRAWINGS - ISSUED FOR CLIENT REVIEW	
					CONSTRUCTION	CONSTRUCTION	CONSTRUCTION	CONSTRUCTION	CONSTRUCTION	D BY DESCRIPTION
					TJF	TJF	TJF	TJF	TJF	BY CHECKE
					/23 ASC	Z3 ASC	/23 ASC	/23 ASC	/22 JLD	DRAWN
					1 06/21,	0 06/05,	_C 05/24,	<del>-B 04/14</del> ,	A 07/28,	REV. DATI
PROFESSIONAL ENGINEER SEAL		ANNUMBER OF ANNUM	and the second second	I = Lo Cot CENT OF			THE PROPAGATION & THE SAME	No. And Solar	THE ONAL ENTRY	- 多頭頭頭頭目を目を見られて
						I	UUU Z		NON THE SULUTIONS	Lurrich Witches Loodogment
		Centered on Solutions <sup>**</sup>		(203) 488 0580	(203) 400-0000 (203) 488-8587 FOX	63-2 North Branford Road	Branford, CT 06405			www.CentekEng.com
				OILE INAMIC: L'AINFIELU/MIF/A447742					EAIRFIEL D. CT 06824	
DA SC JC	ATE CAL	L E: NC	).		07 AS 22	/2 N	8/ OT 3.0	22 ED		
		EI	Т _Е D	YF IC E	РІС TF ГА	CA RI(	L CA S	\L		
F						- 4	4	•		

![](_page_19_Figure_0.jpeg)

![](_page_19_Figure_1.jpeg)

1	TINNED COPPER GROUND BAR, 1/4" x 4" x 20", NEWTON INSTRUMENT CO. HOLE CENTERS TO MATCH NEMA DOUBLE LUG CONFIGURATION.
2	INSULATORS, NEWTON INSTRUMENT CAT. NO. 3061-4.
3	5/8" LOCK WASHERS, NEWTON INSTRUMENT CO. CAT. NO. 3015–8.
4	WALL MOUNTING BRACKET, NEWTON INSTRUMENT CO. CAT NO. A—6056.
5	$5/8-11 \times 1$ " STAINLESS STEEL TRUSS SPANNER MACHINE SCREWS.

![](_page_19_Picture_3.jpeg)

![](_page_19_Figure_4.jpeg)

# NOTES:

1. USE GROUND PLATE DETAIL IF 10 FT. GROUND ROD DEPTH CANNOT BE ACHIEVED DUE TO LEDGE CONDITION OR IF EXISTING TOWER FOUNDATION IS ENCOUNTERED.

![](_page_19_Picture_7.jpeg)

![](_page_19_Figure_10.jpeg)

![](_page_19_Figure_11.jpeg)

# ELECTRICAL SPECIFICATIONS

# **SECTION 16010**

1.02. GENERAL REQUIREMENTS

- A. THE ENTIRE ELECTRICAL INSTALLATION SHALL BE MADE IN STRICT ACCORDANCE WITH ALL LOCAL, STATE AND NATIONAL CODES AND REGULATIONS WHICH MAY APPLY AND NOTHING IN THE DRAWINGS OR SPECIFICATIONS SHALL BE INTERPRETED AS AN INFRINGEMENT OF SUCH CODES OR REGULATIONS.
- B. THE ELECTRICAL CONTRACTOR IS TO BE RESPONSIBLE FOR THE COMPLETE INSTALLATION AND COORDINATION OF THE ENTIRE ELECTRICAL SERVICE. ALL ACTIVITIES TO BE COORDINATED THROUGH OWNERS REPRESENTATIVE. DESIGN ENGINEER AND OTHER AUTHORITIES HAVING JURISDICTION OF TRADES.
- C. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL PERMITS AND PAY ALL FEES THAT MAY BE REQUIRED FOR THE ELECTRICAL WORK AND FOR THE SCHEDULING OF ALL INSPECTIONS THAT MAY BE REQUIRED BY THE LOCAL AUTHORITY.
- D. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION WITH THE BUILDING OWNER FOR NEW AND/OR DEMOLITION WORK INVOLVED.
- E. NO MATERIAL OTHER THAN THAT CONTAINED IN THE "LATEST LIST OF ELECTRICAL FITTINGS" APPROVED BY THE UNDERWRITERS' LABORATORIES, SHALL BE USED IN ANY PART OF THE WORK. ALL MATERIAL FOR WHICH LABEL SERVICE HAS BEEN ESTABLISHED SHALL BEAR THE U.L. LABEL.
- F. THE CONTRACTOR SHALL GUARANTEE ALL NEW WORK FOR A PERIOD OF ONE YEAR FROM THE ACCEPTANCE DATE BY THE OWNER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING WARRANTIES FROM ALL EQUIPMENT MANUFACTURERS FOR SUBMISSION TO THE OWNER.
- G. DRAWINGS INDICATE GENERAL ARRANGEMENT OF WORK INCLUDED IN CONTRACT. CONTRACTOR SHALL, WITHOUT EXTRA CHARGE, MAKE MODIFICATIONS TO THE LAYOUT OF THE WORK TO PREVENT CONFLICT WITH WORK OF OTHER TRADES AND FOR THE PROPER INSTALLATION OF WORK. CHECK ALL DRAWINGS AND VISIT JOB SITE TO VERIFY SPACE AND TYPE OF EXISTING CONDITIONS IN WHICH WORK WILL BE DONE, PRIOR TO SUBMITTAL OF BID.
- H. THE ELECTRICAL CONTRACTOR SHALL SUPPLY THREE (3) COMPLETE SETS OF APPROVED DRAWINGS, ENGINEERING DATA SHEETS, MAINTENANCE AND OPERATING INSTRUCTION MANUALS FOR ALL SYSTEMS AND THEIR RESPECTIVE EQUIPMENT. THESE MANUALS SHALL BE INSERTED IN VINYL COVERED 3-RING BINDERS AND TURNED OVER TO OWNER'S REPRESENTATIVE ONE (1) WEEK PRIOR TO FINAL PUNCH LIST.
- I. ALL WORK SHALL BE INSTALLED IN A NEAT AND WORKMAN LIKE MANNER AND WILL BE SUBJECT TO THE APPROVAL OF THE OWNER'S REPRESENTATIVE.
- J. ALL EQUIPMENT AND MATERIALS TO BE INSTALLED SHALL BE NEW, UNLESS OTHERWISE NOTED.
- K. BEFORE FINAL PAYMENT, THE CONTRACTOR SHALL PROVIDE A COMPLETE SET OF PRINTS (AS-BUILTS), LEGIBLY MARKED IN RED PENCIL TO SHOW ALL CHANGES FROM THE ORIGINAL PLANS.
- L. PROVIDE TEMPORARY POWER AND LIGHTING IN WORK AREAS AS REQUIRED.
- M. SHOP DRAWINGS:
- 1. CONTRACTOR SHALL SUBMIT SIX (6) COPIES OF SHOP DRAWINGS ON ALL EQUIPMENT AND MATERIALS PROPOSED FOR USE ON THIS PROJECT, GIVING ALL DETAILS, WHICH INCLUDE DIMENSIONS, CAPACITIES, ETC.
- 2. CONTRACTOR SHALL SUBMIT SIX (6) COPIES OF ALL TEST REPORTS CALLED FOR IN THE SPECIFICATIONS AND DRAWINGS.
- N. THE ENTIRE ELECTRICAL INSTALLATION SHALL BE IN ACCORDANCE WITH OWNER'S SPECIFICATIONS, AND REQUIREMENTS OF ALL LOCAL AUTHORITIES HAVING JURISDICTION. IT IS THE CONTRACTOR'S RESPONSIBILITY TO COORDINATE WITH APPROPRIATE INDIVIDUALS TO OBTAIN ALL SUCH SPECIFICATIONS AND REQUIREMENTS. NOTHING CONTAINED IN. OR OMITTED FROM. THESE DOCUMENTS SHALL RELIEVE CONTRACTOR FROM THIS OBLIGATION.

# SECTION 16111

1.01. CONDUITS

- A. MINIMUM CONDUIT SIZE FOR BRANCH CIRCUITS, LOW VOLTAGE CONTROL AND ALARM CIRCUITS SHALL BE 3/4". CONDUITS SHALL BE PROPERLY FASTENED AS REQUIRED BY THE N.E.C.
- B. THE INTERIOR OF RACEWAYS/ENCLOSURES INSTALLED UNDERGROUND SHALL BE CONSIDERED TO BE WET LOCATION, INSULATED CONDUCTORS SHALL BE LISTED FOR USE IN WET LOCATIONS. PROVIDE WEATHERPROOF CONSTRUCTION IN WET LOCATIONS.
- C. CONDUIT INSTALLED UNDERGROUND SHALL BE INSTALLED TO MEET MINIMUM COVER REQUIREMENTS OF TABLE 300.5.
- D. PROVIDE RIGID GALVANIZED STEEL CONDUIT (RMC) FOR THE FIRST 10 FOOT SECTION WHEN LEAVING A BUILDING OR SECTIONS PASSING THROUGH FLOOR SLABS
- E. ONLY LISTED PVC CONDUIT AND FITTINGS ARE PERMITTED FOR THE INSTALLATION OF ELECTRICAL CONDUCTORS. SUITABLE FOR UNDERGROUND APPLICATIONS.

CONDUIT SCHEDULE SECTION 16111							
CONDUIT TYPE	NEC REFERENCE	APPLICATION	MIN. BURIAL DEPTH (PER NEC TABLE 300.5) <sup>2,3</sup>				
ЕМТ	ARTICLE 358	INTERIOR CIRCUITING, EQUIPMENT ROOMS, SHELTERS	N/A				
RMC, RIGID GALV. STEEL	ARTICLE 344, 300.5, 300.50	ALL INTERIOR/ EXTERIOR CIRCUITING, ALL UNDERGROUND INSTALLATIONS.	6 INCHES				
PVC, SCHEDULE 40	ARTICLE 352, 300.5, 300.50	INTERIOR/ EXTERIOR CIRCUITING AND GROUNDING SYSTEMS, UNDERGROUND INSTALLATIONS, WHERE NOT SUBJECT TO PHYSICAL DAMAGE. <sup>1</sup>	18 INCHES				
PVC, SCHEDULE 80 ARTICLE 35 300.5, 300.		INTERIOR/ EXTERIOR CIRCUITING AND GROUNDING SYSTEMS, UNDERGROUND INSTALLATIONS, WHERE SUBJECT TO PHYSICAL DAMAGE. <sup>1</sup>	18 INCHES				
LIQUID TIGHT FLEX. METAL	ARTICLE 350	SHORT LENGTHS (MAX. 3FT.) WIRING TO VIBRATING EQUIPMENT IN WET LOCATIONS.	N/A				
FLEX. METAL	ARTICLE 348	SHORT LENGTHS (MAX. 3FT.) WIRING TO VIBRATING EQUIPMENT IN WET LOCATIONS.	N/A				
<sup>1</sup> PHYSICAL DAMAGE IS SUBJECT TO THE AUTHORITY HAVING JURISDICTION.							
2							

" UNDERGROUND CONDUIT INSTALLED UNDER ROADS, HIGHWAYS, DRIVEWAYS, PARKING LOTS SHALL HAVE MINIMUM DEPTH OF 24". <sup>3</sup> WHERE SOLID ROCK PREVENTS COMPLIANCE WITH MINIMUM COVER DEPTHS. WIRING SHALL BE INSTALLED IN PERMITTED RACEWAY FOR DIRECT BURIAL. THE RACEWAY SHALL BE COVERED BY A MINIMUM OF 2" OF CONCRETE EXTENDING DOWN TO ROCK.

# **SECTION 16123**

- 1.01. CONDUCTORS
- A. ALL CONDUCTORS SHALL BE TYPE THWN (INT. APPLICATION) AND XHHW (EXT. APPLICATION), 75 DEGREE C, 600 VOLT INSULATION, SOFT ANNEALED STRANDED COPPER. #10 AWG AND SMALLER SHALL BE SPLICED USING ACCEPTABLE SOLDERLESS PRESSURE CONNECTORS. #8 AWG AND LARGER SHALL BE SPLICED USING COMPRESSION SPLIT-BOLT TYPE CONNECTORS. #12 AWG SHALL BE THE MINIMUM SIZE CONDUCTOR FOR LINE VOLTAGE BRANCH CIRCUITS. REFER TO PANEL SCHEDULE FOR BRANCH CIRCUIT CONDUCTOR SIZE(S). CONDUCTORS SHALL BE COLOR CODED FOR CONSISTENT PHASE IDENTIFICATION:
- 120/208/240V 277/480V COLOR BLACK COLOR BROWN ORANGE RFD BLUF YELLOW CONTINUOUS WHITE GREY CONTINUOUS GREEN GREEN WITH YELLOW STRIPE
- B. MINIMUM BENDING RADIUS FOR CONDUCTORS SHALL BE 12 TIMES THE LARGEST DIAMETER OF BRANCH CIRCUIT CONDUCTOR.

# **SECTION 16130**

# 1.01. BOXES

- A. FURNISH AND INSTALL OUTLET BOXES FOR ALL DEVICES, SWITCHES, RECEPTACLES, ETC., BOXES TO BE ZINC COATED STEEL.
- B. FURNISH AND INSTALL PULL BOXES IN MAIN FEEDERS RUNS WHERE REQUIRED. PULL BOXES SHALL BE GALVANIZED STEEL WITH SCREW REMOVABLE COVERS, SIZE AND QUANTITY AS REQUIRED. PROVIDE WEATHERPROOF CONSTRUCTION IN WET LOCATIONS.

# **SECTION 16140**

- 1.01. WIRING DEVICES
- A. THE FOLLOWING LIST IS PROVIDED TO CONVEY THE QUALITY AND RATING OF WIRING DEVICES WHICH ARE TO BE INSTALLED. A COMPLETE LIST OF ALL DEVICES MUST BE SUBMITTED BEFORE INSTALLATION FOR APPROVAL.
- 1. 15 MINUTE TIMER SWITCH INTERMATIC #FF15M (INTERIOR LIGHTS)
- 2. DUPLEX RECEPTACLE P&S #2095 (GFCI) SPECIFICATION GRADE
- 3. SINGLE POLE SWITCH P&S #CSB20AC2 (20A-120V HARD USE) SPECIFICATION GRADE
- 4. DUPLEX RECEPTACLE P&S #5362 (20A-120V HARD USE) SPECIFICATION GRADE
- B. PLATES ALL PLATES USED SHALL BE CORROSION RESISTANT TYPE 304 STAINLESS STEEL. PLATES SHALL BE FROM SAME MANUFACTURER AS SWITCHES AND RECEPTACLES. PROVIDE WEATHERPROOF HOUSING FOR DEVICES LOCATED IN WET LOCATIONS.
- C. OTHER MANUFACTURERS OF THE SWITCHES, RECEPTACLES AND PLATES MAY BE SUBMITTED FOR APPROVAL BY THE ENGINEER.

# **SECTION 16170**

1.01. DISCONNECT SWITCHES

A. FUSIBLE AND NON-FUSIBLE, 600V, HEAVY DUTY DISCONNECT SWITCHES SHALL BE AS MANUFACTURED BY SQUARE "D". PROVIDE FUSES AS CALLED FOR ON THE CONTRACT DRAWINGS. AMPERE RATING SHALL BE CONSISTENT WITH LOAD BEING SERVED. DISCONNECT SWITCH COVER SHALL BE MECHANICALLY INTERLOCKED TO PREVENT COVER FROM OPENING WHEN THE SWITCH IS IN THE "ON" POSITION. EXTERIOR APPLICATIONS SHALL BE NEMA 3R CONSTRUCTION WITH PADLOCK FEATURE.

# **SECTION 16190**

- 1.01. SEISMIC RESTRAINT
- A. ALL DEVICES SHALL BE INSTALLED IN ACCORDANCE WITH ZONE 2 SEISMIC REQUIREMENTS.

# **SECTION 16195**

- 1.01. LABELING AND IDENTIFICATION NOMENCLATURE FOR ELECTRICAL EQUIPMENT
- A. CONTRACTOR SHALL FURNISH AND INSTALL NON-METALLIC ENGRAVED BACK-LIT NAMEPLATES ON ALL PANELS AND MAJOR ITEMS OF ELECTRICAL EQUIPMENT
- B. LETTERS TO BE WHITE ON BLACK BACKGROUND WITH LETTERS 1-1/2 INCH HIGH WITH 1/4 INCH MARGIN.
- C. IDENTIFICATION NOMENCLATURE SHALL BE IN ACCORDANCE WITH OWNER'S STANDARDS.

# **SECTION 16450** 1.01. GROUNDING

- GROUNDING SOURCES.

- CORROSION

- RACEWAY(S).

- 1. GROUND BARS

- SPECIFICATIONS.

# **SECTION 16470**

# 1.01. DISTRIBUTION EQUIPMENT

A. REFER TO CONTRACT DRAWINGS FOR DETAILS AND SCHEDULES.

# **SECTION 16477** 1.01. FUSES

A. FUSES SHALL BE NONRENEWABLE TYPE AS MANUFACTURED BY "BUSSMAN" OR APPROVED EQUAL. FUSES RATED TO 1/10 AMPERE UP TO 600 AMPERES SHALL BE EQUIVALENT TO BUSSMAN TYPE LPN-RK (250V) UL CLASS RK1, LOW PEAK, DUAL ELEMENT, TIME-DELAY FUSES. FUSES SHALL HAVE SEPARATE SHORT CIRCUIT AND OVERLOAD ELEMENTS AND HAVE AN INTERRUPTING RATING OF 200 KAIC. UPON COMPLETION OF WORK, PROVIDE ONE SPARE SET OF FUSES FOR EACH TYPE INSTALLED.

# **SECTION 16960**

1.01. TESTS BY INDEPENDENT ELECTRICAL TESTING FIRM

A. CONTRACTOR SHALL RETAIN THE SERVICES OF A LOCAL INDEPENDENT ELECTRICAL TESTING FIRM (WITH MINIMUM 5 YEARS COMMERCIAL EXPERIENCE IN THE ELECTRICAL TESTING INDUSTRY) AS SPECIFIED BY OWNER TO PERFORM:

TEST 1: THERMAL OVERLOAD AND MAGNETIC TRIP TEST, AND CABLE INSULATION TEST FOR ALL CIRCUIT BREAKERS RATED 100 AMPS OR GREATER.

- REQUIRING WITNESSING.

# **SECTION 16961**

- 1.01. TESTS BY CONTRACTOR

### A. ALL NON-CURRENT CARRYING PARTS OF THE ELECTRICAL AND TELEPHONE CONDUIT SYSTEMS SHALL BE MECHANICALLY AND ELECTRICALLY CONNECTED TO PROVIDE AN INDEPENDENT RETURN PATH TO THE EQUIPMENT

B. GROUNDING SYSTEM WILL BE IN ACCORDANCE WITH THE LATEST ACCEPTABLE EDITION OF THE NATIONAL ELECTRICAL CODE AND REQUIREMENTS PER LOCAL INSPECTOR HAVING JURISDICTION.

C. GROUNDING OF PANELBOARDS:

1. PANELBOARD SHALL BE GROUNDED BY TERMINATING THE PANELBOARD FEEDER'S EQUIPMENT GROUND CONDUCTOR TO THE EQUIPMENT GROUND BAR KIT(S) LUGGED TO THE CABINET. ENSURE THAT THE SURFACE BETWEEN THE KIT AND CABINET ARE BARE METAL TO BARE METAL. PRIME AND PAINT OVER TO PREVENT

2. CONDUIT(S) TERMINATING INTO THE PANELBOARD SHALL HAVE GROUNDING TYPE BUSHINGS. THE BUSHINGS SHALL BE BONDED TOGETHER WITH BARE #10 AWG COPPER CONDUCTOR WHICH IN TURN IS TERMINATED INTO THE PANELBOARD'S EQUIPMENT GROUND BAR KIT(S).

# D. EQUIPMENT GROUNDING CONDUCTOR:

1. EACH EQUIPMENT GROUND CONDUCTOR SHALL BE SIZED IN ACCORDANCE WITH THE N.E.C. ARTICLE 250-122. 2. THE MINIMUM SIZE OF EQUIPMENT GROUND CONDUCTOR SHALL BE #12 AWG COPPER.

3. EACH FEEDER OR BRANCH CIRCUIT SHALL HAVE EQUIPMENT GROUND CONDUCTOR(S) INSTALLED IN THE SAME

E. CELLULAR GROUNDING SYSTEM:

CONTRACTOR SHALL PROVIDE A CELLULAR GROUNDING SYSTEM WITH THE MAXIMUM AC RESISTANCE TO GROUND OF 10 OHM BETWEEN ANY POINT ON THE GROUNDING SYSTEM AS MEASURED BY 3-POINT GROUNDING TEST. (REFER TO SECTION 16960).

PROVIDE THE CELLULAR GROUNDING SYSTEM AS SPECIFIED ON DRAWINGS, INCLUDING, BUT NOT LIMITED TO:

2. EXTERIOR GROUNDING (WHERE REQUIRED DUE TO MEASURED AC RESISTANCE GREATER THAN SPECIFIED). 3. ANTENNA GROUND CONNECTIONS AND PLATES.

F. CONTRACTOR, AFTER COMPLETION OF THE COMPLETE GROUNDING SYSTEM BUT PRIOR TO CONCEALMENT/BURIAL OF SAME, SHALL NOTIFY OWNER'S PROJECT ENGINEER WHO WILL HAVE A DESIGN ENGINEER VISIT SITE AND MAKE A VISUAL INSPECTION OF THE GROUNDING GRID AND CONNECTIONS OF THE SYSTEM.

G. ALL EQUIPMENT SHALL BE BONDED TO GROUND AS REQUIRED BY N.E.C., MFG. SPECIFICATIONS, AND OWNER'S

TEST 2: RESISTANCE TO GROUND TEST ON THE CELLULAR GROUNDING SYSTEM.

THE TESTING FIRM SHALL INCLUDE THE FOLLOWING INFORMATION WITH THE REPORT:

1. TESTING PROCEDURE INCLUDING THE MAKE AND MODEL OF TEST EQUIPMENT

2. CERTIFICATION OF TESTING EQUIPMENT CALIBRATION WITHIN SIX (6) MONTHS OF DATE OF TESTING. INCLUDE CERTIFICATION LAB ADDRESS AND TELEPHONE NUMBER.

3. GRAPHICAL DESCRIPTION OF TESTING METHOD ACTUALLY IMPLEMENTED.

B. THESE TESTS SHALL BE PERFORMED IN THE PRESENCE AND TO THE SATISFACTION OF OWNER'S CONSTRUCTION REPRESENTATIVE. TESTING DATA SHALL BE INITIALED AND DATED BY THE CONSTRUCTION REPRESENTATIVE AND INCLUDED WITH THE WRITTEN REPORT/ANALYSIS.

C. THE CONTRACTOR SHALL FORWARD SIX (6) COPIES OF THE INDEPENDENT ELECTRICAL TESTING FIRM'S REPORT/ANALYSIS TO ENGINEER A MINIMUM OF TEN (10) WORKING DAYS PRIOR TO THE JOB TURNOVER. D. CONTRACTOR TO PROVIDE A MINIMUM OF ONE (1) WEEK NOTICE TO OWNER AND ENGINEER FOR ALL TESTS

A. ALL TESTS AS REQUIRED UPON COMPLETION OF WORK, SHALL BE MADE BY THIS CONTRACTOR. THESE SHALL BE CONTINUITY AND INSULATION TESTS: TEST TO DETERMINE THE QUALITY OF MATERIALS, ETC. AND SHALL BE MADE IN ACCORDANCE WITH N.E.C. RECOMMENDATIONS. ALL FEEDERS AND BRANCH CIRCUIT WIRING (EXCEPT CLASS 2 SIGNAL CIRCUITS) MUST BE TESTED FREE FROM SHORT CIRCUIT AND GROUND FAULT CONDITIONS AT 500V IN A REASONABLY DRY AMBIENT OF APPROXIMATELY 70 DEGREES F.

B. CONTRACTOR SHALL PERFORM LOAD PHASE BALANCING TESTS. CIRCUITS SHALL BE CONNECTED TO THE PANELBOARDS SO THAT THE NEW LOAD IS DISTRIBUTED AS EQUALLY AS POSSIBLE BETWEEN EACH LOAD AND NEUTRAL. 10% SHALL BE CONSIDERED AS A REASONABLE AND ACCEPTABLE ALLOWANCE. BRANCH CIRCUITS SHALL BE BALANCED ON THEIR OWN PANELBOARDS; FEEDER LOADS SHALL, IN TURN, BE BALANCED ON THE SERVICE EQUIPMENT. REASONABLE LOAD TEST SHALL BE ARRANGED TO VERIFY LOAD BALANCE IF REQUESTED BY THE ENGINEER.

C. ALL TESTS, UPON REQUEST, SHALL BE REPEATED IN THE PRESENCE OF OWNER'S REPRESENTATIVE. ALL TESTS SHALL BE DOCUMENTED AND TURNED OVER TO OWNER. OWNER SHALL HAVE THE AUTHORITY TO STOP ANY OF THE WORK NOT BEING PROPERLY INSTALLED. ALL SUCH DETECTED WORK SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL EXPENSE TO THE OWNER AND THE TESTS SHALL BE REPEATED.

![](_page_20_Figure_128.jpeg)

# Exhibit D

**Structural Analysis Report** 

![](_page_22_Picture_0.jpeg)

Centered on Solutions<sup>™</sup>

# <u>Structural Analysis of</u> <u>Utility Pole</u>

T-Mobile Site Ref: CT11317B

Eversource Structure No. 19725 125' Tall Electric Transmission Pole

> 280 Morehouse Road Fairfield, CT

CENTEK Project No. 22073.03

Date: April 6, 2023

Max Stress Ratio = 88.7%

![](_page_22_Picture_9.jpeg)

**Prepared for:** T-Mobile USA 35 Griffin Road Bloomfield, CT 06002

# Table of Contents

# SECTION 1 - REPORT

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANALYSIS
- DESIGN BASIS
- RESULTS
- CONCLUSION

# SECTION 2 - CONDITIONS & SOFTWARE

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAMS
  - PLS POLE

# SECTION 3 - DESIGN CRITERIA

- CRITERIA FOR DESIGN OF PCS FACILITIES ON OR EXTENDING ABOVE METAL ELECTRIC TRANSMISSON TOWERS
- DESIGN CRITERIA TABLE
- SHAPE FACTOR CRITERIA
- WIRE LOADS

# SECTION 4 - DRAWINGS

- SK-1 POLE ELEVATION
- SK-2 FEEDLINE PLAN

# SECTION 5 - NECS LOAD CALCULATIONS

EQUIPMENT AND COAX LOADS

# SECTION 6 - UTILITY TOWER ANALYSIS

- PLS REPORT
- ANCHOR BOLT ANALYSIS
- FLANGE PLATE AND FLANGE BOLT ANALYSIS

# SECTION 7 - REFERENCE MATERIAL

- RF DATA SHEET
- EQUIPMENT CUT SHEETS

# <u>Introduction</u>

The purpose of this report is to analyze the 125' utility pole located in Fairfield, CT for the proposed antenna and equipment upgrade by T-Mobile.

The loads consist of the following:

- <u>AT&T (Final Configuration):</u> <u>Antennas</u>: Three (3) CCI TPA65R-BU4D panel antennas and six (6) Commscope TMAT192123B68-31 TMAs mounted on one (1) Platform (SitePro p/n RMQLP-4120-H10) to the utility pole with a RAD center elevation of 111-ft above grade. <u>Cables:</u> Twelve (12) 1-5/8" Ø coax cables mounted to the outside of the pole as indicated in Section 4 of this report.
- <u>T-MOBILE (Final Configuration):</u> <u>Antennas</u>: Three (3) RFS APXVAALL24\_43 panel antennas, three (3) RFS APX16DWV-16DWVS panel antennas and six (6) Commscope ATSBT-TOP-MF-4G Bias Tees mounted on one (1) Platform (SitePro p/n RMQLP-496-HK) to the utility pole with a RAD center elevation of 121-ft above grade. <u>Cables:</u> Twenty-four (24) 1-1/4" Ø coax cables mounted to the outside of the pole as indicated in Section 4 of this report.

# <u>Primary assumptions used in the analysis</u>

- Design steel stresses are defined by AISC-LRFD 14<sup>th</sup> edition for design of the antenna Mast and antenna supporting elements.
- ASCE Manual No. 48-19, "Design of Steel Transmission Pole Structures", defines allowable steel stresses for evaluation of the utility pole.
- All utility pole members are adequately protected to prevent corrosion of steel members.
- All proposed antenna mounts are modeled as listed above.
- Pipe mast will be properly installed and maintained.
- No residual stresses exist due to incorrect pole erection.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds conform to the requirements of AWS D1.1.
- Pipe mast and utility pole will be in plumb condition.
- Utility pole was properly installed and maintained and all members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.
- Any deviation from the analyzed loading will require a new analysis for verification of structural adequacy.

# <u>Analysis</u>

Structural analysis of the utility pole was independently completed using the current version of PLSPole computer program licensed to CENTEK Engineering, Inc.

NESC prescribed loads for the proposed wireless equipment were calculated to analyze the utility tower. Section 5 of this report details these loads.

# <u>Design Basis</u>

Our analysis was performed in accordance with ASCE 48-19, "Design of Steel Transmission Pole Structures", NESC C2-2023 and Eversource Design Criteria.

UTILITY POLE ANALYSIS

The purpose of this analysis is to determine the adequacy of the existing utility pole to support the proposed antenna loads. The loading and design requirements were analyzed in accordance with the Eversource Design Criteria Table, NESC C2-2023 ~ Construction Grade B, and ASCE Manual No. 48-19.

Load cases considered:

Load Case 1: NESC Heavy Wind	
Wind Pressure	4.0 psf
Radial Ice Thickness	0.5"
Vertical Overload Capacity Factor	1.50
Wind Overload Capacity Factor	2.50
Wire Tension Overload Capacity Factor	1.65
Load Case 2: NESC Extreme Wind	
Wind Speed 11	10 mph <sup>(1)</sup>
Radial Ice Thickness	0"
Load Case 3: NESC Extreme Ice w/ Wind	
Wind Pressure	6.4 psf
Radial Ice Thickness	0.75"
Vertical Overload Capacity Factor	1.0
Wind Overload Capacity Factor	1.0

Note 1: NESC C2-2023, Section 25, Rule 250C: Extreme Wind Loading, 1.25 x Gust Response Factor (wind speed: 3-second gust)

# <u>Results</u>

UTILITY POLE

This analysis finds that the subject utility pole is adequate to support the proposed antenna mast and related appurtenances. The pole stresses meet the requirements set forth by the ASCE Manual No. 48-19, "Design of Steel Transmission Pole Structures", for the applied NESC Heavy and Hi-Wind load cases. The detailed analysis results are provided in Section 6 of this report. The analysis results are summarized as follows:

A maximum usage of **88.66%** occurs in the utility pole base plate under the **NESC Extreme** loading condition.

### POLE SECTION:

The utility pole was found to be within allowable limits.

Tower Section	Elevation	Stress Ratio (% of capacity)	Result
Section 3	53.00' -100.00' (AGL)	57.96%	PASS

### BASE PLATE:

The base plate was found to be within allowable limits from the PLS output.

Tower Component	Design Limit	Stress Ratio (percentage of capacity)	Result
Base Plate	Bending	88.66%	PASS

### FLANGE:

The flange bolts and flange plate were found to be within allowable limits.

Tower Component	Design Limit	Stress Ratio (% of capacity)	Result
Flange Bolts	Tension	54.6%	PASS
Flange Plate	Bending	50.1%	PASS

### FOUNDATION AND ANCHORS

The base of the tower is connected to the foundation by means of (24)  $2.25^{"}$ , ASTM A615-75 anchor bolts embedded into the concrete foundation structure. Review of the foundation consisted of a comparison of the base reactions obtained from the proposed tower analysis and the original foundation design.

### **BASE REACTIONS:**

From PLS-Pole analysis of utility pole based on NESC/NU prescribed loads.

Load Case	Shear	Axial	Moment
NESC Heavy Wind	29.48 kips	115.65 kips	2386.79 ft-kips
NESC Extreme Wind	53.61 kips	57.99 kips	4344.25 ft-kips
NESC Extreme Ice w/ Wind	22.73 kips	101.83 kips	1854.34 ft-kips

Note 1 – 10% increase to be applied to tower base reactions for foundation verification per OTRM 051

# ANCHOR BOLTS:

The anchor bolts were found to be within allowable limits.

Tower Component	Design Limit	Stress Ratio (% of capacity)	Result
Anchor Bolts	Tension	50.9%	PASS

### FOUNDATION:

Force	Original Design Loading	Proposed Loading	Result
Moment	7,478 ft-kips	4,779 ft-kips	PASS
Shear	97.3 kips	59.0 kips	PASS

Note 1: Taken from Sabre design calculations.

# <u>Conclusion</u>

This analysis shows that the subject utility pole *is adequate* to support the proposed equipment upgrade.

The analysis is based, in part on the information provided to this office by Eversource and T-Mobile. If the existing conditions are different than the information in this report, CENTEK engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:

Timothy J. Lynn, PE Structural Engineer

![](_page_27_Picture_14.jpeg)

# <u>STANDARD CONDITIONS FOR FURNISHING OF</u> <u>PROFESSIONAL ENGINEERING SERVICES ON</u> <u>EXISTING STRUCTURES</u>

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of CENTEK engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to CENTEK engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an un-corroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the "as new" condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222.
- All services are performed, results obtained, and recommendations made in accordance with generally accepted engineering principles and practices. CENTEK engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.

# <u>GENERAL DESCRIPTION OF STRUCTURAL</u> <u>ANALYSIS PROGRAM~PLS-POLE</u>

PLS-POLE provides all of the capabilities a structural engineer requires to design transmission, substation or communications structures. It does so using a simple easy to use graphical interface that rests upon our time tested finite element engine. Regardless of whether you want to model a simple wood pole or a guyed steel X-Frame; PLS-POLE can handle the job simply, reliably and efficiently.

### Modeling Features:

- Structures are made of standard reusable components that are available in libraries. You can
  easily create your own libraries or get them from a manufacturer
- Structure models are built interactively using interactive menus and graphical commands
- Automatic generation of underlying finite element model of structure
- Steel poles can have circular, 4, 6, 8, 12, 16, or 18-sided, regular, elliptical or user input cross sections (flat-to-flat or tip-to-tip orientations)
- Steel and concrete poles can be selected from standard sizes available from manufacturers
- Automatic pole class selection
- Cross brace position optimizer
- Capability to specify pole ground line rotations
- Capability to model foundation displacements
- Can optionally model foundation stiffness
- Guys are easily handled (modeled as exact cable elements in nonlinear analysis)
- Powerful graphics module (members color-coded by stress usage)
- Graphical selection of joints and components allows graphical editing and checking
- Poles can be shown as lines, wire frames or can be rendered as 3-d polygon surfaces

### Analysis Features:

- Automatic distribution of loads in 2-part suspension insulators (v-strings, horizontal vees, etc.)
- Design checks for ASCE, ANSI/TIA/EIA 222 (Revisions F and G) or other requirements
- Automatic calculation of dead and wind loads
- Automated loading on structure (wind, ice and drag coefficients) according to:
  - ASCE 74-1991
  - NESC 2002
  - NESC 2007
  - IEC 60826:2003
  - EN50341-1:2001 (CENELEC)
  - EN50341-3-9:2001 (UK NNA)
  - EN50341-3-17:2001 (Portugal NNA)
  - ESAA C(b)1-2003 (Australia)
  - TPNZ (New Zealand)
  - REE (Spain)
  - EIA/TÌA 222-F
  - ANSI/TIA 222-G
  - CSA S37-01
- Automated microwave antenna loading as per EIA/TIA 222-F and ANSI/TIA 222-G
- Detects buckling by nonlinear analysis

Results Features:

- Detects buckling by nonlinear analysis
- Easy to interpret text, spreadsheet and graphics design summaries
   Automatic determination of allowable wind and weight spans
- Automatic determination of interaction diagrams between allowable wind and weight spans
- Automatic tracking of part numbers and costs

# <u>Criteria for Design of PCS Facilities On or</u> <u>Extending Above Metal Electric Transmission</u> <u>Towers & Analysis of Transmission Towers</u> <u>Supporting PCS Masts</u><sup>(1)</sup>

# <u>Introduction</u>

This criteria is the result from an evaluation of the methods and loadings specified by the separate standards, which are used in designing telecommunications towers and electric transmission towers. That evaluation is detailed elsewhere, but in summary; the methods and loadings are significantly different. This criteria specifies the manner in which the appropriate standard is used to design PCS facilities including masts and brackets (hereafter referred to as "masts"), and to evaluate the electric transmission towers to support PCS masts. The intent is to achieve an equivalent level of safety and security under the extreme design conditions expected in Connecticut and Massachusetts.

ANSI Standard TIA-222 covering the design of telecommunications structures specifies a limit state design approach. This approach applies the loads from extreme weather loading conditions, and designs the structure so that the design strength exceeds the required strength.

ANSI Standard C2-2023 (National Electrical Safety Code) covering the design of electric transmission metal structures is based upon an ultimate strength/yield stress design approach. This approach applies a multiplier (overload capacity factor) to the loads possible from extreme weather loading conditions, and designs the structure so that it does not exceed its ultimate strength (yield stress).

Each standard defines the details of how loads are to be calculated differently. Most of the NU effort in "unifying" both codes was to establish what level of strength each approach would provide, and then increasing the appropriate elements of each to achieve a similar level of security under extreme weather loadings.

Two extreme weather conditions are considered. The first is an extreme wind condition (hurricane) based upon a 50-year recurrence (2% annual probability). The second is a winter condition combining wind and ice loadings.

The following sections describe the design criteria for any PCS mast extending above the top of an electric transmission tower, and the analysis criteria for evaluating the loads on the transmission tower from such a mast from the lower portions of such a mast, and loads on the pre-existing electric lower portions of such a mast, and loads on the pre-existing electric transmission tower and the conductors it supports.

<u>Note 1</u>: Prepared from documentation provide from Northeast Utilities.

# <u>PCS Mast</u>

The PCS facility (mast, external cable/trays, including the initial and any planned future support platforms, antennas, etc. extending the full height above the top level of the electric transmission structure) shall be designed in accordance with the provisions of TIA 222-H:

# <u>ELECTRIC TRANSMISSION TOWER</u>

The electric transmission tower shall be analyzed using yield stress theory in accordance with the attached table titled "Eversource Design Criteria". This specifies uniform loadings (different from the TIA loadings) on the each of the following components of the installed facility:

- PCS mast for its total height above ground level, including the initial and planned future support platforms, antennas, etc. above the top of an electric transmission structure.
- Conductors are related devices and hardware.
- Electric transmission structure. The loads from the PCS facility and from the electric conductors shall be applied to the structure at conductor and PCS mast attachment points, where those load transfer to the tower.

The uniform loadings and factors specified for the above components in the table are based upon the National Electrical Safety Code 2023 Edition Extreme Wind (Rule 250C), Combined Ice and Wind (Rule 250B-Heavy) and Extreme Ice w/ Wind (Rule 250D) Loadings. These provide equivalent loadings compared to TIA and its loads and factors with the exceptions noted above. (Note that the NESC does not require the projected wind surfaces of structures and equipment to be increased by the ice covering.)

In the event that the electric transmission tower is not sufficient to support the additional loadings of the PCS mast, reinforcement will be necessary to upgrade the strength of the overstressed members.

# Eversource

# **Overhead Transmission Standards**

								<u>ب</u>
		Attachment A ES Design Criteria	Basic Wind Speed	Pressure	Height Factor	Gust Factor	Load or Stress Factor	Force Coef Shape Facto
			V (MPH)	Q (PSF)	Kz	Gh		
	тіа/еіа	Antenna Mount	TIA	TIA (0.75Wi)	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
e Condition	Неачу	Tower/Pole Analysis with antennas extending above top of Tower/Pole (Yield Stress)		4	1	1	2.5	1.6 Flat Surfaces 1.3 Round Surfaces
	NESC	Tower/Pole Analysis with antennas below top of Tower/Pole (on two faces)		4	1	1	2.5	1.6 Flat Surfaces 1.3 Round Surfaces
		Conductors: Conductor Loads Provided by ES					-	
	TIA/EIA	Antenna Mount	85	TIA	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
Wind Condition eme Wind	treme Wind	Tower/Pole Analysis with antennas extending above top of Tower/Pole	, telecor tower/p	For winc Rule 2 Apply a 1.2 nmunicati ole and ap	1.6 Flat Surfaces 1.3 Round Surfaces			
High	NESC Ext	Tower/Pole Analysis with antennas below top of Tower/Pole Tower/Pole For wind speed use OTRM 060 Map 1, Rule 250C: Extreme Wind Loading Height above ground is based on overall height to top of tower/pole					60 Map 1, Loading rall height to top of	1.6 Flat Surfaces 1.3 Round Surfaces
		Conductors:			Cond	uctor Load	ds Provided by ES	
C Extreme Ice with Wind Condition*		Tower/Pole Analysis with antennas extending above top of Tower/Pole	F 4 P telecor tower/p	For wind speed use OTRM 060 Map 1, Rule 250D: Extreme Ice with Wind Loading 4 PSF Wind Load 1.25 x Gust Response Factor Apply a 1.25 x Gust Response Factor to all telecommunication equipment projected above top of tower/pole and apply a 1.0 x Gust Response Factor to the				1.6 Flat Surfaces 1.3 Round Surfaces
		Tower/Pole Analysis with antennas below top of Tower/Pole	F Height a	For wind speed use OTRM 060 Map 1, Rule 250D: Extreme Ice with Wind Loading 4 PSF Wind Load Height above ground is based on overall height to top of tower/pole			1.6 Flat Surfaces 1.3 Round Surfaces	
I Č	4	Conductors: Conductor Loads Provided by ES						

# Attachment A Eversource Design Criteria

Communication Antennas on Transmission Structures					
Eversource	Design	OTRM 059	Rev. 1		
Approved by: CPS (CT/WMA) JCC (NH/EMA)		Page 8 of 10	11/19/2018		

# **Overhead Transmission Standards**

determined from NESC applied loading conditions (not TIA Loads) on the structure and mount as specified below, and shall include the wireless communication mast and antenna loads per NESC criteria)

The strength reduction factor obtained from the field investigation shall be applied to the members or connections that are showing signs of deterioration from their original condition With the written approval of Eversource Transmission Line Engineering on a case by case the existing structures may be analyzed initially using the current NESC code, then it is permitted to use the original design code with the original conductor load should the existing tower fail the current NESC code.

The structure shall be analyzed using yield stress theory in accordance with Attachment A, "Eversource Design Criteria." This specifies uniform loadings (different from the TIA loadings) on each of the following components of the installed facility:

- a) Wireless communication mast for its total height above ground level, including the initial and any planned future equipment (Support Platforms, Antennas, TMA's etc.) above the top of an electric transmission structure.
- b) Conductors and related devices and hardware (wire loads will be provided by Eversource).
- c) Electric Transmission Structure
  - i) The loads from the wireless communication equipment components based on NESC and Eversource Criteria in Attachment A, and from the electric conductors shall be applied to the structure at conductor and wireless communication mast attachment points, where those loads transfer to the tower. ii)
  - ii) Shape Factor Multiplier:

NESC Structure Shape	Cd
Polyround (for polygonal steel poles)	1.3
Flat	1.6
Open Lattice	3.2
Pole with Coaxial Cable	See Below Table

iii) When Coaxial Cables are mounted alongside the pole structure, the shape multiplier shall be:

Mount Type	Cable Cd	Pole Cd	
Coaxial Cables on outside periphery (One layer)	1.45	1.45	
Coaxial Cables mounted on stand offs	1.6	1.6	

d) The uniform loadings and factors specified for the above components in Attachment A, "Eversource Design Criteria" are based upon the National Electric Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to the TIA and its loads and factors with the exceptions noted above.

Communication Antennas on Transmission Structures							
Eversource	Design	OTRM 059	Rev. 1				
Approved by: CPS (CT/WMA) JCC (NH/EMA)		Page 3 of 10	11/19/2018				

Northeast Utilities System			Wire Loads				
Project Name Work Order			1714/1720/1222 Line Rebuild 80060915				
	Structure #		PC	CS-2 (1976	5 & 19725)		
	Line #			1714/1	720		
P	repared By		GJG		Date	6/3/20	22
(	Checked By		JFAP		Date	6/3/20	22
ш.	_						
		Str	ructure Data				
Structure Height (AGL)	12	5	Load Zone		С	entral CT	
# of Circuits	2		Insulation Type		uspension (Concrete Foundation		undation
Insulator Weight	15	0	Broken Wire Side		Back		
Broken Wire Side	Le	ft	Structure Type		Double Circuit Steel Pole		Pole
		N N	Wire Data				
Circuit #		Left			Right		
Shield Wire	]	FOCAS-12	0		FOCAS-120	)	
Conductor	FA	LCON/AC	SS	F	ALCON/AC	SS	
# of Conductors		1			1		
			•				
		Lir	ne Geometry				
		Circuit 1	<u>,</u>		Circuit 2		
	Ahead	Back	Total	Ahead	Back	Total	
Wind Span	300	300	600	300	300	600	
Weight Span	650	650	1300	650	650	1300	
Minimum Line Angle	0	0	0	0	0	0	
Maximum Line Angle	2.5	2.5	5	2.5	2.5	5	
	<b>I</b>	Wi	ire Tensions				
	Left Circuit Right Circuit						
	Ahead	Back	Ahead	Back			
NESC Rule 250B	14000	14000	14000	14000	or		
NESC Rule 250C	13447	13447	13447	13447	letc		
NESC Rule 250D	17202	17202	17202	17202	ndt		
60°F, No wind or ice	7271	7271	7271	7271	C		
NESC Rule 250B	6000	6000	6000	6000			
NESC Rule 250C	6236	6236	6236	6236	ere sid		
NESC Rule 250D	7829	7829	7829	7829	hie Win		
60°F, No wind or ice	2429	2429	2429	2429			
All Loads include Overl	oad Factors	out not Pole	e Shape Facto	ors			
Load Case			Descript	ion			
1 NESC Rule	250B: 0°F. <sup>1</sup> /	2" of ice. 4	psf wind				
2 NESC Rule	2 NESC Rule 250C: (Extreme Wind Loading)						
3 NESC Rule 250C; Extreme Wind Longtitudinal On The Pole Only							
4 NESC Rule 250D; 15°F 1" of ice. 4 psf or NU Ice Case: 32°F 1" Ice							
5 NESC Rule 250B with no OLFs (Service Load)							
6 60°F, No wind or Ice (Deflection)							
7a NESC Rule	7a NESC Rule 250B/261C Broken Wire Case (Broken SW and Borken Conductor)						
7b NESC Rule 250B/261C Broken Wire Case (Broken SW or Broken Phase)							
10 INLSC Rule 250D/2010 Bloken whe case (Bloken Sw of Bloken Hase)							


Double Circuit Steel Pole Configuration X Denotes Broken Wire Location. This attachment receives case 7 loads. All others receive Case 1 Loads for Case 7

Left Circuit				Right Circuit					
	Case	Vertical	Transverse	Longitudinal		Case	Vertical	Transverse	Longitudinal
ctor	1	6911.1105	2715.9771	0		1	6911.1105	2715.9771	0
	2	2953.82	3965.0998	0	•	2	2953.82	3965.0998	0
	3	2953.82	634.31313	0	ctoi	3	2953.82	634.31313	0
npi	4	7069.594	2249.6814	0	npi	4	7069.594	2249.6814	0
Con	5	4607.407	1770.3428	0	Con	5	4607.407	1770.3428	0
Ľ	6	2953.82	634.31313	0	)	6	2953.82	634.31313	0
	7a	3455.5553	1357.9886	15400		7a	3455.5553	1357.9886	15400
	7b	3455.5553	1357.9886	15400		7b	3455.5553	1357.9886	15400
	Case	Vertical	Transverse	Longitudinal		Case	Vertical	Transverse	Longitudinal
	1	2511.6702	1444.7759	0		1	2511.6702	1444.7759	-6.281738
e	2	673.4	1724.821	0	e	2	673.4	1724.821	-5.93529
Vir	3	673.4	211.90298	0	Wir	3	673.4	211.90298	-2.31187
Shield V	4	3484.0936	1230.5924	0	ld V	4	3484.0936	1230.5924	-7.451473
	5	1674.4468	871.03265	0	hie	5	1674.4468	871.03265	-5.710671
	6	673.4	211.90298	0	S	6	673.4	211.90298	-2.31187
	7a	1255.8351	722.38796	6600		7a	1255.8351	722.38796	6593.7183
	7b	1255.8351	722.38796	6600	] [	7b	1255.8351	722.38796	6593.7183





	Subject:		Loads - Struct	ure #19725
Centered on Solutions <sup>™</sup> www.centekeng.com           63-2 North Branford Road         P: (203) 488-0580           Branford, CT 06405         F: (203) 488-8587	Location:		Fairfield, CT	
	Rev. 1: 5/5/23		Prepared by: T	.J.L Checked by: C.F.C.
			000 110. 22010	
Ba	sic Components			
Heavy	Wind Pressure =	p:= 4.00⋅psf	(User Input NESC 2023	Figure 250-1 & Table 250-1)
Ba	asic Windspeed =	V := 110 mph	(User Input)	
Radial	l Ice Thickness =	Ir := 0.50·in	(User Input NESC 2023	Figure 250-1 & Table 250-1)
Rad	dial lceDensity=	Id := 56.0.pcf	(User Input)	
Factors for Extreme Wine	d Calculation			
Elevation of Top of MastAbo	ve Grade =	TME := 125 ft	(User Input)	
Multiplier Gust Resp	onse Factor =	m := 1.25	(User Input - Only for NES	C Extreme wind case)
		-	2	
		(TME)	9.5	
Velocity Pressur	re Coefficient =	$Kz := 2.01 \cdot \left( \frac{1}{900} \right)$	= 1.326	(NESC 2023 Table 250-2)
Turbulence Intens	sity Constant =	C <sub>exp</sub> ≔ 0.2		(NESC 2023 Table 250-3)
Integral Length Scale of Turbulence C	Constant =	L <sub>s</sub> := 220		(NESC 2023 Table 250-3)
F	ffective Height -	0.67 TME 9	0.75	(NESC 2023 Table 250 3)
E		$Z_{\rm S} \coloneqq 0.07 \cdot 1 \text{ ME} = 8$	3.75	(NESC 2023 Table 250-5)
		$\frac{1}{6}$		
Turbul	lence Intensity =	$I_{z} := C_{ovp} \cdot \left(\frac{33}{2}\right)^{\circ}$	= 0.171	(NESC 2023 Table 250-3)
	·	$z exp(z_s)$		. ,
		Γ 1	0.5 <sub>۲</sub>	
I	Response Term =	$B_t := \left  \frac{1}{\Gamma (\tau - \tau)} \right $	= 0.908	(NESC 2023 Table 250-3)
		1 + 0.56 -	s       _	
			s/]]	
		[1 + (4.61·I	B•)]	
Gust Re	esponse Factor =	Grf:= $\frac{1}{(1+6.1)}$	$\frac{-1}{1} = 0.84$	(NESC 2023 Table 250-3)
		$(1 + 0.1)^{-1}$	<u>z)</u>	
	Wind Pressure =	qz := 0.00256⋅Kz⋅V	2 ·Grf⋅psf = 34.5·psf	(NESC 2023 Section 250.C.1)
				. ,
NESC Extreme Ice w/ Wind	Components			
Heavy	Wind Pressure =	p <sub>ex</sub> ≔ 6.4 · psf	(User Input NESC 2023	Figure 250-3 & Table 250-4)
Radial	I Ice Thickness =	Ir <sub>ex</sub> := 0.75 in	(User Input NESC 2023	Figure 250-3)
	Shape Factors			
Shape Factor for Rour	nd Members =	Cd <sub>R</sub> ≔ 1.3	(User Input)	
Shape Factor for F	lat Members =	Cd <sub>F</sub> := 1.6	(User Input)	
Shape Factor for Coax Cables Attached to Outside c	ofPole =	Cd <sub>coax</sub> := 1.6	(User Input)	
<u>0</u>	verload Factors			
Overload Factors for	Wind Loads:			
NESC H	leavy Loading =	2.5	(User Input)	
NESC Extr	reme Loading =	1.0	(User Input)	
NESC Extreme Ice with Wir	nd Loading =	1.0	(User Input)	
Overload Factors for Ver	rticalLoads:			
NESC H	leavy Loading =	1.5	(User Input)	
NESC Extr	reme Loading =	1.0	(User Input)	
NESC Extreme Ice with Wir	nd Loading =	1.0	(User Input)	



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

(User Input)

(User Input)

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

### Development of Wind & Ice Load on Antennas

Antenna Data:
Antenna Model =

Antenna Shape =

Anterna Height =

Antenna Width =

Antenna Thickness =

Antenna Weight =

Number of Antennas =

Gravity Load (without ice)

Weight of All Antennas=

Gravity Load (ice only)

Volume of Each Antenna =

Volume of Ice on EachAntenna =

Weight of Ice on Each Antenna =

Weight of Ice on All Antennas =

Gravity Load (Extreme ice only)

Volume of Extreme Iceon Each Antenna =

Weight of Extreme Ice on Each Antenna =

#### Weight of Extreme Ice on All Antennas =

Wind Load (NESC Heavy)

SurfaceArea for One Antenna w/ Ice =

Antenna Projected Surface Area w/ ke =

TotalAntenna Wind Forcew/Ice =

Wind Load (NESC Extreme)

SurfaceArea for One Antenna =

Antenna Projected Surface Area =

TotalAnten na Wind Force=

Wind Load (NESC Extreme Ice w/ Wind)

Surface Area for One Antenna w/ Extreme Ice =

Antenna Projected Surface Area w/ Extreme Ice =

Total Anten na Wind Forcew/Extreme lce =

(AT&T) CCITPA65-BU4D Flat

Lant := 48·in Want := 20.7 · in (User Input) Tant := 7.7 · in (User Input) WT<sub>ant</sub> := 60·lb (User Input)  $N_{ant} = 3$ (User Input)

## Wt<sub>ant1</sub> := WT<sub>ant</sub> N<sub>ant</sub> = 180lb

 $V_{ant} := L_{ant} W_{ant} T_{ant} = 7651 \cdot in^3$ 

 $V_{ice} \coloneqq (L_{ant} + 2 \cdot Ir)(W_{ant} + 2 \cdot Ir)(T_{ant} + 2 \cdot Ir) - V_{ant} = 1600 \cdot in^{3}$ 

 $W_{ICEant} := V_{ice} \cdot Id = 52Ib$ 

 $Wt_{ice.ant1} := W_{ICEant} \cdot N_{ant} = 156 lb$ 

$$V_{ice.ex} := (L_{ant} + 2 \cdot Ir_{ex})(W_{ant} + 2 \cdot Ir_{ex})(T_{ant} + 2 \cdot Ir_{ex}) - V_{ant} = 2459 \cdot in^3$$

W<sub>ICE.exant</sub> := V<sub>ice.ex</sub>·Id = 80lb

Wtice.ex.ant1 := WICE.exant Nant = 239lb

 $SA_{ICEant} := (L_{ant} + 2 \cdot Ir) \cdot (W_{ant} + 2 \cdot Ir) = 7.4 \text{ ft}^2$ A<sub>ICEant</sub> := SA<sub>ICEant</sub> N<sub>ant</sub> = 22.2 ft<sup>2</sup>  $Fi_{ant1} := p \cdot Cd_F \cdot A_{ICEant} = 142Ib$ 

 $SA_{ant} := L_{ant} W_{ant} = 6.9 ft^2$  $A_{ant} := SA_{ant} \cdot N_{ant} = 20.7 \text{ ft}^2$  $F_{ant1} := qz \cdot Cd_F \cdot A_{ant} \cdot m = 1428 lb$ 

 $SA_{ICE.exant} := (L_{ant} + 2 \cdot Ir_{ex}) \cdot (W_{ant} + 2 \cdot Ir_{ex}) = 7.6 \text{ ft}^2$  $A_{ICE.exant} := SA_{ICE.exant} \cdot N_{ant} = 22.9 \text{ft}^2$ Fiex.ant1 := pex·CdF·AICE.exant = 234lb



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

### Development of Wind & Ice Load on Antennas

Antenna Model = Antenna Shape =

Anterna Height=

Antenna Width =

Antenna Thickness =

Antenna Weight =

Number of Antennas =

Gravity Load (without ice)

Weight of All Antennas=

Gravity Load (ice only)

Volume of Each Antenna =

Volume of Ice on EachAntenna =

Weight of Ice on EachAntenna =

Weight of Ice on All Antennas =

### Gravity Load (Extreme ice only)

Volume of Extreme Iceon Each Antenna =

Weight of Extreme Ice on Each Antenna =

Weight of Extreme Ice on All Antennas =

## Wind Load (NESC Heavy)

SurfaceArea for One Antenna w/ Ice =

Antenna Projected Surface Area w/ lce =

Total Antenna Wind Forcew/lce =

Wind Load (NESC Extreme)

SurfaceArea for One Antenna =

Antenna Projected Surface Area =

TotalAnten na Wind Force =

Wind Load (NESC Extreme Ice w/ Wind)

Surface Area for One Antenna w/ Extreme Ice =

Antenna Projected Surface Area w/ Extreme Ice =

Total Anten na Wind Forcew/Extreme lce =

### (AT&T)

Commscope TMAT 192123B68-31

Flat	(User Input)
L <sub>ant</sub> ≔ 9.37⋅in	(User Input)
W <sub>ant</sub> := 11.142⋅in	(User Input)
T <sub>ant</sub> := 3.819 ·in	(User Input)
WT <sub>ant</sub> := 21·lb	(User Input)
N <sub>ant</sub> := 6	(User Input)

## $Wt_{ant2} := WT_{ant} N_{ant} = 126Ib$

$$V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 399 \cdot in^3$$

$$V_{ice} := (L_{ant} + 2 \cdot Ir)(W_{ant} + 2 \cdot Ir)(T_{ant} + 2 \cdot Ir) - V_{ant} = 208 \cdot In^3$$

 $W_{ICEant} := V_{ice} \cdot Id = 7Ib$ 

 $Wt_{ice.ant2} := W_{ICEant} \cdot N_{ant} = 40 \text{ lb}$ 

$$V_{ice.ex} := (L_{ant} + 2 \cdot Ir_{ex})(W_{ant} + 2 \cdot Ir_{ex})(T_{ant} + 2 \cdot Ir_{ex}) - V_{ant} = 332 \cdot in^3$$

 $W_{ICE.exant} := V_{ice.ex} \cdot Id = 111b$  $W_{ice.ex.ant2} := W_{ICE.exant} \cdot N_{ant} = 651b$ 

 $SA_{ICEant} := (L_{ant} + 2 \cdot Ir) \cdot (W_{ant} + 2 \cdot Ir) = 0.9 \text{ ft}^{2}$  $A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 5.2 \text{ ft}^{2}$  $Fi_{ant2} := p \cdot Cd_{F} \cdot A_{ICEant} = 34 \text{ lb}$ 

 $SA_{ant} := L_{ant} W_{ant} = 0.7 \text{ ft}^2$   $A_{ant} := SA_{ant} N_{ant} = 4.4 \text{ ft}^2$  $F_{ant2} := qz \cdot CdF \cdot A_{ant} \cdot m = 300 \text{ lb}$ 

$$\begin{split} & \mathsf{SA}_{\mathsf{ICE.exant}} \coloneqq \left(\mathsf{L}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) \cdot \left(\mathsf{W}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) = 1 \mathsf{ft}^2 \\ & \mathsf{A}_{\mathsf{ICE.exant}} \coloneqq \mathsf{SA}_{\mathsf{ICE.exant}} \cdot \mathsf{N}_{\mathsf{ant}} = 5.7 \, \mathsf{ft}^2 \\ & \mathsf{Fi}_{\mathsf{ex.ant2}} \coloneqq \mathsf{p}_{\mathsf{ex}} \cdot \mathsf{Cd}_{\mathsf{F}} \cdot \mathsf{A}_{\mathsf{ICE.exant}} = 59 \mathsf{lb} \end{split}$$

NESC Load Calculations.xmcd



Location:

Rev. 1: 5/5/23

## Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

### Development of Wind & Ice Load on Mounts

Mount Data:	(AT&T)		
Mount Type:	SitePro RMQLP-4120-H10		
Mount EPA (no ice) =	EPA := 28.15.ft <sup>2</sup>	(User Input from SitePro Document)	
Mount EPA (0.5" ice) =	$EPA_{ice} \coloneqq 34.10 \cdot ft^2$	(User Input from SitePro Document)	
Mount EPA (0.75" ice) =	$EPA_{ice.ex} \coloneqq 37.10 \cdot ft^2$	(User Input from SitePro Document/Interpolation)	
Weight (no ice) =	W := 3265·lb	(User Input from SitePro Document)	
Weight (0.5" ice) =	W <sub>ice</sub> := 3657·lb	(User Input from SitePro Document)	
Weight (0.75" ice) =	$W_{ice.ex} := 3920 \cdot lb$	(User Input from SitePro Document/Interpolation)	
Weight 0.5" ice on Antenna Pipes =	$Wap_{ice} := \left[ \left( 3.375 \right)^2 - (2.3)^2 \right]$	$(75)^{2} \cdot 120 \cdot 12 \cdot 12 \cdot 13 \cdot \frac{\pi}{4} \cdot (1d) = 211 \cdot 1b$	
Weight 0.75" ice on Antenna Pipes =	$Wap_{ice.ex} := \left[ \left[ (3.875)^2 - ($	$2.375)^{2} \cdot 120 \cdot 12 \cdot 10^{3} \cdot \frac{\pi}{4} \cdot (Id) = 344 \cdot Ib$	
Total Pipe Length =	$TPL := 12 \cdot 10 \cdot ft = 120 ft$		
Total Antenna Length =	$TAL := 48 \cdot in \cdot 3 = 12 ft$		
Exposed Pipe Area =	ExPA := (TPL – TAL)2.375 · in = 21.375 ft <sup>2</sup>		
Exposed Pipe Area (0.5" lce) =	$ExPA_{ice} := (TPL - TAL)3.375 \cdot in = 30.375 ft^2$		
Exposed Pipe Area (0.75" lce) =	ExPA <sub>ice.ex</sub> := (TPL - TAL)	$3.875 \cdot \text{in} = 34.875 \text{ft}^2$	
Mount Projected SurfaceArea =	$CdAa := 1.3 \cdot ExPA + EPA =$	55.9ft <sup>2</sup>	
Mount Projected SurfaceArea w/Ice =	$CdAa_{ice} := 1.3 \cdot ExPA_{ice} + EPA_{ice} = 73.6 ft^2$		
Mount Projected SurfaceArea w/Extreme Ice =	CdAa <sub>ice.ex</sub> := 1.3.ExPA <sub>ice.e</sub>	$ex + EPA_{ice.ex} = 82.4 \text{ ft}^2$	

### Gravity Loads (without ice)

Weight of All Mounts =
Gravity Load (ice only)
Weight of Ice on All Mounts =
Gravity Load (extreme ice only)
Weight of Ice on All Mounts =
Wind Load (NESC Heavy)
Total Mount Wind Force w/ Ice =
Wind Load (NESC Extreme)
Total Mount Wind Force =
Wind Load (NESC Extreme Ice w/ Wind)
Total Mount Wind Force w/ Extreme Ice =

# $Wt_{mnt1} := W = 3265 lb$

Wt<sub>ice.mnt1</sub> := W<sub>ice</sub> - W + Wap<sub>ice</sub> = 603lb

Wt<sub>ice.ex.mnt1</sub> := W<sub>ice.ex</sub> - W + Wap<sub>ice.ex</sub> = 999lb

 $Fi_{mnt1} := p CdAa_{ice} = 294 Ib$ 

 $F_{mnt1} := qz \cdot CdAa \cdot m = 2412 lb$ 

 $Fi_{ex.mnt1} := p_{ex} \cdot CdAa_{ice.ex} = 528Ib$ 



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

#### Development of Wind & Ice Load on Antennas

Antenna Data	l,
Antenna Model =	

Antenna Shape =

Antenna Height =

Antenna Width =

Antenna Thickness =

Antenna Weight =

Number of Antennas =

Gravity Load (without ice)

Weight of All Antennas=

Gravity Load (ice only)

Volume of Each Antenna =

Volume of Ice on EachAntenna =

Weight of Ice on Each Antenna =

Weight of Ice on All Antennas =

#### Gravity Load (Extreme ice only)

Volume of Extreme Iceon Each Antenna =

Weight of Extreme Ice on Each Antenna =

Weight of Extreme Ice on All Antennas =

Wind Load (NESC Heavy)

SurfaceArea for One Antenna w/ Ice =

Antenna Projected Surface Area w/ lce =

Total Antenna Wind Forcew/lce =

Wind Load (NESC Extreme)

SurfaceArea for One Antenna =

Antenna Projected Surface Area =

TotalAnten na Wind Force=

Wind Load (NESC Extreme Ice w/ Wind)

Surface Area for One Antenna w/ Extreme Ice =

Antenna Projected Surface Area w/ Extreme Ice =

Total Anten na Wind Forcew/Extreme lce =

 $F_{ant3} := qz \cdot Cd_F \cdot A_{ant} \cdot m = 3309 lb$ 

 $SA_{ICE.exant} := \left(L_{ant} + 2 \cdot Ir_{ex}\right) \cdot \left(W_{ant} + 2 \cdot Ir_{ex}\right) = 17.2 ft^{2}$ A<sub>ICE.exant</sub> := SA<sub>ICE.exant</sub>·N<sub>ant</sub> = 51.7ft<sup>2</sup> Fiex.ant3 := pex·CdF·AICE.exant = 530lb

Flat (User Input) Lant := 95.9.in (User Input) Want := 24 · in (User Input) T<sub>ant</sub> := 8.5 · in (User Input) WTant := 150·lb (User Input)  $N_{ant} = 3$ (User Input)

## Wtant3 := WTant Nant = 450lb

(T-Mobile)

RFSAPXVAALL24 43

 $V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 19564 \cdot in^3$  $V_{ice} \coloneqq (L_{ant} + 2 \cdot Ir)(W_{ant} + 2 \cdot Ir)(T_{ant} + 2 \cdot Ir) - V_{ant} = 3450 \cdot in^{3}$ 

WICEant := Vice Id = 112lb

Wt<sub>ice.ant3</sub> := W<sub>ICEant</sub> N<sub>ant</sub> = 335lb

 $V_{ice.ex} \coloneqq (L_{ant} + 2 \cdot Ir_{ex})(W_{ant} + 2 \cdot Ir_{ex})(T_{ant} + 2 \cdot Ir_{ex}) - V_{ant} = 5273 \cdot in^{3}$ 

W<sub>ICE.exant</sub> := V<sub>ice.ex</sub>·Id = 171lb Wt<sub>ice.ex.ant3</sub> := W<sub>ICE.exant</sub>·N<sub>ant</sub> = 513lb

 $SA_{ICEant} := (L_{ant} + 2 \cdot Ir) \cdot (W_{ant} + 2 \cdot Ir) = 16.8 ft^2$  $A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 50.5 \text{ft}^2$ Fiant3 := p·Cd<sub>F</sub>·A<sub>ICEant</sub> = 323lb

 $SA_{ant} := L_{ant} W_{ant} = 16 ft^2$  $A_{ant} := SA_{ant} \cdot N_{ant} = 47.9 \text{ ft}^2$ 



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

### Development of Wind & Ice Load on Antennas

Antenna Data:	
Antenna Model =	

Antenna Shape = Ante ma Height = Antenna Width = Antenna Thickness = Antenna Weight = Number of Antennas = (T-Mbbile)

Flat(User Input) $L_{ant} \coloneqq 55.9 \cdot in$ (User Input) $W_{ant} \coloneqq 13 \cdot in$ (User Input) $T_{ant} \coloneqq 3.15 \cdot in$ (User Input) $WT_{ant} \coloneqq 45 \cdot lb$ (User Input)Number 12(User Input)	RFSAPX16DWV-16DWVS	
Lant := 55.9·in       (User Input)         Want := 13·in       (User Input)         Tant := 3.15·in       (User Input)         WTant := 45·lb       (User Input)	Flat	(User Input)
Want ≔ 13·in       (User Input)         Tant ≔ 3.15·in       (User Input)         WTant ≔ 45·lb       (User Input)         Number 2       (User Input)	L <sub>ant</sub> ≔ 55.9⋅in	(User Input)
$T_{ant} := 3.15 \cdot in$ (User Input) $WT_{ant} := 45 \cdot lb$ (User Input) $N_{ant} := 2$ (User Input)	W <sub>ant</sub> := 13⋅in	(User Input)
WT <sub>ant</sub> := 45·lb (User Input)	T <sub>ant</sub> := 3.15⋅in	(User Input)
N 2 (Liser loput)	WT <sub>ant</sub> := 45·lb	(User Input)
Nant = 5 (Ose input)	N <sub>ant</sub> := 3	(User Input)

Gravity Load (without ice)

Weight of All Antennas=

## Gravity Load (ice only)

Volume of Each Antenna =

Volume of Ice on EachAntenna =

Weight of Ice on EachAntenna =

Weight of Ice on All Antennas =

### Gravity Load (Extreme ice only)

Volume of Extreme Iceon Each Antenna =

Weight of Extreme Ice on Each Antenna =

### Weight of Extreme Ice on All Antennas =

Wind Load (NESC Heavy)

SurfaceArea for One Antenna w/ Ice =

Antenna Projected Surface Area w/ ke =

TotalAntennaWindForcew/lce=

Wind Load (NESC Extreme)

SurfaceArea for One Antenna =

Antenna Projected Surface Area =

TotalAnten na Wind Force=

Wind Load (NESC Extreme Ice w/ Wind)

Surface Area for One Antenna w/ Extreme Ice =

Antenna Projected Surface Area w/ Extreme Ice =

#### Total Anten na Wind Forcew/Extreme lce =

$$\begin{split} & \mathsf{V}_{ant} \coloneqq \mathsf{L}_{ant} \cdot \mathsf{W}_{ant} \cdot \mathsf{T}_{ant} = 2289 \cdot \mathsf{in}^3 \\ & \mathsf{V}_{ice} \coloneqq \big(\mathsf{L}_{ant} + 2 \cdot \mathsf{Ir}\big) \big(\mathsf{W}_{ant} + 2 \cdot \mathsf{Ir}\big) \big(\mathsf{T}_{ant} + 2 \cdot \mathsf{Ir}\big) - \mathsf{V}_{ant} = 1017 \cdot \mathsf{in}^3 \end{split}$$

 $W_{ICEant} := V_{ice} \cdot Id = 33 Ib$ 

Wt<sub>ant4</sub> := WT<sub>ant</sub> N<sub>ant</sub> = 135lb

Wt<sub>ice.ant4</sub> := W<sub>ICEant</sub>·N<sub>ant</sub> = 99lb

 $\mathsf{V}_{ice.ex} := \left(\mathsf{L}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) \left(\mathsf{W}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) \left(\mathsf{T}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) - \mathsf{V}_{ant} = 1581 \cdot \mathsf{in}^3$ 

 $W_{ICE.exant} := V_{ice.ex} \cdot Id = 51Ib$ 

Wt<sub>ice.ex.ant4</sub> := W<sub>ICE.exant</sub>·N<sub>ant</sub> = 154lb

 $\begin{aligned} & \mathsf{SA}_{\mathsf{ICEant}} \coloneqq \left(\mathsf{L}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}\right) \cdot \left(\mathsf{W}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}\right) = 5.5 \, \mathsf{ft}^2 \\ & \mathsf{A}_{\mathsf{ICEant}} \coloneqq \mathsf{SA}_{\mathsf{ICEant}} \cdot \mathsf{N}_{\mathsf{ant}} = 16.6 \, \mathsf{ft}^2 \\ & \mathsf{Fi}_{\mathsf{ant4}} \coloneqq \mathsf{p} \cdot \mathsf{Cd}_{\mathsf{F}} \cdot \mathsf{A}_{\mathsf{ICEant}} = 106 \, \mathsf{lb} \end{aligned}$ 

 $SA_{ant} \coloneqq L_{ant} W_{ant} = 5ft^2$  $A_{ant} \coloneqq SA_{ant} N_{ant} = 15.1ft^2$  $F_{ant4} \coloneqq qz Cd_F A_{ant} m = 1045lb$ 

$$\begin{split} &\mathsf{SA}_{\mathsf{ICE.exant}} \coloneqq \left(\mathsf{L}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) \cdot \left(\mathsf{W}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) = 5.8\,\mathsf{ft}^2 \\ &\mathsf{A}_{\mathsf{ICE.exant}} \coloneqq \mathsf{SA}_{\mathsf{ICE.exant}} \cdot \mathsf{N}_{\mathsf{ant}} = 17.3\,\mathsf{ft}^2 \\ &\mathsf{Fi}_{\mathsf{ex.ant4}} \coloneqq \mathsf{p}_{\mathsf{ex}} \cdot \mathsf{Cd}_{\mathsf{F}} \cdot \mathsf{A}_{\mathsf{ICE.exant}} = 178\mathsf{lb} \end{split}$$



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

### Development of Wind & Ice Load on Antennas

Antenna Data:
Antenna Model =

Antenna Shape = Anterna Height = Antenna Width = Antenna Thickness = Antenna Weight = Number of Antennas = (T-Mobile)

CommscopeATSBT-TOP-MF-4G		
Flat	(User Input)	
L <sub>ant</sub> := 5.63⋅in	(User Input)	
W <sub>ant</sub> := 3.701 · in	(User Input)	
T <sub>ant</sub> := 1.969 ⋅in	(User Input)	
WT <sub>ant</sub> := 2·lb	(User Input)	
N <sub>ant</sub> := 6	(User Input)	

# Wt<sub>ant5</sub> := WT<sub>ant</sub>·N<sub>ant</sub> = 12lb

$$V_{ant} := L_{ant} W_{ant} T_{ant} = 41 in^3$$

 $V_{ice} \coloneqq (L_{ant} + 2 \cdot Ir)(W_{ant} + 2 \cdot Ir)(T_{ant} + 2 \cdot Ir) - V_{ant} = 52 \cdot in^{3}$ 

 $W_{ICEant} := V_{ice} \cdot Id = 2Ib$ 

Wt<sub>ice.ant5</sub> := W<sub>ICEant</sub>·N<sub>ant</sub> = 10lb

 $\mathsf{V}_{ice.ex} \coloneqq \left(\mathsf{L}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) \left(\mathsf{W}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) \left(\mathsf{T}_{ant} + 2 \cdot \mathsf{Ir}_{ex}\right) - \mathsf{V}_{ant} = 88 \cdot \mathsf{in}^3$ 

 $W_{ICE.exant} := V_{ice.ex} \cdot Id = 3Ib$ 

 $Wt_{ice.ex.ant5} := W_{ICE.exant} \cdot N_{ant} = 17Ib$ 

$$\begin{split} & \mathsf{SA}_{\mathsf{ICEant}} \coloneqq \left(\mathsf{L}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}\right) \cdot \left(\mathsf{W}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}\right) = 0.2 \, \mathsf{ft}^2 \\ & \mathsf{A}_{\mathsf{ICEant}} \coloneqq \mathsf{SA}_{\mathsf{ICEant}} \cdot \mathsf{N}_{\mathsf{ant}} = 1.3 \, \mathsf{ft}^2 \\ & \mathsf{Fi}_{\mathsf{ant5}} \coloneqq \mathsf{p} \cdot \mathsf{Cd}_{\mathsf{F}} \cdot \mathsf{A}_{\mathsf{ICEant}} = \mathsf{8lb} \end{split}$$

 $SA_{ant} \coloneqq L_{ant} W_{ant} = 0.1 \text{ ft}^2$  $A_{ant} \coloneqq SA_{ant} N_{ant} = 0.9 \text{ ft}^2$  $F_{ant5} \coloneqq qz Cd_{F} A_{ant} = 60 \text{ lb}$ 

 $\begin{aligned} & \mathsf{SA}_{\mathsf{ICE},\mathsf{exant}} \coloneqq \left(\mathsf{L}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) \cdot \left(\mathsf{W}_{\mathsf{ant}} + 2 \cdot \mathsf{Ir}_{\mathsf{ex}}\right) = 0.3 \, \mathsf{ft}^2 \\ & \mathsf{A}_{\mathsf{ICE},\mathsf{exant}} \coloneqq \mathsf{SA}_{\mathsf{ICE},\mathsf{exant}} \cdot \mathsf{N}_{\mathsf{ant}} = 1.5 \, \mathsf{ft}^2 \\ & \mathsf{Fi}_{\mathsf{ex},\mathsf{ant5}} \coloneqq \mathsf{p}_{\mathsf{ex}} \cdot \mathsf{Cd}_{\mathsf{F}} \cdot \mathsf{A}_{\mathsf{ICE},\mathsf{exant}} = 16 \, \mathsf{Ib} \end{aligned}$ 

Gravity Load (without ice) Weight of All Antenna s=

Gravity Load (ice only)

Volume of Each Antenna =

Volume of Ice on EachAntenna =

Weight of Ice on EachAntenna =

Weight of Ice on All Anten nas =

### Gravity Load (Extreme ice only)

Volume of Extreme Iceon Each Antenna =

Weight of Extreme Ice on Each Antenna =

### Weight of Extreme Ice on All Antennas =

Wind Load (NESC Heavy)

SurfaceArea for One Antenna w/ Ice =

Antenna Projected Surface Area w/ ke =

Total Antenna Wind Forcew/lce =

Wind Load (NESC Extreme)

SurfaceArea for One Antenna =

Antenna Projected Surface Area =

Total Anten na Wind Force=

Wind Load (NESC Extreme Ice w/ Wind)

Surface Area for One Antenna w/ Extreme Ice =

Antenna Projected Surface Area w/ Extreme Ice =

Total Anten na Wind Forcew/Extreme lce =



Location:

Rev. 1: 5/5/23

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

## Development of Wind & Ice Load on Mounts

Mount Data:	(T-Mbbile)	
Mount Type:	SitePro RMQLP-496-HK	
Mount EPA (no ice) =	$EPA := 26.29 \cdot ft^2$	(User Input from SitePro Document)
Mount EPA (0.5" ice) =	$EPA_{ice} := 32.25 \cdot ft^2$	(User Input from SitePro Document)
Mount EPA (0.75" ice) =	$EPA_{ice.ex} \coloneqq 35.12 \cdot ft^2$	(User Input from SitePro Document/Interpolation)
Weight (no ice) =	$W \coloneqq 2130 {\cdot} \text{lb}$	(User Input from SitePro Document)
Weight (0.5" ice) =	W <sub>ice</sub> := 2580·lb	(User Input from SitePro Document)
Weight (0.75" ice) =	W <sub>ice.ex</sub> := 2873·lb	(User Input from SitePro Document/Interpolation)
Weight 0.5" ice on Antenna Pipes =	Wap <sub>ice</sub> :=[[(3.375) <sup>2</sup> - (	$(2.375)^2 \cdot 96 \cdot 12 \cdot \ln^3 \cdot \frac{\pi}{4} \cdot (Id) = 169 \cdot Ib$
Weight 0.75" ice on Antenna Pipes =	Wap <sub>ice.ex</sub> := [[(3.875) <sup>2</sup>	$-(2.375)^2 \cdot 96.12 \cdot in^3 \cdot \frac{\pi}{4} \cdot (Id) = 275 \cdot Ib$
Total Pipe Length =	$TPL := 12 \cdot 8 \cdot ft = 96  ft$	
Total Anten na Leng h =	$TAL := 95.9 \cdot in \cdot 3 + 55.9 \cdot ir$	n·3 = 37.95 ft
Exposed Pipe Area =	ExPA := (TPL – TAL)2.3	$75 \cdot in = 11.489 ft^2$
Exposed Pipe Area (0.5" lce) =	ExPA <sub>ice</sub> := (TPL - TAL);	$3.375 \cdot in = 16.327 ft^2$
Exposed Pipe Area (0.75' lce) =	ExPA <sub>ice.ex</sub> ≔ (TPL – TA	AL)3.875 in = 18.745 ft <sup>2</sup>
Mount Projected SurfaceArea =	CdAa:= 1.3·ExPA + EPA	$A = 41.2 \text{ft}^2$
Mount Projected Surface Area w/ Ice =	CdAa <sub>ice</sub> := 1.3 ExPA <sub>ice</sub>	+ $EPA_{ice} = 53.5 ft^2$
Mount Projected SurfaceArea w/ Extreme Ice =	CdAa <sub>ice.ex</sub> := 1.3⋅ExPA <sub>ic</sub>	$ce.ex + EPA_{ice.ex} = 59.5 ft^2$

Gravity Loads (without ice)
Weight of All Mounts =
Gravity Load (ice only)
Weight of Ice on All Mounts =
Gravity Load (extreme ice only)
Weight of Ice on All Mounts =
Wind Load (NESC Heavy)
Total Mount Wind Force w/ Ice =
Wind Load (NESC Extreme)
Total Mount Wind Force =
Wind Load (NESC Extreme Ice w/ Wind)
Total Mount Wind Force w/ Extreme Ice =

Wt<sub>mnt2</sub> := W = 2130 lb

 $Wt_{ice.mnt2} \coloneqq W_{ice} - W + Wap_{ice} = 619lb$ 

 $Wt_{ice.ex.mnt2} := W_{ice.ex} - W + Wap_{ice.ex} = 1018 lb$ 

 $Fi_{mnt2} := p \cdot CdAa_{ice} = 214 Ib$ 

F<sub>mnt2</sub> := qz·CdAa·m = 1778lb

 $Fi_{ex.mnt2} := p_{ex} \cdot CdAa_{ice.ex} = 381lb$ 



Location:

Loads - Structure #19725

Fairfield, CT

Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03

Rev. 1: 5/5/23

# **Total Equipment Loads:**

# AT&T Loads:

NESC Heavy Wind Vertical =

$Wt_{tot} := (Wt_{ant1} + Wt_{ant2} + Wt_{mnt1}) = 3571 lb$			
$Wt_{ice.tot} := (Wt_{ice.ant1} + Wt_{ice.ant2} + Wt_{ice.mnt1}) = 799lb$			
	$(Wt_{tot} + Wt_{ice.tot}) \cdot 1.5 = 6555 lb$		
NESC Heavy Wind Trasnsverse =	$(Fi_{ant1} + Fi_{ant2} + Fi_{mnt1}) \cdot 2.5 = 1174 \text{ lb}$		
NESC Extreme Wind Vertical =	$(Wt_{ant1} + Wt_{ant2} + Wt_{mnt1}) = 3571 \text{ lb}$		
NESC Extreme Wind Trasnsverse =	(Fant1 + Fant2 + Fmnt1) = 4141 lb		
NESC Extreme Ice w/Wind Vertical =			
$Wt_{ice.ex.tot} := (Wt_{ice.ex.ant1} + Wt_{ice.ex.ant2} + Wt_{ice.ex.mnt1}) = 1302 lb$			
	$(Wt_{tot} + Wt_{ice.ex.tot}) = 4873  lb$		
NESC Extreme Ice w/Wind Trasps Jerse =	(Fi <sub>ex.ant1</sub> + Fi <sub>ex.ant2</sub> + Fi <sub>ex.mnt1</sub> ) = 821lb		

T-Mobile Loads:

NESC Heavy Wind Vertical =

 $Wt_{tot} \coloneqq (Wt_{ant3} + Wt_{ant4} + Wt_{ant5} + Wt_{mnt2}) = 2727 \text{ lb}$   $Wt_{ice.tot} \coloneqq (Wt_{ice.ant3} + Wt_{ice.ant4} + Wt_{ice.ant5} + Wt_{ice.mnt2}) = 1063 \text{ lb}$   $(Wt_{tot} + Wt_{ice.tot}) \cdot 1.5 = 5685 \text{ lb}$ 

 NESC Heavy Wind Trasnsverse =
  $(Fi_{ant3} + Fi_{ant4} + Fi_{ant5} + Fi_{mnt2}) \cdot 2.5 = 1629 \text{ lb}$  

 NESC Extreme Wind Vertical =
  $(Wt_{ant3} + Wt_{ant4} + Wt_{ant5} + Wt_{mnt2}) = 2727 \text{ lb}$  

 NESC Extreme Wind Trasnsverse =
  $(F_{ant3} + F_{ant4} + F_{ant5} + F_{mnt2}) = 6191 \text{ lb}$  

 NESC Extreme lce w/Wind Vertical =
  $(Wt_{ice.ex.ant3} + Wt_{ice.ex.ant4} + Wt_{ice.ex.ant5} + Wt_{ice.ex.mnt2}) = 1701 \text{ lb}$ 
 $(Wt_{tot} + Wt_{ice.ex.tot}) = 4428 \text{ lb}$ 

NESC Extreme Ice w/Wind Trasnsverse =

 $(Fi_{ex.ant3} + Fi_{ex.ant4} + Fi_{ex.ant5} + Fi_{ex.mnt2}) = 1104 Ib$ 

	Subject:			Coax Cable on	Pole #19725
Centered on Solutions <sup>10</sup> www.centekeng.com 63-2 North Branford Road P: (203) 488-0580 Paraford C1 06405 F: (203) 488-8587	Location:			Fairfield, CT	
(1, (20) 400 30)	Rev. 0: 4/6/23			Prepared by: T. Job No. 22073	J.L Checked by: C.F.C. 03
Coax Cable	on CL&P Pole				
Coax	ial Cable Span	Coax <sub>Span</sub> :=	= 10ft	(User Input)	
HeawyV	/ind Pressure =	p:= 4⋅psf		(User Input)	
Radial I	ce Thickness =	Ir := 0.5∙in		(User Input)	
Radi	al Ice Density=	ld:= 56 · pcf		(User Input)	
Extreme Ice w/Wi	nd Pressure =	p <sub>ex</sub> ≔ 6.4·ps	sf	(User Input)	
Extreme Radial los	e Thickness =	Ir <sub>ex</sub> := 0.75·i	in	(User Input)	
В	asic Windspeed =	V := 110	mph	(User Input)	
Height to Top of CoaxAb	oove Grade =	TC := 125	ft	(User Input)	
Multiplier Gust Res	oonse Factor =	m := 1.00	(User	Input - Only for NESC	Extreme wind case)
Velocity Pressu	re Coefficient =	Kz := 2.01 ·	$\left(\frac{0.67TC}{900}\right)^{\frac{2}{9.5}}$	= 1.219	(NESC 2023 Table 250-2)
Turbulence Inten	sity Constant =	C <sub>exp</sub> := 0.2			(NESC 2023 Table 250-3)
Integral Length Scale of Turbulence	Constant =	L <sub>s</sub> := 220			(NESC 2023 Table 250-3)
	Effective Height =	z <sub>s</sub> ≔ 0.67·T0	C = 83.75 1		(NESC 2023 Table 250-3)
Turbu	lence Intensity =	$I_z := C_{exp} \cdot \left( - \frac{1}{2} \right)$	$\frac{33}{z_s}\right)^{\overline{6}} = 0.171$	I	(NESC 2023 Table 250-3)
	Response Term =	$B_t := \left[ \frac{1}{1 + (1 + 1)^2} \right]$	$\frac{1}{\left(0.56 \cdot \frac{z_s}{L_s}\right)} \right]^{0.5}$	5 = 0.908	(NESC 2023 Table 250-3)
Gust R	esponse Factor =	$Grf := \left[1 + \left(1 + \left$	$\frac{4.61 \cdot I_{z} \cdot B_{t})}{+ 6.1 \cdot I_{z}} =$	0.84	(NESC 2023 Table 250-3)
	Wind Pressure =	qz:= 0.0025	$6 \cdot Kz \cdot V^2 \cdot Grf =$	31.7 psf	(NESC 2023 Section 250.C.1)
Dia	neter of Coax Cable =	D <sub>coa</sub>	<sub>ix</sub> ≔ 1.98 in	(User Input)	
V	/eight of Coax Cable =	W <sub>co</sub>	ax≔ 1.04·plf	(User Input)	
Nu	mber of Coax Cables =	N <sub>coa</sub>	ux ≔ 36	(User Input)	(12)AT&T CoaxCables (24) T-Mobile Coax Cables
Number of Proj	ected Coax Cables =	NP <sub>cc</sub>	<sub>Dax</sub> ≔ 4	(User Input)	{1-5/8 size conservatively used for all}

CENTEK engineering Subject:	Coax Cable on Pole #19725
Centered on Solutions <sup>®</sup> www.centekeng.com 63-2 North Branford Road P: (203) 488-0580 Exclusion:	Fairfield, CT
Rev. 0: 4/6/23	Prepared by: T.J.L Checked by: C.F.C. Job No. 22073.03
Shape Factor =	Cd <sub>coax</sub> := 1.6 (User Input)
Overload Factor for NESC Heavy Wind Transverse Load =	OF <sub>HWT</sub> := 2.5 (User Input)
Overload Factor for NESC Heavy Wind Vertical Load =	OF <sub>HWV</sub> := 1.5 (User Input)
Overload Factor for NESC Extreme Wind TransverseLoad =	OF <sub>EWT</sub> := 1.0 (User Input)
Overload Factor for NESC Extreme Wind Vertical Load =	OF <sub>EWV</sub> ≔ 1.0 (User Input)
Overload Factor for NESC Extreme Ice w/Wind Transverse Load =	OF <sub>EIT</sub> := 1.0 (User Input)
Overload Factor for NESC Extreme Ice w/ Wind Vertical Load =	OF <sub>EIV</sub> ≔ 1.0 (User Input)
Wind Area without loe =	$A := \left(NP_{coax} \cdot D_{coax}\right) = 7.92 \cdot in$
Wind Area with Ice =	$A_{ice} := \left(NP_{coax} \cdot D_{coax} + 2 \cdot Ir\right) = 8.92 \cdot in$
Wind Area with Extreme Ice =	$A_{\text{ice.ex}} \coloneqq \left(NP_{\text{coax}} \cdot D_{\text{coax}} + 2 \cdot Ir_{\text{ex}}\right) = 9.42 \cdot in$
IceAreaper Liner Ft =	$\operatorname{Ai}_{\operatorname{coax}} \coloneqq \frac{\pi}{4} \cdot \left[ \left( D_{\operatorname{coax}} + 2 \cdot Ir \right)^2 - D_{\operatorname{coax}}^2 \right] = 0.027  \mathrm{ft}^2$
Weight of Ice on All Coax Cables =	$W_{ice} := Ai_{coax} \cdot Id \cdot N_{coax} = 54.538 \cdot plf$
Extreme IceArea per Liner Ft=	$\operatorname{Ai}_{\operatorname{coax.ex}} \coloneqq \frac{\pi}{4} \cdot \left[ \left( D_{\operatorname{coax}} + 2 \cdot Ir_{ex} \right)^2 - D_{\operatorname{coax}}^2 \right] = 0.045  \mathrm{ft}^2$
Weight of Extreme Ice on All Coax Cables =	$W_{ice.ex} := Ai_{coax.ex} \cdot Id \cdot N_{coax} = 90.054 \cdot plf$
Heavy Wind Vertical Load =	
$Heavy_WInd_{Vert} \coloneqq \boxed{\left(N_{coax} \cdot W_{coax} + W_{ice}\right) \cdot Coax_{Span} \cdot OF_{HWV}}$	
Heavy Wind Transverse Load =	
$Heavy\_Wind_{Trans} := \overbrace{\left( p \cdot A_{ice} \cdot Cd_{coax} \cdot Coax_{Span} \cdot OF_{HWT} \right)}$	Heavy_WInd <sub>Vert</sub> = 1380 lb Heavy_Wind <sub>Trans</sub> = 119lb
Extreme Wind Vertical Load =	
$Extreme\_Wind_{Vert} \coloneqq \overbrace{(N_{coax} \cdot W_{coax} \cdot Coax_{Span} \cdot OF_{EWV})}^{Vert}$	
Extreme Wind Transverse Load =	
$Extreme\_Wind_{Trans} \coloneqq \boxed{\left[ \left( qz \cdot psf \cdot A \cdot Cd_{coax} \right) \cdot Coax_{Span} \cdot OF_{EWT} \right]}$	Extreme_Wind <sub>Vert</sub> = 374lb Extreme_Wind <sub>Trans</sub> = 335lb
Extreme Ice w/Wind Vertical Load =	
$Extreme\_lce_{Vert} \coloneqq \boxed{\left[ \left( N_{coax} \cdot W_{coax} + W_{ice.ex} \right) \cdot Coax_{Span} \cdot OF_{EIV} \right]}$	
Extreme Ice w/Wind Transverse Load =	
$Extreme\_lce_{Trans} \coloneqq \overline{\left(P_{ex} \cdot A_{ice.ex} \cdot Cd_{coax} \cdot Coax_{Span} \cdot OF_{EIT}\right)}$	Extreme_Ice <sub>Vert</sub> = 1275Ib Extreme_Ice <sub>Trans</sub> = 80Ib
Coax Cable on Pole.xmcd.xmcd	Page 5.2-2

Centek Engineering Inc, Project: "039-23-23422-125FT" PLS-POLE Version 17.50, 10:13:14 AM Friday, May 05, 2023 Undeformed geometry displayed

Z

X

¥



1

Centered on Solutions* 63-2 North Branford Road	www.centekeng.com P: (203) 488-0580	Location:		Fairfield, CT
Branford, CT 06405	F: (203) 488-8587	Rev. 1: 5/5/23		Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03
	Anchor Bolt A	nalysis:		
	Inp	out Data:		
		Bolt Force:		
	Maximum Tensile	Force =	T <sub>Max</sub> := 124 kips	(User Input from PLS-Pole)
	Maximum Shear Force a	Base =	V <sub>base</sub> := 54⋅kips	(User Input from PLS-Pole)
	Anchor	Bolt Data:		
	UseASTMA615	Grade 75		
	Number of Anc h	or Bolts=	N := 24	(User Input)
	Bolt "Column" D	istance =	l := 3.0·in	(User Input)
	Bolt Ultimate S	rength =	F <sub>u</sub> ≔ 100 ksi	(User Input)
	Bolt Yeild	Strength=	F <sub>y</sub> ≔ 75·ksi	(User Input)
	Bolt	Modulus=	E := 29000 ksi	(User Input)
	Diameter of Ancho	or Bolts =	D:= 2.25 in	(User Input)
	Threads	per Inch =	n:= 4.5	(User Input)
	Anchor Bolt A	nalysis:		
	StressAre	a ofBolt =	$A_{S} \coloneqq \frac{\pi}{4} \cdot \left(D - \frac{0.9743 \cdot in}{n}\right)^2$	$^{2}$ = 3.248·in <sup>2</sup>
r	Vaximum Shear Force pe	er Bolt =	$V_{Max} \coloneqq \frac{V_{base}}{N} = 2.3 \times 10$	) <sup>3</sup> lbf
	Shear Stress	per Bolt =	$f_V := \frac{V_{Max}}{A_s} = 692.8  psi$	
	Tensile Stress Pe	rmitted =	$F_t := 0.75 \cdot F_u = 75 \cdot ksi$	
	Shear Stress Pe	ermitted =	F <sub>v</sub> := 0.35F <sub>u</sub> = 35·ksi	

Permitted Axial Tensile Stress in Conjuction with Shear =

Bolt Tension % of Capacity =

Condition1 =

$$\begin{split} & \frac{T_{Max}}{F_{tv}\cdot A_s} = 50.92 \cdot \% \\ & \text{Condition1:= if} \Biggl( \frac{T_{Max}}{F_{tv}\cdot A_s} \leq 1.00, \text{"OK"}, \text{"Overstressed"} \Biggr) \end{split}$$

 $F_{tv} := F_t \sqrt{1 - \left(\frac{f_v}{F_v}\right)^2} = 74.99 \cdot ksi$ 

Anchor Bolt Analysis Pole #19725

Condition1 = "OK"



Location:

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

# Rev. 1: 5/5/23

# Flange Bolt and Flange Plate Analysis:

Input Data:	Flange @ 115-ft	
Tower Reactions:		
Overturning Moment =	OM := 41·ft·kips	(User Input)
Shear Force =	Shear := 7·kips	(User Input)
Axial Force =	Axial := 3 kips	(User Input)
Flange Bolt Data: UseAST MA325		
Number of Flange Bolts =	N := 8	(User Input)
Diameter of Bolt Circle =	$D_{bc} := 20 \cdot in$	(User Input)
Bolt Minimum Tensile Strength =	F <sub>ub</sub> ≔ 120 ksi	(User Input)
Bolt Modulus =	E := 29000 ksi	(User Input)
Diameter of Flange Bolts =	D := 1.00·in	(User Input)
Threads per Inch =	n:= 8	(User Input)
Flange Plate Data:		

UseASTMA871 Grade 65		
Plate Yield Strength =	Fy <sub>bp</sub> := 65·ksi	(User Input)
Flange Plate Thickness =	t <sub>bp</sub> ≔ 1.in	(User Input)
Flange Plate Diameter =	D <sub>bp</sub> := 22.75 ⋅ in	(User Input)
Outer Pole Diameter =	D <sub>pole</sub> := 16.67 ⋅ in	(User Input)



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Geometric Layout Data:

Distance from Bolts to Centroid of Pole:

Radius of Bolt Circle =:

$$R_{bc} \coloneqq \frac{D_{bc}}{2} = 10 \cdot in$$

i:= 1.. N

d<sub>i</sub>:

Distance to Bolts =

$$\begin{array}{ll} \underset{k=}{\overset{i}{\mid}} \theta \leftarrow 2 \cdot \pi \cdot \left(\frac{i}{N}\right) & d_{1} = 7.07 \cdot \text{in} & d_{7} = -7.07 \cdot \text{in} \\ d \leftarrow R_{bc} \cdot \sin(\theta) & d_{2} = 10.00 \cdot \text{in} & d_{8} = -0.00 \cdot \text{in} \\ d_{3} = 7.07 \cdot \text{in} & d_{9} = \bullet \cdot \text{in} \\ d_{4} = 0.00 \cdot \text{in} & d_{10} = \bullet \cdot \text{in} \\ d_{5} = -7.07 \cdot \text{in} & d_{11} = \bullet \cdot \text{in} \\ d_{6} = -10.00 \cdot \text{in} & d_{12} = \bullet \cdot \text{in} \end{array}$$

Critical Distances For Bending in Plate:

Outer Pole Radius =

$$\mathsf{R}_{\mathsf{pole}} \coloneqq \frac{\mathsf{D}_{\mathsf{pole}}}{2} = 8.335 \cdot \mathsf{in}$$

MomentArms of Bolts about Neutral Axis =

$$MA_{1} = 0.00 \cdot in \qquad MA_{7} = 0.00 \cdot in$$

$$MA_{2} = 1.66 \cdot in \qquad MA_{8} = 0.00 \cdot in$$

$$MA_{3} = 0.00 \cdot in \qquad MA_{9} = \bullet \cdot in$$

$$MA_{4} = 0.00 \cdot in \qquad MA_{10} = \bullet \cdot in$$

$$MA_{5} = 0.00 \cdot in \qquad MA_{11} = \bullet \cdot in$$

$$MA_{6} = 0.00 \cdot in \qquad MA_{12} = \bullet \cdot in$$

$$\mathsf{B}_{\text{eff}} \coloneqq .8{\cdot}2{\cdot}\sqrt{\left(\frac{\mathsf{D}_{bp}}{2}\right)^2 - \left(\frac{\mathsf{D}_{pole}}{2}\right)^2} = 12.4{\cdot}\text{in}$$

 $MA_{i} := if(d_{i} \ge R_{pole}, d_{i} - R_{pole}, 0in)$ 

Effective Width of Flangeplate for Bending =



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Flange Bolt Analysis:

### Calculated Flange Bolt Properties:

Polar Moment of Inertia =

GrossArea of Bolt=

NetArea of Bdt =

Check Flange Bolts:

Maximum Shear Stress =

Permitted Shear Stress =

Maximum Tensile Stress =

Condition1 =

$$V_{Max} := \frac{Shear}{N \cdot A_g} = 1.1 \cdot ksi$$
$$F_{v} := (0.35 \cdot F_{ub}) = 42 \cdot ksi$$

 $A_n := \frac{\pi}{4} \cdot \left( D - \frac{0.9743 \cdot in}{n} \right)^2 = 0.606 \cdot in^2$ 

 $I_p := \sum_i \left( \overset{d}{_i} \right)^2 = 400 \cdot \text{in}^2$ 

 $A_g \coloneqq \frac{\pi}{4} \cdot D^2 = 0.785 \cdot in^2$ 

 $\begin{array}{l} \text{Condition1} \coloneqq \text{if} \Big( \mathsf{V}_{Max} \leq \mathsf{F}_{v}, "\mathsf{OK"}, "\mathsf{Overstressed"} \Big) \\ \hline \\ \begin{array}{l} \mathsf{V}_{Max} \\ \hline \\ \mathsf{F}_{v} \\ \end{array} = 2.65 \cdot \% \end{array}$ 

$$\mathsf{T}_{Max} \coloneqq \frac{\left(\mathsf{OM} \cdot \frac{\mathsf{R}_{bc}}{\mathsf{I}_p} - \frac{\mathsf{Axial}}{\mathsf{N}}\right)}{\mathsf{A}_n} = 19.7 \cdot \mathsf{ksi}$$

Permitted Tensile Stress =

Condition2 =

 $F_t := (0.75 \cdot F_{ub}) = 90 \cdot ksi$ 

Condition2:= if  $\left( \frac{T_{Max}}{F_{t}} \le 1.00, "OK", "Overstressed" \right)$ 

 $\frac{\mathsf{T}_{Max}}{\mathsf{F}_{t}} = 21.87 \cdot \%$ 

Condition2 = "OK"

$$\begin{split} F_{t.v} &\coloneqq F_t \cdot \sqrt{1 - \left(\frac{V_{Max}}{F_v}\right)^2} = 90 \cdot ksi \\ \text{Condition3} &\coloneqq \text{if} \left(\frac{T_{Max}}{F_{t.v}} \le 1.00, "OK", "Overstressed"\right) \qquad \qquad \frac{T_{Max}}{F_{t.v}} = 21.88 \cdot \% \\ \text{Condition3} &= "OK" \end{split}$$

Condition3 =

Flange Bolts and Flange Plate.xmcd.xmcd



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Flange Plate Analysis:

Force from Bolts =  $C_1 := \frac{OM \cdot d_1}{I_p} + \frac{Axial}{N}$   $C_1 = 9.1 \cdot kips$   $C_7 = -8.3 \cdot kips$   $C_2 = 12.7 \cdot kips$   $C_8 = 0.4 \cdot kips$   $C_3 = 9.1 \cdot kips$   $C_10 = \bullet \cdot kips$   $C_4 = 0.4 \cdot kips$   $C_{10} = \bullet \cdot kips$   $C_5 = -8.3 \cdot kips$   $C_{11} = \bullet \cdot kips$  $C_6 = -11.9 \cdot kips$   $C_{12} = \bullet \cdot kips$ 

Maximum Bending Stress in Plate =

$$f_{bp} \coloneqq \sum_{i} \frac{6 \cdot C_{i} \cdot MA_{i}}{\left(B_{eff} t_{bp}^{2}\right)} = 10.2 \cdot ksi$$

Allowable Bending Stress in Plate =

 $F_{bp} := 0.9 \cdot Fy_{bp} = 58.5 \cdot ksi$ 

Plate Bending Stress % of Capacity =

$$\frac{^{1}\text{bp}}{\text{F}_{\text{bp}}} = 17.5.\%$$

Condition1 =

Condition 1 := if 
$$\left( \frac{f_{bp}}{F_{bp}} < 1.00, "Ok", "Overstressed" \right)$$



Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

(User Input)

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

# Location:

Rev. 1: 5/5/23

# Flange Bolt and Flange Plate Analysis:

Bolt

Input Data:	Flange @ 100-ft	
Tower Reactions:		
Overturning Moment =	OM := 203 ft kips	(User Input)
Shear Force =	Shear := 13·kips	(User Input)
Axial Force =	Axial := 7.5 kips	(User Input)
Flange Bolt Data:		
UseASTMA325		
Number of Flange Bolts =	N := 12	(User Input)
Diameter of Bolt Circle =	D <sub>bc</sub> := 26.75 · in	(User Input)
Minimum Tensile Strength =	F <sub>ub</sub> := 120 ksi	(User Input)
Bolt Modulus =	E := 29000·ksi	(User Input)
Diameter of Flange Bolts =	D := 1.00 · in	(User Input)
Threads per Inch =	n:= 8	(User Input)
Flange Plate Data:		
UseASTMA871 Grade 65		
Plate Yield Strength =	Fy <sub>bp</sub> ≔ 65 ksi	(User Input)
Flange Plate Thickness =	t <sub>bp</sub> := 1.25 in	(User Input)
Flange Plate Diameter =	D <sub>bp</sub> := 29.5 in	(User Input)
Outer Pole Diameter =	$D_{rate} := 22.17 \cdot in$	(User Input)

 $D_{\text{pole}} := 22.17 \cdot \text{in}$ 



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Geometric Layout Data:

## Distance from Bolts to Centroid of Pole:

Radius of Bolt Circle =:

$$R_{bc} \coloneqq \frac{D_{bc}}{2} = 13.375 \text{ in}$$

i:= 1.. N

Distance to Bolts =

$$\begin{array}{lll} d_{i} \coloneqq & \left| \begin{array}{l} \theta \leftarrow 2 \cdot \pi \cdot \left( \frac{i}{N} \right) & d_{1} = 6.69 \cdot in & d_{7} = -6.69 \cdot in \\ d \leftarrow R_{bc} \cdot sin(\theta) & d_{2} = 11.58 \cdot in & d_{8} = -11.58 \cdot in \\ d_{3} = 13.38 \cdot in & d_{9} = -13.38 \cdot in \\ d_{4} = 11.58 \cdot in & d_{10} = -11.58 \cdot in \\ d_{5} = 6.69 \cdot in & d_{11} = -6.69 \cdot in \\ d_{6} = 0.00 \cdot in & d_{12} = -0.00 \cdot in \end{array}$$

Critical Distances For Bending in Plate:

Outer Pole Radius =

$$\mathsf{R}_{\mathsf{pole}} \coloneqq \frac{\mathsf{D}_{\mathsf{pole}}}{2} = 11.085 \cdot \mathsf{in}$$

MomentArms of Bolts about Neutral Axis =

Effective Width of Flangeplate for Bending =

$$\mathsf{MA}_i := \mathsf{if} \Big( \mathsf{d}_i \geq \mathsf{R}_{pole}, \mathsf{d}_i - \mathsf{R}_{pole}, \mathsf{0in} \Big)$$

$MA_1 = 0.00 \cdot in$	$MA_7 = 0.00 \cdot in$
$MA_2 = 0.50 \cdot in$	$\text{MA}_8 = 0.00 \cdot \text{in}$
$MA_3 = 2.29 \cdot in$	$MA_9 = 0.00 \cdot in$
$MA_4 = 0.50 \cdot in$	$MA_{10} = 0.00 \cdot in$
$MA_5 = 0.00 \cdot in$	$MA_{11} = 0.00 \cdot in$
MA <sub>6</sub> = 0.00∙in	MA <sub>12</sub> = 0.00∙in

$$\mathsf{B}_{eff} \coloneqq .8{\cdot}2{\cdot}\sqrt{\left(\frac{\mathsf{D}_{bp}}{2}\right)^2 - \left(\frac{\mathsf{D}_{pole}}{2}\right)^2} = 15.6{\cdot}\text{in}$$

Flange Bolts and Flange Plate.xmcd.xmcd



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

 $\frac{V_{Max}}{F_{V}} = 3.28.\%$ 

# Flange Bolt Analysis:

### Calculated Flange Bolt Properties:

Polar Moment of Inertia =

GrossArea of Bolt=

$$A_{g} \coloneqq \frac{\pi}{4} \cdot D^{2} = 0.785 \cdot in^{2}$$
$$\pi \left( 0.9743 \cdot in \right)^{2}$$

 $I_p := \sum_i (d_i)^2 = 1.073 \times 10^3 \cdot in^2$ 

 $A_n := \frac{\pi}{4} \cdot \left( D - \frac{0.9743 \cdot in}{n} \right)^2 = 0.606 \cdot in^2$ 

Check Flange Bolts:

NetArea of Bdt =

Maximum Shear Stress =

Permitted Shear Stress =

Condition1 =

$$\begin{split} V_{Max} &\coloneqq \frac{Shear}{N \cdot A_g} = 1.4 \cdot ksi \\ F_v &\coloneqq \left( 0.35 \cdot F_{ub} \right) = 42 \cdot ksi \end{split}$$

 $Condition1 := if \left( V_{Max} \leq F_{v}, "OK", "Overstressed" \right)$ Condition1 = "OK"

$$T_{Max} := \frac{\left(OM \cdot \frac{R_{bc}}{I_{p}} - \frac{Axial}{N}\right)}{A_{n}} = 49.1 \cdot ksi$$

Maximum Tensile Stress =

Permitted Tensile Stress =

Condition2 =

 $F_t := (0.75 \cdot F_{ub}) = 90 \cdot ksi$  $\frac{\mathsf{T}_{Max}}{\mathsf{F}_{\mathsf{t}}} = 54.53 \cdot \%$ Condition2 := if  $\left(\frac{T_{Max}}{F_{t}} \le 1.00, "OK", "Overstressed"\right)$ 

Condition2 = "OK"

$$\begin{split} F_{t.v} &\coloneqq F_t \sqrt{1 - \left(\frac{V_{Max}}{F_v}\right)^2} = 90 \cdot ksi \\ \text{Condition3} &\coloneqq \text{if} \left(\frac{T_{Max}}{F_{t.v}} \leq 1.00, \text{"OK"}, \text{"Overstressed"}\right) \qquad \qquad \frac{T_{Max}}{F_{t.v}} = 54.56 \cdot \% \\ \text{Condition3} &= \text{"OK"} \end{split}$$

Permitted Tensile Stress with Shear =

Condition3 =



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Flange Plate Analysis:

Force from Bolts =

$C_i := \frac{OM \cdot d_i}{I} + \frac{Axial}{N}$		
'p 'Y	C <sub>1</sub> = 15.8⋅kips	C <sub>7</sub> = −14.6 kips
	C <sub>2</sub> = 26.9⋅kips	$C_8^{} = -25.7 \cdot kips$
	C <sub>3</sub> = 31.0⋅kips	$C_9 = -29.7 \cdot kips$
	C <sub>4</sub> = 26.9⋅kips	$C_{10} = -25.7 \cdot kips$
	C <sub>5</sub> = 15.8⋅kips	$C_{11} = -14.6$ ·kips
	$C_6 = 0.6 \cdot kips$	$C_{12}^{} = 0.6 \cdot kips$

Maximum Bending Stress in Plate =

$$f_{bp} := \sum_{i} \frac{6 \cdot C_{i} \cdot MA_{i}}{\left(B_{eff} t_{bp}^{2}\right)} = 24.1 \cdot ksi$$

Allowable Bending Stress in Plate =

 $\mathsf{F}_{bp} \coloneqq 0.9 \cdot \mathsf{Fy}_{bp} = 58.5 \cdot ksi$ 

Plate Bending Stress % of Capacity =

$$\frac{{}^{I}bp}{F_{bp}} = 41.2.\%$$

•

Condition1 =

Condition 1 := if 
$$\left( \frac{f_{bp}}{F_{bp}} < 1.00, "Ok", "Overstressed" \right)$$

Condition1 = "Ok"



Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

Location:

Rev. 1: 5/5/23

# Flange Bolt and Flange Plate Analysis:

Input Data:	Flange@53-ft	
Tower Reactions:		
Overturning Moment =	OM := 1712·ft·kips	(User Input)
Shear Force =	Shear := 46·kips	(User Input)
Axial Force =	Axial := 38 kips	(User Input)
<u>Flange Bolt Data:</u> UseASTMA325		
Number of Flange Bolts =	N := 40	(User Input)
Diameter of Bolt Circle =	D <sub>bc</sub> := 45.5·in	(User Input)
Bolt Minimum Tensile Strength =	F <sub>ub</sub> := 120⋅ksi	(User Input)
Bolt Modulus =	E := 29000 ksi	(User Input)
Diameter of Flange Bolts =	D := 1.25 in	(User Input)
Threads per Inch =	n:= 7	(User Input)
<u>Flange Plate Data:</u> UseAST MA588 Grade 50		
Plate Yield Strength =	Fy <sub>bp</sub> := 50⋅ksi	(User Input)
Flange Plate Thickness =	t <sub>bp</sub> := 2.5 · in	(User Input)
Flange Plate Diameter =	D <sub>bp</sub> := 48.875·in	(User Input)
Outer Pole Diameter =	$D_{pole} := 39.92 \cdot in$	(User Input)



Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

B8-0580 Location:

Rev. 1: 5/5/23

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

# Geometric Layout Data:

Distance from Bolts to Centroid of Pole:

Radius of Bolt Circle =:

$$R_{bc} \coloneqq \frac{D_{bc}}{2} = 22.75 \cdot in$$

i := 1.. N

Distance to Bolts =

$$\begin{array}{lll} \mathsf{d}_{i} \coloneqq & \left| \begin{array}{c} \theta \leftarrow 2 \cdot \pi \cdot \left( \frac{i}{\mathsf{N}} \right) & \mathsf{d}_{1} = 3.56 \cdot \mathsf{in} & \mathsf{d}_{7} = 20.27 \cdot \mathsf{in} \\ \mathsf{d} \leftarrow \mathsf{R}_{\mathsf{bc}} \cdot \mathsf{sin}(\theta) & \mathsf{d}_{2} = 7.03 \cdot \mathsf{in} & \mathsf{d}_{8} = 21.64 \cdot \mathsf{in} \\ \mathsf{d}_{3} = 10.33 \cdot \mathsf{in} & \mathsf{d}_{9} = 22.47 \cdot \mathsf{in} \\ \mathsf{d}_{4} = 13.37 \cdot \mathsf{in} & \mathsf{d}_{10} = 22.75 \cdot \mathsf{in} \\ \mathsf{d}_{5} = 16.09 \cdot \mathsf{in} & \mathsf{d}_{11} = 22.47 \cdot \mathsf{in} \\ \mathsf{d}_{6} = 18.41 \cdot \mathsf{in} & \mathsf{d}_{12} = 21.64 \cdot \mathsf{in} \end{array}$$

Critical Distances For Bending in Plate:

 $R_{pole} := \frac{D_{pole}}{2} = 19.96 \cdot \text{in}$ 

MomentArms of Bolts about Neutral Axis =

$$\mathsf{MA}_{i} \coloneqq \mathsf{if} \Big( \mathsf{d}_{i} \geq \mathsf{R}_{pole}, \mathsf{d}_{i} - \mathsf{R}_{pole}, \mathsf{0in} \Big)$$

$MA_1 = 0.00 \cdot in$	$MA_7 = 0.31 \cdot in$
$\text{MA}_2 = 0.00 \cdot \text{in}$	$MA_8 = 1.68 \cdot in$
$\text{MA}_3 = 0.00 \cdot \text{in}$	$MA_9 = 2.51 \cdot in$
$\text{MA}_4 = 0.00 \cdot \text{in}$	MA <sub>10</sub> = 2.79∙in
$\text{MA}_5 = 0.00 \cdot \text{in}$	MA <sub>11</sub> = 2.51∙in
$MA_6 = 0.00 \cdot in$	MA <sub>12</sub> = 1.68∙in

$$\mathsf{B}_{eff} \coloneqq .8{\cdot}2{\cdot}\sqrt{\left(\frac{\mathsf{D}_{bp}}{2}\right)^2 - \left(\frac{\mathsf{D}_{pole}}{2}\right)^2} = 22.6{\cdot}\text{in}$$

Effective Width of Flangeplate for Bending =



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

 $\frac{V_{Max}}{F_{V}} = 2.23.\%$ 

## Flange Bolt Analysis:

Calculated Flange Bolt Properties:

Polar Moment of Inertia =

$$I_{p} := \sum_{i} (d_{i})^{2} = 1.035 \times 10^{4} \cdot \text{in}^{2}$$
$$A_{g} := \frac{\pi}{4} \cdot D^{2} = 1.227 \cdot \text{in}^{2}$$
$$A_{n} := \frac{\pi}{4} \cdot \left(D - \frac{0.9743 \cdot \text{in}}{n}\right)^{2} = 0.969 \cdot \text{in}^{2}$$

GrossArea of Bolt=

NetArea of Bdt =

### Check Flange Bolts:

Maximum Shear Stress =

Permitted Shear Stress =

Condition1 =

$$V_{Max} := \frac{Shear}{N \cdot A_g} = 0.9 \cdot ksi$$
$$F_{v_s} := (0.35 \cdot F_{v_s}) = 42 \cdot ksi$$

$$F_{v} := (0.35 \cdot F_{ub}) = 42 \cdot ksi$$

Condition 1 := if  $(V_{Max} \le F_V, "OK", "Overstressed")$ Condition1 = "OK"

$$T_{Max} := \frac{\left(OM \cdot \frac{R_{bc}}{I_p} - \frac{Axial}{N}\right)}{A_n} = 45.6 \cdot ksi$$

Maximum Tensile Stress =

Permitted Tensile Stress =

Condition2 =

$$Condition 2 := if \left( \frac{T_{Max}}{F_t} \le 1.00, "OK", "Overstressed" \right) \qquad \qquad \frac{T_{Max}}{F_t} = 50.68 \cdot \%$$

Condition2 = "OK"

 $F_t := (0.75 \cdot F_{ub}) = 90 \cdot ksi$ 

Condition3 =

$$\begin{split} F_{t,v} &\coloneqq F_t \cdot \sqrt{1 - \left(\frac{V_{Max}}{F_v}\right)^2} = 90 \cdot ksi \\ \text{Condition3} &\coloneqq \text{if} \left(\frac{T_{Max}}{F_{t,v}} \leq 1.00, \text{"OK"}, \text{"Overstressed"}\right) \\ \hline \qquad \frac{T_{Max}}{F_{t,v}} = 50.69 \cdot \% \\ \text{Condition3} &= \text{"OK"} \end{split}$$



Location:

Rev. 1: 5/5/23

Flange Bolts and Flangeplate Analysis

Structure 19725 Fairfield, CT

Prepared by: T.J.L. Checked by: C.F.C. Job No. 22073.03

## Flange Plate Analysis:

Force from Bolts =

$C_i := \frac{OM \cdot d_i}{1} + \frac{Axial}{1}$		
I I <sub>p</sub> N	$C_1 = 8.0 \cdot kips$	$C_7 = 41.2$ kips
	C <sub>2</sub> = 14.9⋅kips	$C_8^{} = 43.9 \cdot kips$
	C <sub>3</sub> = 21.4⋅kips	$C_9 = 45.5 \cdot kips$
	C <sub>4</sub> = 27.5⋅kips	C <sub>10</sub> = 46.1⋅kips
	C <sub>5</sub> = 32.9⋅kips	C <sub>11</sub> = 45.5 kips
	C <sub>6</sub> = 37.5 kips	C <sub>12</sub> = 43.9 kips
	5	

Maximum Bending Stress in Plate =

$$f_{bp} := \sum_{i} \frac{6 \cdot C_{i} \cdot MA_{i}}{\left(B_{eff} t_{bp}^{2}\right)} = 22.6 \cdot ksi$$

Allowable Bending Stress in Plate =

 $F_{bp} := 0.9 \cdot Fy_{bp} = 45 \cdot ksi$ 

Plate Bending Stress % of Capacity =

$$\frac{f_{bp}}{F_{bp}} = 50.1.\%$$

Condition1 =

Condition 1 := if 
$$\left( \frac{f_{bp}}{F_{bp}} < 1.00, "Ok", "Overstressed" \right)$$

Condition1 = "Ok"

RAN Template:A&L Template:67D94B\_Flagpole Outdoor67D94B\_1DP+1QP+1OP

CT11317B\_L600\_5

					Print Name: Standard PORs: L600_L600 Coverage
Section 1 - Site Information					
Site ID: CT11317B Status: Final Version: 5 Project Type: L600 Approved: 03/13/2023 6:23:55 Approved By: Farhan.Badar@T Last Modified: 03/13/2023 6:23 Last Modified By: Farhan.Bada	Site I Site 0 Site 7 Plan PM Mark T-Mobile.com Vend 1:55 PM Land ar@T-Mobile.com	Site Name: Fairfield/MP/X44&X42 Site Class: Utility Lattice Tower Site Type: Structure Non Building Plan Year: Market: CONNECTICUT CT Vendor: Ericsson Landlord: Northeast Utilities		Latitude: 41.209987 Longitude: -73.2615 Address: 280 Moreh City, State: Fairfield, Region: NORTHEAS	39 ouse Drive (Tower 876 Line 1730) CT ST
RAN Template:     67D94B_Flagpole Outdoor       AL Template:     67D94B_1DP+1QP+1OP					
Sector Count: 3	Antenna Count: 6	Coax Line Cou	nt: 22	TMA Count: 0	RRU Count: 0
Section 2 - Existing Template Images					

704Bu.png

CT11317B\_L600\_5\_2023-03-14



794A Outdoor.png



Section 3 - Proposed Template Images



67D94BR\_1QP+10P.JPG



Section 4 - Siteplan Images

----- This section is intentionally blank. -----

A&L Template: 67D94B\_1DP+1QP+1OP

Print Name: Standard PORs: L600\_L600 Coverage

Section 5 - RAN Equipment

Existing RAN Equipment			
Template: 794B GSM Shutdown Outdoor			
Enclosure	1	2	
Enclosure Type	Ground Mount (Ericsson)	(RBS 6102)	
Radio	RRUS11 B12 (x 3)	RUS01 B2 (x3)       RUS01 B2 (x3)       RUS01 B4 (x3)         L1900       G1900       L2100         RUS01 B4 (x3)       U2100 (DECOMMISSIONED))	
Baseband		BB 6630 L700 L1900 L2100	

Proposed RAN Equipment				
Template: 67D94B_Flagpole Outdoor				
Enclosure	1	2		
Enclosure Type	Ground Mount (Ericsson)	RBS 6102		
Radio	Radio 4480 B71+B85 (x 3) L600 L700	RUS01 B2 (x 6)         RUS01 B4 (x 6)           L1900         L2100		
Baseband		BB 6630         DUG20         DUW30         RP 6651           L1900         L2100         L600         L700		
RAN Scope of Work:				
Install (1) BB6648 for L6/ L7/5G N600. Remove existing TMA Existing: (18) Coaxial Lines Add (6) Coaxial Lines for new total of (24).				

67D94B\_Flagpole Outdoor

CT11317B\_L600\_5

Print Name: Standard PORs: L600\_L600 Coverage

# Section 6 - A&L Equipment

Existing Template: 794B\_1HP U19 shutdown Proposed Template: 67D94B\_1DP+1QP+1OP

Sector 1 (Existing) view from behind							
Coverage Type	A - Outdoor Macro						
Antenna	1		2				
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (Quad))		(Andrew - LNX-6515DS-A1M (Dual)				
Azimuth	60		60				
M. Tilt	0		0				
Height (ft)	95		95				
Ports	P1	P2	P3				
Active Tech	(L1900) (G1900)	(L2100)	L700				
Dark Tech							
Restricted Tech							
Decomm. Tech		U2100					
E. Tilt	2		2				
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)				
TMAs	Generic Twin Style 1A - PCS (At Cabinet)	Generic Twin Style 1B - AWS (At Cabinet)					
Diplexer / Combiners							
Radio							
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							
Ground TMA's							
Sector 1 (Proposed) view from behind							
--------------------------------------	--	-----------------------------	--	--	----	----	--
Coverage Type	A - Outdoor Macro						
Antenna	1	2					
Antenna Model	RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	(RFS - APXVAALL24_43-U-NA20 (Octo))				
Azimuth	60		60				
M. Tilt							
Height (ft)	95		95				
Ports	P1	P2	P3	P4	P5	P6	
Active Tech	(G1900) (L1900) (N1900)	(L2100)	L700 L600 N600	L700 L600 N600			
Dark Tech							
Restricted Tech							
Decomm. Tech							
E. Tilt							
Cables	1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. <b>(x2)</b>	1-1/4" Coax - 126 ft. ( <b>x2</b> )			
TMAs							
Diplexer / Combiners							
Radio							
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							

https://rfeapp-rfds-ui-prd01.geo.mesh.t-mobile.com/datasheet/printout/e199ec3f-ba3d-4b09-8a5a-db44b84a55ec/6b957f19-68f5-4104-94f7-64aad66f...9/13

Sector 2 (Existing) view from behind							
Coverage Type	A - Outdoor Macro						
Antenna	1		2				
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	Andrew - LNX-6515DS-A1M (Dual)				
Azimuth	180		180				
M. Tilt	0		0				
Height (ft)	95		95				
Ports	P1	P2	P3				
Active Tech	G1900 (L1900)	L2100	L700				
Dark Tech							
Restricted Tech							
Decomm. Tech		(U2100)					
E. Tilt	2		2				
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)				
TMAs	Generic Twin Style 1A - PCS (At Cabinet)	Generic Twin Style 1B - AWS (At Cabinet)					
Diplexer / Combiners							
Radio							
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							

	Sector 2 (Proposed) view from behind						
Coverage Type	(A - Outdoor Macro)						
Antenna	1	2					
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	RFS - APXVAALL	24_43-U-NA20 (Oct	o))		
Azimuth	180		180				
M. Tilt							
Height (ft)	95		95				
Ports	P1	P2	P3	P4	P5	P6	
Active Tech	(G1900) (L1900) (N1900)	(L2100)	L700 L600 N600	L700 L600 N600			
Dark Tech							
Restricted Tech							
Decomm. Tech							
E. Tilt							
Cables	(1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft.			
TMAs							
Diplexer / Combiners							
Radio							
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							

Sector 3 (Existing) view from behind							
Coverage Type	A - Outdoor Macro						
Antenna	1		2				
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	Andrew - LNX-6515DS-A1M (Dual)				
Azimuth	300		300				
M. Tilt	0		0				
Height (ft)	95		95				
Ports	P1	P2	P3				
Active Tech	G1900 (L1900)	L2100	L700				
Dark Tech							
Restricted Tech							
Decomm. Tech		(U2100)					
E. Tilt	2		2				
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)				
TMAs	Generic Twin Style 1A - PCS (At Cabinet)	Generic Twin Style 1B - AWS (At Cabinet)					
Diplexer / Combiners							
Radio							
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							

Sector 3 (Proposed) view from behind							
Coverage Type	A - Outdoor Macro						
Antenna	1	1	2				
Antenna Model	RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	RFS - APXVAALL	24_43-U-NA20 (Octo	0)		
Azimuth	300		300				
M. Tilt							
Height (ft)	95		95				
Ports	P1	P2	P3	P4	P5	P6	
Active Tech	L1900 (N1900) (G1900)	(L2100)	L700 L600 N600	L700 L600 N600			
Dark Tech							
Restricted Tech							
Decomm. Tech							
E. Tilt							
Cables	(1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft.			
TMAs							
Diplexer / Combiners							
Radio							
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)				
Unconnected Equipment:							
Scope of Work:							



## Dual Slant Polarized Quad Band (8 Port) Antenna, 617-894/617-894/1695-2690/1695-2690MHz, 65deg, 16.2/16.1/18.9/18.7dBi, 2.4m (8ft), VET, RET, 2-12°/2°

#### **FEATURES / BENEFITS**

This antenna provides a 8 Port multi-band flexible platform for advanced use for flexible use in deployment scenarios for encompassing 600, 700, 800, AWS, PCS & BRS applications.

- 24 Inch Width For Easier Zoning
- Field Replaceable (Integrated) AISG RET platform for reduced environmental exposure and long lasting quality
- Superior elevation pattern performance across the entire electrical down tilt range
- Includes three AISG RET motors Includes 0.5m AISG jumper for optional daisy chain of two
- high band RET motors for one single AISG point of high band tilt control.
- Output Description (Contraction) Low band arrays driven by a single RET motor



#### **Technical Features**

Frequency Band	MHz	617-698	698-806	806-894	
Gain Typical	dBi	15.5	16.1	16.2	
Gain Over All Tilts	dBi	15.2 +/3	15.6 +/5	15.8 +/4	
Horizontal Beamwidth @3dB	Deg	65 +/-3	64 +/-2	62 +/-3	
Vertical Beamwidth @3dB	Deg	9.9 +/7	8.6 +/7	7.6 +/4	
Electrical Downtilt Range	Deg		2 to 12		
Upper Side Lobe Suppression Peak to +20	dB	15	14	14	
Front-to-Back, at +/-30°, Copolar	dB	25	25	29	
Cross Polar Discrimination (XPD) @ Boresight	dB	18	18	17	
Cross Polar Discrimination (XPD) @ +/-60	dB	5	5	6	
3rd Order PIM 2 x 43dBm	dBc		-153		
VSWR	-	1.5:1			
Cross Polar Isolation	dB	25			
Maximum Effective Power per Port	Watt	400			

#### LOW BAND LEFT ARRAY (617-894 MHZ) [R1]

APXVAALL24\_43-U-NA20

REV: C

www.rfsworld.com



## Dual Slant Polarized Quad Band (8 Port) Antenna, 617-894/617-894/1695-2690/1695-2690MHz, 65deg, 16.2/16.1/18.9/18.7dBi, 2.4m (8ft), VET, RET, 2-12°/2-12°/2-12°/2-12°

HIGH BAND RIGHT ARRAY (16	6 <mark>95-2690</mark>	MHZ) [Y2]				
Frequency Band	MHz	1695-1880	1850-1990	1920-2200	2200-2490	2490-2690
Gain Typical	dBi	17.7	18.1	18.7	18.5	18.0
Gain Over All Tilts	dBi	17.1 +/6	17.6 +/5	18 +/7	17.9 +/6	17.4 +/6
Horizontal Beamwidth @3dB	Deg	67 +/- 5	64 +/- 5	65 +/- 5	62 +/- 7	60 +/- 9
Vertical Beamwidth @3dB	Deg	5.7 +/5	5.2 +/3	4.7 +/6	4.2 +/3	4.2 +/3
Electrical Downtilt Range	Deg			2 to 12		
Upper Side Lobe Suppression Peak to +20	dB	15	15	14	14	13
Front-to-Back, at +/-30°, Copolar	dB	27	28	26	23	21
Cross Polar Discrimination (XPD) @ Boresight	dB	21	17	14	16	18
Cross Polar Discrimination (XPD) @ +/-60	dB	10	8	7	4	1
3rd Order PIM 2 x 43dBm	dBc			-153		
VSWR	-			1.5:1		
Cross Polar Isolation	dB	25				
Maximum Effective Power per Port	Watt			300		

#### **ELECTRICAL SPECIFICATIONS**

Impedance	Ohm	50.0
Polarization	Deg	±45°

#### MECHANICAL SPECIFICATIONS

Dimensions - H x W x D	mm (in)	2436 x 609 x 215 (95.9 x 24 x 8.5)
Weight (Antenna Only)	kg (lb)	55.7 (122.8)
Weight (Mounting Hardware only)	kg (lb)	12.3 (27.1)
Packing size- HxWxD	mm (in)	2565 x 735 x 390 (101 x 28.9 x 15.4)
Shipping Weight	kg (lb)	77.9 (171.7)
Connector type		8 x 4.3-10 female at bottom + 6 AISG connectors (3 male, 3 female)
Adjustment mechanism		Integrated RET solution AISG compliant (Field Replaceable) + Manual Override + External Tilt Indicator
Radome Material / Color		Fiber Glass / Light Grey RAL7035

#### **TESTING AND ENVIRONMENTAL**

Temperature Range	°C (°F)	-40 to 60 (-40 to 140 )
Grounding type		DC Grounded
Lightning protection		IEC 61000-4-5
Survival/Rated Wind Velocity	km/h	240 (150 )
Wind Load @Rated Wind Front	N	1428.0
Wind Load @Rated Wind Side	N	434.0
Wind Load @Rated Wind Rear	N	1544.0
Environmental		ETSI 300-019-2-4 Class 4.1E

#### APX16DWV-16DWVS-E-A20

Optimizer® Side-by-Side Dual Polarized Antenna, 1710-2200, 65deg, 18.4dBi, 1.4m, VET, 0-10deg RET

#### **Product Description**

A combination of two X-Polarized antennas in a single radome, this pair of variable tilt antennas provides exceptional suppression of all upper sidelobes at all downtilt angles. It also features a wide downtilt range. This antenna is optimized for performance across the entire frequency band (1710-2200 MHz). The antenna comes pre-connected with two antenna control units (ACU).

#### Features/Benefits

•Variable electrical downtilt - provides enhanced precision in controlling intercell interference. The tilt is infield adjustable 0-10 deg.

•High Suppression of all Upper Sidelobes (Typically <-20dB). •Gain tracking – difference between AWS UL (1710-1755 MHz) and DL (2110-2155 MHz) <1dB.

•Two X-Polarised panels in a single radome.

•Azimuth horizontal beamwidth difference <4deg between AWS UL (1710-1755 MHz) and DL (2110-2155 MHz).

•Low profile for low visual impact.

•Dual polarization; Broadband design.

•Includes (2) AISG 2.0 Compatible ACU-A20-N antenna control units.

#### **Technical Specifications**

Electrical Specifications	
Frequency Range, MHz	1710-2200
Horizontal Beamwidth, deg	65
Vertical Beamwidth, deg	5.9 to 7.7
Electrical Downtilt, deg	0-10
Gain, dBi (dBd)	18.4 (16.3)
1st Upper Sidelobe Suppression, dB	> 18 (typically > 20)
Upper Sidelobe Suppression, dB	> 18 all (typically > 20)
Front-To-Back Ratio, dB	>26 (typically 28)
Polarization	Dual pol +/-45°
VSWR	< 1.5:1
Isolation between Ports, dB	> 30
3rd Order IMP @ 2 x 43 dBm, dBc	> 150 (155 Typical)
Impedance, Ohms	50
Maximum Power Input, W	300
Lightning Protection	Direct Ground
Connector Type	(4) 7-16 Long Neck Female
Mechanical Specifications	
Dimensions - HxWxD, mm (in)	1420 x 331 x 80 (55.9 x 13 x 3.15)
Weight w/o Mtg Hardware, kg (lb)	18.5 (40.7)
Survival Wind Speed, km/h (mph)	200 (125)
Rated Wind Speed, km/h (mph)	160 (100)
Max Wind Loading Area, m <sup>2</sup> (ft <sup>2</sup> )	0.47 (5.03)
Front Thrust @ Rated Wind, N (lbf)	756 (170)
Maximum Thrust @ Rated Wind, N (lbf)	756 (170)
Wind Load - Side @ Rated Wind, N (lbf)	231 (52)
Wind Load - Rear @ Rated Wind, N (lbf)	408 (92)
Radome Material	Fiberglass
Radome Color	Light Grey RAL7035
Mounting Hardware Material	Diecasted Aluminum
Shipping Weight, kg (lb)	24.5 (53.9)
Packing Dimensions, HxWxD, mm (in)	1520 x 408 x 198 (59.8 x 16 x 7.8)



#### Vertical Pattern



Ordering Information

Mounting Hardware

APM40-2 + APM40-E2

**Horizontal Pattern** 



APX16DWV-16DWVS-E-A20

Please visit us on the internet at http://www.rfsworld.com/

## ATSBT-TOP-MF-4G



#### Top Smart Bias Tee

- Reduces cable and site lease costs by eliminating the need for AISG home run cables
- AISG 1.1 and 2.0 compliant
- Operates at 10-30 Vdc
- Weatherproof AISG connectors
- Intuitive schematics simplify and ensure proper installation
- Enhanced lightning protection plus grounding stud for additional surge protection
- 7-16 DIN female connector (ANT)
- 7-16 DIN male connector (BTS)

Product Classification	
Product Type	RET bias tee
General Specifications	
AISG Input Connector	8-pin DIN Female
Antenna Interface	7-16 DIN Female
Antenna Interface Signal	RF   dc Blocked
BTS Interface	7-16 DIN Male
BTS Interface Signal	AISG data   RF   dc
Color	Silver
EU Certification	CE
Grounding Lug Thread Size	M8
Smart Bias Tee Type	10-30 V Top
Dimensions	
Height	143 mm   5.63 in
Width	94 mm   3.701 in
Depth	50 mm   1.969 in
Electrical Specifications	
3rd Order IMD	-158 dBc
3rd Order IMD Test Method	Two +43 dBm carriers
Insertion Loss, typical	0.1 dB
Electromagnetic Compatibility (EMC)	CFR 47 Part 15, Subpart B, Class B   EN 55022, Class B   ICES-003 Issue 4 CAN

Page 1 of 4

©2022 CommScope, Inc. All rights reserved. All trademarks identified by ® or <sup>™</sup> are registered trademarks, respectively, of CommScope. All specifications are subject to change without notice. See www.commscope.com for the most current information. Revised: February 18, 2022



## ATSBT-TOP-MF-4G





Material Type

Aluminum

#### Environmental Specifications

**Operating Temperature** 

**Ingress Protection Test Method** 

-40 °C to +70 °C (-40 °F to +158 °F) IEC 60529:2001, IP66

#### Packaging and Weights

Weight, net

0.8 kg | 1.764 lb

#### Regulatory Compliance/Certifications

#### Agency

Classification

Page 3 of 4

©2022 CommScope, Inc. All rights reserved. All trademarks identified by ® or <sup>™</sup> are registered trademarks, respectively, of CommScope. All specifications are subject to change without notice. See www.commscope.com for the most current information. Revised: February 18, 2022





A **valmont V** COMPANY

1545 Pidco Drive Plymouth, IN 46563 Phone: 574.936.4221 Fax: 574.936.8925 Email: SP1Engineering@valmont.com www.sitepro1.com

June 15, 2020

#### Site Pro 1 / Valmont Mounting System:

Part Number	= RMQLP-xxx-HK / RMQLP-xxx + PRK-1245L + HRK14
Part Description	= 14' Low Pro-Platform with Reinforcement and Handrail System

#### Mount EPA (no antenna pipes, walkway included, (0.67\*EPA)):

EPA <sub>N</sub>	= 39.24(26.29) sq-Ft	EPA <sub>N (0.5" Ice)</sub>	= 48.14(32.25) sq-Ft	EPA <sub>N (1" Ice)</sub>	= 56.69(37.98) sq-Ft
EPA <sub>T</sub>	= 38.48(25.78) sq-Ft	EPA <sub>T</sub> (0.5" Ice)	= 47.60(31.89) sq-Ft	EPA <sub>T(1" Ice)</sub>	= 56.46(37.82) sq-Ft
Weight	= 2130 lb	Weight (0.5" Ice)	=2580 lb	Weight (1" Ice)	= 3165 lb

#### **Classification Rating:**

Heavy 10

#### **Design Standards**

ANSI/TIA-222-G-2012 ANSI/TIA-222-H-2018 ASCE 7-16 AT&T Mount Classification International Building Code 2018 TIA-5053

#### **Analysis and Modeling Technique**

An elastic, three-dimensional, frame, truss model was developed to examine the structural behavior of the mount. All orientations in the engineering model correspond with the assembly drawing constraints. The mount was analyzed with four (4) mounting locations (antenna, mount pipe, radio, dish, and any other appurtenance) evenly spaced across the face of the mount, with no vertical eccentricity. Wind directions considered were perpendicular (normal) to the face of the frame and at 30 degree increments up to 90 degrees (tangential) to the face of the frame. Wind, dead weight and ice weight on the mount was also included in the model.

#### **Modeling Software**

Autodesk Inventor RISA-3D ANSYS Workbench

New York 1-888-438-7761 Oregon 1-888-880-9191 Texas 1-888-809-5151 Florida 1-844-278-6371

## Exhibit E

**Mount Analysis** 



Centered on Solutions<sup>™</sup>

#### <u>Antenna Mount Analysis</u> <u>Report</u>

Site Ref: CT11317B

280 Morehouse Road Fairfield, CT

Centek Project No. 22073.03

Date: May 18, 2023

Max Stress Ratio = 45%



**Prepared for:** T-Mobile USA 35 Griffin Road Bloomfield, CT 06002 CENTEK Engineering, Inc. Mount Analysis T-Mobile Site Ref. ~ CT11317B Fairfield, CT May 18, 2023

### Table of Contents

#### SECTION 1 - REPORT

- ANTENNA AND APPURTENANCE SUMMARY
- STRUCTURE LOADING
- CONCLUSION

#### SECTION 2 - CALCULATIONS

- WIND LOAD ON APPURTENANCES
- RISA3D OUTPUT REPORT
- CONNECTION

#### SECTION 3 - REFERENCE MATERIALS

RF DATA SHEET



May 18, 2023

Mr. Matthew Bandle Northeast Site Solutions 1053 Farmington Ave, Unit G Farmington, CT 06032

Re: Structural Letter ~ Antenna Mount T-Mobile – Site Ref: CT11317B 280 Morehouse Road Fairfield, CT

Centek Project No. 22073.03

Dear Mr. Bandle,

Centek Engineering, Inc. has reviewed the T-Mobile antenna installation at the above referenced site. The purpose of the review is to determine the structural adequacy of the **proposed mount, consisting of one (1) platform mount (SitePro P/N: RMQLP-496-HK)** to support the proposed equipment configuration. The review considered the effects of wind load, dead load and ice load in accordance with the 2021 International Building Code as modified by the 2022 Connecticut State Building Code (CTBC) including ASCE 7-16 and ANSI/TIA-222-H *Structural Standard for Antenna Supporting Structures, Antennas and Small Wind Turbine Support Structures*".

The loads considered in this analysis consist of the following:

T-Mobile:

<u>Platform:</u> Three (3) RFS APXVAALL24\_43 panel antennas, three (3) RFS APX16DWV-16DWVS panel antennas and six (6) Commscope ATSBT-TOP-MF-4G Bias Tees mounted on one (1) Platform to the utility pole with a RAD center elevation of 121-ft above grade.

The antenna mount was analyzed per the requirements of the 2021 International Building Code as modified by the 2022 Connecticut State Building Code considering a Ultimate design wind speed of 130 mph for Fairfield as required in Appendix P of the 2022 Connecticut State Building Code.

Based on our review of the installation, it is our opinion that the **subject antenna mount has sufficient capacity** to support the aforementioned antenna configuration.

If there are any questions regarding this matter, please feel free to call.

Respectfully Submitted by:

Timothy J. Lynn, PE

Timothy J. Lynn, PE Structural Engineer



RAN Template:A&L Template:67D94B\_Flagpole Outdoor67D94B\_1DP+1QP+1OP

CT11317B\_L600\_5

					Print Name: Standard PORs: L600_L600 Coverage
Section 1 - Site Information					
Site ID:CT11317BSite Name:Fairfield/MP/X44&X42Status:FinalSite Class:Utility Lattice TowerVersion:5Site Type:Structure Non BuildingProject Type:L600Plan Year:Approved:03/13/2023 6:23:55 PMMarket:CONNECTICUT CTApproved By:Farhan.Badar@T-Mobile.comVendor:EricssonLast Modified:03/13/2023 6:23:55 PMLandlord:Northeast UtilitiesLast Modified By:Farhan.Badar@T-Mobile.comVendord:Northeast Utilities			Latitude: 41.209987 Longitude: -73.2615 Address: 280 Moreh City, State: Fairfield, Region: NORTHEAS	i39 iouse Drive (Tower 876 Line 1730) CT ST	
RAN Template: 67D94B_Flagpo	le Outdoor		AL Template:	67D94B_1DP+1QP+1OP	
Sector Count: 3	Antenna Count: 6	Coax Line Count: 22 TMA Count: 0		TMA Count: 0	RRU Count: 0
Section 2 - Existing Template Images					

704Bu.png

CT11317B\_L600\_5\_2023-03-14



794A Outdoor.png



Section 3 - Proposed Template Images



67D94BR\_1QP+10P.JPG



Section 4 - Siteplan Images

----- This section is intentionally blank. -----

A&L Template: 67D94B\_1DP+1QP+1OP

Print Name: Standard PORs: L600\_L600 Coverage

Section 5 - RAN Equipment

	Existing RAN Equipment				
	Template: 794B GSM Shutdo	wn Outdoor			
Enclosure	1	2			
Enclosure Type	Ground Mount (Ericsson)	(RBS 6102)			
Radio	RRUS11 B12 (x 3)	RUS01 B2 (x3) RUS01 B2 (x3) RUS01 B4 (x3)   L1900 G1900 L2100   RUS01 B4 (x3) U2100 (DECOMMISSIONED))			
Baseband		BB 6630 L700 L1900 L2100			

Proposed RAN Equipment					
	Template: 67D94B_Flagpole Outdoor				
Enclosure	1	2			
Enclosure Type	Ground Mount (Ericsson)	RBS 6102			
Radio	Radio 4480 B71+B85 (x 3) L600 L700	RUS01 B2 (x 6)   RUS01 B4 (x 6)     L1900   L2100			
Baseband		BB 6630   DUG20   DUW30   RP 6651     L1900   L2100   L600   L700			
RAN Scope of Work	a				
Install (1) BB6648 for L6/ L7/5G N600. Remove existing TMA Existing: (18) Coaxial Lines Add (6) Coaxial Lines for new total of (24).					

67D94B\_Flagpole Outdoor

CT11317B\_L600\_5

Print Name: Standard PORs: L600\_L600 Coverage

#### Section 6 - A&L Equipment

Existing Template: 794B\_1HP U19 shutdown Proposed Template: 67D94B\_1DP+1QP+1OP

Sector 1 (Existing) view from behind					
Coverage Type	A - Outdoor Macro	A - Outdoor Macro			
Antenna	1		2		
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	(Andrew - LNX-6515DS-A1M (Dual)		
Azimuth	60		60		
M. Tilt	0		0		
Height (ft)	95		95		
Ports	P1	P2	P3		
Active Tech	(L1900) (G1900)	(L2100)	L700		
Dark Tech					
Restricted Tech					
Decomm. Tech		U2100			
E. Tilt	2		2		
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)		
TMAs	Generic Twin Style 1A - PCS (At Cabinet)	Generic Twin Style 1B - AWS (At Cabinet)			
Diplexer / Combiners					
Radio					
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)		
Unconnected Equip	Unconnected Equipment:				
Scope of Work:	Scope of Work:				
Ground TMA's					

Sector 1 (Proposed) view from behind						
Coverage Type	A - Outdoor Macro					
Antenna	1			2		
Antenna Model	RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	RFS - APXVAALL	24_43-U-NA20 (Oct	0)	
Azimuth	60		60			
M. Tilt						
Height (ft)	95		95			
Ports	P1	P2	P3	P4	P5	P6
Active Tech	(G1900) (L1900) (N1900)	(L2100)	L700 L600 N600	L700 L600 N600		
Dark Tech						
Restricted Tech						
Decomm. Tech						
E. Tilt						
Cables	1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. <b>(x2)</b>	1-1/4" Coax - 126 ft. ( <b>x2</b> )		
TMAs						
Diplexer / Combiners						
Radio						
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)			
Unconnected Equipment:						
Scope of Work:						

https://rfeapp-rfds-ui-prd01.geo.mesh.t-mobile.com/datasheet/printout/e199ec3f-ba3d-4b09-8a5a-db44b84a55ec/6b957f19-68f5-4104-94f7-64aad66f...9/13

	Sector 2 (Existing) view from behind				
Coverage Type	A - Outdoor Macro				
Antenna	1		2		
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	Andrew - LNX-6515DS-A1M (Dual)		
Azimuth	180		180		
M. Tilt	0		0		
Height (ft)	95		95		
Ports	P1	P2	P3		
Active Tech	G1900 (L1900)	L2100	L700		
Dark Tech					
Restricted Tech					
Decomm. Tech		(U2100)			
E. Tilt	2		2		
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)		
TMAs	Generic Twin Style 1A - PCS (At Cabinet) Generic Twin Style 1B - AWS (At Cabinet)				
Diplexer / Combiners					
Radio					
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)		
Unconnected Equip	Unconnected Equipment:				
Scope of Work:	Scope of Work:				

	Sector 2 (Proposed) view from behind					
Coverage Type	A - Outdoor Macro					
Antenna	1			2	2	
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	RFS - APXVAALL	24_43-U-NA20 (Oct	o))	
Azimuth	180		180			
M. Tilt						
Height (ft)	95		95			
Ports	P1	P2	P3	P4	P5	P6
Active Tech	(G1900) (L1900) (N1900)	(L2100)	L700 L600 N600	L700 L600 N600		
Dark Tech						
Restricted Tech						
Decomm. Tech						
E. Tilt						
Cables	(1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft.		
TMAs						
Diplexer / Combiners						
Radio						
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)			
Unconnected Equip	ment:	-				
Scope of Work:						

Sector 3 (Existing) view from behind					
Coverage Type	(A - Outdoor Macro)				
Antenna	1		2		
Antenna Model	(RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	Andrew - LNX-6515DS-A1M (Dual)		
Azimuth	300		300		
M. Tilt	0		0		
Height (ft)	95		95		
Ports	P1	P2	P3		
Active Tech	G1900 (L1900)	L2100	L700		
Dark Tech					
Restricted Tech					
Decomm. Tech		(U2100)			
E. Tilt	2		2		
Cables	1-1/4" Coax - 125 ft. (x2)	1-1/4" Coax - 125 ft. (x2)	(1-1/4" Coax - 125 ft. (x2)		
TMAs	Generic Twin Style 1A - PCS (At Cabinet) Generic Twin Style 1B - AWS (At Cabinet)				
Diplexer / Combiners					
Radio					
Sector Equipment			Andrew Smart Bias T (Ericsson) (At Antenna)		
Unconnected Equip	Unconnected Equipment:				
Scope of Work:	Scope of Work:				

	Sector 3 (Proposed) view from behind					
Coverage Type	A - Outdoor Macro					
Antenna	1	1		2		
Antenna Model	RFS - APX16DWV-16DWV-S-E-A20 (	Quad)	RFS - APXVAALL	24_43-U-NA20 (Octo	0)	
Azimuth	300		300			
M. Tilt						
Height (ft)	95		95			
Ports	P1	P2	P3	P4	P5	P6
Active Tech	L1900 (N1900) (G1900)	(L2100)	L700 L600 N600	L700 L600 N600		
Dark Tech						
Restricted Tech						
Decomm. Tech						
E. Tilt						
Cables	(1-1/4" Coax - 126 ft. (x2)	(1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft. (x2)	1-1/4" Coax - 126 ft.		
TMAs						
Diplexer / Combiners						
Radio						
Sector Equipment	Andrew Smart Bias T (Ericsson) (At Antenna)		Andrew Smart Bias T (Ericsson) (At Antenna)			
Unconnected Equip	Unconnected Equipment:					
Scope of Work:						

## Exhibit F

**Power Density/RF Emissions Report** 



## Radio Frequency Emissions Analysis Report

# **T** Mobile

### Site ID: CT11317B

Fairfield/MP/X44&X42 280 Morehouse Drive (Tower 876 Line 1730) Fairfield, CT 06824

May 15, 2023

Fox Hill Telecom Project Number: 230531

Site Compliance Summary					
Compliance Status:	COMPLIANT				
Site total MPE% of FCC					
general population	1.69 %				
allowable limit:					



May 15, 2023

T-MOBILE Attn: RF Manager 35 Griffin Road South Bloomfield, CT 06009

#### Emissions Analysis for Site: CT11317B – Fairfield/MP/X44&X42

Fox Hill Telecom, Inc ("Fox Hill") was directed to analyze the proposed upgrades to the T-MOBILE facility located at **280 Morehouse Drive (Tower 876 Line 1730), Fairfield, CT**, for the purpose of determining whether the emissions from the Proposed T-MOBILE Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ( $\mu$ W/cm2). The number of  $\mu$ W/cm<sup>2</sup> calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits, therefore it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) - (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

<u>General population/uncontrolled exposure</u> limits apply to situations in which the general population may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general population would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

General population exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ( $\mu$ W/cm<sup>2</sup>). The general population exposure limits for the 600 MHz & 700 MHz frequencybands are approximately 400  $\mu$ W/cm<sup>2</sup> and 467  $\mu$ W/cm<sup>2</sup> respectively. The general population exposure limit for the 1900 MHz (PCS) and 2100 MHz (AWS) frequency bands is 1000  $\mu$ W/cm<sup>2</sup>. Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.



<u>Occupational/controlled exposure</u> limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over their exposure and can exercise control over the potential for exposure and can exercise through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.



#### CALCULATIONS

Calculations were performed for the proposed upgrades to the T-MOBILE antenna facility located at **280 Morehouse Drive (Tower 876 Line 1730), Fairfield, CT**, using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65 for far field modeling calculations.

In OET-65, plane wave power densities in the Far Field of an antenna are calculated by considering antenna gain and reflective waves that would contribute to exposure.

Since the radiation pattern of an antenna has developed in the **Far Field** region the power gain in specific directions needs to be considered in exposure predictions to yield an Effective Radiated Power (ERP) in each specific direction from the antenna. Also, since the vertical radiation pattern of the antenna is considered, the exposure calculations would most likely be reduced significantly at ground level, resulting in a more realistic estimate of the actual exposure levels. To determine a worst-case scenario at each point along the calculation radials, each point was calculated using the antenna gain value at each angle of incident and compared against the result using an isotropic radiator at the antenna height with the greater of the two used to yield the more pessimistic far field value for each point along the calculation radial.

Additionally, to model a truly "worst case" prediction of exposure levels at or near a surface, such as at ground-level or on a rooftop, reflection off the surface of antenna radiation power can be assumed, resulting in a potential 1.6 times increase in power density in calculating far field power density values.

With these factors Considered, the worst case **Far Field prediction model** utilized in this analysis is determined by the following equation:

Equation 9 per FCC OET65 for Far Field Modeling

$$S = \frac{33.4 \ ERP}{R^2}$$

$$\begin{split} S &= Power \ Density \ (in \ \mu w/cm^2) \\ ERP &= Effective \ Radiated \ Power \ from \ antenna \ (watts) \\ R &= Distance \ from \ the \ antenna \ (meters) \end{split}$$

Predicted far field power density values for all carriers identified in this report were calculated 6 feet above the ground level and are displayed as a percentage of the applicable FCC standards. All emissions values for other carriers were calculated using the same Far Field model outlined above, using industry standard radio configurations and frequency band selection based upon available licenses in this geographic area for emissions contribution estimates.



For each T-Mobile sector the following channel counts, frequency bands and power levels were utilized as shown in *Table 1*:

Technology	Frequency Band	Channel Count	Transmit Power per Channel (W)
GSM	1900 MHz (PCS)	1	15
LTE / 5G NR	1900 MHz (PCS)	4	40
LTE	2100 MHz (AWS)	4	40
LTE / 5G NR	600 MHz	2	40
LTE	700 MHz	2	20

Table 1: Channel Data Table



The following T-Mobile antennas listed in *Table 2* were used in the modeling for transmission in the 600 MHz, 700 MHz, 1900 MHz (PCS) and 2100 MHz (AWS) frequency bands. This is based on feedback from the carrier with regards to anticipated antenna selection. Maximum gain values for all antennas are listed in the Inventory and Power Data table below.

	Antenna		Antenna
Sector	Number	Antenna Make / Model	Centerline (ft)
А	1	RFS APX16DWV-16DWV-S-E-A20	121
А	2	RFS APXVAALL24_43-U-NA20	121
В	1	RFS APX16DWV-16DWV-S-E-A20	121
В	2	RFS APXVAALL24_43-U-NA20	121
С	1	RFS APX16DWV-16DWV-S-E-A20	121
С	2	RFS APXVAALL24 43-U-NA20	121

Table 2: Antenna Data

All calculations were done with respect to uncontrolled / general population threshold limits.



#### RESULTS

Per the calculations completed for the proposed T-MOBILE configurations *Table 3* shows resulting emissions power levels and percentages of the FCC's allowable general population limit.

Antenna			Antenna Gain	Channel	Total TX			
ID	Antenna Make / Model	Frequency Bands	(dBd)	Count	Power (W)	ERP (W)	MPE %	
Antenna	RFS	1900 MHz (PCS) /						
A1	APX16DWV-16DWV-S-E-A20	2100 MHz (AWS)	15.9	9	335	13,033.01	0.92	
Antenna	RFS							
A2	APXVAALL24 43-U-NA20	600 MHz / 700 MHz	13.65 / 13.85	4	120	2,824.56	0.77	
Sector A Composite MPE%							1.69	
Antenna	RFS	1900 MHz (PCS) /						
B1	APX16DWV-16DWV-S-E-A20	2100 MHz (AWS)	15.9	9	335	13,033.01	0.92	
Antenna	RFS							
B2	APXVAALL24 43-U-NA20	600 MHz / 700 MHz	13.65 / 13.85	4	120	2,824.56	0.77	
Sector B Composite MPE%							1.69	
Antenna	RFS	1900 MHz (PCS) /						
C1	APX16DWV-16DWV-S-E-A20	2100 MHz (AWS)	15.9	9	335	13,033.01	0.92	
Antenna	RFS							
C2	APXVAALL24_43-U-NA20	600 MHz / 700 MHz	13.65 / 13.85	4	120	2,824.56	0.77	
Sector C Composite MPE%								

Table 3: T-MOBILE Emissions Levels


The Following table (*table 4*) shows all additional identified carriers on site and their emissions contribution estimates, along with the newly calculated maximum T-MOBILE MPE contributions per this report. FCC OET 65 specifies that for carriers utilizing directional antennas that the highest recorded sector value be used for composite site MPE values due to their greatly reduced emissions contributions in the directions of the adjacent sectors. For this site, all three T-Mobile sectors have the same configuration yielding the same results for all three sectors. *Table 5* below shows a summary for each T-MOBILE Sector as well as the composite estimated MPE value for the site.

Site Composite MPE%				
Carrier	MPE%			
T-MOBILE – Max Per Sector Value	1.69 %			
No Additional Carriers	NA			
Site Total MPE %:	1.69 %			

Table 4: All Carrier MPE Contributions

T-MOBILE Sector A Total:	1.69 %
T-MOBILE Sector B Total:	1.69 %
T-MOBILE Sector C Total:	1.69 %
Site Total:	1.69 %

Table 5: Site MPE Summary



*Table 6* below details a breakdown by frequency band and technology for the MPE power values for the maximum calculated T-MOBILE sector(s). For this site, all three T-Mobile sectors have the same configuration yielding the same results for all three sectors.

T-MOBILE _ Frequency Band / Technology Max Power Values (Per Sector)	# Channels	Watts ERP (Per Channel)	Height (feet)	Total Power Density (µW/cm <sup>2</sup> )	Frequency (MHz)	Allowable MPE (µW/cm <sup>2</sup> )	Calculated % MPE
T-Mobile 1900 MHz (PCS) GSM	1	583.57	121	0.40	1900 MHz (PCS)	1000	0.04%
T-Mobile 1900 MHz (PCS) LTE / 5G NR	4	1,556.18	121	4.40	1900 MHz (PCS)	1000	0.44%
T-Mobile 2100 MHz (AWS) LTE	4	1,556.18	121	4.40	2100 MHz (AWS)	1000	0.44%
T-Mobile 600 MHz LTE / 5G NR	2	926.96	121	2.16	600 MHz	400	0.54%
T-Mobile 700 MHz LTE	2	485.32	121	1.07	700 MHz	467	0.23%
						Total:	1.69 %

Table 6: T-MOBILE Maximum Sector MPE Power Values



#### **Summary**

All calculations performed for this analysis yielded results that were **within** the allowable limits for general population exposure to RF Emissions.

The anticipated maximum composite contributions from the T-MOBILE facility as well as the site composite emissions estimates value with regards to compliance with FCC's allowable limits for general population exposure to RF Emissions are shown here:

T-MOBILE Sector	Power Density Value (%)
Sector A:	1.69 %
Sector B:	1.69 %
Sector C:	1.69 %
T-MOBILE Maximum	1 60 %
Total (per sector):	1.09 70
Site Total:	1.69 %
Site Compliance Status:	COMPLIANT

The estimated composite MPE value for this site assuming all carriers present is **1.69** % of the allowable FCC established general population limit sampled at the ground level. This is based upon the far field calculations performed for all carriers identified in this report.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite estimated values calculated were well within the allowable 100% threshold standard per the federal government.

Scott Heffernan Principal RF Engineer Fox Hill Telecom, Inc Worcester, MA 01609 (978)660-3998

# Exhibit G

Letter of Authorization



56 Prospect Street, Hartford, CT 06103

P.O. Box 270 Hartford, CT 06141-0270 (860) 665-5000

November 8, 2021

Mr. Sheldon Freincle Northeast Site Solutions 420 Main St, Sturbridge, MA 01566

RE: T-Mobile Antenna Site CT11317B, Morehouse Drive, Fairfield CT, Eversource Structure 876

Dear Mr. Freincle:

Based on our reviews of the site drawings, the structural analysis and foundation review provided by Centek Engineering, along with a third party review performed by Paul J. Ford and Company, we accept the proposed modification.

Please work with Christopher Gelinas of Eversource Real Estate to process the site lease amendment. Please do not hesitate to contact us with questions or concerns. Christopher can be contacted at 860-665-2008, and I can be contacted at (203) 623-0409.

Sincerely,

Richard Badon

Richard Badon Transmission Line Engineering

Ref: 2021-1004 - CT11317B Structural Analysis Rev2 (21051.10) 2021-0709 - CT11317B Mount Analysis Rev0 (21051.10) 2021-1102\_21051.10 CT11317B Fairfield\_MP - Rev2 CDs (S&S)

# Exhibit H

**Recipient Mailings** 



## Instructions

- 1. Each Click-N-Ship® label is unique. Labels are to be used as printed and used only once. DO NOT PHOTO COPY OR ALTER LABEL.
- 2. Place your label so it does not wrap around the edge of the package.
- 3. Adhere your label to the package. A self-adhesive label is recommended. If tape or glue is used, DO NOT TAPE OVER BARCODE. Be sure all edges are secure.
- 4. To mail your package with PC Postage®, you may schedule a Package Pickup online, hand to your letter carrier, take to a Post Office™, or drop in a USPS collection box.
- 5. Mail your package on the "Ship Date" you selected when creating this label.

# Click-N-Ship® Label Record

#### **USPS TRACKING #:** 9405 5036 9930 0576 7094 05 Priority Mail® Postage: \$9.65 Trans. #: 591852791 Total. \$9.65 Print Date: 07/17/2023 07/17/2023 Ship Date: Expected 07/19/2023 Delivery Date: From: DEBORAH CHASE Ref#: CT11317B NORTHEAST SITE SOLUTIONS STE 1 420 MAIN ST STURBRIDGE MA 01566-1359 To: **BRENDA L KUPCHICK** FIRST SELECTWOMAN- TOWN OF FAIRFIELD 725 OLD POST RD FAIRFIELD CT 06824-6684 $^{ m t}$ Retail Pricing Priority Mail rates apply. There is no fee for USPS Tracking $^{ m R}$ service on Priority Mail service with use of this electronic rate shipping label. Refunds for unused postage paid labels can be requested online 30 days from the print date.



## Instructions

- 1. Each Click-N-Ship® label is unique. Labels are to be used as printed and used only once. DO NOT PHOTO COPY OR ALTER LABEL.
- 2. Place your label so it does not wrap around the edge of the package.
- 3. Adhere your label to the package. A self-adhesive label is recommended. If tape or glue is used, DO NOT TAPE OVER BARCODE. Be sure all edges are secure.
- 4. To mail your package with PC Postage®, you may schedule a Package Pickup online, hand to your letter carrier, take to a Post Office™, or drop in a USPS collection box.
- 5. Mail your package on the "Ship Date" you selected when creating this label.

# Click-N-Ship® Label Record

#### **USPS TRACKING #:** 9405 5036 9930 0576 7094 29 Priority Mail® Postage: \$9.65 Trans. #: 591852791 Total. \$9.65 Print Date: 07/17/2023 07/17/2023 Ship Date: Expected 07/19/2023 Delivery Date: From: DEBORAH CHASE Ref#: CT11317B NORTHEAST SITE SOLUTIONS STE 1 420 MAIN ST STURBRIDGE MA 01566-1359 To: JIM WENDT PLANNING DIRECTOR-TOWN OF FAIRFIELD SULLIVAN INDEPENDENCE HALL 725 OLD POST RD FAIRFIELD CT 06824-6684 \* Retail Pricing Priority Mail rates apply. There is no fee for USPS Tracking® service on Priority Mail service with use of this electronic rate shipping label. Refunds for unused postage paid labels can be requested online 30 days from the print date.



## Instructions

- 1. Each Click-N-Ship® label is unique. Labels are to be used as printed and used only once. DO NOT PHOTO COPY OR ALTER LABEL.
- 2. Place your label so it does not wrap around the edge of the package.
- 3. Adhere your label to the package. A self-adhesive label is recommended. If tape or glue is used, DO NOT TAPE OVER BARCODE. Be sure all edges are secure.
- 4. To mail your package with PC Postage®, you may schedule a Package Pickup online, hand to your letter carrier, take to a Post Office™, or drop in a USPS collection box.
- 5. Mail your package on the "Ship Date" you selected when creating this label.

# Click-N-Ship® Label Record





## Instructions

- 1. Each Click-N-Ship® label is unique. Labels are to be used as printed and used only once. DO NOT PHOTO COPY OR ALTER LABEL.
- 2. Place your label so it does not wrap around the edge of the package.
- 3. Adhere your label to the package. A self-adhesive label is recommended. If tape or glue is used, DO NOT TAPE OVER BARCODE. Be sure all edges are secure.
- 4. To mail your package with PC Postage®, you may schedule a Package Pickup online, hand to your letter carrier, take to a Post Office™, or drop in a USPS collection box.
- 5. Mail your package on the "Ship Date" you selected when creating this label.

# Click-N-Ship® Label Record

#### **USPS TRACKING #:** 9405 5036 9930 0576 7094 43 Priority Mail® Postage: \$9.65 Trans. #: 591852791 Total. \$9.65 Print Date: 07/17/2023 07/17/2023 Ship Date: Expected 07/19/2023 Delivery Date: From: DEBORAH CHASE Ref#: CT11317B NORTHEAST SITE SOLUTIONS STE 1 420 MAIN ST STURBRIDGE MA 01566-1359 To: CHIJIAN ZHANG 280 MOREHOUSE DR FAIRFIELD CT 06825-2374 $^{\star}$ Retail Pricing Priority Mail rates apply. There is no fee for USPS Tracking® service on Priority Mail service with use of this electronic rate shipping label. Refunds for unused postage paid labels can be requested online 30 days from the print date.

	VITEI STAL	D STA SER	TES VICE.
FTSKDAL	458 MAIN	ST	
07/17/2023	B00)275-	518-9998 8777	
Product			04:18 PM
	uty	Unit Price	Price
Prepaid Mail Fairfield, CT Weight: 1 lb Acceptance Dat Mon 07/17/2 Tracking #: 9405 5036 s	1 06824 8.20 oz e: 2023 9930 0576	5 7094 29	\$0.00
Prepaid Mail Fairfield, CT C Weight: 1 lb 8 Acceptance Date Mon 07/17/2 Tracking #: 9405 5036 99	1 16824 : 50 oz : 023 930 0576	7094 05	\$0.00
Prepaid Mail Fairfield, CT 06 Weight: 1 lb 8. Acceptance Date: Mon 07/17/20 Tracking #: 9405 5036 99	1 5825 00 oz 23 30 0576	7094 43	\$0.00
Prepaid Mail Hartford, CT 0610 Weight: 1 lb 7.5 Acceptance Date: Mon 07/17/202 Tracking #: 9405 5036 993	1 93 90 oz 23 90 0576 7	<b>'</b> 094 36	\$0.00
Grand Total:	No. 201 (1) (1) (1) (1) (1) (1)		
	an ba an an an an an an an an		<b>\$U.00</b>
Text your tracking nu to get the latest sta and Data rates may visit www.usps.com U 1-800-22	umber to itus. Sta apply. γ SPS Trac 2-1811.	28777 (2 andard Me You may a king or	2USPS) ssage lso call
Preview y Track your Sign up fo https://informedde	our Mail Package or FREE ( Əlivery.(	s D Jsps.com	
All sales final on s Refunds for guarante Thank you for y	stamps ar ed servi our busi	nd postag ces only ness.	ie.
lell us about vo	UP AVAAA	in	

Tell us about your experience. Go to: https://postalexperience.com/Pos or scan this code with your mobile device,



or call 1-800-410-7420.

UFN: 242703-0518 Receipt #: 840-50180227-2-3222960-1 Clerk: 5