

June 25, 2021

Melanie A. Bachman
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Notice of Exempt Modification

Facility Address: 36 Ritch Avenue West, Greenwich, CT
Facility Coordinates: 41.00506388, -73.64831111

Dear Ms. Bachman,

American Tower (ATC) currently maintains an Existing Cellular Tower Facility (79' Monopine) at 36 Ritch Avenue West, Greenwich, CT 06830. The property is owned by 36 Ritch Avenue LLC. American Tower (ATC) now intends to install an 80kw Generator within the leased, fenced ground space area of the facility. The purpose of the generator installation is to allow for a shared back up emergency power option for its current (and future) wireless carrier tenants.

Because this proposed generator is within the existing, approved compound space, and the applicant is NOT requesting expansion of ground space beyond the approved conditions, please accept this letter, as notification pursuant to Regulations of Connecticut State Agencies @16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. @16-50j-72(b)(2). IN accordance with R.C.S.A.@16-50j-73, a copy of this letter is being sent to Fred Camillo, the First Selectman of the Town of Greenwich, Katie DeLuca, Director of Planning and Zoning, as well as the property owner and tower owner.

ATTACHMENT A

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A @ 16-50j-72(b)(2).

1. The proposed modifications will not result in an increase in the height of the existing structure.
2. The proposed modifications will not require the extension of the site boundary
3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The operation of the generator back up power facility will not increase radio frequency emissions at the facility to the level at or above the Federal Communications Commission safety standard.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The existing structure and its foundation can support the proposed loading if the tower will be reinforced to support them. <<< NOTE – This condition is N/A. The proposed Generator is based on the ground, and not associated or loaded onto the tower or foundation.

For the foregoing reasons, American Tower (ATC) respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. @16-50j-72(b)(2).

If you have any questions, I can be reached at mweber@nbcllc.com or 215.416.0363

Best Regards,

Margie Weber

Attachments

cc: Fred Camillo
Katie DeLuca
Property Owner
American Tower (ATC)



LETTER OF AUTHORIZATION

ATC Site No./Name/Project: 414240 / Byram CT / ATC273525
Site Address: Address: 48 Ritch Avenue West, Greenwich, CT 06830
Licensee: T-Mobile Northeast LLC dba T-Mobile

I, Margaret Robinson, Senior Counsel for American Tower*, operator of the tower facility located at the address identified above (the "Tower Facility"), do hereby authorize **T-Mobile Northeast LLC dba T-Mobile**, its successors and assigns, and/or its agent, (collectively, the "Licensee") to act as American Tower's non-exclusive agent for the sole purpose of filing and consummating any land-use or building permit application(s) as may be required by the applicable permitting authorities for Licensee's telecommunications' installation.

We understand that this application may be denied, modified or approved with conditions. The above authorization is limited to the acceptance by Licensee only of conditions related to Licensee's installation and any such conditions of approval or modifications will be Licensee's sole responsibility.

Signature:

Print Name: Margaret Robinson
Senior Counsel
American Tower*


NOTARY BLOCK

Commonwealth of MASSACHUSETTS
County of Middlesex

This instrument was acknowledged before me by Margaret Robinson, Senior Counsel for American Tower*, personally known to me (or proved to me on the basis of satisfactory evidence) to be the person whose name is subscribed to the within instrument and acknowledged to me that he executed the same.

WITNESS my hand and official seal, this 14th of May 2021.

NOTARY SEAL



Notary Public 
My Commission Expires: March 25, 2027

***American Tower includes all affiliates and subsidiaries of American Tower Corporation.**

Property Detail Report

For Property Located At :

36 RITCH AVE W, GREENWICH, CT 06830



Owner Information

Owner Name: 36 RITCH AVE LLC
Mailing Address: 16B ARTHUR ST, GREENWICH CT 06831-5107 C026
Vesting Codes: //

Location Information

Legal Description:
County: FAIRFIELD, CT APN: GREE-000004-000000-002334-S000000
Census Tract / Block: 113.00 / 1 Alternate APN: 1841552
Township-Range-Sect: Subdivision:
Legal Book/Page: Map Reference: /
Legal Lot: Tract #:
Legal Block: School District:
Market Area: School District Name:
Neighbor Code: Munic/Township: GREENWICH

Owner Transfer Information

Recording/Sale Date: / Deed Type:
Sale Price: 1st Mtg Document #:
Document #:

Last Market Sale Information

Recording/Sale Date: / 1st Mtg Amount/Type: /
Sale Price: 1st Mtg Int. Rate/Type: /
Sale Type: 1st Mtg Document #: /
Document #: 2nd Mtg Amount/Type: /
Deed Type: 2nd Mtg Int. Rate/Type: /
Transfer Document #: Price Per SqFt:
New Construction: Multi/Split Sale:
Title Company:
Lender:
Seller Name:

Prior Sale Information

Prior Rec/Sale Date: / Prior Lender:
Prior Sale Price: Prior 1st Mtg Amt/Type: /
Prior Doc Number: Prior 1st Mtg Rate/Type: /
Prior Deed Type:

Property Characteristics

Year Built / Eff: 2012 / Total Rooms/Offices
Gross Area: Total Restrooms:
Building Area: 644 Roof Type:
Tot Adj Area: Roof Material:
Above Grade: Construction: STEEL/HEAVY
of Stories: 1 Foundation:
Other Improvements: Building Permit Exterior wall:
Basement Area: Condition: AVERAGE

Site Information

Zoning: R-7 Acres: 0.27 County Use:
Lot Area: 11,761 Lot Width/Depth: x State Use: TELEPHONE EXCHANGE STATION (430)
Land Use: TELEPHONE FACILITY Commercial Units:
Site Influence: Sewer Type: Water Type:
Building Class:

Tax Information

Total Value: \$2,030,000 Assessed Year: 2020 Property Tax: \$24,401.00
Land Value: \$464,800 Improved %: 77% Tax Area: 124
Improvement Value: \$1,565,200 Tax Year: 2020 Tax Exemption:
Total Taxable Value:


Street Map Plus Report

For Property Located At




RealQuest

36 RITCH AVE W, GREENWICH, CT 06830



Imagery ©2021, Maxar Technologies, New York GIS, USDA Farm Service Agency



VICINITY MAP



AMERICAN TOWER®

ATC SITE NAME: BYRAM PARK CT
 SITE NUMBER: 414240
 SITE ADDRESS: 48 RITCH AVENUE WEST
 GREENWICH, CT 06830



LOCATION MAP


**SHARED GENERATOR PROGRAM
 ANCHOR TENANT**

AMERICAN TOWER®
A.T. ENGINEERING SERVICE, PLLC
 3500 REGENCY PARKWAY
 SUITE 100
 CARY, NC 27518
 PHONE: (919) 468-0112
 COA: PEC.0001553

THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THE SPECIFIED CARRIER IS STRICTLY PROHIBITED. TITLE TO THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.

| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| | | | |
| | | | |
| | | | |
| | | | |

ATC SITE NUMBER:
414240
 ATC SITE NAME:
BYRAM PARK CT
 SITE ADDRESS:
 48 RITCH AVENUE WEST
 GREENWICH, CT 06830



| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

TITLE SHEET

SHEET NUMBER:
G-001

REVISION:
0

| COMPLIANCE CODE | PROJECT SUMMARY | PROJECT DESCRIPTION | SHEET INDEX | | | | |
|--|---|--|--|--------------|----------|----------|-----|
| ALL WORK SHALL BE PERFORMED AND MATERIALS INSTALLED IN ACCORDANCE WITH THE CURRENT EDITIONS OF THE FOLLOWING CODES AS ADOPTED BY THE LOCAL GOVERNMENT AUTHORITIES. NOTHING IN THESE PLANS IS TO BE CONSTRUED TO PERMIT WORK NOT CONFORMING TO THESE CODES. 1. INTERNATIONAL BUILDING CODE (IBC) 2. NATIONAL ELECTRIC CODE (NEC) 3. LOCAL BUILDING CODE 4. CITY/COUNTY ORDINANCES | <u>SITE ADDRESS:</u> 48 RITCH AVENUE WEST GREENWICH, CT 06830 COUNTY: FAIRFIELD <u>GEOGRAPHIC COORDINATES:</u> LATITUDE: 41.00506388 LONGITUDE: -73.64831111 GROUND ELEVATION: 53' AMSL <u>ZONING INFORMATION:</u> JURISDICTION: TOWN OF GREENWICH PARCEL NUMBER: GREE-000004-000000-002334-S000000 | THE PROPOSED PROJECT INSTALLS AN OPTIONAL STANDBY GENERATOR SYSTEM, AUTOMATIC TRANSFER SWITCH, GENERATOR AUXILIARY POWER DISTRIBUTION, AND REMOTE MONITORING COMMUNICATIONS CIRCUITRY FOR A COMMUNICATION TOWER TENANT. | SHEET NO: | DESCRIPTION: | REV: | DATE: | BY: |
| | <u>PROJECT TEAM</u> <u>ATC REGIONAL NETWORK DEVELOPMENT PROJECT MANAGER:</u> MARTIN GUMBS (646) 669-4302 <u>ATC NETWORK OPERATIONS CENTER:</u> (877) 518-6937 <u>TOWER OWNER:</u> AMERICAN TOWER 10 PRESIDENTIAL WAY WOBURN, MA 01801 <u>PROPERTY OWNER:</u> 36 RITCH AVENUE, LLC 16B ARTHUR STREET GREENWICH, CT 06831 <u>ENGINEERED BY:</u> ATC TOWER SERVICES 3500 REGENCY PARKWAY SUITE 100 CARY, NC 27518 | PROJECT NOTES 1. THE FACILITY IS UNMANNED. 2. A TECHNICIAN WILL VISIT THE SITE APPROXIMATELY ONCE A MONTH FOR ROUTINE INSPECTION AND MAINTENANCE. 3. THE PROJECT WILL NOT RESULT IN ANY SIGNIFICANT LAND DISTURBANCE OR EFFECT OF STORM WATER DRAINAGE. 4. NO SANITARY SEWER, POTABLE WATER OR TRASH DISPOSAL IS REQUIRED. 5. HANDICAP ACCESS IS NOT REQUIRED. | C-101 | SITE PLAN | 0 | 06/03/21 | AB |
| | PROJECT LOCATION DIRECTIONS TAKE RITCH AVE W AND HAMILTON AVE TO GLEN ST IN GREENWICH, 4 MIN (1.6 MI), HEAD NORTHEAST ON I-95 N, 0.2 MI, TAKE EXIT 2 FOR BYRAM TOWARD DELAVAN AVE, 0.2 MI, CONTINUE ONTO DORAN AVE, 361 FT, TURN LEFT ONTO BYRAM SHORE RD, 167 FT, TURN RIGHT ONTO RITCH AVE W, 0.6 MI, CONTINUE ONTO HAMILTON AVE, 0.5 MI, TAKE RODWELL AVE TO HAMILTON AVE, 43 S (0.2 MI), TURN RIGHT ONTO GLEN ST, 351 FT, GLEN ST TURNS LEFT AND BECOMES RODWELL AVE, 476 FT, RODWELL AVE TURNS LEFT AND BECOMES STONE AVE, 358 FT, CONTINUE ON HAMILTON AVE. DRIVE TO RITCH AVE W, 3 MIN (1.1 MI), TURN LEFT ONTO HAMILTON AVE, 0.6 MI, CONTINUE ONTO RITCH AVE W, DESTINATION WILL BE ON THE RIGHT, | C-501 | CONCRETE PAD DETAILS | 0 | 06/03/21 | AB | |
| UTILITY COMPANIES POWER COMPANY: EVERSOURCE PHONE: (866) 554-6025 TELEPHONE COMPANY: UNKNOWN PHONE: N/A | <u>PROJECT TEAM</u> <u>ATC REGIONAL NETWORK DEVELOPMENT PROJECT MANAGER:</u> MARTIN GUMBS (646) 669-4302 <u>ATC NETWORK OPERATIONS CENTER:</u> (877) 518-6937 <u>TOWER OWNER:</u> AMERICAN TOWER 10 PRESIDENTIAL WAY WOBURN, MA 01801 <u>PROPERTY OWNER:</u> 36 RITCH AVENUE, LLC 16B ARTHUR STREET GREENWICH, CT 06831 <u>ENGINEERED BY:</u> ATC TOWER SERVICES 3500 REGENCY PARKWAY SUITE 100 CARY, NC 27518 | C-502 | CONCRETE PAD DETAILS | 0 | 06/03/21 | AB | |
| | <u>PROJECT TEAM</u> <u>ATC REGIONAL NETWORK DEVELOPMENT PROJECT MANAGER:</u> MARTIN GUMBS (646) 669-4302 <u>ATC NETWORK OPERATIONS CENTER:</u> (877) 518-6937 <u>TOWER OWNER:</u> AMERICAN TOWER 10 PRESIDENTIAL WAY WOBURN, MA 01801 <u>PROPERTY OWNER:</u> 36 RITCH AVENUE, LLC 16B ARTHUR STREET GREENWICH, CT 06831 <u>ENGINEERED BY:</u> ATC TOWER SERVICES 3500 REGENCY PARKWAY SUITE 100 CARY, NC 27518 | E-601 | ELECTRICAL ONE-LINE AND WIRING DETAILS | 0 | 06/03/21 | AB | |
| | | | R-601 | SUPPLEMENTAL | | | |

Copyright © 2021 ATC IP LLC, All Rights Reserved.

GENERAL CONSTRUCTION NOTES:

- ALL WORK SHALL CONFORM TO ALL CURRENT APPLICABLE FEDERAL, STATE, AND LOCAL CODES, INCLUDING ANSIEIA/TIA-222, AND COMPLY WITH ATC CONSTRUCTION SPECIFICATIONS.
- CONTRACTOR SHALL CONTACT LOCAL 811 FOR IDENTIFICATION OF UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.
- CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL REQUIRED INSPECTIONS.
- ALL DIMENSIONS TO, OF, AND ON EXISTING BUILDINGS, DRAINAGE STRUCTURES, AND SITE IMPROVEMENTS SHALL BE VERIFIED IN FIELD BY CONTRACTOR WITH ALL DISCREPANCIES REPORTED TO THE ENGINEER.
- DO NOT CHANGE SIZE OR SPACING OF STRUCTURAL ELEMENTS.
- DETAILS SHOWN ARE TYPICAL; SIMILAR DETAILS APPLY TO SIMILAR CONDITIONS UNLESS OTHERWISE NOTED.
- THESE DRAWINGS DO NOT INCLUDE NECESSARY COMPONENTS FOR CONSTRUCTION SAFETY WHICH SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR.
- CONTRACTOR SHALL BRACE STRUCTURES UNTIL ALL STRUCTURAL ELEMENTS NEEDED FOR STABILITY ARE INSTALLED. THESE ELEMENTS ARE AS FOLLOWS: LATERAL BRACING, ANCHOR BOLTS, ETC.
- CONTRACTOR SHALL DETERMINE EXACT LOCATION OF EXISTING UTILITIES, GROUNDS DRAINS, DRAIN PIPES, VENTS, ETC. BEFORE COMMENCING WORK.
- INCORRECTLY FABRICATED, DAMAGED, OR OTHERWISE MISFITTING OR NONCONFORMING MATERIALS OR CONDITIONS SHALL BE REPORTED TO THE ATC CM PRIOR TO REMEDIAL OR CORRECTIVE ACTION. ANY SUCH REMEDIAL ACTION SHALL REQUIRE WRITTEN APPROVAL BY THE ATC CM PRIOR TO PROCEEDING.
- EACH CONTRACTOR SHALL COOPERATE WITH THE ATC CM, AND COORDINATE HIS WORK WITH THE WORK OF OTHERS.
- CONTRACTOR SHALL REPAIR ANY DAMAGE CAUSED BY CONSTRUCTION OF THIS PROJECT TO MATCH EXISTING PRE-CONSTRUCTION CONDITIONS TO THE SATISFACTION OF THE ATC CONSTRUCTION MANAGER.
- ALL CABLE/CONDUIT ENTRY/EXIT PORTS SHALL BE WEATHERPROOFED DURING INSTALLATION USING A SILICONE SEALANT.
- WHERE EXISTING CONDITIONS DO NOT MATCH THOSE SHOWN IN THIS PLAN SET, CONTRACTOR SHALL NOTIFY THE ATC CONSTRUCTION MANAGER IMMEDIATELY.
- CONTRACTOR SHALL ENSURE ALL SUBCONTRACTORS ARE PROVIDED WITH A COMPLETE AND CURRENT SET OF DRAWINGS AND SPECIFICATIONS FOR THIS PROJECT.
- CONTRACTOR SHALL REMOVE ALL RUBBISH AND DEBRIS FROM THE SITE AT THE END OF EACH DAY.
- CONTRACTOR SHALL COORDINATE WORK SCHEDULE WITH LANDLORD AND TAKE PRECAUTIONS TO MINIMIZE IMPACT AND DISRUPTION OF OTHER OCCUPANTS OF THE FACILITY.
- CONTRACTOR SHALL FURNISH ATC WITH A PDF MARKED UP AS-BUILT SET OF DRAWINGS UPON COMPLETION OF WORK.
- PRIOR TO SUBMISSION OF BID, CONTRACTOR SHALL COORDINATE WITH ATC CM TO DETERMINE WHAT, IF ANY, ITEMS WILL BE PROVIDED. ALL ITEMS NOT PROVIDED SHALL BE PROVIDED AND INSTALLED BY THE CONTRACTOR. CONTRACTOR WILL INSTALL ALL ITEMS PROVIDED.
- PRIOR TO SUBMISSION OF BID, CONTRACTOR SHALL COORDINATE WITH ATC CONSTRUCTION MANAGER TO DETERMINE IF ANY PERMITS WILL BE OBTAINED BY ATC. ALL REQUIRED PERMITS NOT OBTAINED BY ATC MUST BE OBTAINED, AND PAID FOR, BY THE CONTRACTOR.
- CONTRACTOR SHALL INSTALL ALL SITE SIGNAGE IN ACCORDANCE WITH ATC SPECIFICATIONS AND REQUIREMENTS.
- CONTRACTOR SHALL SUBMIT ALL SHOP DRAWINGS TO ATC FOR REVIEW AND APPROVAL PRIOR TO FABRICATION.
- ALL EQUIPMENT SHALL BE INSTALLED ACCORDING TO MANUFACTURER'S SPECIFICATIONS AND LOCATED ACCORDING TO ATC SPECIFICATIONS, AND AS SHOWN IN THESE PLANS.
- THE CONTRACTOR SHALL SUPERVISE AND DIRECT THE PROJECT DESCRIBED HEREIN. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ALL THE CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES AND PROCEDURES AND FOR COORDINATING ALL PORTIONS OF THE WORK UNDER THE CONTRACT.
- CONTRACTOR SHALL NOTIFY ATC CM A MINIMUM OF 48 HOURS IN ADVANCE OF POURING CONCRETE OR BACKFILLING ANY UNDERGROUND UTILITIES, FOUNDATIONS OR SEALING ANY WALL, FLOOR OR ROOF PENETRATIONS FOR ENGINEERING REVIEW AND APPROVAL.
- CONTRACTOR SHALL BE RESPONSIBLE FOR SITE SAFETY INCLUDING COMPLIANCE WITH ALL APPLICABLE OSHA STANDARDS AND RECOMMENDATIONS AND SHALL PROVIDE ALL NECESSARY SAFETY DEVICES INCLUDING PPE AND PPM AND CONSTRUCTION DEVICES SUCH AS WELDING AND FIRE PREVENTION, TEMPORARY SHORING, SCAFFOLDING, TRENCH BOXES/SLOPING, BARRIERS, ETC.
- THE CONTRACTOR SHALL PROTECT AT HIS OWN EXPENSE, ALL EXISTING FACILITIES AND SUCH OF HIS NEW WORK LIABLE TO INJURY DURING THE CONSTRUCTION PERIOD. ANY DAMAGE CAUSED BY NEGLIGENCE ON THE PART OF THIS CONTRACTOR OR HIS REPRESENTATIVES, OR BY THE ELEMENTS DUE TO NEGLIGENCE ON THE PART OF THIS CONTRACTOR OR HIS

REPRESENTATIVES, EITHER TO THE EXISTING WORK, OR TO HIS WORK OR THE WORK OF ANY OTHER CONTRACTOR, SHALL BE REPAIRED AT HIS EXPENSE TO THE OWNER'S SATISFACTION.

- ALL WORK SHALL BE INSTALLED IN A FIRST CLASS, NEAT AND WORKMANLIKE MANNER BY MECHANICS SKILLED IN THE TRADE INVOLVED. THE QUALITY OF WORKMANSHIP SHALL BE SUBJECT TO THE APPROVAL OF THE ATC CM. ANY WORK FOUND BY THE ATC CM TO BE OF INFERIOR QUALITY AND/OR WORKMANSHIP SHALL BE REPLACED AND/OR REWORKED AT CONTRACTOR EXPENSE UNTIL APPROVAL IS OBTAINED.
- IN ORDER TO ESTABLISH STANDARDS OF QUALITY AND PERFORMANCE, ALL TYPES OF MATERIALS LISTED HEREINAFTER BY MANUFACTURER'S NAMES AND/OR MANUFACTURER'S CATALOG NUMBER SHALL BE PROVIDED BY THESE MANUFACTURERS AS SPECIFIED.

CONCRETE AND REINFORCING STEEL NOTES:

- DESIGN AND CONSTRUCTION OF ALL CONCRETE ELEMENTS SHALL CONFORM TO THE LATEST EDITIONS OF ALL APPLICABLE CODES INCLUDING: ACI 301 "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS", ACI 117 "SPECIFICATIONS FOR TOLERANCES FOR CONCRETE CONSTRUCTION AND MATERIALS", AND ACI 318 "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE."
- MIX DESIGN SHALL BE APPROVED BY ATC CM PRIOR TO PLACING CONCRETE.
- CONCRETE SHALL BE NORMAL WEIGHT, 6 % AIR ENTRAINED (+/- 1.5%) WITH A SLUMP RANGE OF 3-5" AND HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI UNLESS OTHERWISE NOTED.
- THE FOLLOWING MATERIALS SHALL BE USED:
 - PORTLAND CEMENT: ASTM C150, TYPE 2
 - REINFORCEMENT: ASTM A185, PLAIN STEEL WELDED WIRE FABRIC
 - REINFORCEMENT BARS: ASTM A615, GRADE 60, DEFORMED
 - NORMAL WEIGHT AGGREGATE: ASTM C33
 - WATER: ASTM C 94/C 94M
 - ADMIXTURES:
 - WATER-REDUCING AGENT: ASTM C 494/C 494M, TYPE A
 - AIR-ENTERING AGENT: ASTM C 260/C 260M
 - SUPERPLASTICIZER: ASTM C494, TYPE F OR TYPE G
 - RETARDING: ASTM C 494/C 494M, TYPE B
- MINIMUM CONCRETE COVER FOR REINFORCING STEEL SHALL BE NO LESS THAN 3".
- A 3/4" CHAMFER SHALL BE PROVIDED AT ALL EXPOSED EDGES OF CONCRETE IN ACCORDANCE WITH ACI 301 SECTION 4.2.4, UNLESS NOTED OTHERWISE.
- INSTALLATION OF CONCRETE EXPANSION/WEDGE ANCHOR SHALL BE PER MANUFACTURER'S WRITTEN RECOMMENDED PROCEDURE. THE ANCHOR BOLT, DOWEL, OR ROD SHALL CONFORM TO MANUFACTURER'S RECOMMENDATION FOR EMBEDMENT DEPTH OR AS SHOWN ON THE DRAWINGS. NO REBAR SHALL BE CUT WITHOUT PRIOR ATC CM APPROVAL WHEN DRILLING HOLES IN CONCRETE.
- ADMIXTURES SHALL CONFORM TO THE APPROPRIATE ASTM STANDARD AS REFERENCED IN "METHOD 1" OF ACI 301.
- DO NOT WELD OR TACK WELD REINFORCING STEEL.
- ALL DOWELS, ANCHOR BOLTS, EMBEDDED STEEL, ELECTRICAL CONDUITS, PIPE SLEEVES, GROUNDS AND ALL OTHER EMBEDDED ITEMS AND FORMED DETAILS SHALL BE IN PLACE BEFORE START OF CONCRETE PLACEMENT.
- REINFORCEMENT SHALL BE COLD BENT WHENEVER BENDING IS REQUIRED.
- DO NOT PLACE CONCRETE IN WATER, ICE, OR ON FROZEN GROUND.
- DO NOT ALLOW REINFORCEMENT, CONCRETE OR SUBBASE TO FREEZE DURING CONCRETE CURING AND SETTING PERIOD, OR FOR A MINIMUM OF 3 DAYS AFTER PLACEMENT.
- FOR COLD-WEATHER(ACI 306) AND HOT-WEATHER(ACI 301M) CONCRETE PLACEMENT, CONFORM TO APPLICABLE ACI CODES AND RECOMMENDATIONS. IN EITHER CASE, MATERIALS CONTAINING CHLORIDE, CALCIUM, SALTS, ETC. SHALL NOT BE USED. PROTECT FRESH CONCRETE FROM WEATHER FOR 7 DAYS, MINIMUM.
- ALL CONCRETE SHALL HAVE A "SMOOTH FORM FINISH."
- UNLESS OTHERWISE NOTED:
 - A. ALL REINFORCING STEEL SHALL BE DEFORMED BARS CONFORMING TO ASTM A615/A 615M/A-996, GRADE 60.
 - B. WELDED WIRE FABRIC SHALL CONFORM TO ASTM A185.
- SPLICING OF REINFORCEMENT IS PERMITTED ONLY AT LOCATIONS SHOWN IN THE CONTRACT DRAWINGS OR AS ACCEPTED BY THE ENGINEER. UNLESS OTHERWISE SHOWN OR NOTED REINFORCING STEEL SHALL BE SPLICED TO DEVELOP ITS FULL TENSILE CAPACITY (CLASS A) IN ACCORDANCE WITH ACI 318.
- REINFORCING BAR DEVELOPMENT LENGTHS, AS COMPUTED IN ACCORDANCE WITH ACI 318, FORM THE BASIS FOR BAR EMBEDMENT LENGTHS AND BAR SPLICED LENGTHS SHOWN IN THE

DRAWINGS. APPLY APPROPRIATE MODIFICATION FACTORS FOR TOP STEEL, BAR SPACING, COVER AND THE LIKE.

- DETAILING OF REINFORCING STEEL SHALL CONFORM TO "ACI MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE STRUCTURES" (ACI 315).
- ALL SLAB CONSTRUCTION SHALL BE CAST MONOLITHICALLY WITHOUT HORIZONTAL CONSTRUCTION JOINTS, UNLESS SHOWN IN THE CONTRACT DRAWINGS.
- LOCATION OF ALL CONSTRUCTION JOINTS ARE SUBJECT TO THE REQUIREMENTS OF THE CONTRACT DOCUMENTS, CONFORMANCE WITH ACI 318, AND ACCEPTANCE OF THE ENGINEER. DRAWINGS SHOWING LOCATION OF DETAILS OF THE PROPOSED CONSTRUCTION JOINTS SHALL BE SUBMITTED WITH REINFORCING STEEL PLACEMENT DRAWINGS.
- SPLICES OF WWF, AT ALL SPLICED EDGES, SHALL BE SUCH THAT THE OVERLAP MEASURED BETWEEN OUTERMOST CROSS WIRES OF EACH FABRIC SHEET IS NOT LESS THAN THE SPACING OF THE CROSS WIRE PLUS 2 INCHES, NOR LESS THAN 6".
- BAR SUPPORTS SHALL BE ALL-GALVINIZED METAL WITH PLASTIC TIPS.
- ALL REINFORCEMENT SHALL BE SECURELY TIED IN PLACE TO PREVENT DISPLACEMENT BY CONSTRUCTION TRAFFIC OR CONCRETE. TIE WIRE SHALL BE OF SUFFICIENT STRENGTH FOR INTENDED PURPOSE, BUT NOT LESS THAN NO. 18 GAUGE.
- SLAB ON GROUND:
 - A. COMPACT SUBGRADE AND ENSURE THERE IS PLACE 6" GRAVEL BENEATH SLAB.
 - B. PROVIDE VAPOR BARRIER BENEATH SLAB ON GROUND.

STRUCTURAL STEEL NOTES:

- STRUCTURAL STEEL SHALL CONFORM TO THE LATEST EDITION OF THE AISC "SPECIFICATION FOR THE DESIGN, FABRICATION AND ERECTION OF STRUCTURAL STEEL FOR BUILDINGS."
- STRUCTURAL STEEL ROLLED SHAPES, PLATES AND BARS SHALL CONFORM TO THE FOLLOWING ASTM DESIGNATIONS:
 - A. ASTM A-572, GRADE 50 - ALL W SHAPES, UNLESS NOTED OR A992 OTHERWISE
 - B. ASTM A-36 - ALL OTHER ROLLED SHAPES, PLATES AND BARS UNLESS NOTED OTHERWISE
 - C. ASTM A-500, GRADE B - HSS SECTION (SQUARE, RECTANGULAR, AND ROUND)
 - D. ASTM A-325, TYPE SC OR N - ALL BOLTS FOR CONNECTING STRUCTURAL MEMBERS
 - E. ASTM F-1554 07 - ALL ANCHOR BOLTS, UNLESS NOTED OTHERWISE
- ALL EXPOSED STRUCTURAL STEEL MEMBERS SHALL BE HOT-DIPPED GALVANIZED AFTER FABRICATION PER ASTM A123. EXPOSED STEEL HARDWARE AND ANCHOR BOLTS SHALL BE GALVANIZED PER ASTM A153 OR B695.
- ALL FIELD CUT SURFACES, FIELD DRILLED HOLES AND GROUND SURFACES WHERE EXISTING PAINT OR GALVANIZATION REMOVAL WAS REQUIRED SHALL BE REPAIRED WITH (2) BRUSHED COATS OF ZRC GALVILITE COLD GALVANIZING COMPOUND PER ASTM A780 AND MANUFACTURER'S RECOMMENDATIONS.
- DO NOT DRILL HOLES THROUGH STRUCTURAL STEEL MEMBERS EXCEPT AS SHOWN AND DETAILED ON STRUCTURAL DRAWINGS.
- CONNECTIONS:
 - A. ALL WELDING TO BE PERFORMED BY AWS CERTIFIED WELDERS AND CONDUCTED IN ACCORDANCE WITH THE LATEST EDITION OF THE AWS WELDING CODE D1.1.
 - B. ALL WELDS SHALL BE INSPECTED VISUALLY. 25% OF WELDS SHALL BE INSPECTED WITH DYE PENETRANT OR MAGNETIC PARTICLE TO MEET THE ACCEPTANCE CRITERIA OF AWS D1.1. REPAIR ALL WELDS AS NECESSARY.
 - C. INSPECTION SHALL BE PERFORMED BY AN AWS CERTIFIED WELD INSPECTOR.
 - D. IT IS THE CONTRACTORS RESPONSIBILITY TO PROVIDE BURNING/WELDING PERMITS AS REQUIRED BY LOCAL GOVERNING AUTHORITY AND IF REQUIRED SHALL HAVE FIRE DEPARTMENT DETAIL FOR ANY WELDING ACTIVITY.
 - E. ALL ELECTRODES TO BE LOW HYDROGEN, MATCHING FILLER METAL, PER AWS D1.1, UNLESS NOTED OTHERWISE.
 - F. MINIMUM WELD SIZE TO BE 0.1875 INCH FILLET WELDS, UNLESS NOTED OTHERWISE.
 - G. PRIOR TO FIELD WELDING GALVANIZING MATERIAL, CONTRACTOR SHALL GRIND OFF GALVANIZING 1/2" BEYOND ALL FIELD WELD SURFACES. AFTER WELD AND WELD INSPECTION IS COMPLETE, REPAIR ALL GROUND AND WELDED SURFACES WITH ZRC GALVILITE COLD GALVANIZING COMPOUND PER ASTM A780 AND MANUFACTURERS RECOMMENDATIONS.




THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THE SPECIFIED CARRIER IS STRICTLY PROHIBITED. TITLE TO THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.

| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| | | | |
| | | | |
| | | | |
| | | | |

ATC SITE NUMBER:
414240

ATC SITE NAME:
BYRAM PARK CT

SITE ADDRESS:
48 RITCH AVENUE WEST
GREENWICH, CT 06830



| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

GENERAL NOTES

| | |
|-------------------------------|-----------------------|
| SHEET NUMBER: G-002 | REVISION: 0 |
|-------------------------------|-----------------------|

Copyright © 2021 ATC IP LLC. All Rights Reserved.

SITE PLAN NOTES:


- THIS SITE PLAN REPRESENTS THE BEST PRESENT KNOWLEDGE AVAILABLE TO THE ENGINEER AT THE TIME OF THIS DESIGN. THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO CONSTRUCTION AND VERIFY ALL EXISTING CONDITIONS RELATED TO THE SCOPE OF WORK FOR THIS PROJECT.
- ICE BRIDGE, CABLE LADDER, COAX PORT, AND COAX CABLE ARE SHOWN FOR REFERENCE ONLY. CONTRACTOR SHALL CONFIRM THE EXACT LOCATION OF ALL PROPOSED AND EXISTING EQUIPMENT AND STRUCTURES DEPICTED ON THIS PLAN. BEFORE UTILIZING EXISTING CABLE SUPPORTS, COAX PORTS, INSTALLING NEW PORTS OR ANY OTHER EQUIPMENT, CONTRACTOR SHALL VERIFY ALL ASPECTS OF THE COMPONENTS MEET THE ATC SPECIFICATIONS.
- IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE WITH THE ATC CONSTRUCTION MANAGER AND LOCAL UTILITY COMPANY FOR THE INSTALLATION OF CONDUITS, CONDUCTORS, BREAKERS, DISCONNECTS, OR ANY OTHER EQUIPMENT REQUIRED FOR ELECTRICAL SERVICE. ALL ELECTRICAL WORK SHALL BE PERFORMED IN ACCORDANCE WITH LATEST EDITION OF THE STATE AND NATIONAL CODES, ORDINANCES AND REGULATIONS APPLICABLE TO THIS PROJECT.
- CONTRACTOR SHALL INSURE THAT ALL WORKING SPACE REQUIREMENTS ARE MET PER APPLICABLE CODES AND MANUFACTURER SPECIFICATIONS.
- ABOVE GROUND CONDUITS NEED TO BE SUPPORTED/FASTENED PER NEC 344, NEC 352, AND PER ATC CONSTRUCTION SPECIFICATIONS.
- THE FOLLOWING SIGNS SHALL BE INSTALLED AT TENANT SERVICE MAIN DISCONNECT PER NEC 702.7.
 - "CAUTION: TWO SOURCES OF SUPPLY STANDBY GENERATOR LOCATED OUTDOORS"
 - "WARNING: SHOCK HAZARD EXISTS IF GROUNDING ELECTRODE CONDUCTOR OR BONDING JUMPER CONNECTION IN THIS EQUIPMENT IS REMOVED WHILE ALTERNATE SOURCE IS ENERGIZED"

RODENT CONTROL AROUND GENERATOR ENVELOPE:



- INSTALL ALL PROVIDED SEALS, PLUGS, COVERS, ETC. IN GENERATOR AND FUEL TANK ENVELOPE. SEAL ALL REMAINING OPENINGS (EXCEPT NORMAL VENTING) WITH RODENT FOAM SEALANT. NO OPENING SHALL BE LARGER THAN 1/4 INCH ANY DIMENSION.
- SEAL ALL CONDUITS INCLUDING CONDUITS ENTERING GENERATOR EQUIPMENT, BOXES, ATTACHMENTS, ETC. WITH RODENT FOAM SEALANT.
- SEAL ALL CONDUIT ACCESS OPENINGS THROUGH CONCRETE PAD WITH CONCRETE.
- SLOPE GRAVEL BASE AT CONCRETE PAD PERIMETER FROM ABOVE PAD BASE TO EXISTING GRADE LEVEL TYPICAL ALL PERIMETER SIDES.

| LEGEND | |
|--------|---------------------------|
| ⊗ | GROUNDING TEST WELL |
| ATS | AUTOMATIC TRANSFER SWITCH |
| B | BOLLARD |
| CSC | CELL SITE CABINET |
| D | DISCONNECT |
| E | ELECTRICAL |
| F | FIBER |
| GEN | GENERATOR |
| G | GENERATOR RECEPTACAL |
| HH, V | HAND HOLE, VAULT |
| IB | ICE BRIDGE |
| K | KENTROX BOX |
| LC | LIGHTING CONTROL |
| M | METER |
| PB | PULL BOX |
| PP | POWER POLE |
| T | TELCO |
| TRN | TRANSFORMER |
| — x — | CHAINLINK FENCE |

| APPROXIMATE TRENCH DISTANCES | |
|------------------------------|----------------------|
| 25' | POWER CONDUIT TRENCH |



1 DETAILED SITE PLAN

AMERICAN TOWER®
A.T. ENGINEERING SERVICE, PLLC
 3500 REGENCY PARKWAY
 SUITE 100
 CARY, NC 27518
 PHONE: (919) 468-0112
 COA: PEC.0001553

THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.


| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| | | | |
| | | | |
| | | | |

ATC SITE NUMBER:
414240

ATC SITE NAME:
BYRAM PARK CT

SITE ADDRESS:
 48 RITCH AVENUE WEST
 GREENWICH, CT 06830


SEAL:




| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

SITE PLAN


SHEET NUMBER: **C-101** REVISION: **0**



PAD NOTES:

- PADS SHALL BE PRE-CAST MATCHING THIS DESIGN WHERE ALLOWED BY LOCAL JURISDICTION.
- PADS SHALL HAVE A MIN 28 DAY COMPRESSIVE STRENGTH AS SPECIFIED ON G-002, CONCRETE AND REINFORCING STEEL NOTES #3
- REFER TO CONCRETE & REINFORCED STEEL NOTES ON SHEET G-002 & ATC CONSTRUCTION SPECIFICATION 033000 FOR CAST-IN-PLACE PADS.
- STUB UP AREA SHALL BE FILLED WITH QUIKRETE, OR APPROVED EQUAL, PRIOR TO FINAL SET OF GENERATOR ON PAD.
- AFTER FINAL SET OF GENERATOR ON PAD, GROUT ALL EXTERIOR OPENINGS AT PAD INTERFACE SO THAT FINISHED MAXIMUM OPENING SHALL BE 1/4 INCH.
- GROUT SHALL BE PER ATC CONSTRUCTION SPECIFICATION DIVISION 03, CONCRETE.


1 REINFORCED PAD LAYOUT
SCALE: N.T.S.



TRENCH NOTES:

- IF FREE OF ORGANIC OR OTHER DELETERIOUS MATERIAL, EXCAVATED MATERIAL MAY BE USED FOR BACKFILL. IF NOT, PROVIDE CLEAN, COMPACTIBLE MATERIAL.
- COMPACT IN 8" LIFTS USING A MECHANICAL PLATE TAMPER, MIN 3 PASSES. REMOVE ANY LARGE ROCKS PRIOR TO BACKFILLING. CONTRACTOR TO VERIFY LOCATION OF EXISTING U/G UTILITIES PRIOR TO DIGGING. SEE ATC CONSTRUCTION SPECIFICATION 312000 SECTION 3.15.
- IF CURRENT AS-BUILT DRAWINGS ARE NOT AVAILABLE CONTRACTOR SHALL HAND DIG U/G TRENCHING.
- CONFIRM SPACING AND DEPTH WITH NEC OR LOCAL CODE REQUIREMENTS


3 CONDUIT TRENCH DETAILS
SCALE: N.T.S.



PAD NOTES:

- SUBGRADE AND FILL SHALL CONSIST OF CLEAN SOIL. DELETRIOUS MATERIAL AND ORGANICS SHALL BE REMOVED.
- MECHANICALLY COMPACT FOOTPRINT OF PAD PLUS 2' PERIMETER USING A MECHANICAL PLATE TAMPER, MIN 3 PASSES. SEE ATC CONSTRUCTION SPECIFICATION 312000 ACCESS ROAD AND EARTH WORK.
- USE GALVANIZED HILTI EXPANSION ANCHORS OR, APPROVED EQUAL, FOR EQUIPMENT ANCHORAGE.
- FOR SIZE AND LOCATION OF ANCHORS AND OTHER REQUIREMENT, SEE EQUIPMENT VENDOR DRAWINGS.

2 GRAVEL PREPARATION
SCALE: N.T.S.



H-FRAME NOTES:

- IF IT IS NECESSARY TO EXTEND THE H-FRAME, AN ADDITIONAL POST SHALL BE REQUIRED.
- PROPOSED UNISTRUTS TO BE FIELD CUT AND SHALL NOT EXTEND MORE THAN 6 INCHES BEYOND THE LAST POST.
- SPRAY ENDS OF UNISTRUT WITH COLD GALVANIZING SPRAY PAINT, ALLOW TO DRY, THEN COVER WITH RUBBER PROTECTIVE CAPS FOR SAFETY.
- UNISTRUT TO BE CUT FLUSH WITH NO SHARP OR JAGGED EDGES.
- ALL PROPOSED HARDWARE TO BE MOUNTED AND GROUNDED PER MANUFACTURERS SPECS
- ALL ITEMS ARE PROPOSED UNLESS OTHERWISE NOTED.
- LAYOUT H-FRAME & PROPOSED EQUIPMENT EXACTLY AS SHOWN TO ALLOW FOR FUTURE EQUIPMENT. ANY DEVIATIONS MUST BE APPROVED BY ATC CM, IN WRITING, NO EXCEPTIONS.
- FOOTINGS SHALL BE ONE OF THE FOLLOWING: USS POLECRETE STABILIZER SYSTEM, PRECAST CONCRETE (WHERE ALLOWED BY JURISDICTION) OR CAST IN PLACE. FOR PRECAST FOOTINGS, CONTRACTORS SHALL THOROUGHLY COMPACT THE PERIMETER (2' MIN) OF FOOTING WITH MECHANICAL PLATE TAMPER.

4 H-FRAME
SCALE: N.T.S.

THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THE SPECIFIED CARRIER IS STRICTLY PROHIBITED. TITLE TO THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.

| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| | | | |
| | | | |
| | | | |
| | | | |

ATC SITE NUMBER:
414240

ATC SITE NAME:
BYRAM PARK CT

SITE ADDRESS:
48 RITCH AVENUE WEST
GREENWICH, CT 06830

SEAL:



| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

CONCRETE PAD DETAILS

| | |
|---------------|-----------|
| SHEET NUMBER: | REVISION: |
| C-501 | 0 |

Copyright © 2021 ATC IP LLC, All Rights Reserved.



AMERICAN TOWER®
A.T. ENGINEERING SERVICE, PLLC
 3500 REGENCY PARKWAY
 SUITE 100
 CARY, NC 27518
 PHONE: (919) 468-0112
 COA: PEC.0001553

THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THE SPECIFIED CARRIER IS STRICTLY PROHIBITED. TITLE TO THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.

| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| | | | |
| | | | |
| | | | |
| | | | |

ATC SITE NUMBER:

414240


ATC SITE NAME:

BYRAM PARK CT

SITE ADDRESS:

48 RITCH AVENUE WEST
 GREENWICH, CT 06830


SEAL:



| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

**CONCRETE PAD
 DETAILS**

| | |
|---------------|-----------|
| SHEET NUMBER: | REVISION: |
| C-502 | 0 |




CONDUIT NOTE:

ABOVE GROUND CONDUITS NEED TO BE SUPPORTED/FASTENED PER NEC 344 AND PER ATC CONSTRUCTION SPECIFICATIONS.


1 CONDUIT ATTACHMENT
 SCALE: N.T.S.

Copyright © 2021 ATC IP LLC, All Rights Reserved.



- ONE-LINE NOTES:**
- CONNECT CT'S PER HTS OWNERS MANUAL-SECTION 3.11.2 INSTRUMENT PACKAGE
 - SPLICE WITH "POLARIS" TAPS OR APPROVED EQUAL, SECURELY WRAPPED WITH COMMERCIAL GRADE NYLON ELECTRICAL TAPE AFTER INSTALLATION IS COMPLETE.
 - UTILIZE EXISTING ENCLOSURES FOR SPLICING (PER NEC 312.8) OR INSTALL NEW JUNCTION BOX AS APPLICABLE PER SITE CONDITIONS AND CODES. SIZE JUNCTION BOX AS PER NEC 314.28
 - IF TAPPING AT TENANT EQUIPMENT, NO TAPS MAY BE MADE WITHIN THEIR EXISTING EQUIPMENT, INCLUDING PPC.
 - TAP GENERATOR PANEL CIRCUIT TO LUGS ON T-TERMINALS (LOAD SIDE) WITH AUXILIARY TAP SCREW. TERMINATE CONDUCTOR ON EACH LUG WITH INSULATED RING TERMINAL PROPERLY SIZED.
 - EMERGENCY POWER OFF PUSHBUTTON IN WEATHERPROOF ENCLOSURE FOR REMOTE SHUTDOWN OF GENERATOR ENCLOSURE. FURNISHED BY GENERATOR MANUFACTURER AND INSTALLED BY CONTRACTOR. CONNECT TO Y TERMINALS LOCATED NEAR TB2 VIA 2#18 AWG WIRES IN 1/2" LFMC.


1 ELECTRICAL ONE-LINE DIAGRAM
SCALE: NOT TO SCALE



GENERATOR INSTALLATION NOTE:
INSTALL GENERATOR AND TRANSFER SWITCH WITH ALL SUPPLIED ACCESSORIES PER MANUFACTURER'S INSTALLATION INSTRUCTIONS AND SPECIFICATIONS. THIS INCLUDES, BUT IS NOT LIMITED TO, ACCESSORIES FOR THE EXHAUST SYSTEM, FUEL SYSTEM, ENCLOSURE INTEGRITY (CAPS, PLUGS, COVERS, ETC.), ELECTRICAL CONNECTIONS, AND GROUNDING CONNECTIONS.

2 GENERATOR GROUNDING
SCALE: NOT TO SCALE

| DEMAND LOAD CALCULATION | |
|---------------------------|---------|
| GENERATOR LOADS | 2.5 KW |
| TENANT PANEL DEMAND LOADS | 25.0 KW |
| TOTAL DEMAND LOADS (KW) | 27.5 KW |
| TOTAL DEMAND CURRENT (A) | 114.5 A |
| AT 120/240V, 1PH, 3W | |




- CT NOTES:**
- CT'S FURNISHED BY GENERATOR MANUFACTURER WITH LEAD WIRE OPTION, 200:1 AMP RATIO.
 - WIRING SHOWN FOR SINGLE PHASE TENANT LOAD ON PHASES A-B. ADJUST ACCORDINGLY FOR INDIVIDUAL SITES THAT ARE BALANCING THREE PHASE SERVICES.
 - 1-PHASE: MOUNT ONE CT WITH WHITE DOT FACING AWAY FROM, AND OTHER CT WITH WHITE DOT FACING TOWARDS, THE ATS TERMINAL CONNECTIONS
 - 3-PHASE: MOUNT ALL CT'S WITH WHITE DOTS ALL FACING AWAY FROM THE ATS TERMINAL CONNECTIONS

3 CT WIRING DIAGRAM
SCALE: NOT TO SCALE

- NOTES:**
- INSTALL NETWORK OPERATING CENTER (NOC) MONITORING COMMUNICATION SYSTEM (RMC-700) ON MAIN UTILITY H-FRAME. THE RMC-700 IS FURNISHED BY ATC, COMPLETE WITH MOUNTING BRACKETS.
 - INSTALL EXTERNAL ANTENNA KIT (FURNISHED BY ATC). ANTENNA MOUNTS TO KENTROX ENCLOSURE OR MOUNTED TO H-FRAME. FEED CABLE THROUGH RMC-700 ENTRY PORT #3 AND CONNECT TO ANTENNA PORT TX/RX. HAND TIGHTEN ONLY. LEAVE POWER AND DATA CABLES IN RMC-700 UNCONNECTED FOR COMMISSIONING TEAM
 - BRANCH CIRCUIT WIRING FOR MONITORING DEVICE SHALL BE 2-#12 AWG CU, 1-#12 AWG CU G, IN 3/4" C.

5 PROPOSED MONITORING
SCALE: NOT TO SCALE



4 COMMUNICATIONS CABLE DETAIL
SCALE: NOT TO SCALE



THESE DRAWINGS AND/OR THE ACCOMPANYING SPECIFICATION AS INSTRUMENTS OR SERVICE ARE THE EXCLUSIVE PROPERTY OF AMERICAN TOWER. THEIR USE AND PUBLICATION SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY ARE PREPARED. ANY USE OR DISCLOSURE OTHER THAN THAT WHICH RELATES TO AMERICAN TOWER OR THE SPECIFIED CARRIER IS STRICTLY PROHIBITED. TITLE TO THESE DOCUMENTS SHALL REMAIN THE PROPERTY OF AMERICAN TOWER WHETHER OR NOT THE PROJECT IS EXECUTED. NEITHER THE ARCHITECT NOR THE ENGINEER WILL BE PROVIDING ON-SITE CONSTRUCTION REVIEW OF THIS PROJECT. CONTRACTOR(S) MUST VERIFY ALL DIMENSIONS AND ADVISE AMERICAN TOWER OF ANY DISCREPANCIES. ANY PRIOR ISSUANCE OF THIS DRAWING IS SUPERSEDED BY THE LATEST VERSION ON FILE WITH AMERICAN TOWER.

| REV. | DESCRIPTION | BY | DATE |
|------|------------------|----|----------|
| 0 | FOR CONSTRUCTION | AB | 06/03/21 |
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |

ATC SITE NUMBER:
414240

ATC SITE NAME:
BYRAM PARK CT

SITE ADDRESS:
48 RITCH AVENUE WEST
GREENWICH, CT 06830




| | |
|--------------|-------------|
| DRAWN BY: | AB |
| APPROVED BY: | PB |
| DATE DRAWN: | 06/03/21 |
| ATC JOB NO: | 13656281_M4 |

ELECTRICAL ONE-LINE AND WIRING DETAILS

| | |
|---------------|-----------|
| SHEET NUMBER: | REVISION: |
| E-601 | 0 |

Copyright © 2021 ATC IP LLC. All Rights Reserved.

REMOTE EMERGENCY STOP SWITCH SURFACE MOUNT, H-PANEL



- MANUFACTURER: PILLA ELECTRICAL PRODUCTS, INC.
- MODEL SG120
- GENERAC PART NUMBER 061129E
- SURFACE MOUNT, NEMA 4X
- NONMETALLIC BACKBOX

DIMENSIONS: mm[INCHES]



GENSET CONTROLS

1 OF 2

REMOTE EMERGENCY STOP SWITCH SURFACE MOUNT, H-PANEL

NOTES:

- 1) THE H-PANEL REMOTE E-STOP HARNESS IS SHOWN IN POSITION BETWEEN EXISTING INTEGRATED SWITCH CONNECTOR AND ENGINE HARNESS CONNECTOR. CONNECTION POINT IS LOCATED BEHIND THE H-PANEL HINGED COVER
- 2) SEE WIRING OR SCHEMATIC DIAGRAM(S) SPECIFIC TO UNIT FOR INFORMATION ON OTHER WIRES
- 3) FACTORY RUNS WIRING OUT OF H-PANEL ALONG ENGINE HARNESS THAT ENTERS LOW VOLTAGE CUSTOMER CONNECTION BOX. TIE WRAP ALONG HARNESS AS NEEDED.
- 4) THE H-PANEL WILL NOT RECOGNIZE THAT REMOTE E-STOP WAS ACTIVATED, BUT WILL STOP UNIT FROM RUNNING



GENSET CONTROLS

2 OF 2

Margie Weber

From: TrackingUpdates@fedex.com
Sent: Tuesday, June 29, 2021 10:32 AM
To: Margie Weber
Subject: FedEx Shipment 774115533127: Your package has been delivered



Hi. Your package was
delivered Tue, 06/29/2021 at
10:25am.



Delivered to 101 FIELD POINT RD, GREENWICH, CT 06830
Received by K.DELUCA


OBTAIN PROOF OF DELIVERY

TRACKING NUMBER [774115533127](#)

FROM NB+C
1777 Sentry Parkway West
Veva 17, Suite 400
BLUE BELL, PA, US, 19422

TO Town of Greewich
Fred Camillo, First Selectman
101 Field Point Road
1st Floor
GREENWICH, CT, US, 06830

| | |
|------------------------------|--------------------------|
| REFERENCE | 100510 |
| SHIPPER REFERENCE | 100510 |
| SHIP DATE | Mon 6/28/2021 03:48 PM |
| DELIVERED TO | Receptionist/Front Desk |
| PACKAGING TYPE | FedEx Envelope |
| ORIGIN | BLUE BELL, PA, US, 19422 |
| DESTINATION | GREENWICH, CT, US, 06830 |
| SPECIAL HANDLING | Deliver Weekday |
| NUMBER OF PIECES | 1 |
| TOTAL SHIPMENT WEIGHT | 0.50 LB |
| SERVICE TYPE | FedEx Standard Overnight |



Download the FedEx[®] Mobile app

Get the flexibility you need to create shipments and request to customize your deliveries through the app.

[LEARN MORE](#)

FOLLOW FEDEX




✉ Please do not respond to this message. This email was sent from an unattended mailbox. This report was generated at approximately 9:31 AM CDT 06/29/2021.

Margie Weber

From: TrackingUpdates@fedex.com
Sent: Tuesday, June 29, 2021 1:57 PM
To: Margie Weber
Subject: FedEx Shipment 774115565523: Your package has been delivered



Hi. Your package was delivered Tue, 06/29/2021 at 1:55pm.




Delivered to 16B ARTHUR ST, GREENWICH, CT 06831

OBTAIN PROOF OF DELIVERY

| | |
|--------------------------|--|
| TRACKING NUMBER | 774115565523 |
| FROM | NB+C 1777 Sentry Parkway West Veva 17, Suite 400 BLUE BELL, PA, US, 19422 |
| TO | 36 Ritch Avenue LLC 16B Arther Street GREENWICH, CT, US, 06831 |
| REFERENCE | 100510 |
| SHIPPER REFERENCE | 100510 |

| | |
|------------------------------|---|
| SHIP DATE | Mon 6/28/2021 03:48 PM |
| DELIVERED TO | Residence |
| PACKAGING TYPE | FedEx Envelope |
| ORIGIN | BLUE BELL, PA, US, 19422 |
| DESTINATION | GREENWICH, CT, US, 06831 |
| SPECIAL HANDLING | Deliver Weekday Residential Delivery |
| NUMBER OF PIECES | 1 |
| TOTAL SHIPMENT WEIGHT | 0.50 LB |
| SERVICE TYPE | FedEx Standard Overnight |



Download the FedEx[®] Mobile app

Get the flexibility you need to create shipments and request to customize your deliveries through the app.

[LEARN MORE](#)

FOLLOW FEDEX



✉ Please do not respond to this message. This email was sent from an unattended mailbox. This report was generated at approximately 12:57 PM CDT 06/29/2021.


All weights are estimated.

Margie Weber

From: TrackingUpdates@fedex.com
Sent: Tuesday, June 29, 2021 10:32 AM
To: Margie Weber
Subject: FedEx Shipment 774115545543: Your package has been delivered



Hi. Your package was
delivered Tue, 06/29/2021 at
10:25am.




Delivered to 101 FIELD POINT RD, GREENWICH, CT 06830
Received by K.DELUCA

OBTAIN PROOF OF DELIVERY

| | |
|------------------------|---|
| TRACKING NUMBER | 774115545543 |
| FROM | NB+C 1777 Sentry Parkway West Veva 17, Suite 400 BLUE BELL, PA, US, 19422 |
| TO | Town of Greewich Katie DeLuca, Director 101 Field Point Road 2nd Floor GREENWICH, CT, US, 06830 |

| | |
|------------------------------|--------------------------|
| REFERENCE | 100510 |
| SHIPPER REFERENCE | 100510 |
| SHIP DATE | Mon 6/28/2021 03:48 PM |
| DELIVERED TO | Receptionist/Front Desk |
| PACKAGING TYPE | FedEx Envelope |
| ORIGIN | BLUE BELL, PA, US, 19422 |
| DESTINATION | GREENWICH, CT, US, 06830 |
| SPECIAL HANDLING | Deliver Weekday |
| NUMBER OF PIECES | 1 |
| TOTAL SHIPMENT WEIGHT | 0.50 LB |
| SERVICE TYPE | FedEx Standard Overnight |



Download the FedEx[®] Mobile app

Get the flexibility you need to create shipments and request to customize your deliveries through the app.

[LEARN MORE](#)

FOLLOW FEDEX




✉ Please do not respond to this message. This email was sent from an unattended mailbox. This report was generated at approximately 9:31 AM CDT 06/29/2021.

STANDBY POWER RATING

80 kW, 100 kVA, 60 Hz

PRIME POWER RATING*

72 kW, 90 kVA, 60 Hz



*Built in the USA using domestic and foreign parts

*EPA Certified Prime ratings are not available in the U.S. or its Territories.


**Certain options or customization may not hold certification valid.

Image used for illustration purposes only


CODES AND STANDARDS

Generac products are designed to the following standards:

 UL2200, UL508, UL142, UL498

 NFPA70, 99, 110, 37

 NEC700, 701, 702, 708

 ISO9001, 8528, 3046, 7637,
Pluses #2b, 4

 NEMA ICS10, MG1, 250, ICS6, AB1

 **ANSI**
American National Standards Institute
ANSI C62.41

POWERING AHEAD

For over 50 years, Generac has led the industry with innovative design and superior manufacturing.

Generac ensures superior quality by designing and manufacturing most of its generator components, including alternators, enclosures and base tanks, control systems and communications software.

Generac's gensets utilize a wide variety of options, configurations and arrangements, allowing us to meet the standby power needs of practically every application.

Generac searched globally to ensure the most reliable engines power our generators. We choose only engines that have already been proven in heavy-duty industrial application under adverse conditions.

Generac is committed to ensuring our customers' service support continues after their generator purchase.

STANDARD FEATURES

ENGINE SYSTEM

General

- Oil Drain Extension
- Air Cleaner
- Fan Guard
- Stainless Steel flexible exhaust connection
- Critical Exhaust Silencer (enclosed only)
- Factory Filled Oil
- Radiator Duct Adapter (open set only)

Fuel System

- Fuel lockoff solenoid
- Primary fuel filter

Cooling System

- Closed Coolant Recovery System
- UV/Ozone resistant hoses
- Factory-Installed Radiator
- Radiator Drain Extension
- 50/50 Ethylene glycol antifreeze
- 120 VAC Coolant Heater

Engine Electrical System

- Battery charging alternator
- Battery cables
- Battery tray
- Solenoid activated starter motor
- Rubber-booted engine electrical connections

ALTERNATOR SYSTEM

- UL2200 GENprotect™
- 12 leads (3-phase, non 600 V)
- Class H insulation material
- Vented rotor
- 2/3 pitch
- Skewed stator
- Auxiliary voltage regulator power winding
- Amortisseur winding
- Brushless Excitation
- Sealed Bearings
- Automated manufacturing (winding, insertion, lacing, varnishing)
- Rotor dynamically spin balanced
- Full load capacity alternator
- Protective thermal switch

GENERATOR SET

- Internal Genset Vibration Isolation
- Separation of circuits - high/low voltage
- Separation of circuits - multiple breakers
- Silencer Heat Shield
- Wrapped Exhaust Piping
- Silencer housed in discharge hood (enclosed only)
- Standard Factory Testing
- 2 Year Limited Warranty (Standby rated Units)
- 1 Year Limited Warranty (Prime rated Units)
- Silencer mounted in the discharge hood (enclosed only)

ENCLOSURE (IF SELECTED)

- Rust-proof fasteners with nylon washers to protect finish
- High performance sound-absorbing material
- Gasketed doors
- Stamped air-intake louvers
- Air discharge hoods for radiator-upward pointing
- Stainless steel lift off door hinges
- Stainless steel lockable handles
- Rhino Coat™ - Textured polyester powder coat

TANKS (IF SELECTED)

- UL 142
- Double wall
- Vents
- Sloped top
- Sloped bottom
- Factory pressure tested (2 psi)
- Rupture basin alarm
- Fuel level
- Check valve in supply and return lines
- Rhino Coat™ - Textured polyester powder coat
- Stainless hardware

CONTROL SYSTEM



Control Panel

- Digital H Control Panel - Dual 4x20 Display
- Programmable Crank Limiter
- 7-Day Programmable Exerciser
- Special Applications Programmable PLC
- RS-232/485
- All-Phase Sensing DVR
- Full System Status
- Utility Monitoring
- Low Fuel Pressure Indication
- 2-Wire Start Compatible
- Power Output (kW)

- Power Factor
- kW Hours, Total & Last Run
- Real/Reactive/Apparent Power
- All Phase AC Voltage
- All Phase Currents
- Oil Pressure
- Coolant Temperature
- Coolant Level
- Engine Speed
- Battery Voltage
- Frequency
- Date/Time Fault History (Event Log)
- Isochronous Governor Control
- Waterproof/sealed Connectors
- Audible Alarms and Shutdowns
- Not in Auto (Flashing Light)
- Auto/Off/Manual Switch
- E-Stop (Red Mushroom-Type)
- NFPA110 Level I and II (Programmable)
- Customizable Alarms, Warnings, and Events
- Modbus protocol
- Predictive Maintenance algorithm
- Sealed Boards
- Password parameter adjustment protection

- Single point ground
- 15 channel data logging
- 0.2 msec high speed data logging
- Alarm information automatically comes up on the display

Alarms

- Oil Pressure (Pre-programmable Low Pressure Shutdown)
- Coolant Temperature (Pre-programmed High Temp Shutdown)
- Coolant Level (Pre-programmed Low Level Shutdown)
- Low Fuel Pressure Alarm
- Engine Speed (Pre-programmed Over speed Shutdown)
- Battery Voltage Warning
- Alarms & warnings time and date stamped
- Alarms & warnings for transient and steady state conditions
- Snap shots of key operation parameters during alarms & warnings
- Alarms and warnings spelled out (no alarm codes)

CONFIGURABLE OPTIONS

ENGINE SYSTEM

General

- Oil Heater
- Industrial Exhaust Silencer

Fuel System

- Flexible fuel lines
- Primary fuel filter

Engine Electrical System

- 10A UL battery charger
- 2.5A UL battery charger
- Battery Warmer

ALTERNATOR SYSTEM

- Alternator Upsizing
- Anti-Condensation Heater
- Tropical coating
- Permanent Magnet Excitation

CIRCUIT BREAKER OPTIONS

- Main Line Circuit Breaker
- 2nd Main Line Circuit Breaker
- Shunt Trip and Auxiliary Contact
- Electronic Trip Breaker

GENERATOR SET

- Gen-Link Communications Software (English Only)
- IBC Seismic Certification
- 8 Position Load Center
- 2 Year Extended Warranty
- 5 Year Warranty
- 5 Year Extended Warranty

ENCLOSURE

- Weather Protected
- Level 1 Sound Attenuation
- Level 2 Sound Attenuation
- Steel Enclosure
- Aluminum Enclosure
- 150 MPH Wind Kit
- 12 VDC Enclosure Lighting Kit
- 120 VAC Enclosure Lighting Kit
- AC/DC Enclosure Lighting Kit
- Door Alarm Switch

TANKS (Size on last page)

- Electrical Fuel Level
- Mechanical Fuel Level
- 8" Fill Extension
- 13" Fill Extension
- 19" Fill Extension

CONTROL SYSTEM

- 21-Light Remote Annunciator
- Remote Relay Panel (8 or 16)
- Oil Temperature Sender with Indication Alarm
- Remote E-Stop (Break Glass-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Flush Mount)
- Remote Communication - Modem
- Remote Communication - Ethernet
- 10A Run Relay
- Ground Fault Indication and Protection Functions

ENGINEERED OPTIONS

ENGINE SYSTEM

- Coolant heater ball valves
- Block Heaters
- Fluid containment pans

ALTERNATOR SYSTEM

- 3rd Breaker Systems

CONTROL SYSTEM

- Spare inputs (x4) / outputs (x4) - H Panel Only
- Battery Disconnect Switch

GENERATOR SET

- Special Testing

ENCLOSURE

- Motorized Dampers
- Door switched for intrusion alert
- Enclosure ambient heaters

TANKS

- Overfill Protection Valve
- UL2085 Tank
- ULC S-601 Tank
- Stainless Steel Tank
- Special Fuel Tanks (MIDEQ and FL DEP/DERM, etc.)
- Vent Extensions

RATING DEFINITIONS

Standby - Applicable for a varying emergency load for the duration of a utility power outage with no overload capability.

Prime - Applicable for supplying power to a varying load in lieu of utility for an unlimited amount of running time. A 10% overload capacity is available for 1 out of every 12 hours. The Prime Power option is only available on International applications. Power ratings in accordance with ISO 8528-1, Second Edition

APPLICATION AND ENGINEERING DATA

ENGINE SPECIFICATIONS

General

| | |
|--------------------------|--------------------------|
| Make | Iveco/FPT |
| EPA Emissions Compliance | Stationary Emergency |
| EPA Emissions Reference | See Emissions Data Sheet |
| Cylinder # | 4 |
| Type | In-Line |
| Displacement - L (cu In) | 4.5 (274.6) |
| Bore - mm (in) | 105 (4.1) |
| Stroke - mm (in) | 132 (5.2) |
| Compression Ratio | 17.5:1 |
| Intake Air Method | Turbocharged/Aftercooled |
| Cylinder Head Type | 2 Valve |
| Piston Type | Aluminium |
| Crankshaft Type | Forged Steel |

Engine Governing

| | |
|-------------------------------------|------------------------|
| Governor | Electronic Isochronous |
| Frequency Regulation (Steady State) | +/- 0.25% |

Lubrication System

| | |
|------------------------------|-------------|
| Oil Pump Type | Gear |
| Oil Filter Type | Full Flow |
| Crankcase Capacity - L (qts) | 13.6 (14.4) |

Cooling System

| | |
|---------------------------------|-------------------------|
| Cooling System Type | Closed |
| Water Pump | Belt Driven Centrifugal |
| Fan Type | Pusher |
| Fan Speed (rpm) | 2538 |
| Fan Diameter mm (in) | 660.4 (26) |
| Coolant Heater Wattage | 1500 |
| Coolant Heater Standard Voltage | 120 V /240 V |

Fuel System

| | |
|--------------------------|------------------------------|
| Fuel Type | Ultra Low Sulfur Diesel Fuel |
| Fuel Specifications | ASTM |
| Fuel Filtering (microns) | 5 |
| Fuel Injection | Stanadyne |
| Fuel Pump Type | Engine Driven Gear |
| Injector Type | Mechanical |
| Fuel Supply Line mm (in) | 12.7 (0.5) NPT |
| Fuel Return Line mm (in) | 12.7 (0.5) NPT |

Engine Electrical System

| | |
|-----------------------------|---------------------------------|
| System Voltage | 12 VDC |
| Battery Charging Alternator | 20 A |
| Battery Size | See Battery Index 0161970SBY |
| Battery Voltage | 12 VDC |
| Ground Polarity | Negative |

ALTERNATOR SPECIFICATIONS

| | |
|-------------------------------------|-----------|
| Standard Model | 390 |
| Poles | 4 |
| Field Type | Revolving |
| Insulation Class - Rotor | H |
| Insulation Class - Stator | H |
| Total Harmonic Distortion | <3% |
| Telephone Interference Factor (TIF) | <50 |

| | |
|------------------------------------|------------------------|
| Standard Excitation | Synchronous Brushless |
| Bearings | One-Pre Lubed & Sealed |
| Coupling | Direct, Flexible Disc |
| Load Capacity - Standby | 100% |
| Prototype Short Circuit Test | Yes |
| Voltage Regulator Type | Digital |
| Number of Sensed Phases | 3 |
| Regulation Accuracy (Steady State) | ± 0.25% |

OPERATING DATA

POWER RATINGS

| | | Standby |
|---------------------------------|-------|-----------|
| Single-Phase 120/240 VAC @1.0pf | 80 kW | Amps: 333 |
| Three-Phase 120/208 VAC @0.8pf | 80 kW | Amps: 278 |
| Three-Phase 120/240 VAC @0.8pf | 80 kW | Amps: 241 |
| Three-Phase 277/480 VAC @0.8pf | 80 kW | Amps: 120 |
| Three-Phase 346/600 VAC @0.8pf | 80 kW | Amps: 96 |

STARTING CAPABILITIES (sKVA)

| | | sKVA vs. Voltage Dip | | | | | | | | | | | |
|------------|-----|----------------------|-----|-----|-----|-----|-----|-------------|-----|-----|-----|-----|-----|
| | | 480 VAC | | | | | | 208/240 VAC | | | | | |
| Alternator | kW | 10% | 15% | 20% | 25% | 30% | 35% | 10% | 15% | 20% | 25% | 30% | 35% |
| Standard | 80 | 59 | 88 | 117 | 147 | 176 | 205 | 44 | 66 | 88 | 110 | 132 | 154 |
| Upsize 1 | 100 | 79 | 118 | 157 | 197 | 236 | 275 | 59 | 89 | 118 | 148 | 177 | 206 |
| Upsize 2 | 130 | 116 | 174 | 232 | 290 | 348 | 406 | 87 | 131 | 174 | 218 | 261 | 305 |

FUEL CONSUMPTION RATES*

| | | Diesel - gal/hr (l/hr) | |
|--|--|------------------------|------------|
| Fuel Pump Lift - ft (m) | | Percent Load | Standby |
| 3 (1) | | 25% | 2.1 (7.9) |
| | | 50% | 3.7 (14.0) |
| Total Fuel Pump Flow (Combustion + Return) | | 75% | 5.2 (19.7) |
| 13.6 gal/hr | | 100% | 6.3 (23.8) |

* Fuel supply installation must accommodate fuel consumption rates at 100% load.

COOLING

| | | Standby |
|--|---------------------|--------------|
| Coolant Flow per Minute | gal/min (l/min) | 32.7 (123.8) |
| Coolant System Capacity | gal (L) | 4.5 (17.44) |
| Heat Rejection to Coolant | BTU/hr | 232,270 |
| Inlet Air | cfm (m³/hr) | 6360 (180) |
| Max. Operating Radiator Air Temp | F° (C°) | 122 (50) |
| Max. Ambient Temperature (before derate) | F° (C°) | 104 (40) |
| Maximum Radiator Backpressure | in H ₂ O | 0.5 |

COMBUSTION AIR REQUIREMENTS

| | | Standby |
|---------------------|--------------|------------|
| Flow at Rated Power | cfm (m³/min) | 306 (8.67) |

ENGINE

| | | Standby |
|--------------------------|----------------|------------|
| Rated Engine Speed | rpm | 1800 |
| Horsepower at Rated kW** | hp | 131 |
| Piston Speed | ft/min (m/min) | 1559 (475) |
| BMEP | psi | 210 |









EXHAUST

| | | Standby |
|-----------------------------------|--------------|-------------|
| Exhaust Flow (Rated Output) | cfm (m³/min) | 782 (22.14) |
| Max. Backpressure (Post Silencer) | inHg (Kpa) | 1.5 (5.1) |
| Exhaust Temp (Rated Output) | °F (°C) | 887 (475) |
| Exhaust Outlet Size (Open Set) | mm (in) | 76.2 (3.0) |

** Refer to "Emissions Data Sheet" for maximum bHP for EPA and SCAQMD permitting purposes.

Deration – Operational characteristics consider maximum ambient conditions. Derate factors may apply under atypical site conditions. Please consult a Generac Power Systems Industrial Dealer for additional details. All performance ratings in accordance with ISO3046, BS5514, ISO8528 and DIN6271 standards.

DIMENSIONS AND WEIGHTS*



YOUR FACTORY RECOGNIZED GENERAC INDUSTRIAL DEALER

OPEN SET

| RUN TIME HOURS | USABLE CAPACITY GAL (L) | L x W x H in (mm) | WT lbs (kg) - Tank & Open Set | |
|----------------|-------------------------|--|-------------------------------|----------|
| | | | Steel | Aluminum |
| NO TANK | - | 93 (2362.2) x 40 (1016) x 49 (1244.6) | 2425 (1100) | |
| 13 | 79 (299) | 93 (2362.2) x 40 (1016) x 62 (1574.8) | 2947 (1201) | |
| 30 | 189 (715.4) | 93 (2362.2) x 40 (1016) x 74 (1879.6) | 3183 (1444) | |
| 48 | 300 (1135.6) | 93 (2362.2) x 40 (1016) x 86 (2184.4) | 3407 (1545) | |
| 56 | 350 (1325) | 110 (2794) x 40 (1016) x 86 (2184.4) | NA | |
| 81 | 510 (1930.5) | 117 (2971.8) x 47 (1193.8) x 86 (2184.4) | 3790 (1719) | |
| 93 | 589 (2229.6) | 128 (3251.2) x 49 (1244.6) x 86 (2184.4) | 4269 (1936) | |

STANDARD ENCLOSURE

| RUN TIME HOURS | USABLE CAPACITY GAL (L) | L x W x H in (mm) | WT lbs (kg) - Enclosure Only | |
|----------------|-------------------------|--|------------------------------|----------|
| | | | Steel | Aluminum |
| NO TANK | - | 112 (2844.8) x 41 (1041.4) x 56 (1422.4) | | |
| 13 | 79 (299) | 112 (2844.8) x 41 (1041.4) x 69 (1752.6) | | |
| 30 | 189 (715.4) | 112 (2844.8) x 41 (1041.4) x 81 (2057.4) | | |
| 48 | 300 (1135.6) | 112 (2844.8) x 41 (1041.4) x 93 (2362.2) | 425 (193) | 155 (70) |
| 56 | 350 (1325) | 112 (2844.8) x 41 (1041.4) x 93 (2362.2) | | |
| 81 | 510 (1930.5) | 117 (2971.8) x 47 (1193.8) x 93 (2362.2) | | |
| 93 | 589 (2229.6) | 128 (3251.2) x 49 (1244.6) x 93 (2362.2) | | |

LEVEL 1 ACOUSTIC ENCLOSURE

| RUN TIME HOURS | USABLE CAPACITY GAL (L) | L x W x H in (mm) | WT lbs (kg) - Enclosure Only | |
|----------------|-------------------------|--|------------------------------|-----------|
| | | | Steel | Aluminum |
| NO TANK | - | 130 (3302) x 41 (1041.4) x 56 (1422.4) | | |
| 13 | 79 (299) | 130 (3302) x 41 (1041.4) x 69 (1752.6) | | |
| 30 | 189 (715.4) | 130 (3302) x 41 (1041.4) x 81 (2057.4) | | |
| 48 | 300 (1135.6) | 130 (3302) x 41 (1041.4) x 93 (2362.2) | 450 (204) | 285 (129) |
| 56 | 350 (1325) | 130 (3302) x 41 (1041.4) x 93 (2362.2) | | |
| 81 | 510 (1930.5) | 130 (3302) x 47 (1193.8) x 93 (2362.2) | | |
| 93 | 589 (2229.6) | 130 (3302) x 49 (1244.6) x 93 (2362.2) | | |

LEVEL 2 ACOUSTIC ENCLOSURE

| RUN TIME HOURS | USABLE CAPACITY GAL (L) | L x W x H in (mm) | WT lbs (kg) - Enclosure Only | |
|----------------|-------------------------|---|------------------------------|-----------|
| | | | Steel | Aluminum |
| NO TANK | - | 112 (2844.8) x 41 (1041.4) x 69 (1752.6) | | |
| 13 | 79 (299) | 112 (2844.8) x 41 (1041.4) x 82 (2082.8) | | |
| 30 | 189 (715.4) | 112 (2844.8) x 41 (1041.4) x 94 (2387.6) | | |
| 48 | 300 (1135.6) | 112 (2844.8) x 41 (1041.4) x 106 (2692.4) | 625 (284) | 395 (180) |
| 56 | 350 (1325) | 112 (2844.8) x 41 (1041.4) x 106 (2692.4) | | |
| 81 | 510 (1930.5) | 117 (2971.8) x 47 (1193.8) x 106 (2692.4) | | |
| 93 | 589 (2229.6) | 128 (3251.2) x 49 (1244.6) x 106 (2692.4) | | |

*All measurements are approximate and for estimation purposes only. Sound dBA can be found on the sound data sheet. Enclosure Only weight is added to Tank & Open Set weight to determine total weight.

Specification characteristics may change without notice. Dimensions and weights are for preliminary purposes only. Please consult a Generac Power Systems Industrial Dealer for detailed installation drawings.