



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

**VIA ELECTRONIC MAIL**

January 25, 2024

Catherine Conklin  
Site Acquisition Specialist  
General Dynamics Wireless Services  
2586 Industry Lane, Suite 100  
Norristown, PA 19403  
[catherine.conklin@gdit.com](mailto:catherine.conklin@gdit.com)

RE: **EM-AT&T-059T-221028** - AT&T notice of intent to modify an existing telecommunications facility located at 75 Roberts Road, Groton, Connecticut. **Request for Project Change.**

Dear Catherine Conklin:

The Connecticut Siting Council (Council) is in receipt of the correspondence dated January 17, 2024 regarding a project change for the above-referenced exempt modification request acknowledged by the Council on November 28, 2022.

Pursuant to the Council's November 28, 2022 exempt modification approval, the request to install a Generac 50 kilowatt (kW) emergency backup generator in lieu of a 30 kW emergency backup generator is hereby approved.

This approval applies only to the project change in the correspondence dated January 17, 2024.

Thank you for your attention and cooperation.

Sincerely,

Melanie A. Bachman  
Executive Director

MAB/ANM/laf

c: The Honorable Rachael Franco, Mayor, Town of Groton ([rfranco@groton-ct.gov](mailto:rfranco@groton-ct.gov))  
John Burt, Town Manager, Town of Groton ([jburt@groton-ct.gov](mailto:jburt@groton-ct.gov))

**From:** Conklin, Catherine (NE) <Catherine.Conklin@gdit.com>

**Sent:** Wednesday, January 17, 2024 4:53 PM

**To:** Bachman, Melanie <Melanie.Bachman@ct.gov>; CSC-DL Siting Council <Siting.Council@ct.gov>

**Subject:** RCTB 10035316 Overlay-Groton Roberts Rd // EM-AT&T-059T-221028 // 75 Roberts Road, Groton, Connecticut

**Importance:** High

Good Afternoon,

Please see attached CSC approval for our AT&T generator project at the above subject site.

We have a slight change to the approval, which is (1) new Generac 50kw diesel generator (instead of 30kw) within the existing grade-level fenced equipment compound. Nothing else is changing.

Could you tell me if there is anything you would need from me.

Thank you

Catherine Conklin

Site Acquisition Specialist

M 301-266-0258

[Catherine.Conklin@gdit.com](mailto:Catherine.Conklin@gdit.com)

4603 Kemper Street

Rockville, MD 20853

[www.gdit.com](http://www.gdit.com)

**GENERAL DYNAMICS**  
Information Technology

"The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged information. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon this information by persons or entities other than the intended recipient is prohibited. If you received this in error, please contact the sender and delete the material from any computer."