


KENNETH C. BALDWIN

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

ORIGINAL

February 5, 2009



Michael Perrone
Siting Analyst
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

**Re: Cellco Partnership d/b/a Verizon Wireless
Exempt Modification Approval**

Dear Mr. Perrone:

Enclosed you will find a letter from Carlo F. Centore, P.E. with Natcomm Inc., confirming that the Verizon Wireless antenna installation was completed in accordance with the requirements of the Structural Analysis submitted as a part of the referenced exempt modification filing. The attached letter relates specifically to the following Siting Council filing.

1. EM-VER-064-080912
Hartford South 4 – 223 Brainard Road, Hartford, CT

If you have any questions regarding any of these materials, please do not hesitate to contact me or Rachel Mayo.

Sincerely,

A handwritten signature in blue ink, appearing to read "Kenya C. Baldwin".

Kenneth C. Baldwin



Law Offices

BOSTON

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY

SARASOTA

www.rc.com

Enclosures

Copy to:

Sandy M. Carter
Brian Ragozzine
Mark Gauger

HART1-1526364-1



February 02, 2009

Mr. Timothy Parks
Verizon Wireless
99 East River Drive
East Hartford, CT 06108

*Re: Structural Certification Letter
Verizon Wireless Site Ref ~ Hartford South 4
223 Brainard Road ~ Hartford, CT*

Natcomm Project No. 09006.00

Dear Mr. Parks,

Natcomm Inc., has been retained by Verizon Wireless to review the structural adequacy of the existing monopole foundation for the proposed installation of (12) panel antennas on a 13-ft low profile platform at the above referenced site.

A previous structural analysis was prepared by GPD Associates (GPD# 2008263.92, dated September 4, 2008 which determined that the tower structure above grade is sufficient for the existing and proposed loading. However, the foundation could not be verified based on the information provided.

Comprehensive research conducted by Natcomm Inc., has established that the existing foundation construction consists of a 45-ft long x 7.0-ft Ø reinforced drilled concrete caisson. Subsurface information was taken from a supplemental geotechnical investigation report prepared by Tectonic Engineering Consultants, P.C., dated March 16, 2000 and was compared against the findings of a subsequent summary of construction inspection letter also prepared by Tectonic Engineering Consultants, P.C., dated June 12, 2000.

The aforementioned supplemental information is available for reference in the Appendix of this review.

Refer to the Antenna and Appurtenance Summary below for a detailed description of the proposed antenna configuration.

Existing antenna/appurtenance configuration:

- AT&T: (Existing)
Antennas: Six (6) Powerwave 7770.00 panel antennas, six (6) Powerwave LPG21401 TMA's on a 13-ft platform with a RAD center elevation of 98-ft AGL.
Coax Cables: Twelve (12) 1-1/4" Ø coax cables (interior).

Proposed antenna/appurtenance configuration:

- **VERIZON WIRELESS (Proposed)**
Antennas: Six (6) Antel LPA 80063/4CF_5 and six (6) Antel LPA 185063/8CF_2 panel antennas on one (1) 13-ft Low Profile Platform with a RAD center elevation of 88-ft above the existing tower base plate.
Coax Cable: Twelve (12) 1-5/8" Ø coax cables (interior).

Re: Structural Certification Letter
Verizon Wireless Site Ref ~ Hartford South 4
223 Brainard Road ~ Hartford, CT

Page 2 of 2

Foundation

Review of the foundation design consisted of verification of applied loads obtained from the GPD Associates tower design calculations and code checks of allowable stresses:

- The tower base reactions developed from the governing Load Case 1 of the aforementioned design calculations were used in the verification of the caisson foundation and are listed below:

Base Reactions	Vector	Proposed Load (kips/ft-kips)
Base	Shear	10
	Axial	15
	Moment	749

- The foundation was found to be within allowable limits.

Foundation	Design Limit	Proposed Loading	Result
Reinforced Concrete Caisson	Moment Capacity	15.0%	PASS
	Lateral Deflection	0.24 in. ⁽¹⁾	PASS

(1) Lateral deflection limited to 0.5 in. for monopole tower structures.

Conclusion

This analysis shows that the subject tower **is adequate** to support the proposed modified antenna configuration.

The analysis is based, in part, on the information provided to this office by Verizon Wireless. If the existing conditions are different than the information in this report, Natcomm, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:

Carlo F. Centore, PE
Principal ~ Structural Engineer





at&t

Glynn Walker
AT&T Mobility
5405 Windward Pkwy
Alpharetta GA, 30004
(770) 708-6122



GPD ASSOCIATES

Kevin Clements
520 South Main St., Suite 2531
Akron, Ohio 44311
(330) 572-2195
kcllements@gpdgroup.com

GPD# 2008263.92
September 4, 2008

STRUCTURAL ANALYSIS REPORT

AT&T DESIGNATION:	Site USID: 4539 Site FA: 10071011 Site Name: EAST HARTFORD HOCHANUM
VERIZON DESIGNATION:	Site Name: Hartford South-4 Site Number: Hartford South-4
ANALYSIS CRITERIA:	Codes: TIA/EIA-222-F & 2003 IBC 80-mph with 0" ice 69-mph with 1/2" ice
SITE DATA:	223 Brainard Road, Hartford, CT 06114, Hartford County Latitude 41° 43' 58.0" N, Longitude 72° 39' 42.8" W 98' Monopole

Mr. Walker,


GPD is pleased to submit this Structural Analysis Report to determine the structural integrity of the aforementioned tower. The purpose of the analysis is to determine the suitability of the tower with the addition of the following proposed loading configuration:

Elev. 88' (6) Antel LPA-80063/4CF_5 Antennas on a 13' PiROD LP Platform, w/ (6) 1-5/8" internal coax
(6) Antel LPA-185063/8CF_2 Antennas on the same Platform, w/ (6) 1-5/8" internal coax

Based on our analysis we have determined the tower is sufficient for the proposed, existing, and reserved loadings as referenced in Appendix A. However, the foundation could not be verified based on the information provided.

We at GPD appreciate the opportunity of providing our continuing professional services to you and AT&T. If you have any questions please do not hesitate to call.

Respectfully submitted,



David B. Granger, P.E.
Connecticut #: 17557



SUMMARY & RESULTS

The purpose of this analysis was to verify that the existing structure is capable of carrying the proposed loading configuration as specified by Verizon Wireless to AT&T. This report was commissioned by Mr. Glynn Walker of AT&T.

No foundation or geotechnical information was available or provided for this report. Therefore, the in place capacity of the existing foundation could not be verified. A geotechnical investigation and foundation exploration are recommended to verify the capacity of the foundation with the proposed loading.

TOWER SUMMARY AND RESULTS

Member	Capacity	Results
Monopole	62.0%	Pass
Base Plate	43.6%	Pass
Anchor Rods	50.4%	Pass
Foundation	Not Verified	N/A

ANALYSIS METHOD

RISA Tower (Version 5.2.0.1), a commercially available software program, was used to create a three-dimensional model of the tower and calculate primary member stresses for various dead, live, wind, and ice load cases. Selected output from the analysis is included in Appendix B. The following table details the information provided to complete this structural analysis. This analysis is solely based on this information.

DOCUMENTS PROVIDED

Document	Remarks	Source
Preliminary Tower Summary	Verizon Wireless Co-location document	G. Walker
Tower Mapping	GPD Associates and STG Communications, dated 8/15/08	GPD
Co-Location Application	Verizon Wireless Application, dated 4/15/08	G. Walker

ASSUMPTIONS

This structural analysis is based on the theoretical capacity of the members and is not a condition assessment of the monopole. This analysis is from information supplied, and therefore, its results are based on and are as accurate as that supplied data. GPD has made no independent determination, nor is it required to, of its accuracy. The following assumptions were made for this structural analysis.

1. The monopole shaft sizes and shape are considered accurate as supplied. The material grade is as per data supplied and/or as assumed and as stated in the materials section.
2. The antenna configuration is as supplied and/or as modeled in the analysis. It is assumed to be complete and accurate. All antennas, mounts, coax and waveguides are assumed to be properly installed and supported as per manufacturer requirements
3. Some assumptions are made regarding antennas and mount sizes and their projected areas based on best interpretation of data supplied and of best knowledge of antenna type and industry practice.
4. All mounts, if applicable, are considered adequate to support the loading. No actual analysis of the mount(s) is performed. This analysis is limited to analyzing the tower only.
5. The soil parameters are as per data supplied or as assumed and stated in the calculations. If no data is available, the foundation system is not verified. In the case of absent foundation data, it is the tower owner's responsibility to insure that the foundation system is adequate to support the structure with its new reactions.
6. The tower and structures have been properly maintained in accordance with TIA Standards and/or with manufacturer's specifications.
7. All welds and connections are assumed to develop at least the member capacity, unless determined otherwise and explicitly stated in this report.
8. All prior structural modifications, if any, are assumed to be as per data supplied/available, to have been properly installed and to be fully effective.
9. Tower Mounted Amplifiers are assumed to be installed behind antennas.
10. All existing loading was obtained from the provided Preliminary Tower Summary, site photos and the Tower Mapping performed by GPD Associates and STG Communications on 8/15/08 and is assumed to be accurate.
11. All proposed coax is assumed to be internal to the monopole.

If any of these assumptions are not valid or have been made in error, this analysis may be affected, and GPD Associates should be allowed to review any new information to determine its effect on the structural integrity of the tower.

DISCLAIMER OF WARRANTIES

GPD ASSOCIATES has performed a site visit to the tower to verify the member sizes or antenna/coax loading. If the existing conditions are not as represented on the tower elevation contained in this report, we should be contacted immediately to evaluate the significance of the discrepancy. This is not a condition assessment of the tower or foundation. This report does not replace a full tower inspection. The tower and foundations are assumed to have been properly fabricated, erected, maintained, in good condition, twist free, and plumb.

The engineering services rendered by GPD ASSOCIATES in connection with this Structural Analysis are limited to a computer analysis of the tower structure and theoretical capacity of its main structural members. All tower components have been assumed to only resist dead loads when no other loads are applied. No allowance was made for any damaged, bent, missing, loose, or rusted members (above and below ground). No allowance was made for loose bolts or cracked welds.

GPD ASSOCIATES does not analyze the fabrication of the structure (including welding). It is not possible to have all the very detailed information needed to perform a thorough analysis of every structural sub-component and connection of an existing tower. GPD ASSOCIATES provides a limited scope of service in that we cannot verify the adequacy of every weld, plate connection detail, etc. The purpose of this report is to assess the feasibility of adding appurtenances usually accompanied by transmission lines to the structure.

It is the owner's responsibility to determine the amount of ice accumulation, if any, that should be considered in the structural analysis.

The attached sketches are a schematic representation of the analyzed tower. If any material is fabricated from these sketches, the contractor shall be responsible for field verifying the existing conditions, proper fit, and clearance in the field. Any mentions of structural modifications are reasonable estimates and should not be used as a precise construction document. Precise modification drawings are obtainable from GPD ASSOCIATES, but are beyond the scope of this report.

Miscellaneous items such as antenna mounts, etc., have not been designed or detailed as a part of our work. We recommend that material of adequate size and strength be purchased from a reputable tower manufacturer.

GPD ASSOCIATES makes no warranties, expressed and/or implied, in connection with this report and disclaims any liability arising from material, fabrication, and erection of this tower. GPD ASSOCIATES will not be responsible whatsoever for, or on account of, consequential or incidental damages sustained by any person, firm, or organization as a result of any data or conclusions contained in this report. The maximum liability of GPD ASSOCIATES pursuant to this report will be limited to the total fee received for preparation of this report.

APPENDIX A

Tower Analysis Summary Form

Tower Analysis Summary Form

General Info	
Site Name	EAST HARTFORD HOCHANUM.....
Site Number	4539
Site F/A	1007/1011
Date of Analysis	9/4/2008
Company Performing Analysis	GPD

The information contained in this summary report is not to be used independently from the PE stamped tower analysis.

Tower Info		Description	Date
Tower Type (C, SST, MP)	MP		
Tower Height (top of steel AGL)	98		
Tower Manufacturer	n/a		
Tower Model	n/a		
Manufacturer Design	n/a		
Foundation Design	n/a		
Geotech Report	n/a		
Tower Mapping	8/15/2008		
Foundation Mapping	n/a		
Previous Structural	n/a		

Steel Yield Strength (ksi)

Pole	50
Base Plate	50
Anchor Rods	75

Note: Yield Strengths Assumed

Existing/Reserved		Antenna				Mount				Transmission Line			
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) each	Azimuth	Quantity	Type	Model	EPA (ft ²) total	Quantity	Size	Attachment Leg/Face
AT&T Mobility	98	6	Panel	7770.00	5.88		1	Platform		24.80	12	1-1/4"	Internal
AT&T Mobility	98	6	TMA	LGP21401	shielded		on same mount						

Design Parameters		Existing Condition				Analysis Results (% Maximum Usage)			
Design Code Used	Location of Tower (County, State)	Tower	Foundation	Guy Wire	Ice Thickness (in)	Structure Classification (I, II, III)	Exposure Category (B, C, D)	Topographic Category (1 to 5)	
TIA/EIA-222-F	Hartford, Connecticut	80'-lastest	n/a	n/a	0.5"				42.2%

Proposed Condition		Proposed Condition				Proposed Condition	
Tower	Foundation	Guy Wire		Tower	Foundation	Guy Wire	

Existing		Antenna				Mount				Transmission Line			
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) each	Azimuth	Quantity	Type	Model	EPA (ft ²) total	Quantity	Size	Attachment Leg/Face
Verizon Wireless	88	6	Panel	LPA-80063/4CF_5	7.01		1	Platform		15.70	6	1-5/8"	Internal
Verizon Wireless	88	6	Panel	LPA-185063/5CF_2	2.97		on same mount				6	1-5/8"	Internal

Proposed		Antenna				Mount				Transmission Line			
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) each	Azimuth	Quantity	Type	Model	EPA (ft ²) total	Quantity	Size	Attachment Leg/Face
AT&T Mobility	98	3	Panel	7770.00	5.88	0,120,240		on same mount					

Future		Antenna				Mount				Transmission Line			
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) each	Azimuth	Quantity	Type	Model	EPA (ft ²) total	Quantity	Size	Attachment Leg/Face
AT&T Mobility	98												

Note: Future loading is in addition to the existing loading at the same elevation.

Revision:1.2
Date: 12/15/06

APPENDIX B

RISA Tower Output File

<p>RISA Tower</p> <p>GPD Group 520 South Main Street, Suite 2531 Akron, OH 44311 Phone: 330.572.2100 FAX: 330.572.2103</p>	Job	4539 EAST HARTFORD HOCHANUM	Page	1 of 2
	Project	2008263.92	Date	10:18:14 09/04/08
	Client	AT&T MOBILITY	Designed by	M. Moellendick

Tower Input Data

There is a pole section.

This tower is designed using the TIA/EIA-222-F standard.

The following design criteria apply:

Tower is located in Hartford County, Connecticut.

Basic wind speed of 80 mph.

Nominal ice thickness of 0.5000 in.

Ice density of 56pcf.

A wind speed of 69 mph is used in combination with ice.

Temperature drop of 50 °F.

Deflections calculated using a wind speed of 60 mph.

A non-linear (P-delta) analysis was used.

Pressures are calculated at each section.

Stress ratio used in pole design is 1.333.

Local bending stresses due to climbing loads, feedline supports, and appurtenance mounts are not considered.

Feed Line/Linear Appurtenances - Entered As Area

Description	Face or Leg	Allow Shield	Component Type	Placement ft	Total Number	C _A A _A	Weight klf
LDF6-50A (1-1/4 FOAM) (ATT)	A	No	Inside Pole	98.00 - 8.00	12	No Ice 1/2" Ice	0.00 0.00
LDF7-50A (1-5/8 FOAM) (VERIZON)	B	No	Inside Pole	88.00 - 8.00	12	No Ice 1/2" Ice	0.00 0.00

Discrete Tower Loads

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustment °	Placement ft	C _A A _A Front	C _A A _A Side	Weight K
Valmont 13' Platform w/o rails (GPD) (ATT)	A	None		0.0000	98.00	No Ice 1/2" Ice	24.80 26.20	24.80 26.20
(3) 7770.00 (ATT)	A	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27
(3) 7770.00 (ATT)	B	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27
(3) 7770.00 (ATT)	C	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27

RISA Tower GPD Group 520 South Main Street, Suite 2531 Akron, OH 44311 Phone: 330.572.2100 FAX: 330.572.2103	Job	4539 EAST HARTFORD HOCHANUM	Page
	Project	2008263.92	Date
	Client	AT&T MOBILITY	Designed by M. Moellendick


Description	Face or Leg	Offset Type	Offsets:	Azimuth Adjustment	Placement	C _{AA} Front	C _{AA} Side	Weight
			Horz	Lateral	Vert	ft	ft ²	K
(2) LGP21401 (ATT)	A	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.31	0.23 0.02
(2) LGP21401 (ATT)	B	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.31	0.23 0.02
(2) LGP21401 (ATT)	C	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.31	0.23 0.02
PiROD 13' Low Profile Platform (VERIZON)	A	None		0.0000	90.00	No Ice 1/2" Ice	15.70 20.10	15.70 20.10
(2) LPA-80063/4CF (VERIZON)	A	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48
(2) LPA-80063/4CF (VERIZON)	B	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48
(2) LPA-80063/4CF (VERIZON)	C	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48
(2) LPA-185063/8CFx2 (VERIZON)	A	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05
(2) LPA-185063/8CFx2 (VERIZON)	B	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05
(2) LPA-185063/8CFx2 (VERIZON)	C	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05

Section Capacity Table

Section No.	Elevation ft	Component Type	Size	Critical Element	P K	SF*P _{allow} K	% Capacity	Pass Fail
L1	98 - 77	Pole	TP28.371x25.44x0.1875	1	-4.36	659.12	21.3	Pass
L2	77 - 40.5	Pole	TP33.466x27.5075x0.25	2	-8.18	1037.47	49.6	Pass
L3	40.5 - 0	Pole	TP39.12x32.4446x0.3125	3	-14.56	1539.31	62.0	Pass
						Summary		
						Pole (L3)	62.0	Pass
						RATING =	62.0	Pass

APPENDIX C

Tower Elevation Drawing



DESIGNED APPURTEINANCE LOADING


TYPE	ELEVATION	TYPE	ELEVATION
Valmont 13' Platform w/o rails (GPD) (ATT)	98	(2) LPA-80063/4CF (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-80063/4CF (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-80063/4CF (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(2) LGP21401 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(2) LGP21401 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
PiROD 13' Low Profile Platform (VERIZON)	90		

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi			

TOWER DESIGN NOTES

1. Tower is located in Hartford County, Connecticut.
2. Tower designed for a 80 mph basic wind in accordance with the TIA/EIA-222-F Standard.
3. Tower is also designed for a 69 mph basic wind with 0.50 in ice.
4. Deflections are based upon a 60 mph wind.
5. TOWER RATING: 62%



GPD Group
520 South Main Street, Suite 2531
Akron, OH 44311
Phone: 330.572.2100
FAX: 330.572.2103

Job: **4539 EAST HARTFORD HOCHANUM**
Project: **2008263.92**
Client: **AT&T MOBILITY** Drawn by: **M. Moellendick** App'd:
Code: **TIA/EIA-222-F** Date: **09/04/08** Scale: **NTS**
Path: **G:\Telecom\2008263.92\visa\4539\Hartford.erl** Dwg No. **E-1**

APPENDIX D

Anchor Rod & Base Plate Analysis

Anchor Rod and Base Plate Stresses
4539 EAST HARTFORD HOCHANUM

Oversetting Moment =	749.00	k*ft
Axial Force =	15.00	k
Shear Force =	10.00	k

Anchor Rods	
Pole Diameter =	39.12 in
Number of Rods =	8
Rod Grade (Fy) =	75 ksi
Rod Circle =	44.878 in
Rod Diameter =	2.25 in
Net Tensile Area =	3.25 in ²
0 Degrees	
Max Tension on Rod =	68.93 kips
Max Compression on Rod =	72.68 kips
45 Degrees	
Max Tension on Rod =	98.26 kips
Max Compression on Rod =	102.01 kips
Allow. Rod Force =	195.00 kips
Anchor Rod Capacity =	50.4% OK

Base Plate	
Plate Strength (Fy) =	50 ksi
Plate Thickness =	2.75 in
Plate Width =	44 in
Est. Dist. b/w Rods =	6 in
w _{calc} =	13.02 in
e =	1.7542 in
w _{max} =	23.105 in
w =	13.02 in
S =	16.41 in ³
f _b =	21.81 ksi
F _b =	50 ksi
Base Plate Capacity =	43.6% OK

TECTONIC ENGINEERING CONSULTANTS P.C.

P.O. Box 37-70 Pleasant Hill Road
Mountaintop, New York 14953

AT&T Wireless PCS LLC
149 Water Street
Norwalk, Connecticut 06854

Attention: Mr. Bill Appleton

OFFICES:
Albany, NY
Carroll, NY
Mt. Vernon, NY
(800) 820-6434
Fax: (914) 234-5999
www.tecnicengineering.com

Cincinnati, OH
Norfolk/Virginia,
Richmond, VA
(800) 820-6434
Fax: (914) 234-5999

March 16, 2000

RE: W.O. 2323-126
**SUPPLEMENTAL GEOTECHNICAL INVESTIGATION
PROPOSED 120-FOOT MONOPOLE AND EQUIPMENT SHELTER
RELOCATED LEASE AREA
EAST HARTFORD (CT-126) - SOBOL ENTERPRISES
223 BRAINARD ROAD
HARTFORD, CONNECTICUT**

Dear Mr. Appleton:

We have performed a supplemental geotechnical investigation at the above referenced site for the proposed monopole and equipment shelter installations. The supplemental investigation was conducted to determine if the design parameters and construction recommendations made in our January 28, 2000 geotechnical report for construction at the originally proposed monopole location is applicable to the new monopole location. The revised monopole location is approximately 200 feet from the originally proposed location.

Results of the investigation indicate that the soils at the relocated monopole position generally have a looser consistency, especially at greater depths. Therefore the recommendations made in our original report are not valid and should not be used for design.

Revised foundation design and construction recommendations are presented herein. These will be preceded by a discussion of the design considerations, a description of the site conditions and a description of the present subsurface investigation and encountered subsurface conditions.

TECTONIC**1.0 DESIGN CONSIDERATIONS**

The proposed structures include a 120-foot high monopole for mounting of communication antennas and an equipment shelter. For the proposed monopole structure, it is expected that the overturning loads will be large, whereas the vertical and horizontal loads will be modest in comparison. The proposed unmanned equipment shelter will have a footprint area of approximately 12-foot by 20-foot. The equipment shelter foundations are expected to be subjected to relatively light loads. The equipment loads from the monopole structure and the unmanned equipment shelter are to be determined by others. We assume that the site will not be re-graded by more than 1 or 2 feet relative to existing grade.

2.0 SITE DESCRIPTION

The project site is located at 223 Brainard Road in Hartford, Connecticut, which is just east of the intersection of Route 5 and Interstate Highway 91. The revised lease area is situated about 140 feet west of an existing movie theater building and about 250 feet east of Interstate Highway 91. The area is generally level and vegetated with grass and weeds. There are sporadic mounds of debris in the area. They were observed to contain leaves, tires and other materials. The ground surface descends south of the site and wetland type vegetation was observed in the lower area. There is also a small brook or ditch about 60 feet west of the proposed lease area.

3.0 FIELD INVESTIGATION

The supplemental field investigation consisted of one test boring, designated as boring B-3, which was drilled at the revised monopole location. These borings supplemented the two borings which were performed during the initial site investigation identified as borings B-1 and B-2. The location of the test borings as well as the locations of the originally proposed and revised monopole locations are shown on the attached Boring Location Plan, Figure 1.

The supplemental boring was drilled by Geotechnical Drilling, Inc. on March 13, 2000. The boring was advanced to a depth of 49 feet utilizing 3 ½ inch diameter hollow-stem augers. Standard Penetration Testing (SPT) and split-spoon sampling were performed continuously to a depth of 12 feet and at 5-foot intervals thereafter. The groundwater level was measured after the completion of the boring. An engineering geologist observed the boring operations on a full time basis. A log of the present boring as well as the logs of the initially conducted borings are attached.

4.0 SUBSURFACE CONDITIONS

The general subsurface stratigraphy encountered at the revised monopole location is similar to that encountered at borings B-1 and B-2 except that the soil consistency was generally softer. At boring B-3, the subsurface conditions consist of an approximately 2-foot thick layer of fill overlying an approximately 28 foot thick layer of loose to very loose silty sands overlying an approximately 17 foot thick layer of very soft silty clay overlying very dense glacial till.

The fill, which consists of brown to gray medium to fine sand with some silt, little fine gravel and trace metal debris had a Standard Penetration Test (SPT) blow count of 10 blows per foot (bpf). This indicates that the fill is in a medium dense condition.

The underlying sands are generally fine to medium to fine in gradation and are tan in color. The sands contain from approximately 10 to 40 percent silt with the silt content decreasing with depth. The sands occasionally contain trace amounts of gravel and are micaceous. SPT blow counts in the sands ranged between 2 and 4 bpf to a depth of 12 feet indicating the sands are in a very loose condition within this depth interval. From a depth of 15 feet to 27 feet, the SPT blow counts ranged between 6 and 8 bpf indicating the sands are in a generally loose condition within this interval.

The underlying silty clay is typically red-gray to red in color and typically contains minor amounts of sand. SPT blow counts in the silty clay ranged from 1 bpf to the weight of the hammer assembly (the sampler penetrates 1-foot under the weight of the hammer alone). These indicate very soft consistencies within the silty clay.

Glacial till underlies the clay at an approximate depth of 47 feet. The till is comprised of red coarse to fine sand with some clayey silt and some fine gravel. An SPT blow count of 72 bpf in the till indicate it is in a very dense condition.

Groundwater was measured at a depth of approximately 2 feet at boring B-3. This corresponds to an approximate groundwater elevation of 408 feet. However, it should be noted that the groundwater level will fluctuate seasonally and with changes in weather conditions.

5.0 MONPOLE FOUNDATION RECOMMENDATIONS

Based on the results of the supplemental subsurface investigation, it is our opinion that construction of the foundations for the proposed monopole structure and the proposed equipment shelter is feasible relative to geotechnical considerations, provided the revised

recommendations presented in this report are incorporated into the design and construction.

5.1 Design Criteria

We recommend the monopole be supported on a drilled shaft foundation. Parameters for a mat foundation can also be provided if this alternative is desired. The drilled shaft foundation should have a minimum embedment depth of 15 feet, or at least 3 times the designed shaft diameter, whichever is deeper. The actual depth of embedment and diameter of the drilled shaft should be determined by the design engineer based on the actual loads and the geotechnical design criteria presented in this report.

For the purpose of design, the groundwater table should be taken as being at the existing ground surface. The geotechnical engineering parameters provided below are based on these groundwater conditions.

The following allowable net bearing pressures and allowable side resistance values should be used to design the drilled shaft to resist the vertical compressive loads:

Depth (feet)	Allowable Net End Bearing Pressure, q_b (Pounds per Sq. Ft.)	Allowable Side Resistance ⁽¹⁾ (Pounds per Sq. Ft.)
0 to 5	NA	NA
5 to 15	NA	120 to 250
15 to 25	2800	250 to 360
25 to 30	500	360 to 400
30 to 47	500	45
47 to 49	12,000	550

(1) The values are estimated based on casting concrete directly against the sidewall of the excavation on the same day that the excavation is started.
Use zero side friction at the top 5 feet.

The following soil parameters are provided for designing to resist lateral movement and tilting and for analyzing lateral deflection and lateral stability. Lateral deflection at the top of the drilled shaft should be checked using a computer program such as LPIL. Maximum deflection should not exceed that recommended by the monopole manufacturer.

Depth (feet)	γ (psf)	ϕ (degrees)	C_u (psf)	K_l (psi)	K_p	ε_{so} (inch/inch)
0 to 5	50	NA	NA	NA	NA	NA
5 to 15	50	28	NA	20	2.77	NA
15 to 30	50	30	NA	20	3.0	NA
30 to 47	45	0	200	30	NA	0.02
47 to 49	60	36	NA	125	3.85	NA

where,

 γ = design unit weight of soil (pounds per cubic foot). ϕ = angle of internal friction (degrees). C_u = undrained shear strength (pounds per square foot). K_l = coefficient of lateral subgrade reaction (pounds per cubic inch) required for p-y curve methods of analysis. K_p = coefficient of passive pressure. ε_{so} = axial strain of soil corresponding to one-half of the maximum principal stress difference.

5.2 Construction Criteria

The drilled shafts should be constructed under the full-time observation of the geotechnical engineer and in accordance with the most recent standards of the ASDC and ACI 336. The geotechnical engineer should observe the drilling to confirm that the subsurface conditions are consistent with those found at the boring location. The bearing stratum should be explored with a probe hole below the bottom of the drilled shaft, at the discretion of the geotechnical engineer, in order to verify the bearing capacity of the underlying stratum. If test results indicate that the stratum is not capable of providing the required bearing pressure, adjustments to the drilled shaft depth should be made as directed by the geotechnical engineer.

The use of slurry or temporary casing or possibly both for the full depth of the shaft could be necessary to maintain stability of the sides and bottom of the hole. Prior to placement of concrete, the bottom of the shaft should be cleared of loose material. Free water in quantities sufficient to cause settlement or affect concrete strength should be removed from the excavation in a manner that will not loosen the subgrade. If the drilled shaft cannot be dewatered, or if dewatering would result in disturbance of the

foundation subgrade or the sidewalls of the excavation, then the concrete should be placed using tremie methods. Tremie concrete methods are also required if slurry is used. If casing is used, concrete placement should be done in a manner to prevent "hecking" of the caisson.

6.0 UNMANNED EQUIPMENT SHELTER FOUNDATION RECOMMENDATIONS

The unmanned equipment shelter is proposed on the east side of the lease area. Based on our review of the project plans, it is our understanding that the equipment platform will be a one-story structure with exterior dimensions of approximately 12 feet by 20 feet and will be supported on conventional spread footings. We recommend that the footings be founded on the natural sand soils. The bottom of the footings should be no less than 3.5 feet below finished grade to protect against frost penetration. An allowable bearing pressure of 750 psi should be used to determine the dimensions of the footings. The widths of the spread footings should be at least 2.5 feet for isolated footings and no less than 1.5 feet for continuous footings.

All footing subgrades should be inspected by the geotechnical engineer. If unsuitable materials such as organic materials, soft, wet soil or debris are encountered, they should be removed from the zone of influence of the footings. The zone of influence for removal of unsuitable materials is defined by the imaginary lines sloping at one vertical (1V) to one horizontal (1H) from the bottom edges of the footings. Material removed from the zone of influence of footings should be replaced with compacted structural fill placed in 8 inch thick loose lifts and compacted to at least 95 percent of the maximum density as determined in the laboratory in accordance with ASTM D1557. In confined areas, where compaction is limited to the use of hand operated equipment, the structural fill should be placed in 4-inch thick loose lifts. Structural fill should be a clean well-graded granular soil having no more than 15 percent by weight passing the No. 200 sieve. The material should also be free of organic matter and debris and have a moisture content suitable for compaction.

Groundwater will likely be encountered during excavation. Dewatering should be performed in a manner that will not disturb or loosen the subgrade soils. Sumping should not be conducted in subgrade areas. If possible, rainfall runoff should be intercepted outside of the excavation area. Subgrade material softened by water or exposure should be removed and replaced with compacted structural fill.

Mr. Appleton/CT-126

Page 7

March 16, 2000

7.0 LIMITATIONS

Our professional services have been performed using that degree of care and skill ordinarily exercised under similar circumstances by reputable geotechnical engineers and geologists practicing in this or similar situations. The interpretation of the field data is based on good judgment and experience. However, no matter how qualified the geotechnical engineer or detailed the investigation, subsurface conditions cannot always be predicted beyond the points of actual sampling and testing. No other warranty, expressed or implied, is made as to the professional advice included in this report.

This report has been prepared for the exclusive use of AT&T Wireless PCS LLC for the specific application to the "East Hartford (CT-126)" site located at 223 Brainerd Road in Hartford, Connecticut.

In the event that any changes in the design or location of the proposed monopole and unmanned equipment shelter structures are planned, the conclusions and recommendations contained in this report shall not be considered valid unless reviewed and verified in writing by Tectonic Engineering Consultants P.C. It is recommended that Tectonic Engineering be retained to provide construction monitoring and inspection services to ensure proper implementation of the recommendations contained herein, which would otherwise limit our professional liability.

We trust this report will allow you to proceed with design of the proposed foundations.

Sincerely,

TECTONIC ENGINEERING CONSULTANTS, PC




Richard P. Kummerle, P.E.
Managing Principal


RPK/GPM File #:\geo\general\2323129\HAWP.doc

Attachments: Figure 1, Boring Location Plan
Boring Logs, B-1, B-2 and B-3
Legend Sheet for Soil Descriptions

Cc: Jeff Kirby, P.E. - Tectonic









TECTONIC ENGINEERING CONSULTANTS P.C.

PROJECT No. 2323.126		BORING No. B-2				
CLIENT: A&T Wireless PCS, LLC	PROJECT: East Hartford (CT-126)	LOCATION: Hartford, CT				
CONTRACTOR: General Borings, Inc.		SHEET No. 1 of 1				
METHOD OF ADVANC. BORING	DIA.	DEPTH				
POWER AUGER:	4 1/4"	TO 4'	MON. WELL <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO			
ROT. DRILL:		SCREEN DEPTH:	TO SURFACE ELEVATION: 9' See Remarks			
CASING:		WEATHER: Clear	DATE START: 1/24/00			
DIAMOND CORE:		DEPTH TO ROCK: N/A	TEMP: 30 F DATE FINISH: 1/24/00			
UNCONFIRMED COMPRESSIVE STRENGTH (ELEVATION (FT.))						
SAMPLES	RECOV.	SOIL CLASS	*CHANGES IN STRATA ARE INFERRED			
DEPTH (FT.)	INCHES (IN.)	RESIST. (BL/6 IN.)	DESCRIPTION OF MATERIAL			
2 DR MIN. (FT.)	2 DR MAX. (FT.)	LENGHT (IN.)	UNIFIDURE SUMMER RESIST. (%)	MOISTURE RESIST. (%)		
1 - 18	10	S-1	14	M	SM	Top 6" possible FILL, organics, gravel
2	9	S-2	18	W	SM	Gy bwn f SAND,some Silt
3 - 13	8	S-2	18	W	SM	Gy bwn f SAND, little Silt
4	5	S-3	16	W	SM	Gy bwn m-f SAND, little Silt (micaceous)
5 - 8	4	S-3	16	W	SM	Gy bwn m-f SAND, little Silt (micaceous)
6	5	S-4	18	W	SM	Bwn m-f SAND, little Silt (micaceous)
7 - 11	6	S-4	18	W	SM	Bwn m-f SAND, little Silt (micaceous)
8	4	S-5	18	W	SM	Same
9 - 15	5	S-5	18	W	SM	Same
10	9	S-6	20	W	SM	Same
11 - 11	4	S-6	20	W	SM	Same
12	7					End of Boring at 12.0' (Water level at 4.5' with augers. After augers pulled, hole caved)
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						

REMARKS: Surface elevation estimated based on "Site Plan & Site Detail Plan" (C-2) by Tectonic Engineering Consultants P.C.






TECTONIC
ENGINEERING CONSULTANTS INC.

LEGEND FOR SOIL DESCRIPTION

GRANULAR SOIL (Coarser than No. 200 sieve)		GRAIN SIZE	
DESCRIPTIVE TERM	SAND	GRAVEL	
coarse " c	No. 4 Sieve to No. 10 Sieve	3" to 3/4"	
medium - m	No. 10 Sieve to No. 40 Sieve	Less than 10% coarse and medium	
fine - f	No. 40 Sieve to No. 200 Sieve	Less than 10% coarse	
COBBLES		Less than 10% coarse and fine	
BOULDERS	3" to 10"	Less than 10% fine	
	10" +	All greater than 10%	
GRADATION DESIGNATIONS		PROPORTIONS OF COMPONENT	
Fine, f		Less than 10% coarse and medium	
medium to fine, m-f		Less than 10% coarse	
medium, m		Less than 10% coarse and fine	
coarse to medium, c-m		Less than 10% fine	
coarse, c		Less than 10% medium and fine	
coarse to fine, c-f		All greater than 10%	
COHESIVE SOIL (Finer than No. 200 sieve)		PLASTICITY	
DESCRIPTION	PLASTICITY INDEX	PLASTICITY	
Silt	0 - 1	none	
Clayey Silt	2 - 5	slight	
Silt & Clay	6 - 10	low	
Clay & Silt	11 - 20	medium	
Silty Clay	21 - 40	high	
Clay	greater than 40	very high	
PROPORTION		PERCENT OF SAMPLE BY WEIGHT	
DESCRIPTIVE TERM		1 - 10	
trace		10 - 20	
little		20 - 35	
some		35 - 50	
and			
The primary component is fully capitalized.			
COLOR	Blue - blue	Gy - gray	Wh - White
	Blk - black	Or - orange	Yl - Yellow
	Bwn - brown	Rd - red	Lgt - light
	Gn - green	Tm - tan	DK - dark
SAMPLE NOTATION		TESTS	
S	- Split Spoon Soil Sample	WOC	- Weight of Casing
U	- Undisturbed Tube Sample	WOR	- Weight of Rods
C	- Core Sample	WH	- Weight of Hammer
B	- Bulk Soil Sample	PPR	- Compressive Strength based on Pocket Penetrometer
NR	- No Recovery of Sample	TV	- Shear Strength (tsf) based on Torvane

NOTES

1. PLAN BASED ON DRAWING ENTITLED
 "SITE DETAIL PLAN", DRAWING NO. C-2,
 REV. 1, DATED 1/7/00 BY TECTONIC
 ENGINEERING CONSULTANTS P.C.



TECTONIC ENGINEERING
 CONSULTANTS P.C.
 P.O. Box 447, 615 Route 32
 Newfield, N.Y. 10930
 (914) 925-5531

BORING LOCATION PLAN

AT&T WIRELESS PCS SITE NO. CT-126
 PROPOSED 120-FOOT MONPOLE
 REVISED MONPOLE LOCATION
 223 BRAINARD ROAD, HARTFORD, CT

Date	Work Order	Opening No.	Rev
3/16/00	2323.126	FIG-1	0

TECTONIC

ENGINEERING
CONSULTANTS P.C.

P.O. Box 37, 70 Pleasant Hill Road
Mountainville, New York 10553

OFFICES:
Albany, NY Cincinnati, OH
Cornwall, NY Northborough, MA
Mt. Vernon, NY Richmond, VA

(800) 929-6531 FAX: (914) 534-5999
www.tectonicengineering.com

Anil Mehta, Structural Engineer
City of Hartford
Department of Licenses and Inspections
550 Main Street
Hartford, CT 06103

June 12, 2000

RE: W.O. 2323.126
AT&T WIRELESS PCS SITE NO. CT-126
223 BRAINARD ROAD
HARTFORD, CT
APPLICATION #20000320
SUMMARY OF CONSTRUCTION INSPECTION

Dear Mr. Mehta:

The foundation for the monopole at the above referenced site was constructed on May 23 and 24, 2000. An engineer from this office was on site both days, and continuously inspected the construction work. In addition, the concrete was sampled and tested by a representative from Eastern Materials Testing Laboratory. Copies of the Field Reports (8 pages total) are attached.


A total of twelve (12) concrete test cylinders (three sets of four) were cast. One cylinder from each set was tested at 7 days. The testing demonstrated that the 7-day strength of the concrete exceeds the specified 28-day requirement. Copies of the laboratory strength test reports (3 pages) are also attached.

On review of these reports, we find that the monopole foundation, as constructed, satisfies all of the design requirements shown on the plans.

If you have any questions or concerns, please contact me directly at (914) 534-5959.

Sincerely,

TECTONIC ENGINEERING CONSULTANTS P.C.



Jeffrey B. Kirby, P.E.
Chief Structural Engineer

No. 21291

LICENSED

CONTRACTOR

STATE OF CONNECTICUT

REGISTRATION NO.

EXPIRES

cc: C. Chapman / AT&T
J. Desjardins / Pinnaclle


D. Garber / AT&T

J. Hiller

T. Critelli

file jk142/AT&T/Conn/126ConstInspRep

TECTONIC ENGINEERING CONSULTANTS P.C.	CAISSON INSTALLATION REPORT		Project No.: 2323.126 Date: 5-23-00
	CAISSON NO:	1	Project: East Hartford (CT-126) Location: 223 Rainward Rd Hartford CT.
Client: AT&T Wireless PCS LLC	Tectonic's Representative: Myron Chapin		
Contractor: Buffalo Drilling Co.	Weather/Temp: Cloudy, Rain		
Contractor's Representative: Mark Brunning	Referenced Plans: Tectonic (1-7-00)		
Drilling Machine: Type: LDM-80T	Structure: Monopole		
Torque (ft.-lb.): 100,000 ft-lb Downward Force (lb.): 50,000 lb	Surface Elevation: 13.0' (See Remarks)		
Drilling Tool: Auger	SKETCH (Include pertinent subsurface soil and/or rock profile and groundwater elevations)		
DESIGN DATA			
Caisson Location: Center-line of Monopole			
Type: Open <input type="checkbox"/> Cased <input checked="" type="checkbox"/> Top 10' ± Cased			
Diameter (in): 84			
Top Elevation: 13.5 ±			
Bottom Elevation: -31.0 ±			
Length (ft): 44.5 ±			
Bell Diameter (in): NA			
AS-BUILT DATA			
Date Drilling Started: 5-23-00			
Date Drilling Completed: 5-24-00			
Date Cleaning Completed: 5-24-00			
Date Caisson Accepted: 5-24-00			
Diameter (in): 84 ±			
Top Elevation: 13.7 ±	3 Estimated		
Bottom Elevation: -36.3'			
Total Length (ft): 45.0'			
Bell Diameter (in): NA			
Deviation from Vertical: Very minimal			
Proof Test Hole: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Depth (ft.)			
Description of Proof Test Hole: NA			
Drilling Slurry (If used note type and proportion of additive and, if required, density, viscosity, sand content, etc.) Shane Pac GCR, a Polymer Slurry by Letco.			
Casing (type, diameter and length) Steel, 7.3" Ø x 10.8' Length from approximately 1.5' to 11.3' deep			
Steel Reinforcement (no. bars, size and length) 30 #10 Vertical w/ #4 hoops as specified			
Concrete: Date Concrete Placed: 5-24-00 Method Placed: Pumped Tremie Volume in Caisson: 67 yd³ (Before to Allotted Concrete Inspection and Test Report for Concrete Data) Inspection performed by Others.			
REMARKS: (setbacks, cave-ins, cavities, waterflow, slurry lost, etc.) Elevation measured using Sighted level and near-by Bench Mark (Elevation accurate to less than 0.5'). (GC: Brois Construction Corp. (John Spiegel))			



FROM : TECTONIC-MOUNTAINVILLE


PHONE NO. : 9145345670

Jun. 13 2000 10:52AM P4

TECTONIC ENGINEERING
CONSULTANTS PC
Highland Mills, NY
Richmond, VA
Albany, NY
Northborough, MA
Cincinnati, OH
(800) 829-6531

JOB 2323.126 East Hartford (CT-126)
SHEET NO. 4 OF 7
CALCULATED BY MC2 DATE 5-23-00
CHECKED BY _____ DATE _____
SCALE _____

Theoretical Volume (yd^3) vs. Drilled
ShaFT height (ft) For a 7' diameter
ShaFT





Eastern
Materials
Testing
Laboratory

FIELD REPORT

A Division of

JAWORSKI
GEOTECH, INC.

Project:	East Hartford Monopole 2323.126 East Hartford, CT	Client:	Techtonic Engineering
Project No.:	00402C	Contractor:	Brois Construction
Date:	May 24, 2000	Weather:	partly cloudy
Purpose:	To review concrete construction and fabricate specimens for strength testing.		

Contractor Activities:

Upon arrival at the site, it was observed that Brois Construction had prepared a ringed rebar cage. The cage was lowered by crane into position into a pre-drilled hole measuring 6-feet in diameter and approximately 43-feet deep. Buffalo Drilling subsequently pumped 80-cubic yards of 5,000 psi concrete that was supplied by Builder's Concrete into the prepared location. American Concrete Pumping Company was contracted to provide the concrete pumping. Upon placement, the concrete was manually worked into position and vibrated.

JGI Activities:

Concrete compressive strength test cylinders were fabricated from today's concrete placement in accordance with ASTM C 31. Refer to the Concrete Strength Test Summary of this date for details.

Locations of today's project activities are illustrated on the attached Field Sketch.

Prepared by: B. Harris

Reviewed by: MGH Date: 5/31/00

TEST RESULTS	<input type="checkbox"/>	DO	<input type="checkbox"/>	DO NOT COMPLY WITH SPECIFICATIONS
	<input type="checkbox"/>	ARE NOT COMPLETE	<input checked="" type="checkbox"/>	OR <input type="checkbox"/> ARE NOT APPLICABLE
A DEVIATION REPORT	<input type="checkbox"/>	IS ATTACHED	<input checked="" type="checkbox"/>	IS NOT ATTACHED
	<input type="checkbox"/>	HAS BEEN AMENDED AND	<input type="checkbox"/>	IS ATTACHED
OBSERVED CONSTRUCTION	<input checked="" type="checkbox"/>	DOES	<input type="checkbox"/>	DOES NOT COMPLY WITH SPECIFICATIONS
	<input type="checkbox"/>	IS NOT COMPLETE	<input type="checkbox"/>	NOT APPLICABLE

The information stated on this report may not be reproduced except in its entirety without the express written consent of Eastern Materials Testing a division of Jaworski Geotech, Inc. Use of the NVLAP designation does not represent endorsement by the NIST or NVLAP. Reports are relevant only to items tested and no other attribution may be made.

FIELD SKETCH

Project: EAST HARTFORD MONOPOLEProject No.: 00402 CDate: 5-24


a Division of Jaworski Geotech, Inc.

Brennard Rd

North



HUSKY HARDWOOD

PARKING LOT CYCLINDER SAMPLES



NVLAP #10315-0

Eastern Materials Testing Laboratory
a division of
JAWORSKI GEOTECH, INC.

A Division of

**JAWORSKI
GEOTECH, INC.**

CONCRETE DATA SUMMARY

Project: East Hartford Monopole
 East Hartford, CT
 Client: Techtonic Consultants
 Supplier: Builder's Concrete

Project No.: 00402C
 Contractor: Brois Construction
 SubContractor: Buffalo Drilling
 JGI Representative: S. Harris

PLACEMENT DATA

Placement Date: 5/24/00

Time: 1:45

Class Concrete: 5,000 psi

Total Quantity 80

Batch Quantity: 10 cy

Method of Placement: chute, pump

Location of Sample: 43' below top of placement

Total Location of Placement:
 cell tower footing

Cylinder Set No.: C1

Truck No.: 19

Ticket No.: 91724

Batch Time: 1:25

Air: Specified: 4-7%
 Measured: 3.75 %Slump Specified: 3-5"
 Measured: 5"

Unit Weight: 149.21 lbs/cu./ft.

Plastic Wt.: Cylinder Wt.:

Concrete Temperature: 80 degrees F

Ambient Temp: 82 degrees

Date Retrieved:

Method of Compression: Neoprene Caps


Cylinder Size: 6 x 12 inches

End Area: 28.27 sq in

BATCH TICKET INFORMATION (reduced to 1 cubic yard)

Cem1	749.0	lbs./cu.yd	Sand:	1206.0	lbs./cu.yd
Cem2		lbs./cu.yd	Water:	241.0	lbs./cu.yd
Cem 3		lbs./cu.yd	Ad1 NCA	152.0	oz/cu.yd
Agg 1 3/4"	1080.0	lbs./cu.yd	Ad2 Air	3.8	oz/cu.yd
Agg 2 1/2"	730.0	lbs./cu.yd	Ad3		oz/cu.yd
Agg 3		lbs./cu.yd	Ad4		oz/100 CWT

Sand Moisture: 4.5% Stone Moisture:

**COMPRESSIVE STRENGTH DATA**

Cylinder ID	C 1 A	C 1	B	C 1	C	C 1	D
Date Cast .	5/24/00	5/24/00		5/24/00		5/24/00	
Date Tested	5/31/00	6/21/00		6/21/00		7/19/00	
Specimen Age	(7 days)	(28 days)	(28 days)	(56 days)			
Cyl. Weight(lbs.)	29.28	29.18		29.08		29.10	
Load (lbs.)	97,888						
Stress (psi)	3,460						
Type of Fracture	a						

Reviewed by: _____ Date: 5/31/00

The information stated on this report may not be reproduced except in its entirety without the express written consent of Eastern Materials Testing, a division of Jaworski Geotech, Inc. Use of the NVLAP designation does not represent endorsement by the NIST or NVLAP. Reports are relevant only to items tested, and no other attribution may be made. Sampling and testing were performed in general accordance with the following ASTM standards: C 39, C 31, C 94, C 143, C 172, C 192, C 231, C 617, and C 1231.



NVLAP #10315-0

Eastern Materials Testing Laboratory
a division of
JAWORSKI GEOTECH, INC.

**CONCRETE DATA SUMMARY**

Project: East Hartford Monopole
 East Hartford, CT
 Client: Techtonic Consultants
 Supplier: Builder's Concrete

Project No.: 00402C
 Contractor: Brois Construction
 SubContractor: Buffalo Drilling
 JGI Representative: B. Harris

PLACEMENT DATA

Placement Date: 5/24/00
 Time: 2:30
 Class Concrete: 5,000 psi
 Total Quantity 80
 Batch Quantity: 10 cy
 Method of Placement: chute, pump
 Location of Sample: 43' below top of placement
 Total Location of Placement:
 cell tower footing


Cylinder Size: 6 x 12 inches
 End Area: 28.27 sq in

Cylinder Set No.: C2
 Truck No.: 18
 Ticket No.: 91727
 Batch Time: 2:00
 Air: Specified: 4-7%
 Measured: 2.5%
 Slump Specified: 3-5"
 Measured: 6.25"
 Unit Weight: 148.19 lbs/cu./ft.
 Plastic Wt.: Cylinder Wt.:
 Concrete Temperature: 80 degrees F
 Ambient Temp: 82 degrees
 Date Retrieved:
 Method of Compression: Neoprene Caps

BATCH TICKET INFORMATION (reduced to 1 cubic yard)

Cem1	750.0	lbs./cu.yd	Sand:	1212.0	lbs./cu.yd
Cem2		lbs./cu.yd	Water:	231.5	lbs./cu.yd
Cem 3		lbs./cu.yd	Ad1 NCA	152.0	oz/cu.yd
Agg 1 3/4"	1080.0	lbs./cu.yd	Ad2 Air	3.8	oz/cu.yd
Agg 2 1/2"	730.0	lbs./cu.yd	Ad3		oz/cu.yd
Agg 3		lbs./cu.yd	Ad4		oz/100 CWT

Sand Moisture: 4.5 % Stone Moisture:

**COMPRESSIVE STRENGTH DATA**

Cylinder ID	C 2 A	C 2	B	C 2	C	C 2	D
Date Cast	5/24/00	5/24/00		5/24/00		5/24/00	
Date Tested	5/31/00	6/21/00		6/21/00		7/19/00	
Specimen Age	(7 days)	(28 days)	(28 days)	(56 days)			
Cyl. Weight(lbs.)	29.08	29.64		29.28		29.36	
Load (lbs.)	109,950						
Stress (psi)	3,890						
Type of Fracture	a						

Reviewed by: _____

Date: 5/31/00

The information stated on this report may not be reproduced except in its entirety without the express written consent of Eastern Materials Testing a division of Jaworski Geotech, Inc. Use of the NVLAP designation does not represent endorsement by the NIST or NVLAP. Reports are relevant only to items tested, and no other attribution may be made. Sampling and testing were performed in general accordance with the following ASTM standards: C 39, C 31, C 94, C 143, C 172, C 192, C 231, C 617, and C 1231.



NVLAP #10315-0

Eastern Materials Testing Laboratory
a division of
JAWORSKI GEOTECH, INC.

**CONCRETE DATA SUMMARY**

Project: East Hartford Monopole
 East Hartford, CT
 Client: Techtonic Consultants
 Supplier: Builder's Concrete

Project No.: 00402C
 Contractor: Brois Construction
 SubContractor: Buffalo Drilling
 JGI Representative: B. Harris

PLACEMENT DATA

Placement Date: 5/24/00
 Time: 3:45
 Class Concrete: 5,000 psi
 Total Quantity 80
 Batch Quantity: 10 cy
 Method of Placement: chute, pump
 Location of Sample: .43' below top of placement

Total Location of Placement:
 cell tower footing


Cylinder Size: 6 x 12 inches
 End Area: 28.27 sq in

Cylinder Set No.: C3
 Truck No.: 19
 Ticket No.: 91730
 Batch Time: 2:30
 Air: Specified: 4-7%
 Measured: 4.5%
 Slump Specified: 3-5"
 Measured: 5"
 Unit Weight: 146.87 lbs/cu./ft.
 Plastic Wt.: Cylinder Wt.:
 Concrete Temperature: 80 degrees F
 Ambient Temp: 82 degrees
 Date Retrieved:
 Method of Compression: Neoprene Caps

BATCH TICKET INFORMATION (reduced to 1 cubic yard)

Cem1	750.0	lbs./cu./yd Sand:
Cem2		lbs./cu./yd Water:
Cem 3		lbs./cu./yd Adl NCA
Agg 1 3/4"	1080.0	lbs./cu./yd Ad2 Air
Agg 2 1/2"	722.0	lbs./cu./yd Ad3
Agg 3		lbs./cu./yd Ad4

1214.0	lbs./cu./yd
247.0	lbs./cu./yd
152.0	oz/cu./yd
3.8	oz/cu./yd
	oz/cu./yd
	oz/100 CWT



Sand Moisture:

Stone Moisture:

COMPRESSIVE STRENGTH DATA

Cylinder ID	C 3 A	C 3 B	C 3 C	C 3 D
Date Cast	5/24/00	5/24/00	5/24/00	5/24/00
Date Tested	5/31/00	6/21/00	6/21/00	7/19/00
Specimen Age	(7 days)	(28 days)	(28 days)	(56 days)
Cyl. Weight(lbs.)	28.82	28.80	28.84	28.84
Load (lbs.)	100,260			
Stress (psi)	3,550			
Type of Fracture	a			

Reviewed by: _____ Date: 5/31/00

The information stated on this report may not be reproduced except in its entirety without the express written consent of Eastern Materials Testing a division of Jaworski Geotech, Inc. Use of the NVLAP designation does not represent endorsement by the NIST or NVLAP. Reports are relevant only to items tested, and no other attribution may be made. Sampling and testing were performed in general accordance with the following ASTM standards: C39, C31, C94, C143, C172, C192, C231, C617, and C1231.



Daniel F. Caruso
Chairman

STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Internet: ct.gov/csc

October 1, 2008

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103-3597

RE: **EM-VER-064-080912** - Cellco Partnership d/b/a Verizon Wireless notice of intent to modify an existing telecommunications facility located at 223 Brainard Road, Hartford, Connecticut.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) hereby acknowledges your notice to modify this existing telecommunications facility, pursuant to Section 16-50j-73 of the Regulations of Connecticut State Agencies with the condition that the foundation be analyzed for adequacy and a signed letter from a Professional Engineer duly licensed in the State of Connecticut is submitted to the Council to certify that the foundation is adequate to support the proposed loading, or in the alternative, that reinforcements were performed to bring the foundation rating to not more than 100 percent.

The proposed modifications are to be implemented as specified here and in your notice dated September 12, 2008, including the placement of all necessary equipment and shelters within the tower compound. The modifications are in compliance with the exception criteria in Section 16-50j-72 (b) of the Regulations of Connecticut State Agencies as changes to an existing facility site that would not increase tower height, extend the boundaries of the tower site, increase noise levels at the tower site boundary by six decibels, and increase the total radio frequencies electromagnetic radiation power density measured at the tower site boundary to or above the standard adopted by the State Department of Environmental Protection pursuant to General Statutes § 22a-162. This facility has also been carefully modeled to ensure that radio frequency emissions are conservatively below State and federal standards applicable to the frequencies now used on this tower.


This decision is under the exclusive jurisdiction of the Council. Please be advised that the validity of this action shall expire one year from the date of this letter. Any additional change to this facility will require explicit notice to this agency pursuant to Regulations of Connecticut State Agencies Section 16-50j-73. Such notice shall include all relevant information regarding the proposed change with cumulative worst-case modeling of radio frequency exposure at the closest point of uncontrolled access to the tower base, consistent with Federal Communications Commission, Office of Engineering and Technology, Bulletin 65. Any deviation from this format may result in the Council implementing enforcement proceedings pursuant to General Statutes § 16-50u including, without limitation, imposition of expenses resulting from such failure and of civil penalties in an amount not less than one thousand dollars per day for each day of construction or operation in material violation.

October 1, 2008

Page 2


Thank you for your attention and cooperation.

Very truly yours,


S. Defek Phelps
Executive Director

SDP/MP/jb

c: The Honorable Eddie A. Perez, Mayor, City of Hartford
Lee C. Erdmann, Chief Operating Officer, City of Hartford
Roger J. O'Brien, Director of Planning, City of Hartford
Christopher B. Fisher, Esq., Cuddy & Feder LLP



Daniel F. Caruso
Chairman

STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Internet: ct.gov/csc

September 16, 2008

The Honorable Eddie A. Perez
Mayor
City of Hartford
Municipal Building
550 Main Street
Hartford, CT 06103

RE: **EM-VER-064-080912** - Cellco Partnership d/b/a Verizon Wireless notice of intent to modify an existing telecommunications facility located at 223 Brainard Road, Hartford, Connecticut.

Dear Mayor Perez:

The Connecticut Siting Council (Council) received this request to modify an existing telecommunications facility, pursuant to Regulations of Connecticut State Agencies Section 16-50j-72.

If you have any questions or comments regarding this proposal, please call me or inform the Council by September 30, 2008.

Thank you for your cooperation and consideration.

Very truly yours,

S. Derek Phelps
Executive Director

SDP/jb

Enclosure: Notice of Intent

c: Roger J. O'Brien, Director of Planning, City of Hartford

ORIGINAL

KENNETH C. BALDWIN

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

September 12, 2008

Via Hand Delivery

S. Derek Phelps
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RECEIVED
SEP 12 2008
CONNECTICUT
SITING COUNCIL

Re: **Notice of Exempt Modification**
223 Brainard Road, Hartford, Connecticut

Dear Mr. Phelps:

Cellco Partnership d/b/a Verizon Wireless ("Cellco") intends to install antennas on the existing 98-foot monopole tower owned by AT&T and located at 223 Brainard Road in Hartford, Connecticut. Please accept this letter as notification pursuant to R.C.S.A. § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to Eddie A. Perez, Mayor of the City of Hartford. Pursuant to a Council directive, a copy of this letter is also being sent to 221-233 Brainard Road LLC, the owner of the property on which the tower is located.

The facility consists of a 98-foot monopole tower capable of supporting multiple carriers at 223 Brainard Road in Hartford. AT&T antennas located at the 98-foot level on the tower. Cellco intends to install four (4) LPA-80063/4CF; two (2) LPA-80080/4CF; four (4) LPA-185063/8CF and two (2) LPA-185080/8CF antennas at the 88-foot level on the tower. Associated equipment, including a propane fueled back-up generator, will be located within a 12' x 30' equipment shelter on the ground adjacent to the tower. Cellco will also install a 1000 gallon propane tank adjacent to its shelter. Attached behind Tab 1 are Project Plans for the proposed Cellco facility.

The planned modifications to the Hartford facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).



Law Offices

BOSTON

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY

SARASOTA

www.rc.com

HART1-1478007-1

ROBINSON & COLE LLP

S. Derek Phelps
September 12, 2008
Page 2

1. The proposed modification will not increase the overall height of the existing tower. Cellco's antennas will be mounted with their centerline at the 88-foot level on the 98-foot tower.

2. The proposed installation of the associated equipment shelter and propane tank will not require an extension of the fenced compound or the lease area.

3. The proposed installation will not increase the noise levels at the facility by six decibels or more.

4. The operation of the antennas will not increase radio frequency (RF) power density levels at the facility to a level at or above the Federal Communications Commission (FCC) adopted safety standard. The RF power density calculations for Cellco antennas would be 24.65% of the FCC standard. A power density calculations table is included behind Tab 2.

Included behind Tab 3 is a Structural Analysis Report confirming that the tower can support the existing and Cellco antennas, and associated equipment.

For the foregoing reasons, Cellco respectfully submits that the proposed antenna installation at the facility constitutes an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,



Kenneth C. Baldwin

Attachments

Copy to:

Eddie A. Perez, Hartford Mayor
221-233 Brainard Road LLC
Sandy M. Carter
Michelle Kababik



**CELLCO PARTNERSHIP
DBA**

verizon wireless

HARTFORD SOUTH 4


223 BRAINARD ROAD

HARTFORD, CONNECTICUT 06114

GENERAL NOTES

1. THE TYPE, DIMENSIONS, MOUNTING HARDWARE, AND POSITIONS OF ALL PROJECT OWNER'S EQUIPMENT ARE SHOWN IN ILLUSTRATIVE FASHION. THESE DRAWINGS ARE NOT INTENDED QUANTITATIVELY FROM WHAT IS SHOWN.
2. THE PROJECT OWNER'S PCS FACILITY IS AN UNPLANNED PRIVATE AND SECURED EQUIPMENT INSTALLATION. IT IS ONLY ACCESSIBLE BY TRAINED TECHNICIANS FOR PERIODIC ROUTINE MAINTENANCE AND THEREFORE DOES NOT REQUIRE ANY WATER OR SANITARY ACCESS. MAINTENANCE AND SECURITY ARE THE RESPONSIBILITY OF THE PROJECT OWNER.
3. THE USE OF THE ANTENNAE, MOUNTING HARDWARE, AND SUPPORT SYSTEMS FOR MOUNTING ANTENNAE AND STATE BUILDING CODE REQUIREMENTS DURING CONSTRUCTION, INSPECTION, AND STRUCTURAL INSPECTIONS WILL BE PROVIDED BY A REGULATED ENGINEER AND APPROVED BY THE LOCAL BUILDING CODE ENFORCEMENT REVIEW AND APPROVAL.
4. ONCE THE FACILITY BECOMES FULLY OPERATIONAL, NORMAL AND ROUTINE MAINTENANCE BY PROJECT OWNER'S TECHNICIANS WILL BE PERFORMED ON A MONTHLY BASIS. THEREFORE, THE ESTIMATED VEHICLE TOP GENERATION RATE (ADT) IS 0.02.

VICINITY MAP



PROJECT SUMMARY


SITE NAME:	HARTFORD SOUTH 4
SITE ADDRESS:	223 BRAINARD ROAD, HARTFORD, CONNECTICUT 06114
CONTACT PERSON:	VERIZON WIRELESS BRIAN TAYLOR (860) 982-2426
TOWER OWNER:	AT&T MOBILITY 5400 WILLOWBROOK PARKWAY ASPHENITA, OK 73004
COVERING CODE:	CONNECTICUT BUILDING CODES CONNECTICUT LIFE SAFETY CODES
APPLICATIONS:	VERIZON WIRELESS 100 EAST HARTFORD, CT 06106
ARCHITECT:	USC CORPORATION, A.C.S., SUITE 3B 500 ENTERPRISE DRIVE, CT 06007
M/F/P DIMENSIONS:	USC CORPORATION, A.C.S., SUITE 3B 500 ENTERPRISE DRIVE, CT 06007
LATITUDE:	41° 45' 58.6" N 072° 39' 43.8" W
LONGITUDE:	72° 39' 43.8" W 41° 45' 58.6" N

PROJECT NO.:	30931138
JOB NO.:	V74-052
DRAWN BY:	KAP
CHECKED BY:	NAL
ISSUED FOR:	X (Initials)
DATE ISSUED:	03/11/06
TIME ISSUED:	10:00 AM

LEGEND	SYMBOL	DESCRIPTION
		SECTION OR SERIAL NUMBER
		SECTION SHEET WHERE ELEMENT OCCURS
		ELEMENT NUMBER
		SHEET WHERE ELEMENT OCCURS

SITE NAME:	HARTFORD SOUTH 4
PROJECT ID:	200834644
PROJECT TYPE:	PSCO
LOCATION CODE:	184930
SITE ADDRESS:	223 BRAINARD ROAD HARTFORD, CONNECTICUT 06114

SCALE:	AS NOTED
TITLE SHEET - PROJECT SUMMARY AND LEGENDS	T-1
CONTRIBUTING PLAN	
AND ANTENNA ORIENTATION PLAN	



General Power Density

Site Name: Hartford S 4, CT
Cumulative Power Density

Operator	Operating Frequency (MHz)	Number of Trans.	ERP Per Trans.	Total ERP	Distance to Target (feet)	Calculated Power Density (mW/cm^2)	Maximum Permissible Exposure* (mW/cm^2)	Fraction of MPE (%)
VZW PCS	1970	3	375	1125	88	0.0522	1.0	5.22%
VZW	880	9	271	2439	88	0.1133	0.583	19.43%
Total Percentage of Maximum Permissible Exposure							24.65%	

*Guidelines adopted by the FCC on August 1, 1996, 47 CFR Part 1 based on NCRP Report 86, 1986 and generally on ANSI/IEEE C95.1-1992

MHz = Megahertz

mW/cm² = milliwatts per square centimeter

ERP = Effective Radiated Power

Absolute worst case maximum values used.



at&t

Glynn Walker
AT&T Mobility
5405 Windward Pkwy
Alpharetta GA, 30004
(770) 708-6122



GPD ASSOCIATES

Kevin Clements
520 South Main St., Suite 2531
Akron, Ohio 44311
(330) 572-2195
kcllements@gpdgroup.com

GPD# 2008263.92
September 4, 2008

STRUCTURAL ANALYSIS REPORT

AT&T DESIGNATION: Site USID: 4539
Site FA: 10071011
Site Name: EAST HARTFORD HOCHANUM

VERIZON DESIGNATION: Site Name: Hartford South-4
Site Number: Hartford South-4

ANALYSIS CRITERIA: Codes: TIA/EIA-222-F & 2003 IBC
80-mph with 0" ice
69-mph with 1/2" ice

SITE DATA: 223 Brainard Road, Hartford, CT 06114, Hartford County
Latitude 41° 43' 58.0" N, Longitude 72° 39' 42.8" W
98' Monopole

Mr. Walker,

GPD is pleased to submit this Structural Analysis Report to determine the structural integrity of the aforementioned tower. The purpose of the analysis is to determine the suitability of the tower with the addition of the following proposed loading configuration:


Elev. 88' (6) Antel LPA-80063/4CF_5 Antennas on a 13' PiROD LP Platform, w/ (6) 1-5/8" internal coax
(6) Antel LPA-185063/8CF_2 Antennas on the same Platform, w/ (6) 1-5/8" internal coax

Based on our analysis we have determined the tower is sufficient for the proposed, existing, and reserved loadings as referenced in Appendix A. However, the foundation could not be verified based on the information provided.

We at GPD appreciate the opportunity of providing our continuing professional services to you and AT&T. If you have any questions please do not hesitate to call.

Respectfully submitted,

David B. Granger, P.E.
Connecticut #: 17557



SUMMARY & RESULTS

The purpose of this analysis was to verify that the existing structure is capable of carrying the proposed loading configuration as specified by Verizon Wireless to AT&T. This report was commissioned by Mr. Glynn Walker of AT&T.

No foundation or geotechnical information was available or provided for this report. Therefore, the in place capacity of the existing foundation could not be verified. A geotechnical investigation and foundation exploration are recommended to verify the capacity of the foundation with the proposed loading.

TOWER SUMMARY AND RESULTS

Member	Capacity	Results
Monopole	62.0%	Pass
Base Plate	43.6%	Pass
Anchor Rods	50.4%	Pass
Foundation	Not Verified	N/A

ANALYSIS METHOD

RISA Tower (Version 5.2.0.1), a commercially available software program, was used to create a three-dimensional model of the tower and calculate primary member stresses for various dead, live, wind, and ice load cases. Selected output from the analysis is included in Appendix B. The following table details the information provided to complete this structural analysis. This analysis is solely based on this information.

DOCUMENTS PROVIDED

Document	Remarks	Source
Preliminary Tower Summary	Verizon Wireless Co-location document	G. Walker
Tower Mapping	GPD Associates and STG Communications, dated 8/15/08	GPD
Co-Location Application	Verizon Wireless Application, dated 4/15/08	G. Walker

ASSUMPTIONS

This structural analysis is based on the theoretical capacity of the members and is not a condition assessment of the monopole. This analysis is from information supplied, and therefore, its results are based on and are as accurate as that supplied data. GPD has made no independent determination, nor is it required to, of its accuracy. The following assumptions were made for this structural analysis.

1. The monopole shaft sizes and shape are considered accurate as supplied. The material grade is as per data supplied and/or as assumed and as stated in the materials section.
2. The antenna configuration is as supplied and/or as modeled in the analysis. It is assumed to be complete and accurate. All antennas, mounts, coax and waveguides are assumed to be properly installed and supported as per manufacturer requirements
3. Some assumptions are made regarding antennas and mount sizes and their projected areas based on best interpretation of data supplied and of best knowledge of antenna type and industry practice.
4. All mounts, if applicable, are considered adequate to support the loading. No actual analysis of the mount(s) is performed. This analysis is limited to analyzing the tower only.
5. The soil parameters are as per data supplied or as assumed and stated in the calculations. If no data is available, the foundation system is not verified. In the case of absent foundation data, it is the tower owner's responsibility to insure that the foundation system is adequate to support the structure with its new reactions.
6. The tower and structures have been properly maintained in accordance with TIA Standards and/or with manufacturer's specifications.
7. All welds and connections are assumed to develop at least the member capacity, unless determined otherwise and explicitly stated in this report.
8. All prior structural modifications, if any, are assumed to be as per data supplied/available, to have been properly installed and to be fully effective.
9. Tower Mounted Amplifiers are assumed to be installed behind antennas.
10. All existing loading was obtained from the provided Preliminary Tower Summary, site photos and the Tower Mapping performed by GPD Associates and STG Communications on 8/15/08 and is assumed to be accurate.
11. All proposed coax is assumed to be internal to the monopole.

If any of these assumptions are not valid or have been made in error, this analysis may be affected, and GPD Associates should be allowed to review any new information to determine its effect on the structural integrity of the tower.

DISCLAIMER OF WARRANTIES

GPD ASSOCIATES has performed a site visit to the tower to verify the member sizes or antenna/coax loading. If the existing conditions are not as represented on the tower elevation contained in this report, we should be contacted immediately to evaluate the significance of the discrepancy. This is not a condition assessment of the tower or foundation. This report does not replace a full tower inspection. The tower and foundations are assumed to have been properly fabricated, erected, maintained, in good condition, twist free, and plumb.

The engineering services rendered by GPD ASSOCIATES in connection with this Structural Analysis are limited to a computer analysis of the tower structure and theoretical capacity of its main structural members. All tower components have been assumed to only resist dead loads when no other loads are applied. No allowance was made for any damaged, bent, missing, loose, or rusted members (above and below ground). No allowance was made for loose bolts or cracked welds.

GPD ASSOCIATES does not analyze the fabrication of the structure (including welding). It is not possible to have all the very detailed information needed to perform a thorough analysis of every structural sub-component and connection of an existing tower. GPD ASSOCIATES provides a limited scope of service in that we cannot verify the adequacy of every weld, plate connection detail, etc. The purpose of this report is to assess the feasibility of adding appurtenances usually accompanied by transmission lines to the structure.

It is the owner's responsibility to determine the amount of ice accumulation, if any, that should be considered in the structural analysis.

The attached sketches are a schematic representation of the analyzed tower. If any material is fabricated from these sketches, the contractor shall be responsible for field verifying the existing conditions, proper fit, and clearance in the field. Any mentions of structural modifications are reasonable estimates and should not be used as a precise construction document. Precise modification drawings are obtainable from GPD ASSOCIATES, but are beyond the scope of this report.

Miscellaneous items such as antenna mounts, etc., have not been designed or detailed as a part of our work. We recommend that material of adequate size and strength be purchased from a reputable tower manufacturer.

GPD ASSOCIATES makes no warranties, expressed and/or implied, in connection with this report and disclaims any liability arising from material, fabrication, and erection of this tower. GPD ASSOCIATES will not be responsible whatsoever for, or on account of, consequential or incidental damages sustained by any person, firm, or organization as a result of any data or conclusions contained in this report. The maximum liability of GPD ASSOCIATES pursuant to this report will be limited to the total fee received for preparation of this report.

APPENDIX A

Tower Analysis Summary Form

Tower Analysis Summary Form

General Info	
Site Name	EAST HARTFORD HOCHANUM
Site Number	4539
Site FA	10071011
Date of Analysis	9/4/2008
Company Performing Analysis	GPD

The information contained in this summary report is not to be used independently from the PE stamped tower analysis.

Tower Info	Description	Date
Tower Type (G, SST, MP)	MP	TI/A/EIA-222-F
Tower Height (top of steel AGL)	98	Hartford, Connecticut
Tower Manufacturer	n/a	Basic Wind Speed (mph).....
Tower Model	n/a	80-rustest
Manufacturer Design	n/a	Ice Thickness (in).....
Foundation Design	n/a	0.5"
Geotechnical Report	n/a	Structure Classification (I., II., III),
Tower Mapping	n/a	Exposure Category (B., C., D),
Foundation Mapping	n/a	Topographic Category (1 to 5)
Previous Structural	n/a	

Steel Yield Strength (ksi)

Pole	50
Base Plate	50
Anchor Rods	75

Note: Yield Strengths Assumed

Existing/Reserved

Antenna		Mount		Transmission Line	
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) total
AT&T Mobility	98	6	Panel	L770.00	5.88
AT&T Mobility	98	6	TMA	LGP21401	shielded

Proposed

Antenna		Mount		Transmission Line	
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) total
Verizon Wireless	88	6	Panel	LPA-800634CF_5	7.01
Verizon Wireless	88	6	Panel	LPA-(85063)CF_2	2.97

Future

Antenna		Mount		Transmission Line	
Antenna Owner	Attachment Height (ft)	Quantity	Type	Model	EPA (ft ²) total
AT&T Mobility	98	3	Panel	L770.00	5.88

Note: Future loading is in addition to the existing loading at the same elevation.

Revision:1.2
Date: 12/15/06

Design Parameters		Analysis Results (% Maximum Usage)	
Existing Condition		Proposed Condition	
Design Code Used	TIA/EIA-222-F	Tower	42.2%
Location of Tower (County, State)	Hartford, Connecticut	Foundation	n/a
Basic Wind Speed (mph)	80-rustest	Guy Wire	n/a
Ice Thickness (in)	0.5"		
Structure Classification (I., II., III),			
Exposure Category (B., C., D),			
Topographic Category (1 to 5)			

Note: Foundation not Verified

Tower Info		Description		Date
Tower Type (G, SST, MP)	MP	Tower	42.2%	
Tower Height (top of steel AGL)	98	Foundation	n/a	
Tower Manufacturer	n/a	Guy Wire	n/a	
Tower Model	n/a			
Manufacturer Design	n/a			
Foundation Design	n/a			
Geotechnical Report	n/a			
Tower Mapping	n/a			
Foundation Mapping	n/a			
Previous Structural	n/a			

Note: Foundation not Verified

APPENDIX B

RISA Tower Output File

<p>RISATower</p> <p>GPD Group 520 South Main Street, Suite 2531 Akron, OH 44311 Phone: 330.572.2100 FAX: 330.572.2103</p>	Job	4539 EAST HARTFORD HOCHANUM	Page
	Project	2008263.92	Date
	Client	AT&T MOBILITY	Designed by M. Moellendick

Tower Input Data

There is a pole section.

This tower is designed using the TIA/EIA-222-F standard.

The following design criteria apply:

Tower is located in Hartford County, Connecticut.

Basic wind speed of 80 mph.

Nominal ice thickness of 0.5000 in.

Ice density of 56pcf.

A wind speed of 69 mph is used in combination with ice.

Temperature drop of 50 °F.

Deflections calculated using a wind speed of 60 mph.

A non-linear (P-delta) analysis was used.

Pressures are calculated at each section.

Stress ratio used in pole design is 1.333.

Local bending stresses due to climbing loads, feedline supports, and appurtenance mounts are not considered.

Feed Line/Linear Appurtenances - Entered As Area

Description	Face or Leg	Allow Shield	Component Type	Placement ft	Total Number	C _{AA}		Weight klf
						ft ² /ft	klf	
LDF6-50A (1-1/4 FOAM) (ATT)	A	No	Inside Pole	98.00 - 8.00	12	No Ice 1/2" Ice	0.00 0.00	0.00 0.00
LDF7-50A (1-5/8 FOAM) (VERIZON)	B	No	Inside Pole	88.00 - 8.00	12	No Ice 1/2" Ice	0.00 0.00	0.00 0.00

Discrete Tower Loads

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustment °	Placement ft	C _{AA}		Weight K
						Front	Side	
Valmont 13' Platform w/o rails (GPD) (ATT)	A	None		0.0000	98.00	No Ice 1/2" Ice	24.80 26.20	24.80 26.20 1.50 2.50
(3) 7770.00 (ATT)	A	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27 0.04 0.07
(3) 7770.00 (ATT)	B	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27 0.04 0.07
(3) 7770.00 (ATT)	C	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	5.88 6.31	2.93 3.27 0.04 0.07

RISATower GPD Group 520 South Main Street, Suite 2531 Akrton, OH 44311 Phone: 330.572.2100 FAX: 330.572.2103	Job	4539 EAST HARTFORD HOCHANUM	Page
	Project	2008263.92	Date
	Client	AT&T MOBILITY	Designed by M. Moellendick


Description	Face or Leg	Offset Type	Offsets:	Azimuth	Placement	C _{AA} Front	C _{AA} Side	Weight	
			Horz	Lateral	Adjustment				
			Vert	ft	°	ft	ft ²	ft ²	K
				ft					
(2) LGP21401 (ATT)	A	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.00	0.23 0.31	0.01 0.02
(2) LGP21401 (ATT)	B	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.00	0.23 0.31	0.01 0.02
(2) LGP21401 (ATT)	C	From Centroid-Face	4.00 0.00 2.25	0.0000	98.00	No Ice 1/2" Ice	0.00 0.00	0.23 0.31	0.01 0.02
PiROD 13' Low Profile Platform (VERIZON)	A	None		0.0000	90.00	No Ice 1/2" Ice	15.70 20.10	15.70 20.10	1.30 1.76
(2) LPA-80063/4CF (VERIZON)	A	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48	0.02 0.07
(2) LPA-80063/4CF (VERIZON)	B	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48	0.02 0.07
(2) LPA-80063/4CF (VERIZON)	C	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	7.01 7.42	6.08 6.48	0.02 0.07
(2) LPA-185063/8CFx2 (VERIZON)	A	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05	0.01 0.03
(2) LPA-185063/8CFx2 (VERIZON)	B	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05	0.01 0.03
(2) LPA-185063/8CFx2 (VERIZON)	C	From Centroid-Face	4.00 0.00 -2.00	0.0000	90.00	No Ice 1/2" Ice	2.97 3.30	2.75 3.05	0.01 0.03

Section Capacity Table

Section No.	Elevation ft	Component Type	Size	Critical Element	P K	SF*P _{allow} K	% Capacity	Pass Fail
L1	98 - 77	Pole	TP28.371x25.44x0.1875	1	-4.36	659.12	21.3	Pass
L2	77 - 40.5	Pole	TP33.466x27.5075x0.25	2	-8.18	1037.47	49.6	Pass
L3	40.5 - 0	Pole	TP39.12x32.4446x0.3125	3	-14.56	1539.31	62.0	Pass
						Summary		
						Pole (L3) 62.0 Pass		
						RATING = 62.0 Pass		

APPENDIX C

Tower Elevation Drawing



DESIGNED APPURTEINANCE LOADING


TYPE	ELEVATION	TYPE	ELEVATION
Valmont 13' Platform w/o rails (GPD) (ATT)	98	(2) LPA-80063/4CF (VERIZON)	90
(2) LPA-80063/4CF (VERIZON)	90	(2) LPA-80063/4CF (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-80063/4CF (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(3) 7770.00 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(2) LGP21401 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(2) LGP21401 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
(2) LGP21401 (ATT)	98	(2) LPA-185063/8CFx2 (VERIZON)	90
PIROD 13' Low Profile Platform (VERIZON)	90		

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi			

TOWER DESIGN NOTES

1. Tower is located in Hartford County, Connecticut.
2. Tower designed for a 80 mph basic wind in accordance with the TIA/EIA-222-F Standard.
3. Tower is also designed for a 69 mph basic wind with 0.50 in ice.
4. Deflections are based upon a 60 mph wind.
5. TOWER RATING: 62%



520 South Main Street, Suite 2531
Akron, OH 44311
Phone: 330.572.2100
FAX: 330.572.2103

Job: 4539 EAST HARTFORD HOCHANUM
Project: 2008263.92
Client: AT&T MOBILITY Drawn by: M. Moellendorf App'd:
Code: TIA/EIA-222-F Date: 09/04/08 Scale: NTS
Path: G:\Telecom\2008263\92iris\4539EHartford.eir Dwg No. E-1

APPENDIX D

Anchor Rod & Base Plate Analysis

Anchor Rod and Base Plate Stresses

4539 EAST HARTFORD HOCHANUM

Oversetting Moment =	749.00	k*ft
Axial Force =	15.00	k
Shear Force =	10.00	k

Anchor Rods		
Pole Diameter =	39.12	in
Number of Rods =	8	
Rod Grade (Fy) =	75	ksi
Rod Circle =	44.878	in
Rod Diameter =	2.25	in
Net Tensile Area =	3.25	in ²
0 Degrees		
Max Tension on Rod =	68.93	kips
Max Compression on Rod =	72.68	kips
45 Degrees		
Max Tension on Rod =	98.26	kips
Max Compression on Rod =	102.01	kips
Allow. Rod Force =	195.00	kips
Anchor Rod Capacity =	50.4%	OK

Base Plate		
Plate Strength (Fy) =	50	ksi
Plate Thickness =	2.75	in
Plate Width =	44	in
Est. Dist. b/w Rods =	6	in
w _{calc} =	13.02	in
e =	1.7542	in
w _{max} =	23.105	in
w =	13.02	in
S =	16.41	in ³
f _b =	21.81	ksi
F _b =	50	ksi
Base Plate Capacity =	43.6%	OK