Robinson+Cole



KENNETH C. BALDWIN

280 Trumbull Street Hartford, CT 06103-3597 Main (860) 275-8200 Fax (860) 275-8299 kbaldwin@rc.com Direct (860) 275-8345

Also admitted in Massachusetts

December 21, 2015

Melanie Bachman Acting Executive Director Connecticut Siting Council 10 Franklin Square New Britain, CT 06051

Re:

TS-VER-069-140117 – Cellco Partnership d/b/a Verizon Wireless 812 Providence Pike, Killingly, Connecticut

Dear Ms. Bachman:

On February 11, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify the existing telecommunications facility at 812 Providence Pike in Killingly, Connecticut. The modifications involved the installation of twelve (12) antennas and associated equipment.

As a condition of the acknowledgement, Cellco is required to provide the Council with a letter stating that Cellco's modifications were consistent with those referenced in the Structural Analysis Report. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the modifications were completed as required.

If you have any questions please do not hesitate to contact me.

Sincerely,

Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks
Rachel A. Mayo

14383606-v1



Centered on Solutions[™]

December 17, 2015

Mr. Tim Parks
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project:

Verizon Danielson 2

812 Providence Tpke, Danielson, CT

Tower Owner:

Cellco Partnership, d.b.a Verizon Wireless

99 East River Drive, East Hartford, CT

Engineer:

Centek Engineering, Inc.

63-2 North Branford Rd, Branford, CT

Centek Project No.: 15003.007

CSC Exempt Mod Reference No.: TS-VER-069-140117

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the Structural Analysis and Modification report s prepared by Centek Engineering, Inc. (Project Number: 09059.000)

Dated 12/6/13 Rev.1:

- □ Review of Centek Engineering, Inc. Structural Analysis and Modification Report dated 12/63/2013.
- □ Field observations by Centek Engineering personnel on 10/22/2015 (See **Note** Below)
- Note: The top wires installed are 9/16" in lieu of the ½" diameter specified. The change in the aforementioned guy wire size was per the direction of Centek Engineering, Inc.

The modification design prepared by Centek demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely

Carlo F. Centore, PE

Principal - Struetural