

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

Also admitted in Massachusetts

ORIGINAL

December 26, 2013

David Martin
Siting Analyst
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-071-130315 – Cellco Partnership d/b/a Verizon Wireless**
1593 Exeter Road, Lebanon, Connecticut

Dear Mr. Martin:

On April 9, 2013, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 1593 Exeter Road in Lebanon. The modification involved the replacement of certain antennas and installation of remote radio heads and fiber line.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that the recommendations specified in the structural report were implemented. Attached is a Tower Modification Certification Letter verifying that these conditions have been satisfied. All construction associated with these modifications has now been completed.

If you have any questions please do not hesitate to contact me or Rachel Mayo.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Sandy M. Carter
Brian Ragozzine
Mark Gauger



Law Offices

BOSTON

PROVIDENCE

HARTFORD

NEW LONDON

STAMFORD

WHITE PLAINS

NEW YORK CITY

ALBANY

SARASOTA

www.rc.com



Centered on Solutions™

November 21, 2013

Mr. Mark Gauger
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Existing Telecommunications Facility Tower Modification Certification Letter

Project: Verizon ~ Lebanon South
1593 Exeter Road
Lebanon, CT

Tower Owner: AT&T Mobility
5405 Windward Pkwy
Alpharetta, GA 30004

Engineer: GPD Group
520 South Main Street Suite 2531, Akron, OH 44311

Centek Project No.: 13008.046

Dear Mr. Gauger,

We are providing this "Existing Telecommunications Facility Tower Modification Certification Letter" with regard to the antenna upgrade by Verizon Wireless at the above referenced project.

The following are the basis for substantiating compliance with the structural analysis prepared by GPD Group (GPD Project No. 2013723.27057.01) dated February 7, 2013:


- ☐ Review of the GPD Structural Analysis dated 02/07/2013.
- ☐ Review of the GPD tower extension drawings N-1 and S-1 dated 12/28/2010.
- ☐ Review of the GPD Post Modification Observation Report (GPD Project No. 2013707.61) dated 10/09/2013.
- ☐ Field observations by Centek personnel of the modifications and coax installation on 11/18/2013 which determined all coax lines were installed in general compliance with the recommendations of the structural analysis report prepared by GPD on 02/07/2013.

With the completed modifications, the tower and foundation do not exceed 100 percent of their post-construction structural rating.

The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above.

Sincerely,

Carlo F. Centore, PE
Principal ~ Structural Engineer



CC: Rachel Mayo, Tim Parks, Steve Schadler