

November 4, 2015

Melanie A. Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: **EM-VER-073-140708 – Cellco Partnership d/b/a Verizon Wireless  
26 Mell Road, Lisbon, Connecticut**

Dear Ms. Bachman:

On July 28, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 26 Mell Road in Lisbon, Connecticut. The modifications involved the replacement of its antennas and installation of remote radio heads and fiber lines.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that the recommendations made in the structural report were complied with. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to the structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

14265296-v1

November 3, 2015

**Mr. Tim Parks**

Verizon Wireless  
99 East River Drive  
East Hartford, Connecticut 06108

**Re: Existing Telecommunications Facility Tower Certification Letter**

**Project:** Verizon Lisbon  
26 Mell Road  
Lisbon, CT

**Tower Owner:** SBA Communications

**Engineer:** FDH Engineering  
6521 Meridien Drive  
Raleigh, NC 27616

**Centek Project No.:** 15003.065

**CSC Exempt Mod Reference No.:** EM-VER-073-140708

Dear Mr. Parks,

We are providing this "Existing Telecommunications Facility Tower Certification Letter" with regard to the antenna upgrade by Verizon Wireless at the above referenced project.

The following are the basis for substantiating compliance with the FDH Engineering structural analysis report (FDH Project No. 1423601400) dated February 24, 2014:

- Review of the FDH structural analysis report dated 02/24/2014.
- Field observations by Centek personnel of the coax and RRH installation on 11/03/2015 which determined all coax lines and RRH's were installed in general compliance with the recommendations of the structural analysis report prepared by FDH Engineering on 02/24/2014.

The structural analysis prepared by FDH Engineering demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the referenced structural analysis.

Sincerely,



Carlo F. Centore, PE  
Principal ~ Structural Engineer

