



56 Prospect Street,
P.O. Box 270
Hartford, CT 06103

Kathleen M. Shanley
Manager – Transmission Siting
Tel: (860) 728-4527

May 22, 2020

Melanie A. Bachman
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

**RE: Notice of Exempt Modification
Eversource Site # 3932
135 New Road, Madison, CT 06443
Latitude: 41-17-36.3 N / Longitude: 72-34-42.2 W**

Dear Ms. Bachman:

The Connecticut Light and Power Company doing business as Eversource Energy (“Eversource”) currently maintains three antennas and one microwave dish mounted near the top of an existing 181-foot guyed tower located at 135 New Road in Madison. See Attachment A, Parcel Map and Property Card. The tower and property are owned by Eversource. Eversource plans to install one 24-foot tall omni-directional antenna to be mounted at 177 feet above ground level (“AGL”) and two 7/8-inch diameter coaxial cables. There will be no changes to the area of the fenced compound, the tower or the existing antennas and equipment currently mounted on the tower. The tower and existing and proposed equipment on the tower are depicted on Attachment B, Construction Drawings, dated March 9, 2020 and Attachment C, Structural Analysis, dated March 4, 2020.

While the Connecticut Siting Council telecommunications database does not provide a docket or petition number for the approval of this structure, it does reference this structure in connection with prior exempt modification filings captioned EM-OCI-076-980825, EM-METRICOM-076-001226, EM-AT&T-076-020927, and EM-T-MOBILE-076-140508. The proposed installation is part of Eversource’s program to update the current obsolete analog voice radio communications system to a modern digital voice communications system. The new system will enable the highest level of voice communications under all operating conditions, including during critical emergency and storm restoration activities. The new radio system will also provide for remote control of distribution safety equipment.

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies (“R.C.S.A.”) §16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this notice is being delivered to Peggy Lyons, First Selectwoman for the Town of Madison and David Anderson, Town Planner for the Town of Madison via the United States Postal Service or private carrier. Proof of delivery is attached. See Attachment D, Proof of Delivery of Notice.

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2):

1. There will be no change to the height of the existing tower.
2. The proposed modifications will not require the extension of the site boundary.
3. The proposed modification will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The operation of the new antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard as shown in the attached Radio Frequency Emissions Report, dated April 2, 2020 (Attachment E – Power Density Report).¹
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, Eversource respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. § 16-50j-72(b)(2). Two copies of this notice and a check in the amount of \$625 are enclosed.

Communications regarding this Notice of Exempt Modification should be directed to Kathleen Shanley at (860) 728-4527.

By:



Kathleen M. Shanley
Manager – Transmission Siting

cc: Honorable Peggy Lyons, First Selectwoman, Town of Madison
David Anderson, Town Planner, Town of Madison

Attachments

- A. Parcel Map and Property Card
- B. Construction Drawings
- C. Structural Analysis
- D. Proof of Delivery of Notice
- E. Power Density Report

¹ It should be noted that the number of transmitting antennas accounted for in the Power Density Report does account for multiple channels for singular antennas. As such, the number of antennas depicted on the Structural Analysis, Construction Drawings and Power Density Report differ. Also, the “Antenna Height” column on Table 1 in the Power Density Report only accounts for the centerline of the Transmit or “TX” antenna centerline.

ATTACHMENT A – PARCEL MAP AND PROPERTY CARD

135 New Road, Madison, CT 06443




Legend

- ⊙ Approximate Tower Location

Location

Notes

This product is for informational purposes and may not have been prepared for, or be suitable for legal, engineering, or surveying purposes. Users of this information should review or consult the primary data and information sources to ascertain the usability of the information.



1:6,751



135 NEW RD

Location 135 NEW RD

MBLU 60/ 8/ / /

Acct# 00379700

Owner CONNECTICUT LIGHT AND POWER CO

Assessment \$3,681,500

Appraisal \$6,186,900

PID 3932

Building Count 2

Current Value

| Appraisal | | | | | |
|----------------|-------------|----------------|--------------|-------------|-------------|
| Valuation Year | Building | Extra Features | Outbuildings | Land | Total |
| 2018 | \$3,705,600 | \$27,500 | \$1,054,700 | \$1,399,100 | \$6,186,900 |

| Assessment | | | | | |
|----------------|-------------|----------------|--------------|-----------|-------------|
| Valuation Year | Building | Extra Features | Outbuildings | Land | Total |
| 2018 | \$2,594,000 | \$19,300 | \$738,300 | \$329,900 | \$3,681,500 |

Parcel Addresses

| Additional Addresses | | |
|----------------------|-----------------|---------|
| Address | City, State Zip | Type |
| 135 NEW RD | | Primary |

Owner of Record

Owner CONNECTICUT LIGHT AND POWER CO
Co-Owner
Care Of

Sale Price \$0
Book & Page 139/ 397
Sale Date

Ownership History

| Ownership History | | | |
|--------------------------------|------------|-------------|-----------|
| Owner | Sale Price | Book & Page | Sale Date |
| CONNECTICUT LIGHT AND POWER CO | \$0 | 139/ 397 | |

Building Information

Building 1 : Section 1

Year Built: 1978
Living Area: 29,608

Building Attributes


| Field | Description |
|------------------|-----------------|
| STYLE | Office Bldg |
| MODEL | Commercial |
| Stories: | 2 |
| Exterior Wall 1 | Stone/Masonry |
| Exterior Wall 2 | Concr/Cinder |
| Roof Structure | Flat |
| Roof Cover | T+G/Rubber |
| Interior Wall 1 | Minim/Masonry |
| Interior Wall 2 | Drywall |
| Interior Floor 1 | Concr-Finished |
| Interior Floor 2 | Carpet |
| Heating Fuel | Electric |
| Heating Type | Forced Air-Duc |
| AC Type | Central |
| Bldg Use | Office Building |
| Total Rooms | |
| Total Bedrms | 00 |
| Total Baths | 0 |
| Fireplace | |
| Xtra Fireplaces | |
| Heat/AC | Heat A/C Split |
| Frame Type | Masonry |
| Baths/Plumbing | Average |
| Ceiling/Wall | Ceil and Wall |
| Rooms/Prtns | Average |
| Wall Height | 14 |

Building Photo



(<http://images.vgsi.com/photos/MadisonCTPhotos//\01\01\34\90>)

Building Layout



(<http://images.vgsi.com/photos/MadisonCTPhotos//Sketches/393>)

| Building Sub-Areas (sq ft) | | | |
|----------------------------|-------------------------|------------|-------------|
| Code | Description | Gross Area | Living Area |
| BAS | First Floor | 21,598 | 21,598 |
| SPA | Service Production Area | 16,020 | 8,010 |
| CAN | Canopy | 21,868 | 0 |
| FCP | Carport | 2,550 | 0 |
| FLL | Finished Lower Level | 19,048 | 0 |
| | | 81,084 | 29,608 |

Building 2 : Section 1

Year Built: 1978
Living Area: 7,042

| Building Attributes : Bldg 2 of 2 | |
|-----------------------------------|--------------|
| Field | Description |
| STYLE | Service Shop |
| MODEL | Commercial |


| | |
|------------------|-----------------|
| Stories: | 1 |
| Exterior Wall 1 | Brick/Masonry |
| Exterior Wall 2 | |
| Roof Structure | Flat |
| Roof Cover | T+G/Rubber |
| Interior Wall 1 | Minim/Masonry |
| Interior Wall 2 | |
| Interior Floor 1 | Concr-Finished |
| Interior Floor 2 | |
| Heating Fuel | Electric |
| Heating Type | Electr Basebrd |
| AC Type | None |
| Bldg Use | Office Building |
| Total Rooms | |
| Total Bedrms | 00 |
| Total Baths | 0 |
| Fireplace | |
| Xtra Fireplaces | |
| Heat/AC | None |
| Frame Type | Masonry |
| Baths/Plumbing | None |
| Ceiling/Wall | None |
| Rooms/Prtns | Light |
| Wall Height | 24 |

Building Photo



(<http://images.vgsi.com/photos/MadisonCTPhotos//\01\01\34\91>)

Building Layout



(<http://images.vgsi.com/photos/MadisonCTPhotos//Sketches/393>)

| Building Sub-Areas (sq ft) | | | |
|----------------------------|-------------|------------|-------------|
| Code | Description | Gross Area | Living Area |
| BAS | First Floor | 7,042 | 7,042 |
| SLB | Slab | 7,042 | 0 |
| | | 14,084 | 7,042 |

Extra Features

| Extra Features | | | | |
|----------------|---------------|-----------|----------|--------|
| Code | Description | Size | Value | Bldg # |
| LDL1 | Load Levelers | 1 UNITS | \$1,700 | 1 |
| MEZ1 | Mezzanine Unf | 3960 S.F. | \$18,400 | 1 |
| MEZ1 | Mezzanine Unf | 1600 S.F. | \$7,400 | 2 |

Land

Land Use

Land Line Valuation

Use Code 3400
Description Office Building
Zone RU-2

Size (Acres) 37.98

Outbuildings

| Outbuildings | | | | | | |
|---------------------|--------------------|-----------------|------------------------|-------------|--------------|---------------|
| Code | Description | Sub Code | Sub Description | Size | Value | Bldg # |
| PAV1 | Paving Asphalt | | | 400000 S.F. | \$280,000 | 1 |
| LT12 | Lights(4) | | | 26 UNITS | \$52,000 | 1 |
| LT10 | Lights (2) | | | 3 UNITS | \$3,000 | 1 |
| LT9 | Lights | | | 18 UNITS | \$12,600 | 1 |
| FN3 | Fence 6' | | | 6000 L.F. | \$36,000 | 1 |
| SHD1 | Shed | | | 96 S.F. | \$600 | 1 |
| SHD1 | Shed | | | 120 S.F. | \$800 | 1 |
| SHD6 | Pump Sta. | | | 192 S.F. | \$14,400 | 1 |
| SHD1 | Shed | | | 96 S.F. | \$600 | 1 |
| SHD1 | Shed | | | 80 S.F. | \$300 | 1 |
| CEL | Cell Tower | | | 4 UNITS | \$654,400 | 1 |

(c) 2020 Vision Government Solutions, Inc. All rights reserved.

ATTACHMENT B – CONSTRUCTION DRAWINGS



**MADISON AWC
135 NEW ROAD
MADISON, CT 06443**

EVERSOURCE ENERGY

107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000



BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

PROJECT SUMMARY

THE GENERAL SCOPE OF WORK CONSISTS OF THE FOLLOWING:
1. INSTALL (1) NEW OMNI/WHIP ANTENNA AT ELEVATION 202'-0"± AGL
2. INSTALL (1) NEW RACK WITH DMR EQUIPMENT IN EXISTING BUILDING

GOVERNING CODES

2018 CONNECTICUT STATE BUILDING CODE (2015 IBC BASIS)
2017 NATIONAL ELECTRIC CODE
TIA-222-H

GENERAL NOTES

THE FACILITY IS UNMANNED AND NOT FOR HUMAN HABITATION. A TECHNICIAN WILL VISIT THE SITE AS REQUIRED FOR ROUTINE MAINTENANCE. THE PROJECT WILL NOT RESULT IN ANY SIGNIFICANT DISTURBANCE OR EFFECT ON DRAINAGE; NO SANITARY SEWER SERVICE, POTABLE WATER, OR TRASH DISPOSAL IS REQUIRED AND NO COMMERCIAL SIGNAGE IS PROPOSED.

SITE INFORMATION

SITE NAME: MADISON AWC
SITE ID NUMBER: #3932
SITE ADDRESS: 135 NEW ROAD
MADISON, CT 06443
MAP: 60
BLOCK: 8
ZONE: RU-2
LATITUDE: 41° 17' 36.3" N
LONGITUDE: 72° 34' 42.2" W
ELEVATION: 62'-6"± AMSL
FEMA/FIRM DESIGNATION: X
ACREAGE: 38 ± AC (BOOK 139, PAGE: 397)

CONTACT INFORMATION

APPLICANTS:
EVERSOURCE ENERGY
107 SELDEN STREET
BERLIN, CT 06037
POWER PROVIDER:
EVERSOURCE ENERGY
(800) 286-2000
PROPERTY OWNER:
EVERSOURCE ENERGY
107 SELDEN STREET
BERLIN, CT 06037
TELCO PROVIDER:
FRONTIER
(800) 921-8102
EVERSOURCE ENERGY
PROJECT MANAGER:
NIKOLL PRECI
(860) 655-3079
CALL BEFORE YOU DIG:
(800) 922-4455


DESIGN TYPE

SITE UPGRADE
SELF-SUPPORT TOWER

DRAWING INDEX

| SHEET NO: | SHEET TITLE |
|-----------|------------------------|
| T-1 | TITLE SHEET |
| C-1 | SITE PLAN |
| C-2 | TOWER ELEVATION |
| G-1 | GROUNDING DETAILS |
| N-1 | NOTES & SPECIFICATIONS |
| N-2 | NOTES & SPECIFICATIONS |
| N-3 | NOTES & SPECIFICATIONS |

LOCATION MAP



DO NOT SCALE DRAWINGS

SUBCONTRACTOR SHALL VERIFY ALL PLANS & EXISTING DIMENSIONS & CONDITIONS ON THE JOB SITE & SHALL IMMEDIATELY NOTIFY THE ENGINEER IN WRITING OF ANY DISCREPANCIES BEFORE PROCEEDING WITH THE WORK OR BE RESPONSIBLE FOR SAME




UNDERGROUND SERVICE ALERT
UTILITIES PROTECTION CENTER, INC.
811

48 HOURS BEFORE YOU DIG

PROJECT NO: 403093
DRAWN BY: TYW
CHECKED BY: TH

| REV | DATE | DESCRIPTION |
|-----|----------|-------------------|
| 0 | 03/09/20 | ISSUED FOR FILING |




IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

MADISON AWC
135 NEW ROAD
MADISON, CT 06443

SHEET TITLE
TITLE SHEET

SHEET NUMBER
T-1



SITE PLAN
NO SCALE



EVERSOURCE
ENERGY

107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000



BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

| | |
|-------------|--------|
| PROJECT NO: | 403093 |
| DRAWN BY: | TYW |
| CHECKED BY: | TH |

| REV | DATE | DESCRIPTION |
|-----|----------|-------------------|
| 0 | 03/09/20 | ISSUED FOR FILING |



IT IS A VIOLATION OF LAW FOR ANY PERSON,
UNLESS THEY ARE ACTING UNDER THE DIRECTION
OF A LICENSED PROFESSIONAL ENGINEER,
TO ALTER THIS DOCUMENT.

MADISON AWC
135 NEW ROAD
MADISON, CT 06443

SHEET TITLE
SITE PLAN

SHEET NUMBER
C-1

TOP OF EXISTING EVERSOURCE ANTENNA
ELEVATION 200'-6"± AGL

TOP OF EXISTING TOWER
ELEVATION 181'-6"± AGL
EXISTING EVERSOURCE ANTENNA
RAD CL ELEVATION 176'-6"± AGL

EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 160'-6"± AGL


EXISTING EVERSOURCE ANTENNA
RAD CL ELEVATION 148'-6"± AGL

EXISTING ANTENNA (NON-EVERSOURCE)
RAD CL ELEVATION 127'-6"± AGL

EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 78'-6"± AGL

EXISTING GRADE
ELEVATION 61'-0"± AMSL

TOWER ELEVATION FACE AC
NO SCALE



TOP OF PROPOSED EVERSOURCE
OMNI/WHIP ANTENNA
ELEVATION 202'-0"± AGL
RX RAD CL ELEVATION 195'-2 3/4"± AGL
TX RAD CL ELEVATION 183'-0 15/16"± AGL
(ANTENNA MECHANICAL LENGTH 24'-3 1/2")

EXISTING TORQUE ARM
ELEVATION 169'-1 7/8"± AGL



EXISTING TORQUE ARM
ELEVATION 129'-1 7/8"± AGL

EXISTING GUY PULL OFF
ELEVATION 62'-0"± AGL

NOTES

- ATTACH TIEBACK TO FRAME MAST BETWEEN TOP AND BOTTOM HSS ARMS. ATTACH OPPOSITE END TO EITHER ADJACENT TOWER LEG. REFER TO ALLOWABLE TIEBACK ANGLE DIAGRAM.
- TRIM TIEBACK PIPE AS REQUIRED TO MAINTAIN A 6" DISTANCE BETWEEN ENDS OF CLAMPS AND ENDS OF PIPE.

ALLOWABLE TIEBACK ANGLE
±20 DEGREES VERTICAL
±45 DEGREES HORIZONTAL



SECTION 1
NO SCALE



TOP OF PROPOSED EVERSOURCE
OMNI/WHIP ANTENNA
ELEVATION 202'-0"± AGL
RX RAD CL ELEVATION 195'-2 3/4"± AGL
TX RAD CL ELEVATION 183'-0 15/16"± AGL
(ANTENNA MECHANICAL LENGTH 24'-3 1/2")


EXISTING TORQUE ARM
ELEVATION 169'-1 7/8"± AGL

EXISTING TORQUE ARM
ELEVATION 129'-1 7/8"± AGL

EXISTING GUY PULL OFF
ELEVATION 62'-0"± AGL

202'-0"± AGL
TOTAL HEIGHT WITH APPURTENANCES

TOWER ELEVATION FACE CB
NO SCALE



TOP OF EXISTING EVERSOURCE ANTENNA
ELEVATION 200'-6"± AGL

TOP OF EXISTING EVERSOURCE ANTENNA
ELEVATION 194'-6"± AGL

TOP OF EXISTING TOWER
ELEVATION 181'-6"± AGL

EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 160'-6"± AGL

EXISTING ANTENNA (NON-EVERSOURCE)
RAD CL ELEVATION 127'-6"± AGL

EXISTING ANTENNA (NON-EVERSOURCE)
RAD CL ELEVATION 89'-6"± AGL

EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 78'-6"± AGL

EXISTING GRADE
ELEVATION 61'-0"± AMSL

PROPOSED (2) 7/8" COAX
CABLES ROUTED TO PROPOSED
OMNI/WHIP ANTENNA



107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000




BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

| | |
|-------------|--------|
| PROJECT NO: | 403093 |
| DRAWN BY: | TYW |
| CHECKED BY: | TH |

| REV | DATE | DESCRIPTION |
|-----|----------|-------------------|
| 0 | 03/09/20 | ISSUED FOR FILING |



IT IS A VIOLATION OF LAW FOR ANY PERSON,
UNLESS THEY ARE ACTING UNDER THE DIRECTION
OF A LICENSED PROFESSIONAL ENGINEER,
TO ALTER THIS DOCUMENT.

MADISON AWC
135 NEW ROAD
MADISON, CT 06443

SHEET TITLE
TOWER
ELEVATION

SHEET NUMBER
C-2




PROJECT NO: 403093

DRAWN BY: TYW

CHECKED BY: TH

| REV | DATE | DESCRIPTION |
|-----|----------|-------------------|
| 0 | 03/09/20 | ISSUED FOR FILING |




IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

MADISON AWC
135 NEW ROAD
MADISON, CT 06443

SHEET TITLE
**GROUNDING
DETAILS**

SHEET NUMBER

G-1




NOTE

1. NUMBER OF GROUND BARS MAY VARY DEPENDING ON THE TYPE OF TOWER, ANTENNA LOCATION AND CONNECTION ORIENTATION. PROVIDE AS REQUIRED.

ANTENNA CABLE GROUNDING

NO SCALE




NOTES

- DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO GROUND BAR.
- GROUNDING KIT SHALL BE TYPE AND PART NUMBER AS SUPPLIED OR RECOMMENDED BY CABLE MANUFACTURER.
- WEATHER PROOFING SHALL BE TYPE AND PART NUMBER AS SUPPLIED OR RECOMMENDED BY CABLE MANUFACTURER.


CONNECTION OF CABLE GROUND KIT TO ANTENNA CABLE

NO SCALE



CABLE INSTALLATION WITH WALL FEED THRU ASSEMBLY

NO SCALE



NOTE

1. PROVIDE GROUND KIT 6" BEFORE TURN

ICE BRIDGE AND ANTENNA CABLE DETAIL

NO SCALE

SYMBOLS

| | |
|---------------------------|--|
| ● | EXOTHERMIC CONNECTION |
| ■ | COMPRESSION CONNECTION |
| ⊕ | 5/8"Øx10'-0" COPPER CLAD STEEL GROUND ROD. |
| ⊕ | TEST GROUND ROD WITH INSPECTION SLEEVE |
| --- | GROUNDING CONDUCTOR |
| (A) | KEY NOTES |
| — X — X — X — X — X — | CHAINLINK FENCE |
| — □ — □ — □ — □ — □ — | WOOD FENCE |
| --- | LEASE AREA |
| ▨ | ICE BRIDGE |
| ▧ | CABLE TRAY |
| — G — G — G — G — G — | GAS LINE |
| — E/T — E/T — E/T — E/T — | UNDERGROUND ELECTRICAL/TELCO |
| — E/C — E/C — E/C — E/C — | UNDERGROUND ELECTRICAL/CONTROL |
| — E — E — E — E — E — | UNDERGROUND ELECTRICAL |
| — T — T — T — T — T — | UNDERGROUND TELCO |
| --- | PROPERTY LINE (PL) |

ABBREVIATIONS

| | | | |
|------|-----------------------------------|------|---|
| AC | ALTERNATING CURRENT | MGB | MASTER GROUNDING BAR |
| AIC | AMPERAGE INTERRUPTION CAPACITY | MIN | MINIMUM |
| ANI | AUXILIARY NETWORK INTERFACE | MW | MICROWAVE |
| ATM | ASYNCHRONOUS TRANSFER MODE | MTS | MANUAL TRANSFER SWITCH |
| ATS | AUTOMATIC TRANSFER SWITCH | NEC | NATIONAL ELECTRICAL CODE |
| AWG | AMERICAN WIRE GAUGE | OC | ON CENTER |
| AWS | ADVANCED WIRELESS SERVICES | PP | POLARIZING PRESERVING |
| BATT | BATTERY | PCU | PRIMARY CONTROL UNIT |
| BBU | BASEBAND UNIT | PDU | PROTOCOL DATA UNIT |
| BTC | BARE TINNED COPPER CONDUCTOR | PWR | POWER |
| BTS | BASE TRANSCEIVER STATION | RECT | RECTIFIER |
| CCU | CLIMATE CONTROL UNIT | RET | REMOTE ELECTRICAL TILT |
| CDMA | CODE DIVISION MULTIPLE ACCESS | RMC | RIGID METALLIC CONDUIT |
| CHG | CHARGING | RF | RADIO FREQUENCY |
| CLU | CLIMATE UNIT | RUC | RACK USER COMMISSIONING |
| COMM | COMMON | RRH | REMOTE RADIO HEAD |
| DC | DIRECT CURRENT | RRU | REMOTE RADIO UNIT |
| DIA | DIAMETER | RWY | RACEWAY |
| DWG | DRAWING | SFP | SMALL FORM-FACTOR PLUGGABLE |
| EC | ELECTRICAL CONDUCTOR | SIAD | SMART INTEGRATED ACCESS DEVICE |
| EMT | ELECTRICAL METALLIC TUBING | SSC | SITE SOLUTIONS CABINET |
| FIF | FACILITY INTERFACE FRAME | T1 | 1544KBPS DIGITAL LINE |
| GEN | GENERATOR | TDMA | TIME-DIVISION MULTIPLE ACCESS |
| GPS | GLOBAL POSITIONING SYSTEM | TMA | TOWER MOUNT AMPLIFIER |
| GSM | GLOBAL SYSTEM FOR MOBILE | TVSS | TRANSIENT VOLTAGE SUPPRESSION SYSTEM |
| HVAC | HEAT/VENTILATION/AIR CONDITIONING | TYP | TYPICAL |
| ICF | INTERCONNECTION FRAME | UMTS | UNIVERSAL MOBILE TELECOMMUNICATION SYSTEM |
| IGR | INTERIOR GROUNDING RING (HALO) | UPS | UNINTERRUPTIBLE POWER SUPPLY (DC POWER PLANT) |
| LTE | LONG TERM EVOLUTION | | |

EVERSOURCE ENERGY

107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000




BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

| | |
|-------------|--------|
| PROJECT NO: | 403093 |
| DRAWN BY: | TYW |
| CHECKED BY: | TH |

| REV | DATE | DESCRIPTION |
|-----|----------|-------------------|
| 0 | 03/09/20 | ISSUED FOR FILING |



IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

MADISON AWC
135 NEW ROAD
MADISON, CT 06443

SHEET TITLE
NOTES & SPECIFICATIONS


SHEET NUMBER

N-3

REFERENCE CUTSHEETS





VHF Omni Antennas (160-222 MHz)

| | | 160-174 MHz | | | | | | 217-222 MHz | | | | | | | | | |
|----------------------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Model Number | | DS1G03F36U-N | DS1G03F36U-D | DS1G06F36U-N | DS1G06F36U-D | DS1G03F36D-N | DS1G03F36D-D | DS2C00F36U-N | DS2C00F36U-D | DS2C03F36U-N | DS2C03F36U-D | DS2C06F36U-N | DS2C06F36U-D | DS2C00F36D-N | DS2C00F36D-D | DS2C03F36D-N | DS2C03F36D-D |
| Input Connector | | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN | N(F) | 7/16 DIN |
| Type | | Single | | Single | | Dual | | Single | | Single | | Single | | Dual | | Dual | |
| ELECTRICAL | Bandwidth, MHz | 14 | | 14 | | 14 | | 5 | | 5 | | 5 | | 5 | | 5 | |
| | Power, Watts | 500 | | 500 | | 350 | | 500 | | 500 | | 500 | | 350 | | 350 | |
| | Gain, dBd | 3 | | 6 | | 3 | | 0 | | 3 | | 6 | | 0 | | 3 | |
| | Horizontal Beamwidth, degrees | 360 | | 360 | | 360 | | 360 | | 360 | | 360 | | 360 | | 360 | |
| | Vertical Beamwidth, degrees | 30 | | 16 | | 30 | | 60 | | 30 | | 16 | | 60 | | 30 | |
| | Beam Tilt, degrees | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | |
| | Isolation (minimum), dB | N/A | | N/A | | 30 | | N/A | | N/A | | N/A | | 30 | | 30 | |
| MECHANICAL | Number of Connectors | 1 | | 1 | | 2 | | 1 | | 1 | | 1 | | 2 | | 2 | |
| | Flat Plate Area, ft ² (m ²) | 2.53 (0.24) | | 4.38 (0.41) | | 4.5 (0.42) | | 1.9 (0.18) | | 1.9 (0.18) | | 2.58 (0.24) | | 2.4 (0.22) | | 4.1 (0.38) | |
| | Lateral Windload Thrust, lbf(N) | 95 (423) | | 164 (730) | | 169 (752) | | 53 (236) | | 69 (307) | | 108 (480) | | 90 (400) | | 169 (752) | |
| | Survival Wind Speed without ice, mph(kph) | 110 (177) | | 75 (121) | | 75 (121) | | 222 (357) | | 172 (277) | | 110 (177) | | 130 (209) | | 75 (121) | |
| | with 0.5" radial ice, mph(kph) | 93 (150) | | 60 (97) | | 65 (105) | | 193 (311) | | 150 (241) | | 96 (154) | | 115 (185) | | 65 (105) | |
| Mounting Hardware included | DSH3V3R | | DSH3V3N | | DSH3V3N | | DSH2V3R | | DSH2V3R | | DSH3V3N | | DSH3V3R | | DSH3V3N | | |
| DIMENSIONS | Length, ft(m) | 12.7 (3.9) | | 21.9 (6.7) | | 22.3 (6.8) | | 7.7 (2.3) | | 9.9 (3) | | 18.1 (5.5) | | 13.6 (4.1) | | 24.3 (7.4) | |
| | Radome O.D., in(cm) | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | | 3 (7.6) | |
| | Mast O.D., in(cm) | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | | 2.5 (6.4) | |
| | Net Weight w/o bracket, lb(kg) | 37 (16.8) | | 60 (27.2) | | 63 (28.6) | | 19 (8.6) | | 26 (11.8) | | 47 (21.3) | | 40 (18.1) | | 70 (31.8) | |
| | Shipping Weight, lb(kg) | 67 (30.4) | | 90 (40.8) | | 93 (42.2) | | 39 (17.7) | | 56 (25.4) | | 77 (34.9) | | 70 (31.8) | | 100 (45.4) | |



TOWER/MAST SIZE AT PROPOSED ANTENNA ATTACHMENT = 2.875" ± DIAMETER.

EXISTING LEG,
1" TO 8" ROUND LEGS
OR 60° ANGLE LEGS



| PARTS LIST | | | | | | |
|-------------|-----|----------|-------------------------------|--------|----------|---------|
| ITEM | QTY | PART NO. | PART DESCRIPTION | LENGTH | UNIT WT. | NET WT. |
| 1 | 1 | CFM | UPPER GATE FOOT WELDMENT | | 13.90 | 13.90 |
| 2 | 1 | CFS | LOWER GATE FOOT WELDMENT | | 12.72 | 12.72 |
| 3 | 2 | GBB | GATE BACKING BAR | | 4.53 | 9.06 |
| 4 | 1 | 4PBG | 48" PIPE MOUNT STANDOFF ARM | | 113.96 | 113.96 |
| 5 | 8 | G12R-12 | 1/2" x 12" GALV. THREADED ROD | | 0.67 | 5.35 |
| 5 | 8 | G12R-15 | 1/2" x 15" GALV. THREADED ROD | | 0.84 | 6.69 |
| 6 | 2 | A1205 | 1/2" x 5" A325 HDG BOLT | | 0.34 | 0.69 |
| 7 | 18 | G12FW | 1/2" HDG USS FLATWASHER | | 0.03 | 0.61 |
| 8 | 18 | G12LW | 1/2" HDG LOCKWASHER | | 0.01 | 0.25 |
| 9 | 18 | G12NUT | 1/2" HDG HEAVY 2H HEX NUT | | 0.07 | 1.29 |
| TOTAL WT. # | | | | | 164.53 | |

TOLERANCE NOTES

TOLERANCES ON DIMENSIONS, UNLESS OTHERWISE NOTED ARE:
 SAWED, SHEARED AND GAS CUT EDGES ($\pm 0.030"$)
 DRILLED AND GAS CUT HOLES ($\pm 0.030"$) - NO CONING OF HOLES
 LASER CUT EDGES AND HOLES ($\pm 0.010"$) - NO CONING OF HOLES
 BENDS ARE $\pm 1/2$ DEGREE
 ALL OTHER MACHINING ($\pm 0.030"$)
 ALL OTHER ASSEMBLY ($\pm 0.060"$)

PROPRIETARY NOTE:
 THE DATA AND TECHNIQUES CONTAINED IN THIS DRAWING ARE PROPRIETARY INFORMATION OF VALMONT INDUSTRIES AND CONSIDERED A TRADE SECRET. ANY USE OR DISCLOSURE WITHOUT THE CONSENT OF VALMONT INDUSTRIES IS STRICTLY PROHIBITED.

DESCRIPTION

48" ULTIMATE UNIVERSAL
STANDOFF FRAME

| | | |
|---------|---------------|---------------|
| CPD NO. | DRAWN BY | ENG. APPROVAL |
| CLASS | DRAWING USAGE | CHECKED BY |
| 81 | 01 | CUSTOMER |
| | | BMC 2/16/2011 |




Engineering
Support Team:
1-888-753-7446

Locations:
New York, NY
Atlanta, GA
Los Angeles, CA
Plymouth, IN
Salem, OR
Dallas, TX

| | | |
|----------|--------|--------|
| PART NO. | USF-4U | PAGE |
| DWG. NO. | USF-4U | 1 OF 1 |

TOWER/MAST SIZE AT PROPOSED ANTENNA ATTACHMENT = 2.875" ± DIAMETER.
 FRAME MAST SIZE AT PROPOSED ANTENNA ATTACHMENT = 3.000" ± DIAMETER.

| PARTS LIST | | | | | | |
|------------|-----|----------|--|------------|-------------|---------|
| ITEM | QTY | PART NO. | PART DESCRIPTION | LENGTH | UNIT WT. | NET WT. |
| 1 | 2 | X-SPTB | SLIDING PIPE TIE BACK PLATE | 5 1/2 in | 5.87 | 11.74 |
| 2 | 2 | X-TBCA | TIE BACK CLIP ANGLE | | 2.08 | 4.16 |
| 3 | 1 | P2126 | 2-3/8" OD X 126" SCH 40 GALVANIZED PIPE | 126 in | 40.75 | 40.75 |
| 4 | 2 | MCP | CLAMP HALF 1/2" THICK, 11-5/8" LONG | 12 1/16 in | 3.59 | 7.19 |
| 5 | 4 | DCP | 1/2" THICK, 5-3/4" CNER TO CENTER CLAMP HALF | 8 1/8 in | 2.42 | 9.68 |
| 6 | 2 | G58R-12 | 5/8" x 12" THREADED ROD (HDG.) | | 1.05 | 2.09 |
| 7 | 4 | G58R-8 | 5/8" x 8" THREADED ROD (HDG.) | | 0.70 | 2.79 |
| 8 | 4 | X-UB5258 | 5/8" X 2-5/8" X 4-1/2" X 2" U-BOLT (HDG.) | | 1.00 | 4.00 |
| 9 | 4 | G5804 | 5/8" x 4" HDG HEX BOLT GR5 | | 0.44 | 1.78 |
| 10 | 2 | G5802 | 5/8" x 2" HDG HEX BOLT GR5 | | 0.27 | 0.54 |
| 11 | 10 | G58FW | 5/8" HDG USS FLATWASHER | 1/8 in | 0.07 | 0.70 |
| 12 | 18 | G58LW | 5/8" HDG LOCKWASHER | | 0.03 | 0.47 |
| 13 | 20 | G58NUT | 5/8" HDG HEAVY 2H HEX NUT | | 0.13 | 2.60 |
| | | | | | TOTAL WT. # | 88.49 |



TOLERANCE NOTES

TOLERANCES ON DIMENSIONS, UNLESS OTHERWISE NOTED ARE:
 SAWED, SHEARED AND GAS CUT EDGES ($\pm 0.030"$)
 DRILLED AND GAS CUT HOLES ($\pm 0.030"$) - NO CONING OF HOLES
 LASER CUT EDGES AND HOLES ($\pm 0.010"$) - NO CONING OF HOLES
 BENDS ARE $\pm 1/2$ DEGREE
 ALL OTHER MACHINING ($\pm 0.030"$)
 ALL OTHER ASSEMBLY ($\pm 0.060"$)

PROPRIETARY NOTE:
 THE DATA AND TECHNIQUES CONTAINED IN THIS DRAWING ARE PROPRIETARY INFORMATION OF VALMONT INDUSTRIES AND CONSIDERED A TRADE SECRET. ANY USE OR DISCLOSURE WITHOUT THE CONSENT OF VALMONT INDUSTRIES IS STRICTLY PROHIBITED.

DESCRIPTION
 SLIDING PIPE
 TIE BACK ASSEMBLY

| | | |
|---------|----------------|----------------|
| CPD NO. | DRAWN BY | ENG. APPROVAL |
| CLASS | SUB | DRAWING USAGE |
| 81 | 02 | CUSTOMER |
| | CEK 10/19/2016 | BMC 11/17/2016 |

SITE PRO 1
 A valmont COMPANY

Engineering Support Team:
 1-888-753-7446

Locations:
 New York, NY
 Atlanta, GA
 Los Angeles, CA
 Plymouth, IN
 Salem, OR
 Dallas, TX

| | | |
|----------|------|--------|
| PART NO. | SPTB | PAGE |
| DWG. NO. | SPTB | 1 OF 3 |

ATTACHMENT C – STRUCTURAL ANALYSIS REPORT

Date: **March 4, 2020**



Black & Veatch Corp.
6800 W. 115th St., Suite 2292
Overland Park, KS 66211
(913) 458-2522

Subject: **Structural Analysis Report**

Eversource Designation: **Site Number:** ES-008
Site Name: MadisonAWC

Engineering Firm Designation: **Black & Veatch Corp. Project Number:** 403093

Site Data: **135 New Road, Madison, CT 06443**
Latitude 41° 17' 36.3", Longitude -72° 34' 42.2"
180 Foot - Guyed Tower

Black & Veatch Corp. is pleased to submit this “**Structural Analysis Report**” to determine the structural integrity of the above mentioned tower.

The purpose of the analysis is to determine acceptability of the tower stress level. Based on our analysis we have determined the tower stress level for the structure and foundation, under the following load case, to be:

LC1: Proposed Equipment Configuration **Sufficient Capacity – 91.7%**

This analysis utilizes an ultimate 3-second gust wind speed of 140 mph as required by the 2018 Connecticut State Building Code. Applicable Standard references and design criteria are listed in Section 2 - Analysis Criteria.

Structural analysis prepared by: Anup Chitale

Respectfully submitted by:

Joshua J. Riley, P.E.

Professional Engineer




TABLE OF CONTENTS

1) INTRODUCTION

2) ANALYSIS CRITERIA

Table 1 - Proposed Equipment Configuration

Table 2 - Other Considered Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

3.1) Analysis Method

3.2) Assumptions

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Table 5 – Tower Component Stresses vs. Capacity

4.1) Recommendations

5) APPENDIX A

tnxTower Output

6) APPENDIX B

Base Level Drawing

7) APPENDIX C

Additional Calculations

1) INTRODUCTION

This tower is a 180 ft Guyed tower manufactured by UNR-Rohn.

2) ANALYSIS CRITERIA

TIA-222 Revision: TIA-222-H
Risk Category: III
Wind Speed: 140 mph ultimate
Exposure Category: B
Topographic Factor: 1
Ice Thickness: 1.5 in
Wind Speed with Ice: 50 mph
Seismic Ss: 0.171
Seismic S1: 0.060
Service Wind Speed: 60 mph

Table 1 - Proposed Equipment Configuration

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) | Note |
|---------------------|----------------------------|--------------------|----------------------|--|----------------------|---------------------|------|
| 177.0 | 190.0 | 1 | dbspectra | DS2C03F36D-D | 2 | 7/8 | - |
| | 177.0 | 1 | site pro 1 | USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support] | | | |

Table 2 - Other Considered Equipment

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) | Note |
|---------------------|----------------------------|--------------------|----------------------|------------------------------|----------------------|---------------------|------|
| 180.5 | 190.5 | 2 | unknown | 20' x 2" Dia Omni | 1 | 1-5/8 | 1 |
| | 187.5 | 1 | unknown | 14' x 3" Dia Omni | 1 | 7/8 | |
| | | 1 | | | | 1 | |
| 176.5 | 176.5 | 1 | unknown | 8.5' Dish | 1 | EW63 | 1 |
| | | 1 | tower mounts | Pipe Mount [PM 602-1] | | | |
| 160.5 | 160.5 | 3 | andrew | LNx-6515DS w/ Mount Pipe | 7 | 1-5/8 1-1/4 | 1 |
| | | 1 | tower mounts | Pipe Mount [PM 602-3] | | | |
| | | 6 | ericsson | AIR 21 | | | |
| | | 3 | ericsson | KRY 112 144/1 | | | |
| | | 3 | ericsson | RRUS 11 | | | |
| 138.5 | 148.5 | 1 | unknown | 20'x3" Omni | 2 | 7/8 | 1 |
| 127.5 | 127.5 | 3 | rfs celwave | APXVSP18-C_TIA w/ Mount Pipe | 3 | 1-1/4 | 1 |
| | | 1 | tower mounts | Sector Mount [SM 502-3] | | | |
| | | 3 | alcatel lucent | FD-RRH-4x45-1900 | | | |
| | | 3 | alcatel lucent | FD-RRH-2x50-800 | | | |
| 89.5 | 89.5 | 1 | andrew | GPS | 1 | 1/2 | 1 |
| | | 1 | tower mounts | Side Arm Mount [SO 203-1] | | | |

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) | Note |
|---------------------|----------------------------|--------------------|--------------------------|-------------------------------------|----------------------|----------------------------|------|
| 78.5 | 78.5 | 1 | tower mounts | Sector Mount [SM 502-3] | 6 1 2 | 7/8 5/8 #8DC Control | 1 |
| | | 3 | kmw communications | AM-X-CD-14-65-00T-RET w/ Mount Pipe | | | |
| | | 6 | lucent | LGP21401 | | | |
| | | 3 | powerwave panel antennas | 7770.00 w/ Mount Pipe | | | |
| | - | - | 18"x18"x 6" Equipment | | | | |
| 76.5 | 1 | raycap | DC6-48-60-18-8F | | | | |

Note:
 1) Existing Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

| Document | Remarks | Reference | Source |
|--|---|----------------|------------|
| TOWER STRUCTURAL ANALYSIS REPORTS | Centek Engineering, Inc., dated 09/20/2018 | Tower geometry | Eversource |
| TOWER FOUNDATION DRAWINGS/DESIGN/SPECS | FDH Engineering, Inc. dated 01/05/2011 | - | Eversource |
| TOWER FOUNDATION DRAWINGS/DESIGN/SPECS | H.E. Bergeron Engineers, P.A. dated 09/23/2003 | - | Eversource |
| GEOTECHNICAL REPORTS | Dr. Clarence Welti, P.E., P.C. dated 06/16/1997 | - | Eversource |

3.1) Analysis Method

tnxTower (version 8.0.5.0), a commercially available analysis software package, was used to create a three-dimensional model of the tower and calculate member stresses for various loading cases. Selected output from the analysis is included in Appendix A.

3.2) Assumptions

- 1) Tower and structures were built and maintained in accordance with the manufacturer's specifications.
- 2) The configuration of antennas, transmission cables, mounts and other appurtenances are as specified in Tables 1 and 2 and the referenced drawings.
- 3) The existing base plate grout was considered in this analysis. Grout must be maintained and inspected periodically and must be replaced if damaged or cracked.
- 4) This analysis was performed under the assumption that all information provided to Black & Veatch is current and correct. This is to include site data, appurtenance loading, tower/foundation details, and geotechnical data.
- 5) Tower loading is based on 2018 drone mapping photos.

This analysis may be affected if any assumptions are not valid or have been made in error. Black & Veatch Corp. should be notified to determine the effect on the structural integrity of the tower.

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

| Section No. | Elevation (ft) | Component Type | Size | Critical Element | P (K) | SF*P_allow (K) | % Capacity | Pass / Fail |
|-------------|----------------|----------------|-------------------|------------------|--------|----------------|------------------|-------------|
| T1 | 181.5 - 161.5 | Leg | Pipe 2.5 STD | 3 | -15.17 | 71.89 | 21.1 | Pass |
| T2 | 161.5 - 141.5 | Leg | Pipe 2.5 STD | 58 | -22.20 | 62.19 | 35.7 | Pass |
| T3 | 141.5 - 121.5 | Leg | Pipe 2.5 STD | 91 | -37.93 | 75.48 | 50.3 | Pass |
| T4 | 121.5 - 101.5 | Leg | Pipe 2.5 STD | 148 | -42.89 | 75.48 | 56.8 | Pass |
| T5 | 101.5 - 81.5 | Leg | Pipe 2.5 STD | 202 | -43.56 | 75.48 | 57.7 | Pass |
| T6 | 81.5 - 61.5 | Leg | Pipe 2.5 STD | 257 | -49.68 | 62.19 | 79.9 | Pass |
| T7 | 61.5 - 41.5 | Leg | Pipe 2.5 STD | 291 | -53.89 | 62.19 | 86.7 | Pass |
| T8 | 41.5 - 21.5 | Leg | Pipe 2.5 STD | 324 | -52.98 | 59.23 | 89.5 | Pass |
| T9 | 21.5 - 6.5 | Leg | Pipe 2.5 STD | 357 | -54.18 | 59.89 | 90.5 | Pass |
| T10 | 6.5 - 1.5 | Leg | Pipe 2.5 STD | 384 | -58.76 | 72.64 | 80.9 | Pass |
| T1 | 181.5 - 161.5 | Diagonal | L1 3/4x1 3/4x3/16 | 31 | 2.53 | 17.26 | 14.6 42.1 (b) | Pass |
| T2 | 161.5 - 141.5 | Diagonal | TS1.5x16ga | 69 | -1.72 | 5.88 | 29.3 36.9 (b) | Pass |
| T3 | 141.5 - 121.5 | Diagonal | L2x2x3/16 | 113 | 2.67 | 20.48 | 13.0 41.0 (b) | Pass |
| T4 | 121.5 - 101.5 | Diagonal | L2 1/2x2 1/2x1/2 | 199 | -3.45 | 55.87 | 6.2 23.8 (b) | Pass |
| T5 | 101.5 - 81.5 | Diagonal | TS1.5x16ga | 212 | -2.01 | 5.88 | 34.2 37.4 (b) | Pass |
| T6 | 81.5 - 61.5 | Diagonal | L2 1/2x2 1/2x1/2 | 273 | -4.43 | 55.87 | 7.9 30.7 (b) | Pass |
| T7 | 61.5 - 41.5 | Diagonal | L2 1/2x2 1/2x1/2 | 320 | -3.51 | 55.87 | 6.3 24.2 (b) | Pass |
| T8 | 41.5 - 21.5 | Diagonal | TS1.5x16ga | 353 | -1.79 | 5.88 | 30.4 37.5 (b) | Pass |
| T9 | 21.5 - 6.5 | Diagonal | L2 1/2x2 1/2x1/2 | 366 | -1.54 | 56.05 | 2.8 10.6 (b) | Pass |
| T4 | 121.5 - 101.5 | Horizontal | L2 1/2x2 1/2x1/2 | 174 | 1.17 | 71.98 | 1.6 8.1 (b) | Pass |
| T5 | 101.5 - 81.5 | Horizontal | L2 1/2x2 1/2x1/2 | 227 | 0.80 | 71.98 | 1.1 5.5 (b) | Pass |
| T10 | 6.5 - 1.5 | Horizontal | C12x20.7 | 391 | 0.02 | 207.18 | 1.0 | Pass |
| T1 | 181.5 - 161.5 | Top Girt | L1 3/4x1 3/4x3/16 | 4 | -0.11 | 14.26 | 0.8 1.2 (b) | Pass |
| T2 | 161.5 - 141.5 | Top Girt | TS1.5x16ga | 61 | -0.90 | 6.73 | 13.4 21.0 (b) | Pass |
| T3 | 141.5 - 121.5 | Top Girt | L2x2x3/16 | 96 | 0.46 | 20.48 | 2.2 7.0 (b) | Pass |
| T4 | 121.5 - 101.5 | Top Girt | L2 1/2x2 1/2x1/2 | 153 | 1.67 | 64.23 | 2.6 11.5 (b) | Pass |
| T5 | 101.5 - 81.5 | Top Girt | TS1.5x16ga | 205 | 0.35 | 8.95 | 3.9 8.1 (b) | Pass |
| T6 | 81.5 - 61.5 | Top Girt | L2 1/2x2 1/2x1/2 | 259 | 0.99 | 64.23 | 1.5 6.8 (b) | Pass |
| T7 | 61.5 - 41.5 | Top Girt | TS1.5x16ga | 293 | -1.60 | 6.73 | 23.8 43.2 (b) | Pass |
| T8 | 41.5 - 21.5 | Top Girt | TS1.5x16ga | 326 | -0.71 | 6.73 | 10.5 19.0 (b) | Pass |
| T9 | 21.5 - 6.5 | Top Girt | L2 1/2x2 1/2x1/2 | 360 | 0.31 | 64.23 | 0.5 2.1 (b) | Pass |
| T10 | 6.5 - 1.5 | Top Girt | C12x20.7 | 386 | 8.47 | 197.32 | 4.3 | Pass |

| Section No. | Elevation (ft) | Component Type | Size | Critical Element | P (K) | SF*P_allow (K) | % Capacity | Pass / Fail | |
|-------------|----------------|---------------------------|-------------------|------------------|--------|----------------|-----------------------|-------------|------|
| T1 | 181.5 - 161.5 | Bottom Girt | L1 3/4x1 3/4x3/16 | 8 | -0.62 | 14.26 | 4.4 9.8 (b) | Pass | |
| T2 | 161.5 - 141.5 | Bottom Girt | TS1.5x16ga | 65 | -0.80 | 6.73 | 11.8 17.2 (b) | Pass | |
| T3 | 141.5 - 121.5 | Bottom Girt | L2x2x3/16 | 97 | 0.86 | 20.48 | 4.2 13.3 (b) | Pass | |
| T4 | 121.5 - 101.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 156 | 0.55 | 64.23 | 0.9 3.8 (b) | Pass | |
| T5 | 101.5 - 81.5 | Bottom Girt | TS1.5x16ga | 209 | -0.57 | 6.73 | 8.4 14.8 (b) | Pass | |
| T6 | 81.5 - 61.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 262 | 3.88 | 64.23 | 6.0 26.7 (b) | Pass | |
| T7 | 61.5 - 41.5 | Bottom Girt | TS1.5x16ga | 296 | -0.79 | 6.73 | 11.8 21.2 (b) | Pass | |
| T8 | 41.5 - 21.5 | Bottom Girt | TS1.5x16ga | 329 | 0.24 | 8.95 | 2.7 5.6 (b) | Pass | |
| T9 | 21.5 - 6.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 362 | 4.32 | 64.23 | 6.7 29.8 (b) | Pass | |
| T10 | 6.5 - 1.5 | Bottom Girt | C12x20.7 | 388 | -3.26 | 197.29 | 6.4 | Pass | |
| T1 | 181.5 - 161.5 | Guy A@169.154 | 9/16 | 407 | 9.63 | 22.05 | 43.7 | Pass | |
| T3 | 141.5 - 121.5 | Guy A@129.154 | 9/16 | 425 | 9.65 | 22.05 | 43.8 | Pass | |
| T6 | 81.5 - 61.5 | Guy A@62.1146 | 3/4 | 435 | 13.89 | 36.73 | 37.8 | Pass | |
| T1 | 181.5 - 161.5 | Guy B@169.154 | 9/16 | 401 | 9.46 | 22.05 | 42.9 | Pass | |
| T3 | 141.5 - 121.5 | Guy B@129.154 | 9/16 | 418 | 9.36 | 22.05 | 42.5 | Pass | |
| T6 | 81.5 - 61.5 | Guy B@62.1146 | 3/4 | 434 | 13.78 | 36.73 | 37.5 | Pass | |
| T1 | 181.5 - 161.5 | Guy C@169.154 | 9/16 | 394 | 9.32 | 22.05 | 42.3 | Pass | |
| T3 | 141.5 - 121.5 | Guy C@129.154 | 9/16 | 412 | 9.60 | 22.05 | 43.5 | Pass | |
| T6 | 81.5 - 61.5 | Guy C@62.1146 | 3/4 | 430 | 13.52 | 36.73 | 36.8 | Pass | |
| T6 | 81.5 - 61.5 | Top Guy Pull-Off@62.1146 | 4 1/2x3/8 | 431 | 2.91 | 48.17 | 6.0 | Pass | |
| T1 | 181.5 - 161.5 | Torque Arm Top@169.154 | P4x.237 | 409 | 13.50 | 107.98 | 12.5 | Pass | |
| T3 | 141.5 - 121.5 | Torque Arm Top@129.154 | P4x.237 | 421 | 12.38 | 107.98 | 11.5 | Pass | |
| T1 | 181.5 - 161.5 | Torque Arm Bottom@169.154 | P4x.237 | 399 | -14.15 | 101.79 | 13.9 | Pass | |
| T3 | 141.5 - 121.5 | Torque Arm Bottom@129.154 | P4x.237 | 417 | -13.17 | 101.79 | 12.9 | Pass | |
| | | | | | | | Summary | | |
| | | | | | | | Leg (T9) | 90.5 | Pass |
| | | | | | | | Diagonal (T1) | 42.1 | Pass |
| | | | | | | | Horizontal (T4) | 8.1 | Pass |
| | | | | | | | Top Girt (T7) | 43.2 | Pass |
| | | | | | | | Bottom Girt (T9) | 29.8 | Pass |
| | | | | | | | Guy A (T3) | 43.8 | Pass |
| | | | | | | | Guy B (T1) | 42.9 | Pass |
| | | | | | | | Guy C (T3) | 43.5 | Pass |
| | | | | | | | Top Guy Pull-Off (T6) | 6.0 | Pass |

| Section No. | Elevation (ft) | Component Type | Size | Critical Element | P (K) | SF*P_allow (K) | % Capacity | Pass / Fail |
|-------------|----------------|----------------|------|------------------|-------|------------------------|-------------|-------------|
| | | | | | | Torque Arm Top (T1) | 12.5 | Pass |
| | | | | | | Torque Arm Bottom (T1) | 13.9 | Pass |
| | | | | | | Bolt Checks | 43.2 | Pass |
| | | | | | | Rating = | 90.5 | Pass |

Table 5 - Tower Component Stresses vs. Capacity - LC1

| Notes | Component | Elevation (ft) | % Capacity | Pass / Fail |
|-------|--|----------------|------------|-------------|
| 1 | Base Foundation | 0 | 17.3 | Pass |
| | Base Foundation Soil Interaction | | 91.7 | Pass |
| 1 | Guy Anchor Foundation Structural (Inner) | 0 | 14.1 | Pass |
| | Guy Anchor Foundation Soil Interaction (Inner) | | 53.7 | Pass |
| 1 | Guy Anchor Foundation Structural (Outer) | 0 | 38.4 | Pass |
| | Guy Anchor Foundation Soil Interaction (Outer) | | 80.2 | Pass |

| | |
|---|--------------|
| Structure Rating (max from all components) = | 91.7% |
|---|--------------|

Note:

- 1) See additional documentation in "Appendix C – Additional Calculations" for calculations supporting the % capacity consumed. Rating per TIA-222-H Section 15.5.

4.1) Recommendations

The tower and its base and anchor foundations have sufficient capacity to carry the proposed load configuration. No modifications are required at this time.

Maximum Tower Deflections - Service Wind

| <i>Section No.</i> | <i>Elevation ft</i> | <i>Horz. Deflection in</i> | <i>Gov. Load Comb.</i> | <i>Tilt °</i> | <i>Twist °</i> | <i>Check*</i> |
|--------------------|---------------------|----------------------------|------------------------|---------------|----------------|---------------|
| T1 | 181.5 - 161.5 | 0.754 | 33 | 0.0225 | 0.0736 | OK |
| T2 | 161.5 - 141.5 | 0.692 | 33 | 0.0127 | 0.061 | OK |
| T3 | 141.5 - 121.5 | 0.653 | 33 | 0.0086 | 0.0341 | OK |
| T4 | 121.5 - 101.5 | 0.654 | 29 | 0.0153 | 0.0334 | OK |
| T5 | 101.5 - 81.5 | 0.678 | 31 | 0.013 | 0.0397 | OK |
| T6 | 81.5 - 61.5 | 0.555 | 31 | 0.0428 | 0.0441 | OK |

*Limit State Deformation (TIA-222-H Section 2.8.2)

- 1) Maximum Rotation = 4 Degrees
- 2) Maximum Deflection = 0.03 * Tower Height = 65 in.

Critical Deflections of Tower at the MW Dish Elevations - Service Wind

| <i>Elevation (ft)</i> | <i>MW Dish</i> | <i>Tilt (°)</i> | <i>Twist (°)</i> | <i>Diameter, D (ft)</i> | <i>Frequency, α (GHz)</i> | <i>Decibel Points</i> | <i>Deformation Limit (θ)*</i> | <i>Deformation Limit Exceeded?</i> |
|-----------------------|----------------|-----------------|------------------|-------------------------|---|-----------------------|---|------------------------------------|
| 176.5 | 8.5' Dish | 0.0181 | 0.0716 | 8 | 10 | 10 dB | 0.664 | Not Exceeded |

*Limit per TIA-222-H Annex D

Maximum Tower Deflections - Design Wind

| <i>Section No.</i> | <i>Elevation ft</i> | <i>Horz. Deflection in</i> | <i>Gov. Load Comb.</i> | <i>Tilt °</i> | <i>Twist °</i> | <i>Combined Max</i> | <i>Check*</i> |
|--------------------|-------------------------|------------------------------------|--------------------------------|-------------------|--------------------|-------------------------|---------------|
| T1 | 181.5 - 161.5 | 3.049 | 33 | 0.0943 | 0.2795 | 0.295 | OK |
| T2 | 161.5 - 141.5 | 2.746 | 33 | 0.0518 | 0.2387 | 0.244 | OK |
| T3 | 141.5 - 121.5 | 2.505 | 33 | 0.0546 | 0.1378 | 0.148 | OK |
| T4 | 121.5 - 101.5 | 2.387 | 33 | 0.0598 | 0.1266 | 0.140 | OK |
| T5 | 101.5 - 81.5 | 2.319 | 29 | 0.0624 | 0.1404 | 0.154 | OK |
| T6 | 81.5 - 61.5 | 1.905 | 31 | 0.1518 | 0.1592 | 0.220 | OK |



*Up to 0.5 degree is considered acceptable per SUB090 Section 7

Critical Deflections of Tower at the MW Dish Elevations - Design Wind

| <i>Elevation ft</i> | <i>Appurtenance</i> | <i>Gov. Load Comb.</i> | <i>Deflection in</i> | <i>Tilt °</i> | <i>Twist °</i> | <i>Radius of Curvature ft</i> |
|-------------------------|---------------------|--------------------------------|--------------------------|-------------------|--------------------|---------------------------------------|
| 176.5 | 8.5' Dish | 33 | 2.971 | 0.0795 | 0.2741 | 297615.000 |

APPENDIX A
TNXTOWER OUTPUT

| Section | T1 | T2 | T3 | T4 | T5 | T6 | T7 | T8 | T9 | T10 |
|-------------------|-------------------|------------|-------------|------------------|--------------|------------------|------------------|------------------|------------------|------|
| Legs | | | | | | | | | | |
| Leg Grade | | | | | | | | | | |
| Diagonals | L1 3/4x1 3/4x3/16 | TS1.5x16ga | L2 2x2x3/16 | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | N.A. |
| Diagonal Grade | A36 | A53-B-35 | A36 | A36 | A36 | A36 | A36 | A36 | A36 | N.A. |
| Top Girts | L1 3/4x1 3/4x3/16 | TS1.5x16ga | L2 2x2x3/16 | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | TS1.5x16ga | N.A. |
| Bottom Girts | L1 3/4x1 3/4x3/16 | TS1.5x16ga | L2 2x2x3/16 | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | TS1.5x16ga | L2 1/2x2 1/2x1/2 | TS1.5x16ga | N.A. |
| Horizontalis | | | | | | | | | | |
| Top Guy Pull-Offs | | | | | | 4 1/2x3/8 | | | | |
| Face Width (ft) | | | | | | | | | | |
| # Panels @ (ft) | | | | | 72 @ 2.34635 | | | | 7 @ 2.29514 | |
| Weight (K) | | | | | | | | | 10.8 | 0.4 |



DESIGNED APPURTENANCE LOADING

| TYPE | ELEVATION | TYPE | ELEVATION |
|--|-----------|---|-----------|
| 20' x 2" Dia Omni | 180.5 | 20'x3" Omni | 138.5 |
| 14' x 3" Dia Omni | 180.5 | (2) 6' x 2" Mount Pipe | 127.5 |
| 20' x 2" Dia Omni | 180.5 | APXVSP18-C_TIA w/ Mount Pipe | 127.5 |
| DS2C03F36D-D | 177 | APXVSP18-C_TIA w/ Mount Pipe | 127.5 |
| USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support] | 177 | APXVSP18-C_TIA w/ Mount Pipe | 127.5 |
| Pipe Mount [PM 602-1] | 176.5 | FD-RRH-2x50-800 | 127.5 |
| 8.5' Dish | 176.5 | FD-RRH-2x50-800 | 127.5 |
| 8'x4" Std Horizontal Mount Pipe | 160.5 | FD-RRH-4x45-1900 | 127.5 |
| 6'x2" Horizontal Pipe | 160.5 | FD-RRH-4x45-1900 | 127.5 |
| LNx-6515DS w/ Mount Pipe | 160.5 | FD-RRH-4x45-1900 | 127.5 |
| LNx-6515DS w/ Mount Pipe | 160.5 | Sector Mount [SM 502-3] | 127.5 |
| LNx-6515DS w/ Mount Pipe | 160.5 | (2) 6' x 2" Mount Pipe | 127.5 |
| (2) AIR 21 | 160.5 | (2) 6' x 2" Mount Pipe | 127.5 |
| (2) AIR 21 | 160.5 | Side Arm Mount [SO 203-1] | 89.5 |
| (2) AIR 21 | 160.5 | GPS | 89.5 |
| KRY 112 TMA | 160.5 | 7770.00 w/ Mount Pipe | 78.5 |
| KRY 112 TMA | 160.5 | AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | 78.5 |
| KRY 112 TMA | 160.5 | AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | 78.5 |
| RRUS 11 | 160.5 | AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | 78.5 |
| RRUS 11 | 160.5 | AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | 78.5 |
| RRUS 11 | 160.5 | (2) LGP21401 TMA | 78.5 |
| 8'x4" Std Horizontal Mount Pipe | 160.5 | (2) LGP21401 TMA | 78.5 |
| Pipe Mount [PM 602-3] | 160.5 | (2) LGP21401 TMA | 78.5 |
| 8'x4" Std Horizontal Mount Pipe | 160.5 | 18"x18"x 6" Equipment | 78.5 |
| 8' x 2" Horizontal Mount Pipe | 148.5 | DC6-48-60-18-8F | 78.5 |
| 7' Hor x 2.5" x 2.5" Angle Mount | 138.5 | 7770.00 w/ Mount Pipe | 78.5 |
| 7' Hor x 2.5" x 2.5" Angle Mount | 138.5 | 7770.00 w/ Mount Pipe | 78.5 |
| 7' Hor x 2.5" x 2.5" Angle Mount | 138.5 | 7770.00 w/ Mount Pipe | 78.5 |
| 7' Hor x 2.5" x 2.5" Angle Mount | 138.5 | Sector Mount [SM 502-3] | 78.5 |
| 6' x 3" Mount Pipe | 138.5 | | |
| 20' x 2" Mount Pipe | 138.5 | | |

SYMBOL LIST


| MARK | SIZE | MARK | SIZE |
|------|----------|------|------|
| A | C12x20.7 | | |

MATERIAL STRENGTH

| GRADE | Fy | Fu | GRADE | Fy | Fu |
|---------|--------|--------|----------|--------|--------|
| A572-50 | 50 ksi | 65 ksi | A53-B-35 | 35 ksi | 60 ksi |
| A36 | 36 ksi | 58 ksi | | | |

TOWER DESIGN NOTES

1. Tower designed for Exposure B to the TIA-222-H Standard.
2. Tower designed for a 140 mph basic wind in accordance with the TIA-222-H Standard.
3. Tower is also designed for a 50 mph basic wind with 1.50 in ice. Ice is considered to increase in thickness with height.
4. Deflections are based upon a 60 mph wind.
5. Tower Risk Category III.
6. Topographic Category 1 with Crest Height of 0.00 ft
7. TOWER RATING: 90.5%



ALL REACTIONS ARE FACTORED

BLACK & VEATCH Building a world of difference.
 6800 W. 115th St., Suite 2292
 Overland Park, KS 66211
 Phone: (913) 458-2984
 FAX: (913) 458-8136

Job: **ES-008 MadisonAWC**
 Project: **403093 (MadisonAWC)**
 Client: _____ Drawn by: Josh Riley App'd: _____
 Code: TIA-222-H Date: 02/25/20 Scale: NTS
 Path: _____ Dwg No. E-1

Tower Input Data


The main tower is a 3x guyed tower with an overall height of 181.50 ft above the ground line.
 The base of the tower is set at an elevation of 1.50 ft above the ground line.
 The face width of the tower is 3.41 ft at the top and tapered at the base.
 This tower is designed using the TIA-222-H standard.

The following design criteria apply:


1. Tower base elevation above sea level: 64.50 ft.
2. Basic wind speed of 140 mph.
3. Risk Category III.
4. Exposure Category B.
5. Simplified Topographic Factor Procedure for wind speed-up calculations is used.
6. Topographic Category: 1.
7. Crest Height: 0.00 ft.
8. Nominal ice thickness of 1.5000 in.
9. Ice thickness is considered to increase with height.
10. Ice density of 56 pcf.
11. A wind speed of 50 mph is used in combination with ice.
12. Temperature drop of 50 °F.
13. Deflections calculated using a wind speed of 60 mph.
14. Pressures are calculated at each section.
15. Safety factor used in guy design is 0.9524.
16. Stress ratio used in tower member design is 1.05.
17. Local bending stresses due to climbing loads, feed line supports, and appurtenance mounts are not considered.

Options

- | | | |
|--|---|--|
| Consider Moments - Legs Consider Moments - Horizontals Consider Moments - Diagonals Use Moment Magnification Use Code Stress Ratios Use Code Safety Factors - Guys Escalate Ice Always Use Max Kz Use Special Wind Profile | Distribute Leg Loads As Uniform Assume Legs Pinned ✓ Assume Rigid Index Plate ✓ Use Clear Spans For Wind Area ✓ Use Clear Spans For KL/r ✓ Retension Guys To Initial Tension ✓ Bypass Mast Stability Checks ✓ Use Azimuth Dish Coefficients ✓ Project Wind Area of Appurt. ✓ Autocalc Torque Arm Areas | Use ASCE 10 X-Brace Ly Rules ✓ Calculate Redundant Bracing Forces Ignore Redundant Members in FEA ✓ SR Leg Bolts Resist Compression All Leg Panels Have Same Allowable Offset Girt At Foundation ✓ Consider Feed Line Torque ✓ Include Angle Block Shear Check Use TIA-222-H Bracing Resist. Exemption Use TIA-222-H Tension Splice Exemption |
| ✓ Include Bolts In Member Capacity ✓ Leg Bolts Are At Top Of Section ✓ Secondary Horizontal Braces Leg Use Diamond Inner Bracing (4 Sided) ✓ SR Members Have Cut Ends SR Members Are Concentric | Add IBC .6D+W Combination ✓ Sort Capacity Reports By Component Triangulate Diamond Inner Bracing Treat Feed Line Bundles As Cylinder Ignore KL/ry For 60 Deg. Angle Legs | <div style="background-color: #e0e0e0; text-align: center; padding: 2px; margin-bottom: 5px;">Poles</div> Include Shear-Torsion Interaction Always Use Sub-Critical Flow Use Top Mounted Sockets Pole Without Linear Attachments Pole With Shroud Or No Appurtenances Outside and Inside Corner Radii Are Known |



Corner & Starmount Guyed Tower



Face Guyed

Tower Section Geometry

| Tower Section | Tower Elevation | Assembly Database | Description | Section Width | Number of Sections | Section Length |
|---------------|-----------------|-------------------|-------------|---------------|--------------------|----------------|
| | ft | | | ft | | ft |
| T1 | 181.50-161.50 | | | 3.41 | 1 | 20.00 |
| T2 | 161.50-141.50 | | | 3.41 | 1 | 20.00 |
| T3 | 141.50-121.50 | | | 3.41 | 1 | 20.00 |
| T4 | 121.50-101.50 | | | 3.41 | 1 | 20.00 |
| T5 | 101.50-81.50 | | | 3.41 | 1 | 20.00 |
| T6 | 81.50-61.50 | | | 3.41 | 1 | 20.00 |
| T7 | 61.50-41.50 | | | 3.41 | 1 | 20.00 |
| T8 | 41.50-21.50 | | | 3.41 | 1 | 20.00 |
| T9 | 21.50-6.50 | | | 3.41 | 1 | 15.00 |
| T10 | 6.50-1.50 | | | 3.41 | 1 | 5.00 |

Tower Section Geometry (cont'd)

| Tower Section | Tower Elevation | Diagonal Spacing | Bracing Type | Has K Brace End Panels | Has Horizontals | Top Girt Offset | Bottom Girt Offset |
|---------------|-----------------|------------------|--------------|------------------------|-----------------|-----------------|--------------------|
| | ft | ft | | | | in | in |
| T1 | 181.50-161.50 | 2.35 | X Brace | No | Yes | 7.3750 | 7.3750 |
| T2 | 161.50-141.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T3 | 141.50-121.50 | 2.35 | X Brace | No | Yes | 7.3750 | 7.3750 |

| Tower Section | Tower Elevation ft | Diagonal Spacing ft | Bracing Type | Has K Brace End Panels | Has Horizontals | Top Girt Offset in | Bottom Girt Offset in |
|---------------|-----------------------|------------------------|--------------|------------------------|-----------------|-----------------------|--------------------------|
| T4 | 121.50-101.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T5 | 101.50-81.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T6 | 81.50-61.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T7 | 61.50-41.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T8 | 41.50-21.50 | 2.35 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T9 | 21.50-6.50 | 2.30 | K Brace Left | No | Yes | 7.3750 | 7.3750 |
| T10 | 6.50-1.50 | 2.00 | X Brace | No | Yes | 6.0000 | 6.0000 |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg Type | Leg Size | Leg Grade | Diagonal Type | Diagonal Size | Diagonal Grade |
|-----------------------|----------|--------------|---------------------|---------------|-------------------|----------------------|
| T1 181.50-161.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L1 3/4x1 3/4x3/16 | A36 (36 ksi) |
| T2 161.50-141.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T3 141.50-121.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L2x2x3/16 | A36 (36 ksi) |
| T4 121.50-101.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T5 101.50-81.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T6 81.50-61.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T7 61.50-41.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T8 41.50-21.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T9 21.50-6.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T10 6.50-1.50 | Pipe | Pipe 2.5 STD | A572-50 (50 ksi) | Equal Angle | | A36 (36 ksi) |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Top Girt Type | Top Girt Size | Top Girt Grade | Bottom Girt Type | Bottom Girt Size | Bottom Girt Grade |
|-----------------------|---------------|-------------------|----------------------|------------------|-------------------|----------------------|
| T1 181.50-161.50 | Equal Angle | L1 3/4x1 3/4x3/16 | A36 (36 ksi) | Equal Angle | L1 3/4x1 3/4x3/16 | A36 (36 ksi) |
| T2 161.50-141.50 | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T3 141.50-121.50 | Equal Angle | L2x2x3/16 | A36 (36 ksi) | Equal Angle | L2x2x3/16 | A36 (36 ksi) |
| T4 121.50-101.50 | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T5 101.50-81.50 | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T6 81.50-61.50 | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T7 61.50-41.50 | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T8 41.50-21.50 | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) | Pipe | TS1.5x16ga | A53-B-35 (35 ksi) |
| T9 21.50-6.50 | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A36 (36 ksi) |
| T10 6.50-1.50 | Channel | C12x20.7 | A36 (36 ksi) | Channel | C12x20.7 | A36 (36 ksi) |

Tower Section Geometry (cont'd)

| Tower Elevation ft | No. of Mid Girts | Mid Girt Type | Mid Girt Size | Mid Girt Grade | Horizontal Type | Horizontal Size | Horizontal Grade |
|-----------------------|------------------|---------------|---------------|-----------------|-----------------|------------------|---------------------|
| T4 121.50-101.50 | None | Flat Bar | | A36 (36 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A572-50 (50 ksi) |
| T5 101.50-81.50 | None | Flat Bar | | A36 (36 ksi) | Equal Angle | L2 1/2x2 1/2x1/2 | A572-50 (50 ksi) |
| T10 6.50-1.50 | None | Single Angle | | A36 (36 ksi) | Channel | C12x20.7 | A36 (36 ksi) |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Gusset Area (per face) ft ² | Gusset Thickness in | Gusset Grade | Adjust. Factor A _r | Adjust. Factor A _r | Weight Mult. | Double Angle Stitch Bolt Spacing Diagonals in | Double Angle Stitch Bolt Spacing Horizontals in | Double Angle Stitch Bolt Spacing Redundants in |
|-----------------------|--|------------------------|-----------------|----------------------------------|----------------------------------|--------------|---|---|--|
| T1 181.50-161.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | Mid-Pt | Mid-Pt | 36.0000 |
| T2 161.50-141.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T3 141.50-121.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T4 121.50-101.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T5 101.50-81.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T6 81.50-61.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T7 61.50-41.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T8 41.50-21.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T9 21.50-6.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T10 6.50-1.50 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Calc K Single Angles | Calc K Solid Rounds | Legs | K Factors ¹ | | | | | | |
|-----------------------|-------------------------|------------------------|------|------------------------|------------------|-----------------|--------|--------|----------------|----------------|
| | | | | X Brace Diags | K Brace Diags | Single Diags | Girts | Horiz. | Sec. Horiz. | Inner Brace |
| | | | | X Y | X Y | X Y | X Y | X Y | X Y | X Y |
| T1 181.50-161.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T2 161.50-141.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T3 141.50-121.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T4 121.50-101.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T5 101.50-81.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T6 81.50- | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |

| Tower Elevation ft | Calc K Single Angles | Calc K Solid Rounds | K Factors ¹ | | | | | | | | | |
|-----------------------|-------------------------|------------------------|------------------------|---------------------|---------------------|-----------------|--------|--------|----------------|----------------|---|---|
| | | | Legs | X Brace Diags | K Brace Diags | Single Diags | Girts | Horiz. | Sec. Horiz. | Inner Brace | | |
| | | | | X Y | X Y | X Y | X Y | X Y | X Y | X Y | | |
| 61.50 | | | | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T7 61.50-41.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T8 41.50-21.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T9 21.50-6.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T10 6.50-1.50 | Yes | Yes | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |

¹Note: K factors are applied to member segment lengths. K-braces without inner supporting members will have the K factor in the out-of-plane direction applied to the overall length.

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|-----------------------|---------------------------|---|---------------------------|------|---------------------------|------|---------------------------|------|---------------------------|------|---------------------------|------|---------------------------|------|
| | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U |
| T1 181.50-161.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T2 161.50-141.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T3 141.50-121.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T4 121.50-101.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T5 101.50-81.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T6 81.50-61.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T7 61.50-41.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T8 41.50-21.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T9 21.50-6.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T10 6.50-1.50 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg Connection Type | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|-----------------------|------------------------|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|------------------|-----|
| | | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. |
| T1 181.50-161.50 | Flange | 0.7500 | 0 | 0.5000 | 1 | 0.5000 | 1 | 0.5000 | 1 | 0.6250 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T2 161.50-141.50 | Flange | 0.7500 | 4 | 0.5000 | 1 | 0.5000 | 1 | 0.5000 | 1 | 0.6250 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T3 141.50-121.50 | Flange | 0.7500 | 4 | 0.5000 | 1 | 0.5000 | 1 | 0.5000 | 1 | 0.6250 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T4 121.50-101.50 | Flange | 0.7500 | 4 | 0.6250 | 1 | 0.6250 | 1 | 0.6250 | 1 | 0.6250 | 0 | 0.6250 | 1 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T5 101.50-81.50 | Flange | 0.7500 | 4 | 0.5000 | 1 | 0.5000 | 1 | 0.5000 | 1 | 0.6250 | 0 | 0.6250 | 1 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |

| Tower Elevation ft | Leg Connection Type | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|-----------------------|---------------------|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|-----------------|-----|------------------|-----|
| | | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. |
| T6 81.50-61.50 | Flange | 0.7500 | 4 | 0.6250 | 1 | 0.6250 | 1 | 0.6250 | 1 | 1.0000 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T7 61.50-41.50 | Flange | 0.7500 | 4 | 0.6250 | 1 | 0.5000 | 1 | 0.5000 | 1 | 1.0000 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T8 41.50-21.50 | Flange | 0.7500 | 4 | 0.5000 | 1 | 0.5000 | 1 | 0.5000 | 1 | 1.0000 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T9 21.50-6.50 | Flange | 0.7500 | 4 | 0.6250 | 1 | 0.6250 | 1 | 0.6250 | 1 | 1.0000 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |
| T10 6.50-1.50 | Flange | 0.7500 | 4 | 0.0000 | 0 | 0.0000 | 0 | 0.0000 | 0 | 1.0000 | 0 | 0.6250 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | | A325N | |

Guy Data

| Guy Elevation ft | Guy Grade | Guy Size | Initial Tension K | % | Guy Modulus ksi | Guy Weight plf | L_u ft | Anchor Radius ft | Anchor Azimuth Adj. ° | Anchor Elevation ft | End Fitting Efficiency % |
|---------------------|-----------|----------|----------------------|-----|--------------------|-------------------|-------------|---------------------|-----------------------------|------------------------|-----------------------------|
| 169.154 | EHS | A 9/16 | 3.50 | 10% | 23000 | 0.671 | 248.23 | 184.00 | 0.0000 | 0.00 | 100% |
| | | B 9/16 | 3.50 | 10% | 23000 | 0.671 | 248.23 | 184.00 | 0.0000 | 0.00 | 100% |
| | | C 9/16 | 3.50 | 10% | 23000 | 0.671 | 248.23 | 184.00 | 0.0000 | 0.00 | 100% |
| 129.154 | EHS | A 9/16 | 3.50 | 10% | 23000 | 0.671 | 222.94 | 184.00 | 0.0000 | 0.00 | 100% |
| | | B 9/16 | 3.50 | 10% | 23000 | 0.671 | 222.94 | 184.00 | 0.0000 | 0.00 | 100% |
| | | C 9/16 | 3.50 | 10% | 23000 | 0.671 | 222.94 | 184.00 | 0.0000 | 0.00 | 100% |
| 62.1146 | EHS | A 3/4 | 5.83 | 10% | 24000 | 1.155 | 160.42 | 150.00 | 0.0000 | 0.00 | 100% |
| | | B 3/4 | 5.83 | 10% | 24000 | 1.155 | 164.86 | 154.80 | 0.0000 | 0.00 | 100% |
| | | C 3/4 | 5.83 | 10% | 24000 | 1.155 | 170.80 | 161.20 | 0.0000 | 0.00 | 100% |

Guy Data(cont'd)

| Guy Elevation ft | Mount Type | Torque-Arm Spread ft | Torque-Arm Leg Angle ° | Torque-Arm Style | Torque-Arm Grade | Torque-Arm Type | Torque-Arm Size |
|---------------------|------------|-------------------------|---------------------------|------------------|------------------|-----------------|-----------------|
| 169.154 | Torque Arm | 7.33 | 30.0000 | Bat Ear | A36 (36 ksi) | Pipe | P4x.237 |
| 129.154 | Torque Arm | 7.33 | 30.0000 | Bat Ear | A36 (36 ksi) | Pipe | P4x.237 |
| 62.1146 | Corner | | | | | | |

Guy Data (cont'd)

| Guy Elevation ft | Diagonal Grade | Diagonal Type | Upper Diagonal Size | Lower Diagonal Size | Is Strap. | Pull-Off Grade | Pull-Off Type | Pull-Off Size |
|---------------------|---------------------|---------------|---------------------|---------------------|-----------|-----------------|---------------|---------------|
| 169.15 | A572-50 (50 ksi) | Solid Round | | | | A36 (36 ksi) | Solid Round | |
| 129.15 | A572-50 (50 ksi) | Solid Round | | | | A36 (36 ksi) | Solid Round | |
| 62.11 | A572-50 (50 ksi) | Solid Round | | | Yes | A36 (36 ksi) | Flat Bar | 4 1/2x3/8 |

Guy Data (cont'd)

| Guy Elevation ft | Cable Weight | | | Tower Intercept | | |
|---------------------|--------------|--------|--------|-----------------|---------|---------------|
| | A K | B K | C K | A ft | B ft | C ft |
| 169.154 | 0.17 | 0.17 | 0.17 | 5.82 | 5.82 | 5.82 |
| | | | | 4.2 | 4.2 | 4.2 sec/pulse |
| 129.154 | 0.15 | 0.15 | 0.15 | 4.71 | 4.71 | 4.71 |
| | | | | 3.7 | 3.7 | 3.7 sec/pulse |
| 62.1146 | 0.19 | 0.19 | 0.20 | 2.54 | 2.68 | 2.87 |
| | | | | 2.7 | 2.8 | 2.9 sec/pulse |

Guy Data (cont'd)

| Guy Elevation ft | Calc K Single Angles | Calc K Solid Rounds | Torque Arm | | Pull Off | | Diagonal | |
|---------------------|-------------------------------|------------------------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | | | K _x | K _y | K _x | K _y | K _x | K _y |
| 169.154 | No | No | 1 | 1 | 1 | 1 | 1 | 1 |
| 129.154 | No | No | 1 | 1 | 1 | 1 | 1 | 1 |
| 62.1146 | No | No | | | 1 | 1 | 1 | 1 |

Guy Data (cont'd)

| Guy Elevation ft | Torque-Arm | | | | Pull Off | | | | Diagonal | | | |
|---------------------|-----------------|--------|---------------------------|------|-----------------|--------|---------------------------|------|-----------------|--------|---------------------------|------|
| | Bolt Size in | Number | Net Width Deduct in | U | Bolt Size in | Number | Net Width Deduct in | U | Bolt Size in | Number | Net Width Deduct in | U |
| 169.154 | 0.0000 A325N | 0 | 0.0000 | 1 | 0.6250 A325N | 0 | 0.0000 | 0.75 | 0.6250 A325N | 0 | 0.0000 | 0.75 |
| 129.154 | 0.0000 A325N | 0 | 0.0000 | 1 | 0.6250 A325N | 0 | 0.0000 | 0.75 | 0.6250 A325N | 0 | 0.0000 | 0.75 |
| 62.1146 | 0.6250 A325N | 0 | 0.0000 | 0.75 | 0.6250 A325N | 4 | 0.0000 | 0.75 | 0.6250 A325N | 0 | 0.0000 | 0.75 |

Guy Pressures

| Guy Elevation ft | Guy Location | z ft | q _z psf | q _z Ice psf | Ice Thickness in |
|---------------------|--------------|---------|-----------------------|------------------------------|------------------------|
| 169.154 | A | 84.58 | 40 | 5 | 1.8952 |
| | B | 84.58 | 40 | 5 | 1.8952 |
| | C | 84.58 | 40 | 5 | 1.8952 |
| 129.154 | A | 64.58 | 37 | 5 | 1.8448 |
| | B | 64.58 | 37 | 5 | 1.8448 |
| | C | 64.58 | 37 | 5 | 1.8448 |
| 62.1146 | A | 31.06 | 30 | 4 | 1.7146 |
| | B | 31.06 | 30 | 4 | 1.7146 |
| | C | 31.06 | 30 | 4 | 1.7146 |

Feed Line/Linear Appurtenances - Entered As Round Or Flat

| Description | Face or Leg | Allow Shield | Exclude From Torque Calculation | Component Type | Placement ft | Face Offset in | Lateral Offset (Frac FW) | # | # Per Row | Clear Spacing in | Width or Diameter in | Perimeter in | Weight plf |
|--------------------------------|-------------|--------------|---------------------------------|----------------|---------------|----------------|--------------------------|---|-----------|------------------|----------------------|--------------|------------|
| LDF7-50A(1-5/8) | B | No | No | Ar (CaAa) | 181.50 - 6.50 | 0.0000 | 0.36 | 1 | 1 | 0.5000 | 1.9800 | | 0.82 |
| LDF5-50A(7/8) | A | No | No | Ar (CaAa) | 181.50 - 6.50 | 0.0000 | 0.48 | 1 | 1 | 0.5000 | 1.0300 | | 0.33 |
| LDF4P-50A(1/2) | A | No | No | Ar (CaAa) | 181.50 - 6.50 | 0.0000 | 0.45 | 1 | 1 | 0.5000 | 0.6300 | | 0.15 |
| *** EW63 | B | No | No | Ar (CaAa) | 176.50 - 6.50 | 0.0000 | 0.43 | 1 | 1 | 0.5000 | 1.5742 | | 0.51 |
| *** | | | | | | | | | | | | | |
| LDF7-50A(1-5/8) | A | No | No | Ar (CaAa) | 160.50 - 6.50 | 0.0000 | -0.35 | 1 | 1 | 0.5000 | 1.9800 | | 0.82 |
| C4006L-NFNF(1-1/4) | A | No | No | Ar (CaAa) | 160.50 - 6.50 | 2.0000 | -0.35 | 1 | 1 | 0.5000 | 1.2800 | | 0.56 |
| LDF7-50A(1-5/8) | A | No | No | Ar (CaAa) | 160.50 - 6.50 | 0.0000 | -0.22 | 6 | 3 | 0.5000 | 2.0100 | | 0.82 |
| *** | | | | | | | | | | | | | |
| LDF5-50A(7/8) | C | No | No | Ar (CaAa) | 148.50 - 6.50 | 0.0000 | -0.45 | 2 | 2 | 0.5000 | 1.0900 | | 0.33 |
| *** | | | | | | | | | | | | | |
| LDF6-50A(1-1/4) | C | No | No | Ar (CaAa) | 127.50 - 6.50 | 0.0000 | 0 | 3 | 3 | 0.5000 | 1.5500 | | 0.60 |
| *** | | | | | | | | | | | | | |
| *** | | | | | | | | | | | | | |
| LDF4P-50A(1/2) | C | No | No | Ar (CaAa) | 89.50 - 6.50 | 0.0000 | -0.35 | 1 | 1 | 0.5000 | 0.6300 | | 0.15 |
| *** | | | | | | | | | | | | | |
| VXL5-50(7/8) | A | No | No | Ar (CaAa) | 78.50 - 6.50 | 0.0000 | 0.2 | 6 | 2 | 0.5000 | 1.0900 | | 0.29 |
| RG6-Fiber | A | No | No | Ar (CaAa) | 78.50 - 6.50 | 0.0000 | 0.2 | 1 | 1 | 0.5000 | 0.6250 | | 0.50 |
| #8 AWG Copper Wire | A | No | No | Ar (CaAa) | 78.50 - 6.50 | 0.0000 | 0.22 | 2 | 2 | 0.3400 | 0.3430 | | 0.05 |
| *** | | | | | | | | | | | | | |
| ** Proposed for Discrete Loads | | | | | | | | | | | | | |
| LCF78-50A(7/8) | B | No | No | Ar (CaAa) | 181.50 - 6.50 | 0.0000 | -0.48 | 2 | 2 | 0.5000 | 1.0900 | | 0.34 |
| *** | | | | | | | | | | | | | |
| *** | | | | | | | | | | | | | |
| *** | | | | | | | | | | | | | |

Feed Line/Linear Appurtenances - Entered As Area

| Description | Face or Leg | Allow Shield | Exclude From Torque Calculation | Component Type | Placement ft | Total Number | C _A A _A ft ² /ft | Weight plf |
|-------------|-------------|--------------|---------------------------------|----------------|--------------|--------------|---|------------|
| *** | | | | | | | | |
| *** | | | | | | | | |
| *** | | | | | | | | |
| *** | | | | | | | | |
| *** | | | | | | | | |

Feed Line/Linear Appurtenances Section Areas

| Tower Sectio n | Tower Elevation ft | Face | A _R ft ² | A _F ft ² | C _{AA} In Face ft ² | C _{AA} Out Face ft ² | Weight K |
|-------------------|-----------------------|------|-----------------------------------|-----------------------------------|---|--|-------------|
| T1 | 181.50-161.50 | A | 0.000 | 0.000 | 3.320 | 0.000 | 0.01 |
| | | B | 0.000 | 0.000 | 10.681 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| T2 | 161.50-141.50 | A | 0.000 | 0.000 | 32.428 | 0.000 | 0.13 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 1.526 | 0.000 | 0.00 |
| T3 | 141.50-121.50 | A | 0.000 | 0.000 | 33.960 | 0.000 | 0.14 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 7.150 | 0.000 | 0.02 |
| T4 | 121.50-101.50 | A | 0.000 | 0.000 | 33.960 | 0.000 | 0.14 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 13.660 | 0.000 | 0.05 |
| T5 | 101.50-81.50 | A | 0.000 | 0.000 | 33.960 | 0.000 | 0.14 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 14.164 | 0.000 | 0.05 |
| T6 | 81.50-61.50 | A | 0.000 | 0.000 | 47.307 | 0.000 | 0.18 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 14.920 | 0.000 | 0.05 |
| T7 | 61.50-41.50 | A | 0.000 | 0.000 | 49.662 | 0.000 | 0.18 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 14.920 | 0.000 | 0.05 |
| T8 | 41.50-21.50 | A | 0.000 | 0.000 | 49.662 | 0.000 | 0.18 |
| | | B | 0.000 | 0.000 | 11.468 | 0.000 | 0.04 |
| | | C | 0.000 | 0.000 | 14.920 | 0.000 | 0.05 |
| T9 | 21.50-6.50 | A | 0.000 | 0.000 | 37.246 | 0.000 | 0.14 |
| | | B | 0.000 | 0.000 | 8.601 | 0.000 | 0.03 |
| | | C | 0.000 | 0.000 | 11.190 | 0.000 | 0.04 |
| T10 | 6.50-1.50 | A | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |

Feed Line/Linear Appurtenances Section Areas - With Ice

| Tower Sectio n | Tower Elevation ft | Face or Leg | Ice Thickness in | A _R ft ² | A _F ft ² | C _{AA} In Face ft ² | C _{AA} Out Face ft ² | Weight K |
|-------------------|-----------------------|-------------------|------------------------|-----------------------------------|-----------------------------------|---|--|-------------|
| T1 | 181.50-161.50 | A | 2.034 | 0.000 | 0.000 | 19.592 | 0.000 | 0.29 |
| | | B | | 0.000 | 0.000 | 41.794 | 0.000 | 0.58 |
| | | C | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| T2 | 161.50-141.50 | A | 2.009 | 0.000 | 0.000 | 74.016 | 0.000 | 1.25 |
| | | B | | 0.000 | 0.000 | 44.239 | 0.000 | 0.62 |
| | | C | | 0.000 | 0.000 | 7.371 | 0.000 | 0.08 |
| T3 | 141.50-121.50 | A | 1.981 | 0.000 | 0.000 | 76.241 | 0.000 | 1.27 |
| | | B | | 0.000 | 0.000 | 43.815 | 0.000 | 0.61 |
| | | C | | 0.000 | 0.000 | 29.170 | 0.000 | 0.32 |
| T4 | 121.50-101.50 | A | 1.948 | 0.000 | 0.000 | 75.495 | 0.000 | 1.25 |
| | | B | | 0.000 | 0.000 | 43.329 | 0.000 | 0.59 |
| | | C | | 0.000 | 0.000 | 48.112 | 0.000 | 0.56 |
| T5 | 101.50-81.50 | A | 1.910 | 0.000 | 0.000 | 74.617 | 0.000 | 1.22 |
| | | B | | 0.000 | 0.000 | 42.757 | 0.000 | 0.58 |
| | | C | | 0.000 | 0.000 | 51.145 | 0.000 | 0.59 |
| T6 | 81.50-61.50 | A | 1.864 | 0.000 | 0.000 | 116.019 | 0.000 | 1.69 |
| | | B | | 0.000 | 0.000 | 42.058 | 0.000 | 0.56 |
| | | C | | 0.000 | 0.000 | 55.656 | 0.000 | 0.65 |
| T7 | 61.50-41.50 | A | 1.804 | 0.000 | 0.000 | 121.043 | 0.000 | 1.72 |
| | | B | | 0.000 | 0.000 | 41.156 | 0.000 | 0.53 |
| | | C | | 0.000 | 0.000 | 54.585 | 0.000 | 0.62 |
| T8 | 41.50-21.50 | A | 1.717 | 0.000 | 0.000 | 117.489 | 0.000 | 1.62 |
| | | B | | 0.000 | 0.000 | 39.859 | 0.000 | 0.50 |
| | | C | | 0.000 | 0.000 | 53.046 | 0.000 | 0.58 |
| T9 | 21.50-6.50 | A | 1.583 | 0.000 | 0.000 | 83.997 | 0.000 | 1.11 |
| | | B | | 0.000 | 0.000 | 28.391 | 0.000 | 0.34 |
| | | C | | 0.000 | 0.000 | 38.002 | 0.000 | 0.40 |
| T10 | 6.50-1.50 | A | 1.397 | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | B | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |

Feed Line Center of Pressure

| Section | Elevation | CP_x | CP_z | CP_x Ice | CP_z Ice |
|---------|---------------|---------|---------|---------------|---------------|
| | ft | in | in | in | in |
| T1 | 181.50-161.50 | 1.5566 | -1.8287 | 1.0954 | -1.9340 |
| T2 | 161.50-141.50 | -2.2608 | -0.8909 | -1.0851 | -2.0253 |
| T3 | 141.50-121.50 | -1.1251 | -0.2522 | -0.1577 | -0.6364 |
| T4 | 121.50-101.50 | -1.0332 | 0.0779 | -0.1685 | -0.3730 |
| T5 | 101.50-81.50 | -1.1414 | 0.1534 | -0.0522 | -0.3011 |
| T6 | 81.50-61.50 | -1.5371 | -0.9063 | -0.5453 | -1.5479 |
| T7 | 61.50-41.50 | -1.7344 | -1.1507 | -0.7193 | -1.8968 |
| T8 | 41.50-21.50 | -2.0470 | -1.3170 | -0.7993 | -2.0455 |
| T9 | 21.50-6.50 | -1.6656 | -1.1117 | -0.7393 | -1.8584 |
| T10 | 6.50-1.50 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Shielding Factor Ka

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|--------------------|-------------------------|-----------------|--------------|
| T1 | 1 | LDF7-50A(1-5/8) | 161.50 - 181.50 | 0.6000 | 0.2909 |
| T1 | 2 | LDF5-50A(7/8) | 161.50 - 181.50 | 0.6000 | 0.2909 |
| T1 | 3 | LDF4P-50A(1/2) | 161.50 - 181.50 | 0.6000 | 0.2909 |
| T1 | 5 | EW63 | 161.50 - 176.50 | 0.6000 | 0.2909 |
| T1 | 23 | LCF78-50A(7/8) | 161.50 - 181.50 | 0.6000 | 0.2909 |
| T2 | 1 | LDF7-50A(1-5/8) | 141.50 - 161.50 | 0.6000 | 0.4974 |
| T2 | 2 | LDF5-50A(7/8) | 141.50 - 161.50 | 0.6000 | 0.4974 |
| T2 | 3 | LDF4P-50A(1/2) | 141.50 - 161.50 | 0.6000 | 0.4974 |
| T2 | 5 | EW63 | 141.50 - 161.50 | 0.6000 | 0.4974 |
| T2 | 7 | LDF7-50A(1-5/8) | 141.50 - 160.50 | 0.6000 | 0.4974 |
| T2 | 8 | C4006L-NFNF(1-1/4) | 141.50 - 160.50 | 0.6000 | 0.4974 |
| T2 | 9 | LDF7-50A(1-5/8) | 141.50 - 160.50 | 0.6000 | 0.4974 |
| T2 | 11 | LDF5-50A(7/8) | 141.50 - 148.50 | 0.6000 | 0.4974 |
| T2 | 23 | LCF78-50A(7/8) | 141.50 - 161.50 | 0.6000 | 0.4974 |
| T3 | 1 | LDF7-50A(1-5/8) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 2 | LDF5-50A(7/8) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 3 | LDF4P-50A(1/2) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 5 | EW63 | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 7 | LDF7-50A(1-5/8) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 8 | C4006L-NFNF(1-1/4) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 9 | LDF7-50A(1-5/8) | 121.50 - | 0.6000 | 0.2827 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|--------------------|---------------------------|--------------|-----------|
| T3 | 11 | LDF5-50A(7/8) | 141.50 121.50 - 141.50 | 0.6000 | 0.2827 |
| T3 | 13 | LDF6-50A(1-1/4) | 121.50 - 127.50 | 0.6000 | 0.2827 |
| T3 | 23 | LCF78-50A(7/8) | 121.50 - 141.50 | 0.6000 | 0.2827 |
| T4 | 1 | LDF7-50A(1-5/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 2 | LDF5-50A(7/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 3 | LDF4P-50A(1/2) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 5 | EW63 | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 7 | LDF7-50A(1-5/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 8 | C4006L-NFNF(1-1/4) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 9 | LDF7-50A(1-5/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 11 | LDF5-50A(7/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 13 | LDF6-50A(1-1/4) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T4 | 23 | LCF78-50A(7/8) | 101.50 - 121.50 | 0.6000 | 0.3104 |
| T5 | 1 | LDF7-50A(1-5/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 2 | LDF5-50A(7/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 3 | LDF4P-50A(1/2) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 5 | EW63 | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 7 | LDF7-50A(1-5/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 8 | C4006L-NFNF(1-1/4) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 9 | LDF7-50A(1-5/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 11 | LDF5-50A(7/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 13 | LDF6-50A(1-1/4) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T5 | 16 | LDF4P-50A(1/2) | 81.50 - 89.50 | 0.6000 | 0.3611 |
| T5 | 23 | LCF78-50A(7/8) | 81.50 - 101.50 | 0.6000 | 0.3611 |
| T6 | 1 | LDF7-50A(1-5/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 2 | LDF5-50A(7/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 3 | LDF4P-50A(1/2) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 5 | EW63 | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 7 | LDF7-50A(1-5/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 8 | C4006L-NFNF(1-1/4) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 9 | LDF7-50A(1-5/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 11 | LDF5-50A(7/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 13 | LDF6-50A(1-1/4) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T6 | 16 | LDF4P-50A(1/2) | 61.50 - 81.50 | 0.6000 | 0.4458 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|--------------------|-------------------------|--------------|-----------|
| T6 | 18 | VXL5-50(7/8) | 61.50 - 78.50 | 0.6000 | 0.4458 |
| T6 | 19 | RG6-Fiber | 61.50 - 78.50 | 0.6000 | 0.4458 |
| T6 | 20 | #8 AWG Copper Wire | 61.50 - 78.50 | 0.6000 | 0.4458 |
| T6 | 23 | LCF78-50A(7/8) | 61.50 - 81.50 | 0.6000 | 0.4458 |
| T7 | 1 | LDF7-50A(1-5/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 2 | LDF5-50A(7/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 3 | LDF4P-50A(1/2) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 5 | EW63 | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 7 | LDF7-50A(1-5/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 8 | C4006L-NFNF(1-1/4) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 9 | LDF7-50A(1-5/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 11 | LDF5-50A(7/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 13 | LDF6-50A(1-1/4) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 16 | LDF4P-50A(1/2) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 18 | VXL5-50(7/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 19 | RG6-Fiber | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 20 | #8 AWG Copper Wire | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T7 | 23 | LCF78-50A(7/8) | 41.50 - 61.50 | 0.6000 | 0.4900 |
| T8 | 1 | LDF7-50A(1-5/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 2 | LDF5-50A(7/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 3 | LDF4P-50A(1/2) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 5 | EW63 | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 7 | LDF7-50A(1-5/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 8 | C4006L-NFNF(1-1/4) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 9 | LDF7-50A(1-5/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 11 | LDF5-50A(7/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 13 | LDF6-50A(1-1/4) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 16 | LDF4P-50A(1/2) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 18 | VXL5-50(7/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 19 | RG6-Fiber | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 20 | #8 AWG Copper Wire | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T8 | 23 | LCF78-50A(7/8) | 21.50 - 41.50 | 0.6000 | 0.5389 |
| T9 | 1 | LDF7-50A(1-5/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 2 | LDF5-50A(7/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 3 | LDF4P-50A(1/2) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 5 | EW63 | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 7 | LDF7-50A(1-5/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|--------------------|-------------------------|--------------|-----------|
| T9 | 8 | C4006L-NFNF(1-1/4) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 9 | LDF7-50A(1-5/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 11 | LDF5-50A(7/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 13 | LDF6-50A(1-1/4) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 16 | LDF4P-50A(1/2) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 18 | VXL5-50(7/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 19 | RG6-Fiber | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 20 | #8 AWG Copper Wire | 6.50 - 21.50 | 0.6000 | 0.5021 |
| T9 | 23 | LCF78-50A(7/8) | 6.50 - 21.50 | 0.6000 | 0.5021 |

Discrete Tower Loads

| Description | Face or Leg | Offset Type | Offsets: Horz Lateral Vert ft ft ft | Azimuth Adjustmen t ° | Placement ft | | C_{AA} Front ft ² | C_{AA} Side ft ² | Weight K |
|---------------------------------|-------------|-------------|---|-----------------------------|-----------------|----------|-----------------------------------|----------------------------------|-------------|
| 20' x 2" Dia Omni | A | From Leg | 0.00 0.00 10.00 | 0.0000 | 180.50 | No Ice | 4.00 | 4.00 | 0.02 |
| | | | | | | 1/2" Ice | 6.03 | 6.03 | 0.05 |
| | | | | | | Ice | 8.06 | 8.06 | 0.08 |
| | | | | | | 1" Ice | 12.12 | 12.12 | 0.14 |
| 14' x 3" Dia Omni | C | From Face | 4.00 0.00 7.00 | 0.0000 | 180.50 | No Ice | 4.20 | 4.20 | 0.04 |
| | | | | | | 1/2" Ice | 5.63 | 5.63 | 0.07 |
| | | | | | | Ice | 7.06 | 7.06 | 0.10 |
| | | | | | | 1" Ice | 9.92 | 9.92 | 0.16 |
| 20' x 2" Dia Omni | B | From Leg | 0.00 0.00 10.00 | 0.0000 | 180.50 | No Ice | 4.00 | 4.00 | 0.02 |
| | | | | | | 1/2" Ice | 6.03 | 6.03 | 0.05 |
| | | | | | | Ice | 8.06 | 8.06 | 0.08 |
| | | | | | | 1" Ice | 12.12 | 12.12 | 0.14 |
| *** | | | | | | | | | |
| Pipe Mount [PM 602-1] | A | From Leg | 0.50 0.00 0.00 | 0.0000 | 176.50 | No Ice | 2.78 | 2.78 | 0.09 |
| | | | | | | 1/2" Ice | 3.21 | 3.21 | 0.11 |
| | | | | | | Ice | 3.64 | 3.64 | 0.14 |
| | | | | | | 1" Ice | 4.54 | 4.54 | 0.21 |
| *** | | | | | | | | | |
| Pipe Mount [PM 602-3] | B | None | | 0.0000 | 160.50 | No Ice | 6.67 | 6.67 | 0.28 |
| | | | | | | 1/2" Ice | 7.70 | 7.70 | 0.34 |
| | | | | | | Ice | 8.74 | 8.74 | 0.42 |
| | | | | | | 1" Ice | 10.90 | 10.90 | 0.63 |
| 8'x4" Std Horizontal Mount Pipe | A | From Leg | 3.00 0.00 0.00 | 0.0000 | 160.50 | No Ice | 1.50 | 1.50 | 0.09 |
| | | | | | | 1/2" Ice | 2.59 | 2.59 | 0.35 |
| | | | | | | Ice | 3.10 | 3.10 | 0.62 |
| | | | | | | 1" Ice | 4.13 | 4.13 | 1.19 |
| 8'x4" Std Horizontal Mount Pipe | B | From Leg | 3.00 0.00 0.00 | 0.0000 | 160.50 | No Ice | 1.50 | 1.50 | 0.09 |
| | | | | | | 1/2" Ice | 2.59 | 2.59 | 0.35 |
| | | | | | | Ice | 3.10 | 3.10 | 0.62 |
| | | | | | | 1" Ice | 4.13 | 4.13 | 1.19 |
| 8'x4" Std Horizontal Mount Pipe | C | From Leg | 3.00 0.00 0.00 | 0.0000 | 160.50 | No Ice | 1.50 | 1.50 | 0.09 |
| | | | | | | 1/2" Ice | 2.59 | 2.59 | 0.35 |
| | | | | | | Ice | 3.10 | 3.10 | 0.62 |
| | | | | | | 1" Ice | 4.13 | 4.13 | 1.19 |
| 6'x2" Horizontal Pipe | C | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 1.43 | 0.01 | 0.02 |
| | | | | | | 2" Ice | | | |

| Description | Face or Leg | Offset Type | Offsets: Horz Lateral Vert ft ft ft | Azimuth Adjustment t ° | Placement ft | C _{AA} Front ft ² | C _{AA} Side ft ² | Weight K |
|--------------------------|-------------|-------------|---|------------------------------|-----------------|---|--|-------------|
| | | | 0.00 | | | 1/2" | 1.92 | 0.03 |
| | | | 0.00 | | | Ice | 2.29 | 0.05 |
| | | | | | | 1" Ice | 3.06 | 0.09 |
| | | | | | | 2" Ice | | |
| LNx-6515DS w/ Mount Pipe | A | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 11.68 | 0.08 |
| | | | 0.00 | | | 1/2" | 12.40 | 0.17 |
| | | | 0.00 | | | Ice | 13.14 | 0.27 |
| | | | | | | 1" Ice | 14.51 | 0.50 |
| | | | | | | 2" Ice | | |
| LNx-6515DS w/ Mount Pipe | B | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 11.68 | 0.08 |
| | | | 0.00 | | | 1/2" | 12.40 | 0.17 |
| | | | 0.00 | | | Ice | 13.14 | 0.27 |
| | | | | | | 1" Ice | 14.51 | 0.50 |
| | | | | | | 2" Ice | | |
| LNx-6515DS w/ Mount Pipe | C | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 11.68 | 0.08 |
| | | | 0.00 | | | 1/2" | 12.40 | 0.17 |
| | | | 0.00 | | | Ice | 13.14 | 0.27 |
| | | | | | | 1" Ice | 14.51 | 0.50 |
| | | | | | | 2" Ice | | |
| (2) AIR 21 | A | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 6.05 | 0.09 |
| | | | 0.00 | | | 1/2" | 6.42 | 0.13 |
| | | | 0.00 | | | Ice | 6.80 | 0.18 |
| | | | | | | 1" Ice | 7.57 | 0.29 |
| | | | | | | 2" Ice | | |
| (2) AIR 21 | B | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 6.05 | 0.09 |
| | | | 0.00 | | | 1/2" | 6.42 | 0.13 |
| | | | 0.00 | | | Ice | 6.80 | 0.18 |
| | | | | | | 1" Ice | 7.57 | 0.29 |
| | | | | | | 2" Ice | | |
| (2) AIR 21 | C | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 6.05 | 0.09 |
| | | | 0.00 | | | 1/2" | 6.42 | 0.13 |
| | | | 0.00 | | | Ice | 6.80 | 0.18 |
| | | | | | | 1" Ice | 7.57 | 0.29 |
| | | | | | | 2" Ice | | |
| KRY 112 TMA | A | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 0.35 | 0.01 |
| | | | 0.00 | | | 1/2" | 0.43 | 0.01 |
| | | | 0.00 | | | Ice | 0.51 | 0.02 |
| | | | | | | 1" Ice | 0.70 | 0.03 |
| | | | | | | 2" Ice | | |
| KRY 112 TMA | B | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 0.35 | 0.01 |
| | | | 0.00 | | | 1/2" | 0.43 | 0.01 |
| | | | 0.00 | | | Ice | 0.51 | 0.02 |
| | | | | | | 1" Ice | 0.70 | 0.03 |
| | | | | | | 2" Ice | | |
| KRY 112 TMA | C | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 0.35 | 0.01 |
| | | | 0.00 | | | 1/2" | 0.43 | 0.01 |
| | | | 0.00 | | | Ice | 0.51 | 0.02 |
| | | | | | | 1" Ice | 0.70 | 0.03 |
| | | | | | | 2" Ice | | |
| RRUS 11 | A | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 2.78 | 0.05 |
| | | | 0.00 | | | 1/2" | 2.99 | 0.07 |
| | | | 0.00 | | | Ice | 3.21 | 0.10 |
| | | | | | | 1" Ice | 3.66 | 0.15 |
| | | | | | | 2" Ice | | |
| RRUS 11 | B | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 2.78 | 0.05 |
| | | | 0.00 | | | 1/2" | 2.99 | 0.07 |
| | | | 0.00 | | | Ice | 3.21 | 0.10 |
| | | | | | | 1" Ice | 3.66 | 0.15 |
| | | | | | | 2" Ice | | |
| RRUS 11 | C | From Leg | 3.00 | 0.0000 | 160.50 | No Ice | 2.78 | 0.05 |
| | | | 0.00 | | | 1/2" | 2.99 | 0.07 |
| | | | 0.00 | | | Ice | 3.21 | 0.10 |
| | | | | | | 1" Ice | 3.66 | 0.15 |
| | | | | | | 2" Ice | | |

| Description | Face or Leg | Offset Type | Offsets: Horz Lateral Vert ft ft ft | Azimuth Adjustment t ° | Placement ft | | C _A A _A Front ft ² | C _A A _A Side ft ² | Weight K |
|----------------------------------|-------------|-------------|---|------------------------------|-----------------|----------|---|--|-------------|
| 8' x 2" Horizontal Mount Pipe | C | From Leg | 3.00 0.00 10.00 | 0.0000 | 148.50 | No Ice | 0.79 | 0.79 | 0.03 |
| | | | | | | 1/2" Ice | 1.59 | 1.59 | 0.28 |
| | | | | | | Ice | 2.08 | 2.08 | 0.54 |
| | | | | | | 1" Ice | 3.10 | 3.10 | 1.09 |
| | | | | | | 2" Ice | | | |
| 20' x 2" Mount Pipe | A | From Face | 3.00 0.00 10.00 | 0.0000 | 138.50 | No Ice | 4.75 | 4.75 | 0.09 |
| | | | | | | 1/2" Ice | 6.78 | 6.78 | 0.12 |
| | | | | | | Ice | 8.82 | 8.82 | 0.17 |
| | | | | | | 1" Ice | 12.96 | 12.96 | 0.31 |
| | | | | | | 2" Ice | | | |
| 20'x3" Omni | A | From Face | 3.00 0.00 10.00 | 0.0000 | 138.50 | No Ice | 4.00 | 4.00 | 0.06 |
| | | | | | | 1/2" Ice | 6.00 | 6.00 | 0.10 |
| | | | | | | Ice | 8.00 | 8.00 | 0.14 |
| | | | | | | 1" Ice | 12.00 | 12.00 | 0.23 |
| | | | | | | 2" Ice | | | |
| 6' x 3" Mount Pipe | A | From Face | 3.00 0.00 0.00 | 0.0000 | 138.50 | No Ice | 1.77 | 1.77 | 0.03 |
| | | | | | | 1/2" Ice | 2.13 | 2.13 | 0.04 |
| | | | | | | Ice | 2.50 | 2.50 | 0.06 |
| | | | | | | 1" Ice | 3.27 | 3.27 | 0.11 |
| | | | | | | 2" Ice | | | |
| 7' Hor x 2.5" x 2.5" Angle Mount | A | From Leg | 1.50 0.00 3.00 | 0.0000 | 138.50 | No Ice | 2.92 | 0.02 | 0.03 |
| | | | | | | 1/2" Ice | 3.60 | 0.07 | 0.05 |
| | | | | | | Ice | 3.94 | 0.13 | 0.07 |
| | | | | | | 1" Ice | 4.74 | 0.32 | 0.13 |
| | | | | | | 2" Ice | | | |
| 7' Hor x 2.5" x 2.5" Angle Mount | C | From Leg | 1.50 0.00 3.00 | 0.0000 | 138.50 | No Ice | 2.92 | 0.02 | 0.03 |
| | | | | | | 1/2" Ice | 3.60 | 0.07 | 0.05 |
| | | | | | | Ice | 3.94 | 0.13 | 0.07 |
| | | | | | | 1" Ice | 4.74 | 0.32 | 0.13 |
| | | | | | | 2" Ice | | | |
| 7' Hor x 2.5" x 2.5" Angle Mount | A | From Leg | 1.50 0.00 -3.00 | 0.0000 | 138.50 | No Ice | 2.92 | 0.02 | 0.03 |
| | | | | | | 1/2" Ice | 3.60 | 0.07 | 0.05 |
| | | | | | | Ice | 3.94 | 0.13 | 0.07 |
| | | | | | | 1" Ice | 4.74 | 0.32 | 0.13 |
| | | | | | | 2" Ice | | | |
| 7' Hor x 2.5" x 2.5" Angle Mount | C | From Leg | 1.50 0.00 -3.00 | 0.0000 | 138.50 | No Ice | 2.92 | 0.02 | 0.03 |
| | | | | | | 1/2" Ice | 3.60 | 0.07 | 0.05 |
| | | | | | | Ice | 3.94 | 0.13 | 0.07 |
| | | | | | | 1" Ice | 4.74 | 0.32 | 0.13 |
| | | | | | | 2" Ice | | | |
| *** | | | | | | | | | |
| Sector Mount [SM 502-3] | C | None | | 0.0000 | 127.50 | No Ice | 29.82 | 29.82 | 1.67 |
| | | | | | | 1/2" Ice | 42.21 | 42.21 | 2.27 |
| | | | | | | Ice | 54.43 | 54.43 | 3.05 |
| | | | | | | 1" Ice | 78.49 | 78.49 | 5.18 |
| | | | | | | 2" Ice | | | |
| (2) 6' x 2" Mount Pipe | A | From Leg | 3.00 0.00 0.00 | 0.0000 | 127.50 | No Ice | 1.43 | 1.43 | 0.02 |
| | | | | | | 1/2" Ice | 1.92 | 1.92 | 0.03 |
| | | | | | | Ice | 2.29 | 2.29 | 0.05 |
| | | | | | | 1" Ice | 3.06 | 3.06 | 0.09 |
| | | | | | | 2" Ice | | | |
| (2) 6' x 2" Mount Pipe | B | From Leg | 3.00 0.00 0.00 | 0.0000 | 127.50 | No Ice | 1.43 | 1.43 | 0.02 |
| | | | | | | 1/2" Ice | 1.92 | 1.92 | 0.03 |
| | | | | | | Ice | 2.29 | 2.29 | 0.05 |
| | | | | | | 1" Ice | 3.06 | 3.06 | 0.09 |
| | | | | | | 2" Ice | | | |
| (2) 6' x 2" Mount Pipe | C | From Leg | 3.00 0.00 0.00 | 0.0000 | 127.50 | No Ice | 1.43 | 1.43 | 0.02 |
| | | | | | | 1/2" Ice | 1.92 | 1.92 | 0.03 |
| | | | | | | Ice | 2.29 | 2.29 | 0.05 |
| | | | | | | 1" Ice | 3.06 | 3.06 | 0.09 |
| | | | | | | 2" Ice | | | |
| APXVSP18-C_TIA w/ Mount Pipe | A | From Leg | 3.00 0.00 0.00 | 0.0000 | 127.50 | No Ice | 8.26 | 7.47 | 0.09 |
| | | | | | | 1/2" Ice | 8.82 | 8.66 | 0.16 |
| | | | | | | Ice | 9.35 | 9.56 | 0.24 |
| | | | | | | 1" Ice | 10.42 | 11.39 | 0.42 |
| | | | | | | 2" Ice | | | |

| Description | Face or Leg | Offset Type | Offsets: Horz Lateral Vert ft ft ft | Azimuth Adjustmen t ° | Placement ft | C _{AA} Front ft ² | C _{AA} Side ft ² | Weight K |
|--|-------------|-------------|---|--------------------------------|-----------------|---|--|-------------|
| | | | 0.00 | | | Ice 6.61 | 5.71 | 0.16 |
| | | | | | | 1" Ice 7.49 | 7.16 | 0.29 |
| | | | | | | 2" Ice | | |
| 7770.00 w/ Mount Pipe | C | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 5.75 | 4.25 | 0.06 |
| | | | 6.00 | | | 1/2" 6.18 | 5.01 | 0.11 |
| | | | 0.00 | | | Ice 6.61 | 5.71 | 0.16 |
| | | | | | | 1" Ice 7.49 | 7.16 | 0.29 |
| | | | | | | 2" Ice | | |
| AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | A | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 5.23 | 4.02 | 0.05 |
| | | | -6.00 | | | 1/2" 5.62 | 4.63 | 0.10 |
| | | | 0.00 | | | Ice 6.01 | 5.26 | 0.15 |
| | | | | | | 1" Ice 6.83 | 6.53 | 0.27 |
| | | | | | | 2" Ice | | |
| AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | B | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 5.23 | 4.02 | 0.05 |
| | | | -6.00 | | | 1/2" 5.62 | 4.63 | 0.10 |
| | | | 0.00 | | | Ice 6.01 | 5.26 | 0.15 |
| | | | | | | 1" Ice 6.83 | 6.53 | 0.27 |
| | | | | | | 2" Ice | | |
| AM-X-CD-14-65-00T-RET_TIA w/ Mount Pipe | C | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 5.23 | 4.02 | 0.05 |
| | | | -6.00 | | | 1/2" 5.62 | 4.63 | 0.10 |
| | | | 0.00 | | | Ice 6.01 | 5.26 | 0.15 |
| | | | | | | 1" Ice 6.83 | 6.53 | 0.27 |
| | | | | | | 2" Ice | | |
| (2) LGP21401 TMA | A | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 0.82 | 0.35 | 0.02 |
| | | | 0.00 | | | 1/2" 0.94 | 0.44 | 0.02 |
| | | | 0.00 | | | Ice 1.06 | 0.54 | 0.03 |
| | | | | | | 1" Ice 1.34 | 0.76 | 0.05 |
| | | | | | | 2" Ice | | |
| (2) LGP21401 TMA | B | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 0.82 | 0.35 | 0.02 |
| | | | 0.00 | | | 1/2" 0.94 | 0.44 | 0.02 |
| | | | 0.00 | | | Ice 1.06 | 0.54 | 0.03 |
| | | | | | | 1" Ice 1.34 | 0.76 | 0.05 |
| | | | | | | 2" Ice | | |
| (2) LGP21401 TMA | C | From Leg | 3.00 | 0.0000 | 78.50 | No Ice 0.82 | 0.35 | 0.02 |
| | | | 0.00 | | | 1/2" 0.94 | 0.44 | 0.02 |
| | | | 0.00 | | | Ice 1.06 | 0.54 | 0.03 |
| | | | | | | 1" Ice 1.34 | 0.76 | 0.05 |
| | | | | | | 2" Ice | | |
| 18"x18"x 6" Equipment | C | From Face | 0.00 | 0.0000 | 78.50 | No Ice 2.70 | 0.92 | 0.02 |
| | | | 0.00 | | | 1/2" 2.90 | 1.05 | 0.04 |
| | | | 0.00 | | | Ice 3.11 | 1.19 | 0.06 |
| | | | | | | 1" Ice 3.56 | 1.49 | 0.11 |
| | | | | | | 2" Ice | | |
| DC6-48-60-18-8F | C | From Leg | 0.00 | 0.0000 | 78.50 | No Ice 0.92 | 0.92 | 0.02 |
| | | | 0.00 | | | 1/2" 1.46 | 1.46 | 0.04 |
| | | | -2.00 | | | Ice 1.64 | 1.64 | 0.06 |
| | | | | | | 1" Ice 2.04 | 2.04 | 0.11 |
| | | | | | | 2" Ice | | |
| ***Proposed*** DS2C03F36D-D | C | From Leg | 4.00 | 0.0000 | 177.00 | No Ice 7.29 | 7.29 | 0.07 |
| | | | 0.00 | | | 1/2" 9.75 | 9.75 | 0.12 |
| | | | 13.00 | | | Ice 12.23 | 12.23 | 0.19 |
| | | | | | | 1" Ice 17.24 | 17.24 | 0.37 |
| | | | | | | 2" Ice | | |
| USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support] | C | From Leg | 2.00 | 0.0000 | 177.00 | No Ice 2.96 | 5.64 | 0.18 |
| | | | 0.00 | | | 1/2" 3.76 | 6.73 | 0.22 |
| | | | 0.00 | | | Ice 4.63 | 7.91 | 0.28 |
| | | | | | | 1" Ice 6.57 | 10.43 | 0.43 |
| | | | | | | 2" Ice | | |
| *** | | | | | | | | |
| *** | | | | | | | | |
| *** | | | | | | | | |

Dishes

| Description | Face or Leg | Dish Type | Offset Type | Offsets: Horz Lateral Vert ft | Azimuth Adjustment ° | 3 dB Beam Width ° | Elevation ft | Outside Diameter ft | Aperture Area ft ² | Weight K | |
|-------------|-------------------|------------------------|----------------|---|----------------------------|----------------------------|-----------------|---------------------------|-------------------------------------|-------------|------|
| 8.5' Dish | A | Paraboloid w/Radome | From Leg | 1.00 | 0.0000 | | 176.50 | 8.50 | No Ice | 56.75 | 0.07 |
| | | | | 0.00 | | | | | 1/2" Ice | 57.56 | 0.30 |
| | | | | 0.00 | | | | | 1" Ice | 58.37 | 0.53 |
| | | | | | | | | | 2" Ice | 59.99 | 0.99 |

Load Combinations

| Comb. No. | Description |
|--------------|--|
| 1 | Dead Only |
| 2 | 1.2 Dead+1.0 Wind 0 deg - No Ice+1.0 Guy |
| 3 | 1.2 Dead+1.0 Wind 30 deg - No Ice+1.0 Guy |
| 4 | 1.2 Dead+1.0 Wind 60 deg - No Ice+1.0 Guy |
| 5 | 1.2 Dead+1.0 Wind 90 deg - No Ice+1.0 Guy |
| 6 | 1.2 Dead+1.0 Wind 120 deg - No Ice+1.0 Guy |
| 7 | 1.2 Dead+1.0 Wind 150 deg - No Ice+1.0 Guy |
| 8 | 1.2 Dead+1.0 Wind 180 deg - No Ice+1.0 Guy |
| 9 | 1.2 Dead+1.0 Wind 210 deg - No Ice+1.0 Guy |
| 10 | 1.2 Dead+1.0 Wind 240 deg - No Ice+1.0 Guy |
| 11 | 1.2 Dead+1.0 Wind 270 deg - No Ice+1.0 Guy |
| 12 | 1.2 Dead+1.0 Wind 300 deg - No Ice+1.0 Guy |
| 13 | 1.2 Dead+1.0 Wind 330 deg - No Ice+1.0 Guy |
| 14 | 1.2 Dead+1.0 Ice+1.0 Temp+Guy |
| 15 | 1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 16 | 1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 17 | 1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 18 | 1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 19 | 1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 20 | 1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 21 | 1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 22 | 1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 23 | 1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 24 | 1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 25 | 1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 26 | 1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp+1.0 Guy |
| 27 | Dead+Wind 0 deg - Service+Guy |
| 28 | Dead+Wind 30 deg - Service+Guy |
| 29 | Dead+Wind 60 deg - Service+Guy |
| 30 | Dead+Wind 90 deg - Service+Guy |
| 31 | Dead+Wind 120 deg - Service+Guy |
| 32 | Dead+Wind 150 deg - Service+Guy |
| 33 | Dead+Wind 180 deg - Service+Guy |
| 34 | Dead+Wind 210 deg - Service+Guy |
| 35 | Dead+Wind 240 deg - Service+Guy |
| 36 | Dead+Wind 270 deg - Service+Guy |
| 37 | Dead+Wind 300 deg - Service+Guy |
| 38 | Dead+Wind 330 deg - Service+Guy |

Maximum Member Forces

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|----------------|------------------|-------------------|------------------|-----------------------|------------|--------------------------------|--------------------------------|
| T1 | 181.5 - 161.5 | Leg | Max Tension | 8 | 13.94 | 0.02 | -0.09 |
| | | | Max. Compression | 18 | -16.11 | 0.01 | -0.08 |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft | |
|---------------|------------------|-------------------|------------------|-----------------|----------------|--------------------------|--------------------------|--|
| T2 | 161.5 - 141.5 | Diagonal | Max. Mx | 11 | -6.54 | 1.03 | 0.04 | |
| | | | Max. My | 2 | -5.67 | -0.01 | 0.93 | |
| | | | Max. Vy | 5 | -1.34 | -0.97 | 0.07 | |
| | | | Max. Vx | 2 | 1.20 | -0.01 | 0.93 | |
| | | | Max Tension | 5 | 2.53 | -0.02 | 0.01 | |
| | | | Max. Compression | 3 | -2.33 | 0.00 | 0.00 | |
| | | | Max. Mx | 9 | 0.82 | -0.03 | 0.00 | |
| | | | Max. My | 3 | -1.81 | -0.01 | 0.02 | |
| | | | Max. Vy | 15 | -0.03 | 0.03 | -0.00 | |
| | | | Max. Vx | 3 | -0.01 | -0.01 | 0.02 | |
| | | | Max Tension | 2 | 0.06 | 0.00 | 0.00 | |
| | | | Max. Compression | 8 | -0.11 | 0.00 | 0.00 | |
| | | | Max. Mx | 26 | -0.05 | -0.02 | 0.00 | |
| | | | Max. My | 7 | -0.02 | 0.00 | 0.00 | |
| | | | Max. Vy | 26 | 0.02 | 0.00 | 0.00 | |
| | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | | |
| | | Top Girt | Max Tension | 11 | 0.59 | 0.00 | 0.00 | |
| | | | Max. Compression | 4 | -0.62 | 0.00 | 0.00 | |
| | | | Max. Mx | 21 | 0.09 | -0.02 | 0.00 | |
| | | | Max. My | 20 | -0.08 | 0.00 | 0.00 | |
| | | | Max. Vy | 21 | 0.02 | 0.00 | 0.00 | |
| | | | Max. Vx | 20 | 0.00 | 0.00 | 0.00 | |
| | | | Bottom Girt | Bottom Tension | 8 | 9.52 | | |
| | | | | Top Tension | 8 | 9.63 | | |
| | | | | Top Cable Vert | 8 | 6.67 | | |
| | | | | Top Cable Norm | 8 | 6.94 | | |
| | | | | Top Cable Tan | 8 | 0.00 | | |
| | | | | Bot Cable Vert | 8 | -6.34 | | |
| | | | | Bot Cable Norm | 8 | 7.09 | | |
| | | | | Bot Cable Tan | 8 | 0.00 | | |
| | | | | Guy A | Bottom Tension | 25 | 8.89 | |
| | | Top Tension | | | 12 | 9.46 | | |
| | | Top Cable Vert | | | 25 | 6.93 | | |
| | | Top Cable Norm | | | 25 | 6.44 | | |
| | | Top Cable Tan | | | 25 | 0.00 | | |
| | | Bot Cable Vert | | | 12 | -5.92 | | |
| | | Bot Cable Norm | | | 12 | 6.64 | | |
| | | Bot Cable Tan | 12 | | 0.00 | | | |
| | | Guy B | Bottom Tension | | 17 | 9.02 | | |
| | | | Top Tension | | 4 | 9.32 | | |
| | | | Top Cable Vert | | 17 | 6.84 | | |
| | | | Top Cable Norm | | 17 | 6.33 | | |
| | | | Top Cable Tan | | 17 | 0.00 | | |
| | | | Bot Cable Vert | | 4 | -6.01 | | |
| | | | Bot Cable Norm | | 4 | 6.73 | | |
| Bot Cable Tan | 4 | | 0.00 | | | | | |
| Guy C | Max Tension | | 23 | 13.50 | 0.00 | 0.00 | | |
| | Max. Compression | | 1 | 0.00 | 0.00 | 0.00 | | |
| | Max. Mx | | 19 | 12.09 | 0.05 | 0.00 | | |
| | Max. My | | 7 | 5.72 | 0.00 | 0.00 | | |
| | Max. Vy | | 19 | -0.05 | 0.00 | 0.00 | | |
| | Max. Vx | | 7 | -0.00 | 0.00 | 0.00 | | |
| | Torque Arm Top | | Max Tension | 2 | 0.76 | 0.00 | 0.00 | |
| | | Max. Compression | 8 | -14.14 | 0.00 | 0.00 | | |
| | | Max. Mx | 19 | -12.27 | 0.06 | 0.00 | | |
| | | Max. My | 4 | -13.01 | 0.00 | 0.00 | | |
| | | Max. Vy | 19 | -0.05 | 0.00 | 0.00 | | |
| | | Max. Vx | 4 | -0.00 | 0.00 | 0.00 | | |
| | | Torque Arm Bottom | Max Tension | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Compression | 18 | -22.20 | -0.02 | 0.03 | |
| | | | Max. Mx | 11 | -10.45 | -0.86 | 0.05 | |
| Max. My | | | 8 | -9.41 | 0.14 | 0.76 | | |
| Max. Vy | | | 5 | -1.33 | -0.15 | 0.02 | | |
| Max. Vx | | | 2 | 1.20 | -0.07 | 0.19 | | |
| Leg | | | Max Tension | 12 | 1.59 | 0.00 | 0.00 | |
| | | | Max. Compression | 4 | -1.72 | 0.00 | 0.00 | |
| | | | Max. Mx | 19 | 0.11 | 0.02 | 0.00 | |
| | Diagonal | | Max. Mx | 11 | -6.54 | 1.03 | 0.04 | |
| | | | Max. My | 2 | -5.67 | -0.01 | 0.93 | |
| | | | Max. Vy | 5 | -1.34 | -0.97 | 0.07 | |
| | | | Max. Vx | 2 | 1.20 | -0.01 | 0.93 | |
| | | | Max Tension | 5 | 2.53 | -0.02 | 0.01 | |
| | | | Max. Compression | 3 | -2.33 | 0.00 | 0.00 | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|-------------------|------------------|------------------|------------------|-----------------|---------|--------------------------|--------------------------|
| T3 | 141.5 - 121.5 | Top Girt | Max. My | 20 | 0.17 | 0.00 | -0.00 |
| | | | Max. Vy | 19 | -0.02 | 0.00 | 0.00 |
| | | | Max. Vx | 20 | 0.00 | 0.00 | 0.00 |
| | | | Max Tension | 11 | 0.90 | 0.00 | 0.00 |
| | | | Max. Compression | 5 | -0.90 | 0.00 | 0.00 |
| | | | Max. Mx | 21 | -0.21 | 0.01 | 0.00 |
| | | Bottom Girt | Max. My | 20 | -0.02 | 0.00 | -0.00 |
| | | | Max. Vy | 21 | 0.02 | 0.00 | 0.00 |
| | | | Max. Vx | 20 | -0.00 | 0.00 | 0.00 |
| | | | Max Tension | 3 | 0.74 | 0.00 | 0.00 |
| | | | Max. Compression | 12 | -0.80 | 0.00 | 0.00 |
| | | | Max. Mx | 25 | -0.05 | 0.01 | 0.00 |
| | | Leg | Max. Vy | 22 | 0.02 | 0.00 | 0.00 |
| | | | Max. Vx | 20 | -0.00 | 0.00 | 0.00 |
| | | Max Tension | 8 | 5.73 | 0.01 | -0.21 | |
| | | Diagonal | Max. Compression | 18 | -38.79 | 0.00 | -0.22 |
| | | | Max. Mx | 6 | -12.42 | -0.79 | -0.30 |
| | | | Max. My | 2 | -14.79 | 0.05 | 0.84 |
| | | | Max. Vy | 6 | -1.17 | -0.79 | -0.30 |
| | | | Max. Vx | 2 | 1.30 | 0.05 | 0.84 |
| | | | Max Tension | 7 | 2.67 | 0.00 | 0.00 |
| | | | Max. Compression | 9 | -2.58 | -0.00 | -0.01 |
| | | | Max. Mx | 19 | -0.42 | 0.08 | 0.00 |
| | | | Max. My | 3 | -1.54 | -0.01 | 0.02 |
| | | | Max. Vy | 19 | -0.05 | 0.08 | 0.00 |
| | | | Max. Vx | 3 | -0.01 | -0.01 | 0.02 |
| | | | Top Girt | Max Tension | 19 | 0.46 | 0.00 |
| | | Max. Compression | | 12 | -0.15 | 0.00 | 0.00 |
| | | Bottom Girt | Max. Mx | 22 | 0.29 | -0.02 | 0.00 |
| | | | Max. My | 7 | 0.16 | 0.00 | 0.00 |
| | | | Max. Vy | 22 | 0.03 | 0.00 | 0.00 |
| | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | | Max Tension | 2 | 0.86 | 0.00 | 0.00 |
| | | | Max. Compression | 12 | -0.37 | 0.00 | 0.00 |
| | | Guy A | Max. Mx | 14 | 0.53 | -0.02 | 0.00 |
| | | | Max. Vy | 14 | -0.03 | 0.00 | 0.00 |
| | | | Bottom Tension | 8 | 9.57 | | |
| | | | Top Tension | 8 | 9.65 | | |
| | | | Top Cable Vert | 8 | 5.68 | | |
| | | | Top Cable Norm | 8 | 7.80 | | |
| | | | Top Cable Tan | 8 | 0.00 | | |
| | | | Bot Cable Vert | 8 | -5.42 | | |
| | | | Bot Cable Norm | 8 | 7.88 | | |
| | | | Bot Cable Tan | 8 | 0.00 | | |
| | | Guy B | Bottom Tension | 12 | 9.28 | | |
| Top Tension | 12 | | 9.36 | | | | |
| Top Cable Vert | 12 | | 5.52 | | | | |
| Top Cable Norm | 12 | | 7.57 | | | | |
| Top Cable Tan | 12 | | 0.00 | | | | |
| Bot Cable Vert | 12 | | -5.26 | | | | |
| Bot Cable Norm | 12 | | 7.64 | | | | |
| Bot Cable Tan | 12 | | 0.00 | | | | |
| Bottom Tension | 4 | | 9.51 | | | | |
| Top Tension | 4 | | 9.60 | | | | |
| Guy C | Top Cable Vert | 4 | 5.65 | | | | |
| | Top Cable Norm | 4 | 7.76 | | | | |
| | Top Cable Tan | 4 | 0.00 | | | | |
| | Bot Cable Vert | 4 | -5.39 | | | | |
| | Bot Cable Norm | 4 | 7.84 | | | | |
| | Bot Cable Tan | 4 | 0.00 | | | | |
| | Bottom Tension | 15 | 12.38 | 0.00 | 0.00 | | |
| | Max. Compression | 1 | 0.00 | 0.00 | 0.00 | | |
| | Max. Mx | 19 | 11.11 | 0.05 | 0.00 | | |
| | Max. My | 2 | 9.88 | 0.00 | -0.00 | | |
| Max. Vy | 19 | 0.05 | 0.00 | 0.00 | | | |
| Torque Arm Bottom | Max. Vx | 2 | 0.00 | 0.00 | 0.00 | | |
| | Max Tension | 6 | 2.56 | 0.00 | 0.00 | | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft | |
|-------------|------------------|----------------|------------------|------------------|------------------|--------------------------|--------------------------|-------|
| T4 | 121.5 - 101.5 | Leg | Max. Compression | 8 | -13.17 | 0.00 | 0.00 | |
| | | | Max. Mx | 19 | -10.40 | 0.06 | 0.00 | |
| | | | Max. My | 4 | -12.94 | 0.00 | 0.00 | |
| | | | Max. Vy | 19 | -0.05 | 0.00 | 0.00 | |
| | | | Max. Vx | 4 | -0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 1 | 0.00 | 0.00 | 0.00 | |
| | | Diagonal | Max. Compression | 17 | -43.60 | -0.15 | -0.30 | |
| | | | Max. Mx | 19 | -38.90 | 0.72 | -0.02 | |
| | | | Max. My | 2 | -17.46 | -0.05 | -0.76 | |
| | | | Max. Vy | 6 | -1.16 | -0.07 | 0.04 | |
| | | | Max. Vx | 2 | 1.30 | 0.08 | 0.04 | |
| | | | Max Tension | 6 | 3.01 | 0.00 | 0.00 | |
| | | | Max. Compression | 11 | -3.45 | 0.00 | 0.00 | |
| | | | Max. Mx | 19 | -0.04 | -0.04 | 0.00 | |
| | | | Max. My | 20 | -0.19 | 0.00 | 0.00 | |
| | | | Max. Vy | 19 | -0.04 | 0.00 | 0.00 | |
| | | | Max. Vx | 20 | -0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 19 | 1.17 | 0.00 | 0.00 | |
| | | | Horizontal | Max. Compression | 17 | -0.74 | 0.00 | 0.00 |
| | | | | Max. Mx | 16 | 1.12 | -0.03 | 0.00 |
| | | | | Max. My | 7 | 0.49 | 0.00 | 0.00 |
| | | | | Max. Vy | 16 | 0.04 | 0.00 | 0.00 |
| | | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | | | Max Tension | 2 | 1.67 | 0.00 | 0.00 |
| | | Top Girt | | Max. Compression | 8 | -1.39 | 0.00 | 0.00 |
| | | | | Max. Mx | 18 | 0.14 | -0.03 | 0.00 |
| | | | | Max. My | 20 | 0.17 | 0.00 | 0.00 |
| | | | | Max. Vy | 18 | 0.04 | 0.00 | 0.00 |
| | | | | Max. Vx | 20 | -0.00 | 0.00 | 0.00 |
| | | | | Max Tension | 7 | 0.55 | 0.00 | 0.00 |
| Bottom Girt | Max. Compression | | 10 | -0.20 | 0.00 | 0.00 | | |
| | Max. Mx | | 14 | 0.43 | -0.03 | 0.00 | | |
| | Max. My | 7 | 0.01 | 0.00 | 0.00 | | | |
| | Max. Vy | 14 | 0.04 | 0.00 | 0.00 | | | |
| | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | | | |
| | Max Tension | 6 | 0.42 | 0.10 | -0.09 | | | |
| T5 | 101.5 - 81.5 | Leg | Max. Compression | 17 | -43.61 | -0.18 | -0.28 | |
| | | | Max. Mx | 19 | -41.96 | 0.48 | -0.01 | |
| | | | Max. My | 8 | -12.54 | 0.03 | 0.43 | |
| | | | Max. Vy | 11 | -0.85 | 0.09 | -0.02 | |
| | | | Max. Vx | 8 | 0.86 | -0.05 | -0.10 | |
| | | | Max Tension | 13 | 1.61 | 0.00 | 0.00 | |
| | | Diagonal | Max. Compression | 7 | -2.01 | 0.00 | 0.00 | |
| | | | Max. Mx | 18 | 0.18 | 0.02 | 0.00 | |
| | | | Max. My | 20 | -0.37 | 0.00 | -0.00 | |
| | | | Max. Vy | 18 | -0.02 | 0.00 | 0.00 | |
| | | | Max. Vx | 20 | -0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 22 | 0.80 | 0.00 | 0.00 | |
| | | | Horizontal | Max. Compression | 17 | -0.75 | 0.00 | 0.00 |
| | | | | Max. Mx | 18 | 0.70 | -0.03 | 0.00 |
| | | | | Max. My | 7 | 0.55 | 0.00 | 0.00 |
| | | | | Max. Vy | 18 | 0.04 | 0.00 | 0.00 |
| | | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | | | Max Tension | 22 | 0.35 | 0.00 | 0.00 |
| | | Top Girt | Max. Compression | 6 | -0.05 | 0.00 | 0.00 | |
| | | | Max. Mx | 14 | 0.22 | 0.01 | 0.00 | |
| | | | Max. Vy | 14 | 0.02 | 0.00 | 0.00 | |
| | | | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 9 | 0.64 | 0.00 | 0.00 | |
| | | | Bottom Girt | Max. Compression | 12 | -0.57 | 0.00 | 0.00 |
| | | | | Max. Mx | 17 | 0.29 | 0.01 | 0.00 |
| | | | | Max. My | 7 | 0.50 | 0.00 | -0.00 |
| | | Max. Vy | | 17 | 0.02 | 0.00 | 0.00 | |
| | | Max. Vx | | 7 | 0.00 | 0.00 | 0.00 | |
| | | Max Tension | | 1 | 0.00 | 0.00 | 0.00 | |
| | | T6 | 81.5 - 61.5 | Leg | Max. Compression | 15 | -54.23 | 0.14 |
| Max. Mx | 5 | | | | -33.49 | -1.00 | -0.00 | |
| Max. My | 2 | | | | -33.94 | 0.17 | 1.01 | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|------------------|------------------|----------------|------------------|-----------------|---------|--------------------------|--------------------------|
| T7 | 61.5 - 41.5 | Diagonal | Max. Vy | 11 | 1.43 | 0.93 | 0.07 |
| | | | Max. Vx | 8 | -1.45 | -0.07 | -0.97 |
| | | | Max Tension | 13 | 4.44 | 0.00 | 0.00 |
| | | | Max. Compression | 3 | -4.43 | 0.00 | 0.00 |
| | | | Max. Mx | 18 | 1.21 | -0.04 | 0.00 |
| | | | Max. My | 7 | -1.90 | 0.00 | 0.00 |
| | | | Max. Vy | 18 | 0.04 | 0.00 | 0.00 |
| | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | | Max Tension | 3 | 0.99 | 0.00 | 0.00 |
| | | | Max. Compression | 9 | -0.73 | 0.00 | 0.00 |
| | | Top Girt | Max. Mx | 14 | 0.19 | -0.03 | 0.00 |
| | | | Max. My | 7 | -0.46 | 0.00 | 0.00 |
| | | | Max. Vy | 14 | 0.04 | 0.00 | 0.00 |
| | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | | Max Tension | 2 | 3.88 | 0.00 | 0.00 |
| | | | Max. Compression | 1 | 0.00 | 0.00 | 0.00 |
| | | | Max. Mx | 14 | 3.14 | -0.03 | 0.00 |
| | | | Max. My | 7 | 2.90 | 0.00 | 0.00 |
| | | | Max. Vy | 14 | 0.04 | 0.00 | 0.00 |
| | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 |
| | | Bottom Girt | Max Tension | 8 | 13.82 | | |
| | | | Top Tension | 8 | 13.89 | | |
| | | | Top Cable Vert | 8 | 5.47 | | |
| | | | Top Cable Norm | 8 | 12.77 | | |
| | | | Top Cable Tan | 8 | 0.00 | | |
| | | | Bot Cable Vert | 8 | -5.24 | | |
| | | | Bot Cable Norm | 8 | 12.79 | | |
| | | | Bot Cable Tan | 8 | 0.00 | | |
| | | | Bottom Tension | 12 | 13.70 | | |
| | | | Top Tension | 12 | 13.78 | | |
| | | Guy A | Top Cable Vert | 12 | 5.28 | | |
| | | | Top Cable Norm | 12 | 12.72 | | |
| | | | Top Cable Tan | 12 | 0.00 | | |
| | | | Bot Cable Vert | 12 | -5.05 | | |
| | | | Bot Cable Norm | 12 | 12.74 | | |
| | | | Bot Cable Tan | 12 | 0.00 | | |
| | | | Bottom Tension | 4 | 13.44 | | |
| | | | Top Tension | 4 | 13.52 | | |
| | | | Top Cable Vert | 4 | 5.01 | | |
| | | | Top Cable Norm | 4 | 12.55 | | |
| | | Guy B | Top Cable Tan | 4 | 0.00 | | |
| | | | Bot Cable Vert | 4 | -4.77 | | |
| | | | Bot Cable Norm | 4 | 12.57 | | |
| | | | Bot Cable Tan | 4 | 0.00 | | |
| | | | Max Tension | 2 | 2.91 | 0.00 | 0.00 |
| | | | Max. Compression | 1 | 0.00 | 0.00 | 0.00 |
| | | | Max. Mx | 14 | 2.36 | 0.03 | 0.00 |
| | | | Max. My | 7 | 2.17 | 0.00 | -0.00 |
| | | | Max. Vy | 14 | -0.04 | 0.00 | 0.00 |
| | | | Max. Vx | 7 | 0.00 | 0.00 | 0.00 |
| Guy C | Max Tension | 1 | 0.00 | 0.00 | 0.00 | | |
| | Max. Compression | 15 | -54.24 | 0.08 | -0.10 | | |
| | Max. Mx | 11 | -8.61 | -0.83 | -0.06 | | |
| | Max. My | 8 | -5.13 | 0.13 | 0.81 | | |
| | Max. Vy | 11 | 1.43 | 0.05 | 0.00 | | |
| | Max. Vx | 8 | -1.45 | 0.03 | -0.08 | | |
| | Max Tension | 13 | 3.32 | 0.00 | 0.00 | | |
| | Max. Compression | 7 | -3.51 | 0.00 | 0.00 | | |
| | Max. Mx | 16 | -1.08 | -0.04 | 0.00 | | |
| | Max. My | 7 | -1.17 | 0.00 | 0.00 | | |
| Top Guy Pull-Off | Max. Vy | 16 | 0.04 | 0.00 | 0.00 | | |
| | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | | |
| | Max Tension | 7 | 1.85 | 0.00 | 0.00 | | |
| | Max. Compression | 13 | -1.60 | 0.00 | 0.00 | | |
| | Max. Mx | 14 | 0.10 | 0.01 | 0.00 | | |
| | Max. My | 7 | 1.85 | 0.00 | -0.00 | | |
| | Max. Vy | 14 | -0.01 | 0.00 | 0.00 | | |
| | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | | |
| | Max Tension | 13 | 0.91 | 0.00 | 0.00 | | |
| | Leg | Max Tension | 13 | 0.91 | 0.00 | 0.00 | |
| Max. Compression | | 13 | -1.60 | 0.00 | 0.00 | | |
| Max. Mx | | 14 | 0.10 | 0.01 | 0.00 | | |
| Max. My | | 7 | 1.85 | 0.00 | -0.00 | | |
| Max. Vy | | 14 | -0.01 | 0.00 | 0.00 | | |
| Max. Vx | | 7 | 0.00 | 0.00 | 0.00 | | |
| Max Tension | | 13 | 0.91 | 0.00 | 0.00 | | |
| Max. Compression | | 13 | -1.60 | 0.00 | 0.00 | | |
| Max. Mx | | 14 | 0.10 | 0.01 | 0.00 | | |
| Max. My | | 7 | 1.85 | 0.00 | -0.00 | | |
| Diagonal | Max. Vy | 14 | -0.04 | 0.00 | 0.00 | | |
| | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | | |
| | Max Tension | 2 | 3.88 | 0.00 | 0.00 | | |
| | Max. Compression | 1 | 0.00 | 0.00 | 0.00 | | |
| | Max. Mx | 14 | 3.14 | -0.03 | 0.00 | | |
| | Max. My | 7 | 2.90 | 0.00 | 0.00 | | |
| | Max. Vy | 14 | 0.04 | 0.00 | 0.00 | | |
| | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | | |
| | Max Tension | 8 | 13.82 | | | | |
| | Top Tension | 8 | 13.89 | | | | |
| Top Girt | Top Cable Vert | 8 | 5.47 | | | | |
| | Top Cable Norm | 8 | 12.77 | | | | |
| | Top Cable Tan | 8 | 0.00 | | | | |
| | Bot Cable Vert | 8 | -5.24 | | | | |
| | Bot Cable Norm | 8 | 12.79 | | | | |
| | Bot Cable Tan | 8 | 0.00 | | | | |
| | Bottom Tension | 12 | 13.70 | | | | |
| | Top Tension | 12 | 13.78 | | | | |
| | Top Cable Vert | 12 | 5.28 | | | | |
| | Top Cable Norm | 12 | 12.72 | | | | |
| Bottom Girt | Top Cable Tan | 12 | 0.00 | | | | |
| | Bot Cable Vert | 12 | -5.05 | | | | |
| | Bot Cable Norm | 12 | 12.74 | | | | |
| | Bot Cable Tan | 12 | 0.00 | | | | |
| | Bottom Tension | 4 | 13.44 | | | | |
| | Top Tension | 4 | 13.52 | | | | |
| | Top Cable Vert | 4 | 5.01 | | | | |
| | Top Cable Norm | 4 | 12.55 | | | | |
| | Top Cable Tan | 4 | 0.00 | | | | |
| | Bot Cable Vert | 4 | -4.77 | | | | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft | |
|------------------|--------------|------------------|------------------|------------------|---------|--------------------------|--------------------------|-------|
| T8 | 41.5 - 21.5 | Leg | Max. Compression | 7 | -0.79 | 0.00 | 0.00 | |
| | | | Max. Mx | 14 | 0.12 | 0.01 | 0.00 | |
| | | | Max. My | 7 | -0.79 | 0.00 | -0.00 | |
| | | | Max. Vy | 14 | -0.01 | 0.00 | 0.00 | |
| | | | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Compression | 21 | -55.25 | 0.15 | 0.16 | |
| | | | Max. Mx | 11 | -22.73 | -0.42 | -0.02 | |
| | | | Max. My | 8 | -22.71 | 0.10 | 0.42 | |
| | | | Max. Vy | 11 | 0.61 | 0.07 | -0.07 | |
| | | | Max. Vx | 8 | -0.67 | 0.06 | 0.01 | |
| | | Diagonal | Max Tension | 13 | 1.61 | 0.00 | 0.00 | |
| | | | Max. Compression | 7 | -1.79 | 0.00 | 0.00 | |
| | | | Max. Mx | 22 | -0.04 | 0.01 | 0.00 | |
| | | | Max. My | 23 | 0.12 | 0.00 | -0.00 | |
| | | | Max. Vy | 22 | -0.01 | 0.00 | 0.00 | |
| | | | Max. Vx | 23 | 0.00 | 0.00 | 0.00 | |
| | | | Top Girt | Max Tension | 7 | 0.82 | 0.00 | 0.00 |
| | | Max. Compression | | 13 | -0.71 | 0.00 | 0.00 | |
| | | Max. Mx | | 14 | 0.08 | 0.01 | 0.00 | |
| | | Max. My | | 7 | 0.82 | 0.00 | -0.00 | |
| | | Max. Vy | | 14 | -0.01 | 0.00 | 0.00 | |
| | | Bottom Girt | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | |
| Max Tension | 13 | | 0.24 | 0.00 | 0.00 | | | |
| Max. Compression | 7 | | -0.15 | 0.00 | 0.00 | | | |
| Max. Mx | 14 | | 0.10 | 0.01 | 0.00 | | | |
| Max. Vy | 14 | | -0.01 | 0.00 | 0.00 | | | |
| T9 | 21.5 - 6.5 | Leg | Max. Vx | 7 | 0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Compression | 22 | -55.74 | -0.03 | -0.17 | |
| | | | Max. Mx | 19 | -55.35 | -3.04 | 1.48 | |
| | | | Max. My | 22 | -55.58 | 0.24 | -3.40 | |
| | | | Max. Vy | 24 | -5.88 | 2.83 | 1.87 | |
| | | | Max. Vx | 20 | 6.82 | 0.20 | -3.39 | |
| | | | Diagonal | Max Tension | 9 | 1.15 | 0.00 | 0.00 |
| | | | | Max. Compression | 2 | -1.54 | 0.00 | 0.00 |
| | | | | Max. Mx | 22 | 0.15 | -0.03 | 0.00 |
| | | | | Max. My | 23 | 0.16 | 0.00 | 0.00 |
| | | Max. Vy | | 22 | -0.03 | 0.00 | 0.00 | |
| | | Max. Vx | | 23 | -0.00 | 0.00 | 0.00 | |
| | | Top Girt | | Max Tension | 7 | 0.31 | 0.00 | 0.00 |
| | | | Max. Compression | 2 | -0.16 | 0.00 | 0.00 | |
| | | | Max. Mx | 23 | 0.20 | -0.03 | 0.00 | |
| | | | Max. My | 7 | 0.24 | 0.00 | 0.00 | |
| | | | Max. Vy | 23 | 0.03 | 0.00 | 0.00 | |
| | | Bottom Girt | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 19 | 4.32 | 0.00 | 0.00 | |
| | | | Max. Compression | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Mx | 23 | 4.10 | -0.03 | 0.00 | |
| | | | Max. My | 7 | 2.14 | 0.00 | 0.00 | |
| T10 | 6.5 - 1.5 | Leg | Max. Vy | 23 | 0.03 | 0.00 | 0.00 | |
| | | | Max. Vx | 7 | -0.00 | 0.00 | 0.00 | |
| | | | Max Tension | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Compression | 22 | -59.88 | -0.41 | 0.03 | |
| | | | Max. Mx | 23 | -52.57 | -4.29 | 0.23 | |
| | | | Max. My | 7 | -22.93 | -1.82 | 0.45 | |
| | | | Max. Vy | 23 | 14.21 | -4.25 | 0.30 | |
| | | | Max. Vx | 7 | -1.39 | -0.64 | 0.41 | |
| | | | Horizontal | Max Tension | 8 | 0.02 | -0.55 | -0.04 |
| | | | | Max. Compression | 7 | -0.01 | 0.27 | 0.05 |
| | | | | Max. Mx | 7 | 0.00 | -0.70 | -0.06 |
| | | Max. My | | 7 | 0.00 | -0.70 | -0.06 | |
| | | Max. Vy | | 7 | -0.59 | -0.66 | -0.05 | |
| | | Max. Vx | | 7 | -0.07 | -0.70 | -0.06 | |
| | | Top Girt | | Max Tension | 23 | 8.68 | -3.03 | -0.07 |
| | | | Max. Compression | 1 | 0.00 | 0.00 | 0.00 | |
| | | | Max. Mx | 24 | 8.63 | -3.04 | -0.08 | |
| | | | Max. My | 7 | 3.98 | -1.80 | -0.08 | |
| | | | Max. Vy | 7 | -0.36 | -1.49 | -0.05 | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|-------------|--------------|----------------|------------------|-----------------|---------|--------------------------|--------------------------|
| | | Bottom Girt | Max. Vx | 7 | -0.05 | -1.80 | -0.08 |
| | | | Max Tension | 1 | 0.00 | 0.00 | 0.00 |
| | | | Max. Compression | 19 | -3.33 | -1.13 | -0.01 |
| | | | Max. Mx | 18 | -3.32 | -1.31 | -0.02 |
| | | | Max. My | 2 | -1.43 | -0.12 | 0.08 |
| | | | Max. Vy | 7 | -3.67 | -1.02 | -0.00 |
| | | | Max. Vx | 2 | 0.38 | -0.74 | -0.05 |

Maximum Reactions

| Location | Condition | Gov. Load Comb. | Vertical K | Horizontal, X K | Horizontal, Z K | |
|--|--|---------------------|------------|-----------------|-----------------|------|
| Mast | Max. Vert | 23 | 166.02 | 0.23 | -0.15 | |
| | Max. H _x | 11 | 70.12 | 1.22 | -0.00 | |
| | Max. H _z | 2 | 70.11 | 0.00 | 1.43 | |
| | Max. M _x | 1 | 0.00 | -0.00 | -0.00 | |
| | Max. M _z | 1 | 0.00 | -0.00 | -0.00 | |
| | Max. Torsion | 13 | 0.90 | 0.65 | 1.12 | |
| | Min. Vert | 1 | 54.41 | -0.00 | -0.00 | |
| | Min. H _x | 5 | 69.76 | -1.23 | -0.02 | |
| | Min. H _z | 8 | 70.93 | -0.00 | -1.28 | |
| | Min. M _x | 1 | 0.00 | -0.00 | -0.00 | |
| | Min. M _z | 1 | 0.00 | -0.00 | -0.00 | |
| | Min. Torsion | 7 | -0.96 | -0.65 | -1.13 | |
| | Guy C @ 184 ft Elev 0 ft Azimuth 240 deg | Max. Vert | 10 | -1.10 | -0.90 | 0.52 |
| | | Max. H _x | 10 | -1.10 | -0.90 | 0.52 |
| Max. H _z | | 4 | -22.00 | -24.39 | 14.10 | |
| Min. Vert | | 4 | -22.00 | -24.39 | 14.10 | |
| Min. H _x | | 4 | -22.00 | -24.39 | 14.10 | |
| Min. H _z | | 10 | -1.10 | -0.90 | 0.52 | |
| Guy B @ 184 ft Elev 0 ft Azimuth 120 deg | Max. Vert | 6 | -1.09 | 0.90 | 0.52 | |
| | Max. H _x | 12 | -22.11 | 24.49 | 14.15 | |
| | Max. H _z | 12 | -22.11 | 24.49 | 14.15 | |
| | Min. Vert | 12 | -22.11 | 24.49 | 14.15 | |
| | Min. H _x | 6 | -1.09 | 0.90 | 0.52 | |
| | Min. H _z | 6 | -1.09 | 0.90 | 0.52 | |
| Guy A @ 184 ft Elev 0 ft Azimuth 0 deg | Max. Vert | 2 | -1.07 | -0.00 | -1.02 | |
| | Max. H _x | 11 | -12.25 | 0.92 | -15.40 | |
| | Max. H _z | 2 | -1.07 | -0.00 | -1.02 | |
| | Min. Vert | 8 | -23.04 | 0.01 | -29.33 | |
| | Min. H _x | 5 | -12.16 | -0.92 | -15.28 | |
| | Min. H _z | 8 | -23.04 | 0.01 | -29.33 | |
| | Max. Vert | 10 | -0.29 | -0.82 | 0.47 | |
| | Max. H _x | 10 | -0.29 | -0.82 | 0.47 | |
| Guy C @ 161.2 ft Elev 0 ft Azimuth 240 deg | Max. H _z | 4 | -4.77 | -10.88 | 6.28 | |
| | Min. Vert | 4 | -4.77 | -10.88 | 6.28 | |
| | Min. H _x | 4 | -4.77 | -10.88 | 6.28 | |
| | Min. H _z | 10 | -0.29 | -0.82 | 0.47 | |
| | Max. Vert | 6 | -0.27 | 0.73 | 0.42 | |
| | Max. H _x | 12 | -5.05 | 11.03 | 6.37 | |
| Guy B @ 154.8 ft Elev 0 ft Azimuth 120 deg | Max. H _z | 12 | -5.05 | 11.03 | 6.37 | |
| | Min. Vert | 12 | -5.05 | 11.03 | 6.37 | |

| Location | Condition | Gov. Load Comb. | Vertical K | Horizontal, X K | Horizontal, Z K |
|--|---------------------|-----------------|------------|-----------------|-----------------|
| Guy A @ 150 ft Elev 0 ft Azimuth 0 deg | Min. H _x | 6 | -0.27 | 0.73 | 0.42 |
| | Min. H _z | 6 | -0.27 | 0.73 | 0.42 |
| | Max. Vert | 2 | -0.26 | -0.00 | -0.78 |
| | Max. H _x | 11 | -2.71 | 0.16 | -6.68 |
| | Max. H _z | 2 | -0.26 | -0.00 | -0.78 |
| | Min. Vert | 8 | -5.24 | 0.00 | -12.79 |
| | Min. H _x | 5 | -2.65 | -0.16 | -6.54 |
| | Min. H _z | 8 | -5.24 | 0.00 | -12.79 |

Tower Mast Reaction Summary

| Load Combination | Vertical K | Shear _x K | Shear _z K | Overtuning Moment, M _x kip-ft | Overtuning Moment, M _z kip-ft | Torque kip-ft |
|--|------------|----------------------|----------------------|--|--|---------------|
| Dead Only | 54.41 | 0.00 | 0.00 | 0.00 | 0.00 | -0.00 |
| 1.2 Dead+1.0 Wind 0 deg - No Ice+1.0 Guy | 70.11 | -0.00 | -1.43 | 0.00 | 0.00 | -0.76 |
| 1.2 Dead+1.0 Wind 30 deg - No Ice+1.0 Guy | 70.19 | 0.65 | -1.12 | 0.00 | 0.00 | -0.61 |
| 1.2 Dead+1.0 Wind 60 deg - No Ice+1.0 Guy | 69.86 | 1.07 | -0.60 | 0.00 | 0.00 | -0.74 |
| 1.2 Dead+1.0 Wind 90 deg - No Ice+1.0 Guy | 69.76 | 1.23 | 0.02 | 0.00 | 0.00 | -0.54 |
| 1.2 Dead+1.0 Wind 120 deg - No Ice+1.0 Guy | 70.07 | 1.21 | 0.71 | 0.00 | 0.00 | 0.40 |
| 1.2 Dead+1.0 Wind 150 deg - No Ice+1.0 Guy | 71.05 | 0.65 | 1.13 | 0.00 | 0.00 | 0.96 |
| 1.2 Dead+1.0 Wind 180 deg - No Ice+1.0 Guy | 70.93 | 0.00 | 1.28 | 0.00 | 0.00 | 0.76 |
| 1.2 Dead+1.0 Wind 210 deg - No Ice+1.0 Guy | 71.20 | -0.65 | 1.12 | 0.00 | 0.00 | 0.52 |
| 1.2 Dead+1.0 Wind 240 deg - No Ice+1.0 Guy | 70.09 | -1.21 | 0.69 | 0.00 | 0.00 | 0.65 |
| 1.2 Dead+1.0 Wind 270 deg - No Ice+1.0 Guy | 70.12 | -1.22 | 0.00 | 0.00 | 0.00 | 0.53 |
| 1.2 Dead+1.0 Wind 300 deg - No Ice+1.0 Guy | 70.17 | -1.07 | -0.61 | 0.00 | 0.00 | -0.35 |
| 1.2 Dead+1.0 Wind 330 deg - No Ice+1.0 Guy | 70.40 | -0.65 | -1.12 | 0.00 | 0.00 | -0.90 |
| 1.2 Dead+1.0 Ice+1.0 Temp+Guy | 164.24 | 0.00 | 0.02 | 0.00 | 0.00 | -0.03 |
| 1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.84 | 0.00 | -0.26 | 0.00 | 0.00 | -0.14 |
| 1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.12 | 0.12 | -0.22 | 0.00 | 0.00 | -0.14 |
| 1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp+1.0 Guy | 164.47 | 0.21 | -0.10 | 0.00 | 0.00 | -0.24 |
| 1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.17 | 0.26 | 0.04 | 0.00 | 0.00 | -0.25 |
| 1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.93 | 0.24 | 0.16 | 0.00 | 0.00 | -0.06 |
| 1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.29 | 0.15 | 0.24 | 0.00 | 0.00 | 0.10 |
| 1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp+1.0 Guy | 164.66 | 0.00 | 0.28 | 0.00 | 0.00 | 0.08 |
| 1.2 Dead+1.0 Wind 210 | 165.33 | -0.15 | 0.24 | 0.00 | 0.00 | 0.07 |

| Load Combination | Vertical K | Shear _x K | Shear _z K | Overturning Moment, M _x kip-ft | Overturning Moment, M _z kip-ft | Torque kip-ft |
|--|---------------|-------------------------|-------------------------|--|--|------------------|
| deg+1.0 Ice+1.0 Temp+1.0 Guy | | | | | | |
| 1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp+1.0 Guy | 166.02 | -0.23 | 0.15 | 0.00 | 0.00 | 0.18 |
| 1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.27 | -0.25 | 0.04 | 0.00 | 0.00 | 0.20 |
| 1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp+1.0 Guy | 164.56 | -0.21 | -0.10 | 0.00 | 0.00 | 0.01 |
| 1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp+1.0 Guy | 165.18 | -0.12 | -0.22 | 0.00 | 0.00 | -0.15 |
| Dead+Wind 0 deg - Service+Guy | 54.73 | 0.00 | -0.27 | 0.00 | 0.00 | -0.13 |
| Dead+Wind 30 deg - Service+Guy | 54.62 | 0.13 | -0.23 | 0.00 | 0.00 | -0.10 |
| Dead+Wind 60 deg - Service+Guy | 54.55 | 0.22 | -0.12 | 0.00 | 0.00 | -0.12 |
| Dead+Wind 90 deg - Service+Guy | 54.65 | 0.25 | 0.01 | 0.00 | 0.00 | -0.08 |
| Dead+Wind 120 deg - Service+Guy | 54.77 | 0.24 | 0.14 | 0.00 | 0.00 | 0.07 |
| Dead+Wind 150 deg - Service+Guy | 54.70 | 0.14 | 0.23 | 0.00 | 0.00 | 0.16 |
| Dead+Wind 180 deg - Service+Guy | 54.64 | 0.00 | 0.26 | 0.00 | 0.00 | 0.12 |
| Dead+Wind 210 deg - Service+Guy | 54.72 | -0.14 | 0.23 | 0.00 | 0.00 | 0.09 |
| Dead+Wind 240 deg - Service+Guy | 54.81 | -0.23 | 0.14 | 0.00 | 0.00 | 0.10 |
| Dead+Wind 270 deg - Service+Guy | 54.70 | -0.25 | 0.01 | 0.00 | 0.00 | 0.08 |
| Dead+Wind 300 deg - Service+Guy | 54.59 | -0.22 | -0.12 | 0.00 | 0.00 | -0.07 |
| Dead+Wind 330 deg - Service+Guy | 54.65 | -0.13 | -0.23 | 0.00 | 0.00 | -0.16 |

Solution Summary

| Load Comb. | Sum of Applied Forces | | | Sum of Reactions | | | % Error |
|------------|-----------------------|---------|---------|------------------|---------|---------|---------|
| | PX K | PY K | PZ K | PX K | PY K | PZ K | |
| 1 | 0.00 | -22.22 | 0.00 | 0.00 | 22.22 | -0.00 | 0.001% |
| 2 | 0.10 | -26.46 | -33.56 | -0.10 | 26.46 | 33.56 | 0.005% |
| 3 | 16.11 | -26.17 | -28.13 | -16.11 | 26.17 | 28.13 | 0.002% |
| 4 | 27.11 | -25.87 | -15.74 | -27.11 | 25.87 | 15.74 | 0.001% |
| 5 | 31.45 | -26.17 | 0.22 | -31.44 | 26.17 | -0.22 | 0.006% |
| 6 | 28.68 | -26.46 | 16.94 | -28.68 | 26.46 | -16.94 | 0.005% |
| 7 | 16.41 | -26.17 | 28.85 | -16.41 | 26.17 | -28.85 | 0.003% |
| 8 | -0.10 | -25.87 | 32.89 | 0.09 | 25.87 | -32.89 | 0.002% |
| 9 | -16.44 | -26.17 | 28.71 | 16.44 | 26.17 | -28.71 | 0.003% |
| 10 | -28.41 | -26.47 | 16.89 | 28.41 | 26.47 | -16.89 | 0.005% |
| 11 | -31.45 | -26.17 | 0.41 | 31.44 | 26.17 | -0.41 | 0.006% |
| 12 | -27.38 | -25.87 | -15.79 | 27.38 | 25.87 | 15.79 | 0.001% |
| 13 | -16.09 | -26.17 | -28.28 | 16.09 | 26.17 | 28.28 | 0.002% |
| 14 | 0.00 | -106.56 | 0.00 | -0.00 | 106.56 | 0.00 | 0.001% |
| 15 | 0.02 | -106.83 | -10.96 | -0.02 | 106.83 | 10.96 | 0.001% |
| 16 | 5.39 | -106.56 | -9.37 | -5.39 | 106.56 | 9.37 | 0.003% |
| 17 | 9.22 | -106.28 | -5.35 | -9.22 | 106.28 | 5.35 | 0.003% |
| 18 | 10.64 | -106.56 | 0.02 | -10.64 | 106.56 | -0.02 | 0.001% |
| 19 | 9.35 | -106.83 | 5.46 | -9.35 | 106.83 | -5.46 | 0.001% |
| 20 | 5.41 | -106.56 | 9.44 | -5.41 | 106.56 | -9.44 | 0.001% |
| 21 | -0.02 | -106.28 | 10.91 | 0.02 | 106.28 | -10.90 | 0.003% |
| 22 | -5.43 | -106.56 | 9.45 | 5.43 | 106.56 | -9.45 | 0.003% |

| Load Comb. | Sum of Applied Forces | | | Sum of Reactions | | | % Error |
|------------|-----------------------|---------|---------|------------------|---------|---------|---------|
| | PX K | PY K | PZ K | PX K | PY K | PZ K | |
| 23 | -9.37 | -106.83 | 5.48 | 9.36 | 106.83 | -5.48 | 0.001% |
| 24 | -10.64 | -106.56 | 0.06 | 10.63 | 106.56 | -0.06 | 0.003% |
| 25 | -9.21 | -106.28 | -5.32 | 9.21 | 106.28 | 5.32 | 0.003% |
| 26 | -5.36 | -106.56 | -9.36 | 5.36 | 106.56 | 9.36 | 0.003% |
| 27 | 0.02 | -22.27 | -6.16 | -0.02 | 22.27 | 6.16 | 0.005% |
| 28 | 2.96 | -22.22 | -5.17 | -2.96 | 22.22 | 5.17 | 0.004% |
| 29 | 4.98 | -22.16 | -2.89 | -4.98 | 22.16 | 2.89 | 0.003% |
| 30 | 5.78 | -22.22 | 0.04 | -5.77 | 22.22 | -0.04 | 0.004% |
| 31 | 5.27 | -22.27 | 3.11 | -5.27 | 22.27 | -3.11 | 0.006% |
| 32 | 3.01 | -22.22 | 5.30 | -3.01 | 22.22 | -5.30 | 0.004% |
| 33 | -0.02 | -22.16 | 6.04 | 0.02 | 22.16 | -6.04 | 0.003% |
| 34 | -3.02 | -22.22 | 5.27 | 3.02 | 22.22 | -5.27 | 0.004% |
| 35 | -5.22 | -22.27 | 3.10 | 5.22 | 22.27 | -3.10 | 0.005% |
| 36 | -5.78 | -22.22 | 0.08 | 5.77 | 22.22 | -0.08 | 0.004% |
| 37 | -5.03 | -22.16 | -2.90 | 5.03 | 22.16 | 2.90 | 0.003% |
| 38 | -2.95 | -22.22 | -5.19 | 2.95 | 22.22 | 5.19 | 0.004% |

Non-Linear Convergence Results

| Load Combination | Converged? | Number of Cycles | Displacement Tolerance | Force Tolerance |
|------------------|------------|------------------|------------------------|-----------------|
| 1 | Yes | 8 | 0.00000001 | 0.00004231 |
| 2 | Yes | 15 | 0.00000001 | 0.00009544 |
| 3 | Yes | 15 | 0.00000001 | 0.00003932 |
| 4 | Yes | 11 | 0.00000001 | 0.00003198 |
| 5 | Yes | 14 | 0.00000001 | 0.00009170 |
| 6 | Yes | 15 | 0.00000001 | 0.00009141 |
| 7 | Yes | 15 | 0.00000001 | 0.00004366 |
| 8 | Yes | 11 | 0.00000001 | 0.00003341 |
| 9 | Yes | 15 | 0.00000001 | 0.00004453 |
| 10 | Yes | 15 | 0.00000001 | 0.00008821 |
| 11 | Yes | 14 | 0.00000001 | 0.00009252 |
| 12 | Yes | 11 | 0.00000001 | 0.00003425 |
| 13 | Yes | 15 | 0.00000001 | 0.00003948 |
| 14 | Yes | 9 | 0.00000001 | 0.00008919 |
| 15 | Yes | 12 | 0.00000001 | 0.00004837 |
| 16 | Yes | 11 | 0.00010000 | 0.00009065 |
| 17 | Yes | 11 | 0.00000001 | 0.00007611 |
| 18 | Yes | 12 | 0.00000001 | 0.00004286 |
| 19 | Yes | 12 | 0.00000001 | 0.00005575 |
| 20 | Yes | 12 | 0.00000001 | 0.00004224 |
| 21 | Yes | 11 | 0.00000001 | 0.00006879 |
| 22 | Yes | 11 | 0.00010000 | 0.00008301 |
| 23 | Yes | 12 | 0.00000001 | 0.00004620 |
| 24 | Yes | 11 | 0.00010000 | 0.00008592 |
| 25 | Yes | 11 | 0.00000001 | 0.00006128 |
| 26 | Yes | 11 | 0.00010000 | 0.00009013 |
| 27 | Yes | 9 | 0.00000001 | 0.00008804 |
| 28 | Yes | 9 | 0.00000001 | 0.00006215 |
| 29 | Yes | 9 | 0.00000001 | 0.00004412 |
| 30 | Yes | 9 | 0.00000001 | 0.00006496 |
| 31 | Yes | 9 | 0.00000001 | 0.00009264 |
| 32 | Yes | 9 | 0.00000001 | 0.00006366 |
| 33 | Yes | 9 | 0.00000001 | 0.00003936 |
| 34 | Yes | 9 | 0.00000001 | 0.00005993 |
| 35 | Yes | 9 | 0.00000001 | 0.00008742 |
| 36 | Yes | 9 | 0.00000001 | 0.00006239 |
| 37 | Yes | 9 | 0.00000001 | 0.00004127 |
| 38 | Yes | 9 | 0.00000001 | 0.00006314 |

Maximum Tower Deflections - Service Wind

| Section No. | Elevation ft | Horz. Deflection in | Gov. Load Comb. | Tilt ° | Twist ° |
|-------------|-----------------|------------------------|-----------------|-----------|------------|
| T1 | 181.5 - 161.5 | 0.754 | 33 | 0.0225 | 0.0736 |
| T2 | 161.5 - 141.5 | 0.692 | 33 | 0.0127 | 0.0610 |
| T3 | 141.5 - 121.5 | 0.653 | 33 | 0.0086 | 0.0341 |
| T4 | 121.5 - 101.5 | 0.654 | 29 | 0.0153 | 0.0334 |
| T5 | 101.5 - 81.5 | 0.678 | 31 | 0.0130 | 0.0397 |
| T6 | 81.5 - 61.5 | 0.555 | 31 | 0.0428 | 0.0441 |
| T7 | 61.5 - 41.5 | 0.370 | 35 | 0.0368 | 0.0445 |
| T8 | 41.5 - 21.5 | 0.272 | 35 | 0.0230 | 0.0423 |
| T9 | 21.5 - 6.5 | 0.167 | 35 | 0.0336 | 0.0261 |
| T10 | 6.5 - 1.5 | 0.046 | 35 | 0.0419 | 0.0217 |

Critical Deflections and Radius of Curvature - Service Wind

| Elevation ft | Appurtenance | Gov. Load Comb. | Deflection in | Tilt ° | Twist ° | Radius of Curvature ft |
|-----------------|-------------------------------|-----------------|------------------|-----------|------------|---------------------------|
| 180.50 | 20' x 2" Dia Omni | 33 | 0.750 | 0.0216 | 0.0732 | 652780 |
| 177.00 | DS2C03F36D-D | 33 | 0.739 | 0.0186 | 0.0718 | 652780 |
| 176.50 | 8.5' Dish | 33 | 0.737 | 0.0181 | 0.0716 | 652780 |
| 169.15 | Guy | 33 | 0.714 | 0.0125 | 0.0677 | 264358 |
| 160.50 | Pipe Mount [PM 602-3] | 33 | 0.689 | 0.0124 | 0.0599 | 162957 |
| 148.50 | 8' x 2" Horizontal Mount Pipe | 33 | 0.662 | 0.0079 | 0.0432 | 135136 |
| 138.50 | 20' x 2" Mount Pipe | 33 | 0.650 | 0.0086 | 0.0312 | 117434 |
| 129.15 | Guy | 33 | 0.647 | 0.0128 | 0.0320 | 116185 |
| 127.50 | Sector Mount [SM 502-3] | 33 | 0.648 | 0.0137 | 0.0322 | 115248 |
| 89.50 | Side Arm Mount [SO 203-1] | 31 | 0.622 | 0.0315 | 0.0429 | 34647 |
| 78.50 | Sector Mount [SM 502-3] | 31 | 0.526 | 0.0448 | 0.0443 | 77291 |
| 62.11 | Guy | 35 | 0.374 | 0.0374 | 0.0444 | 32871 |

Maximum Tower Deflections - Design Wind

| Section No. | Elevation ft | Horz. Deflection in | Gov. Load Comb. | Tilt ° | Twist ° |
|-------------|-----------------|------------------------|-----------------|-----------|------------|
| T1 | 181.5 - 161.5 | 6.048 | 9 | 0.1808 | 0.5367 |
| T2 | 161.5 - 141.5 | 5.502 | 9 | 0.1101 | 0.4666 |
| T3 | 141.5 - 121.5 | 5.062 | 2 | 0.1162 | 0.2791 |
| T4 | 121.5 - 101.5 | 5.069 | 2 | 0.0538 | 0.2419 |
| T5 | 101.5 - 81.5 | 5.043 | 2 | 0.1303 | 0.2617 |
| T6 | 81.5 - 61.5 | 4.225 | 2 | 0.2845 | 0.2847 |
| T7 | 61.5 - 41.5 | 2.966 | 2 | 0.2598 | 0.2817 |
| T8 | 41.5 - 21.5 | 2.137 | 2 | 0.1979 | 0.2635 |
| T9 | 21.5 - 6.5 | 1.247 | 2 | 0.2612 | 0.1564 |
| T10 | 6.5 - 1.5 | 0.334 | 2 | 0.3095 | 0.1299 |

Critical Deflections and Radius of Curvature - Design Wind

| Elevation ft | Appurtenance | Gov. Load Comb. | Deflection in | Tilt ° | Twist ° | Radius of Curvature ft |
|-----------------|-------------------------------|-----------------|------------------|-----------|------------|---------------------------|
| 180.50 | 20' x 2" Dia Omni | 9 | 6.019 | 0.1758 | 0.5352 | 164068 |
| 177.00 | DS2C03F36D-D | 9 | 5.921 | 0.1584 | 0.5294 | 164068 |
| 176.50 | 8.5' Dish | 9 | 5.907 | 0.1560 | 0.5285 | 164068 |
| 169.15 | Guy | 9 | 5.705 | 0.1256 | 0.5087 | 66444 |
| 160.50 | Pipe Mount [PM 602-3] | 9 | 5.477 | 0.1098 | 0.4588 | 45045 |
| 148.50 | 8' x 2" Horizontal Mount Pipe | 9 | 5.195 | 0.1214 | 0.3412 | 24283 |

| Elevation ft | Appurtenance | Gov. Load Comb. | Deflection in | Tilt ° | Twist ° | Radius of Curvature ft |
|-----------------|---------------------------|-----------------------|------------------|-----------|------------|------------------------------|
| 138.50 | 20' x 2" Mount Pipe | 2 | 5.052 | 0.1057 | 0.2604 | 21404 |
| 129.15 | Guy | 2 | 5.046 | 0.0646 | 0.2416 | 20457 |
| 127.50 | Sector Mount [SM 502-3] | 2 | 5.049 | 0.0631 | 0.2413 | 20303 |
| 89.50 | Side Arm Mount [SO 203-1] | 2 | 4.651 | 0.2378 | 0.2783 | 6042 |
| 78.50 | Sector Mount [SM 502-3] | 2 | 4.039 | 0.2917 | 0.2854 | 12509 |
| 62.11 | Guy | 2 | 2.999 | 0.2625 | 0.2816 | 5648 |

Bolt Design Data

| Section No. | Elevation ft | Component Type | Bolt Grade | Bolt Size in | Number Of Bolts | Maximum Load per Bolt K | Allowable Load per Bolt K | Ratio Load Allowable | Allowable Ratio | Criteria |
|----------------|-----------------|------------------------------|---------------|-----------------|-----------------------|----------------------------------|------------------------------------|----------------------------|--------------------|-----------------------|
| T1 | 181.5 | Diagonal | A325N | 0.5000 | 1 | 2.53 | 5.71 | 0.442 | 1.05 | Member Block Shear |
| | | Top Girt | A325N | 0.5000 | 1 | 0.11 | 8.84 | 0.013 | 1.05 | Bolt Shear |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.59 | 5.71 | 0.103 | 1.05 | Member Block Shear |
| T2 | 161.5 | Leg | A325N | 0.7500 | 4 | 1.34 | 30.10 | 0.045 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.5000 | 1 | 1.59 | 4.09 | 0.388 | 1.05 | Member Bearing |
| | | Top Girt | A325N | 0.5000 | 1 | 0.90 | 4.09 | 0.221 | 1.05 | Member Bearing |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.74 | 4.09 | 0.180 | 1.05 | Member Bearing |
| T3 | 141.5 | Leg | A325N | 0.7500 | 4 | 1.83 | 30.10 | 0.061 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.5000 | 1 | 2.67 | 6.20 | 0.431 | 1.05 | Member Bearing |
| | | Top Girt | A325N | 0.5000 | 1 | 0.46 | 6.20 | 0.073 | 1.05 | Member Bearing |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.86 | 6.20 | 0.139 | 1.05 | Member Bearing |
| T4 | 121.5 | Leg | A325N | 0.7500 | 4 | 3.23 | 30.10 | 0.107 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 3.45 | 13.81 | 0.250 | 1.05 | Bolt Shear |
| | | Horizontal | A325N | 0.6250 | 1 | 1.17 | 13.81 | 0.085 | 1.05 | Bolt Shear |
| | | Top Girt | A325N | 0.6250 | 1 | 1.67 | 13.81 | 0.121 | 1.05 | Bolt Shear |
| | | Bottom Girt | A325N | 0.6250 | 1 | 0.55 | 13.81 | 0.040 | 1.05 | Bolt Shear |
| T5 | 101.5 | Leg | A325N | 0.7500 | 4 | 3.63 | 30.10 | 0.121 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.5000 | 1 | 1.61 | 4.09 | 0.393 | 1.05 | Member Bearing |
| | | Horizontal | A325N | 0.6250 | 1 | 0.80 | 13.81 | 0.058 | 1.05 | Bolt Shear |
| | | Top Girt | A325N | 0.5000 | 1 | 0.35 | 4.09 | 0.086 | 1.05 | Member Bearing |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.64 | 4.09 | 0.155 | 1.05 | Member Bearing |
| T6 | 81.5 | Leg | A325N | 0.7500 | 4 | 3.61 | 30.10 | 0.120 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 4.44 | 13.81 | 0.322 | 1.05 | Bolt Shear |
| | | Top Girt | A325N | 0.6250 | 1 | 0.99 | 13.81 | 0.072 | 1.05 | Bolt Shear |
| | | Bottom Girt | A325N | 0.6250 | 1 | 3.88 | 13.81 | 0.281 | 1.05 | Bolt Shear |
| | | Top Guy Pull- Off@62.1146 | A325N | 0.6250 | 4 | 0.73 | 13.81 | 0.053 | 1.05 | Bolt Shear |
| T7 | 61.5 | Leg | A325N | 0.7500 | 4 | 4.52 | 30.10 | 0.150 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 3.51 | 13.81 | 0.254 | 1.05 | Bolt Shear |
| | | Top Girt | A325N | 0.5000 | 1 | 1.85 | 4.09 | 0.453 | 1.05 | Member Bearing |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.91 | 4.09 | 0.222 | 1.05 | Member Bearing |
| T8 | 41.5 | Leg | A325N | 0.7500 | 4 | 4.31 | 30.10 | 0.143 | 1 | Bolt Tension |
| | | Diagonal | A325N | 0.5000 | 1 | 1.61 | 4.09 | 0.394 | 1.05 | Member Bearing |
| | | Top Girt | A325N | 0.5000 | 1 | 0.82 | 4.09 | 0.200 | 1.05 | Member Bearing |
| | | Bottom Girt | A325N | 0.5000 | 1 | 0.24 | 4.09 | 0.059 | 1.05 | Member Bearing |
| T9 | 21.5 | Leg | A325N | 0.7500 | 4 | 4.43 | 30.10 | 0.147 | 1 | Bolt Tension |

| Section No. | Elevation ft | Component Type | Bolt Grade | Bolt Size in | Number Of Bolts | Maximum Load per Bolt K | Allowable Load per Bolt K | Ratio Load Allowable | Allowable Ratio | Criteria |
|-------------|-----------------|----------------|------------|-----------------|-----------------|----------------------------|------------------------------|----------------------|-----------------|--------------|
| T10 | 6.5 | Diagonal | A325N | 0.6250 | 1 | 1.54 | 13.81 | 0.112 | 1.05 | Bolt Shear |
| | | Top Girt | A325N | 0.6250 | 1 | 0.31 | 13.81 | 0.023 | 1.05 | Bolt Shear |
| | | Bottom Girt | A325N | 0.6250 | 1 | 4.32 | 13.81 | 0.313 | 1.05 | Bolt Shear |
| | | Leg | A325N | 0.7500 | 4 | 4.42 | 30.10 | 0.147 | 1 | Bolt Tension |

Guy Design Data

| Section No. | Elevation ft | Size | Initial Tension K | Breaking Load K | Actual T_u K | Allowable ϕT_n K | Required S.F. | Actual S.F. |
|-------------|---------------------|----------|----------------------|--------------------|-------------------|---------------------------|---------------|-------------|
| T1 | 169.15 (A) (406) | 9/16 EHS | 3.50 | 35.00 | 9.41 | 22.05 | 0.952 | 2.231 |
| | 169.15 (A) (407) | 9/16 EHS | 3.50 | 35.00 | 9.63 | 22.05 | 0.952 | 2.181 |
| | 169.15 (B) (400) | 9/16 EHS | 3.50 | 35.00 | 9.45 | 22.05 | 0.952 | 2.222 |
| | 169.15 (B) (401) | 9/16 EHS | 3.50 | 35.00 | 9.46 | 22.05 | 0.952 | 2.219 |
| | 169.15 (C) (394) | 9/16 EHS | 3.50 | 35.00 | 9.32 | 22.05 | 0.952 | 2.253 |
| | 169.15 (C) (395) | 9/16 EHS | 3.50 | 35.00 | 9.27 | 22.05 | 0.952 | 2.266 |
| T3 | 129.15 (A) (424) | 9/16 EHS | 3.50 | 35.00 | 9.25 | 22.05 | 0.952 | 2.270 |
| | 129.15 (A) (425) | 9/16 EHS | 3.50 | 35.00 | 9.65 | 22.05 | 0.952 | 2.176 |
| | 129.15 (B) (418) | 9/16 EHS | 3.50 | 35.00 | 9.36 | 22.05 | 0.952 | 2.243 |
| | 129.15 (B) (419) | 9/16 EHS | 3.50 | 35.00 | 9.36 | 22.05 | 0.952 | 2.243 |
| | 129.15 (C) (412) | 9/16 EHS | 3.50 | 35.00 | 9.60 | 22.05 | 0.952 | 2.188 |
| | 129.15 (C) (413) | 9/16 EHS | 3.50 | 35.00 | 9.24 | 22.05 | 0.952 | 2.273 |
| T6 | 62.11 (A) (435) | 3/4 EHS | 5.83 | 58.30 | 13.89 | 36.73 | 0.952 | 2.518 |
| | 62.11 (B) (434) | 3/4 EHS | 5.83 | 58.30 | 13.78 | 36.73 | 0.952 | 2.539 |
| | 62.11 (C) (430) | 3/4 EHS | 5.83 | 58.30 | 13.52 | 36.73 | 0.952 | 2.588 |

Compression Checks

Leg Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|--------------|---------|-------------|----------------|-------------|------------|-----------------|------------------------------|
| T1 | 181.5 - 161.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 | 1.7040 | -15.17 | 71.89 | 0.211 ¹ |
| T2 | 161.5 - 141.5 | Pipe 2.5 STD | 20.00 | 2.35 | 59.4 K=1.00 | 1.7040 | -22.20 | 59.23 | 0.375 ¹ |
| T3 | 141.5 - 121.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 K=2.00 | 1.7040 | -37.93 | 71.89 | 0.528 ¹ |
| T4 | 121.5 - 101.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 K=1.00 | 1.7040 | -42.89 | 71.89 | 0.597 ¹ |

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|--------------|---------|----------------------|--------------------------|----------------------|---------------------|----------------------|---------------------------------|
| T5 | 101.5 - 81.5 | Pipe 2.5 STD | 20.00 | 2.35 | K=1.00 29.7 | 1.7040 | -43.56 | 71.89 | 0.606 ¹ |
| T6 | 81.5 - 61.5 | Pipe 2.5 STD | 20.00 | 2.35 | K=1.00 59.4 | 1.7040 | -49.68 | 59.23 | 0.839 ¹ |
| T7 | 61.5 - 41.5 | Pipe 2.5 STD | 20.00 | 2.35 | K=2.00 59.4 | 1.7040 | -53.89 | 59.23 | 0.910 ¹ |
| T8 | 41.5 - 21.5 | Pipe 2.5 STD | 20.00 | 2.35 | K=2.00 59.4 | 1.7040 | -52.98 | 59.23 | 0.895 ¹ |
| T9 | 21.5 - 6.5 | Pipe 2.5 STD | 15.00 | 2.30 | K=2.00 58.1 | 1.7040 | -54.18 | 59.89 | 0.905 ¹ |
| T10 | 6.5 - 1.5 | Pipe 2.5 STD | 5.37 | 2.15 | K=2.00 27.2 K=1.00 | 1.7040 | -58.76 | 72.64 | 0.809 ¹ |

* DL controls

¹ P_u / φP_n controls

Diagonal Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|---------------------------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 4.14 | 1.82 | 77.7 | 0.6211 | -2.33 | 18.12 | 0.129 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 4.14 | 3.85 | K=1.22 90.6 | 0.2706 | -1.72 | 5.60 | 0.308 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 4.14 | 1.82 | K=1.00 71.6 | 0.7150 | -2.58 | 21.59 | 0.119 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | K=1.29 104.5 | 2.2500 | -3.45 | 53.21 | 0.065 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 4.14 | 3.85 | K=1.17 90.6 | 0.2706 | -2.01 | 5.60 | 0.359 ¹ |
| T6 | 81.5 - 61.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | K=1.00 104.5 | 2.2500 | -4.43 | 53.21 | 0.083 ¹ |
| T7 | 61.5 - 41.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | K=1.17 104.5 | 2.2500 | -3.51 | 53.21 | 0.066 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 4.14 | 3.85 | K=1.17 90.6 | 0.2706 | -1.79 | 5.60 | 0.319 ¹ |
| T9 | 21.5 - 6.5 | L2 1/2x2 1/2x1/2 | 4.11 | 3.58 | K=1.00 104.1 K=1.18 | 2.2500 | -1.54 | 53.38 | 0.029 ¹ |

¹ P_u / φP_n controls

Horizontal Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|------------------|---------|----------------------|--------------------------|----------------------|---------------------|----------------------|---------------------------------|
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 96.1 | 2.2500 | -0.74 | 67.12 | 0.011 ¹ |
| T5 | 101.5 - 81.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | K=1.33 96.1 | 2.2500 | -0.75 | 67.12 | 0.011 ¹ |
| T10 | 6.5 - 1.5 | C12x20.7 | 1.70 | 1.47 | K=1.33 22.0 K=1.00 | 6.0900 | -0.01 | 192.35 | 0.000 ¹ |

¹ P_u / φP_n controls

Top Girt Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|-----------------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 3.41 | 2.96 | 111.7 K=1.08 | 0.6211 | -0.11 | 13.58 | 0.008 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.90 | 6.41 | 0.141 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 3.41 | 2.96 | 105.1 K=1.17 | 0.7150 | -0.15 | 16.80 | 0.009 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 96.1 K=1.33 | 2.2500 | -1.39 | 57.47 | 0.024 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.05 | 6.41 | 0.007 ¹ |
| T6 | 81.5 - 61.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 96.1 K=1.33 | 2.2500 | -0.73 | 57.47 | 0.013 ¹ |
| T7 | 61.5 - 41.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -1.60 | 6.41 | 0.249 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.71 | 6.41 | 0.110 ¹ |
| T9 | 21.5 - 6.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 96.1 K=1.33 | 2.2500 | -0.16 | 57.47 | 0.003 ¹ |

¹ P_u / φP_n controls

Bottom Girt Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|-----------------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 3.41 | 2.96 | 111.7 K=1.08 | 0.6211 | -0.62 | 13.58 | 0.046 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.80 | 6.41 | 0.124 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 3.41 | 2.96 | 105.1 K=1.17 | 0.7150 | -0.37 | 16.80 | 0.022 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 96.1 K=1.33 | 2.2500 | -0.20 | 57.47 | 0.004 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.57 | 6.41 | 0.088 ¹ |
| T7 | 61.5 - 41.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.79 | 6.41 | 0.124 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 K=1.00 | 0.2706 | -0.15 | 6.41 | 0.023 ¹ |
| T10 | 6.5 - 1.5 | C12x20.7 | 0.34 | 0.10 | 1.5 K=1.00 | 6.0900 | -3.27 | 197.29 | 0.017 ^{*1} |

* DL controls

¹ P_u / φP_n controls

Torque-Arm Bottom Design Data

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------------|---------|---------|----------------------|----------------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 (398) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.17 | 96.94 | 0.136 ¹ |
| T1 | 181.5 - 161.5 (399) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -14.15 | 96.94 | 0.146 ¹ |

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------------|---------|---------|----------------------|----------------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 (404) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.48 | 96.94 | 0.139 ¹ |
| T1 | 181.5 - 161.5 (405) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.15 | 96.94 | 0.136 ¹ |
| T1 | 181.5 - 161.5 (410) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.47 | 96.94 | 0.139 ¹ |
| T1 | 181.5 - 161.5 (411) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -14.08 | 96.94 | 0.145 ¹ |
| T3 | 141.5 - 121.5 (416) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.02 | 96.94 | 0.134 ¹ |
| T3 | 141.5 - 121.5 (417) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.17 | 96.94 | 0.136 ¹ |
| T3 | 141.5 - 121.5 (422) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.07 | 96.94 | 0.135 ¹ |
| T3 | 141.5 - 121.5 (423) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -12.97 | 96.94 | 0.134 ¹ |
| T3 | 141.5 - 121.5 (428) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -12.90 | 96.94 | 0.133 ¹ |
| T3 | 141.5 - 121.5 (429) | P4x.237 | 4.35 | 4.21 | 33.5 K=1.00 | 3.1741 | -13.04 | 96.94 | 0.135 ¹ |

¹ P_u / φP_n controls

Tension Checks

Leg Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|--------------|---------|----------------------|------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 | 1.7040 | 13.94 | 76.68 | 0.182 ¹ |
| T3 | 141.5 - 121.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 | 1.7040 | 5.73 | 76.68 | 0.075 ¹ |
| T5 | 101.5 - 81.5 | Pipe 2.5 STD | 20.00 | 2.35 | 29.7 | 1.7040 | 0.42 | 76.68 | 0.005 ¹ |

¹ P_u / φP_n controls

Diagonal Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 4.14 | 1.82 | 43.0 | 0.3779 | 2.53 | 16.44 | 0.154 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 4.14 | 3.85 | 90.6 | 0.2706 | 1.59 | 8.52 | 0.186 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 4.14 | 1.82 | 37.4 | 0.4484 | 2.67 | 19.50 | 0.137 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | 62.5 | 1.4063 | 3.01 | 61.17 | 0.049 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 4.14 | 3.85 | 90.6 | 0.2706 | 1.61 | 8.52 | 0.189 ¹ |
| T6 | 81.5 - 61.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | 62.5 | 1.4063 | 4.44 | 61.17 | 0.073 ¹ |
| T7 | 61.5 - 41.5 | L2 1/2x2 1/2x1/2 | 4.14 | 3.61 | 62.5 | 1.4063 | 3.32 | 61.17 | 0.054 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 4.14 | 3.85 | 90.6 | 0.2706 | 1.61 | 8.52 | 0.189 ¹ |
| T9 | 21.5 - 6.5 | L2 1/2x2 1/2x1/2 | 4.11 | 3.58 | 62.1 | 1.4063 | 1.15 | 61.17 | 0.019 ¹ |

¹ P_u / φP_n controls

Horizontal Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|------------------|---------|----------------------|------|----------------------|---------------------|----------------------|---------------------------------|
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 1.17 | 68.55 | 0.017 ¹ |
| T5 | 101.5 - 81.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 0.80 | 68.55 | 0.012 ¹ |
| T10 | 6.5 - 1.5 | C12x20.7 | 1.70 | 1.47 | 22.0 | 6.0900 | 0.02 | 197.32 | 0.000 ¹ |

¹ P_u / φP_n controls

Top Girt Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 3.41 | 2.96 | 70.9 | 0.3779 | 0.06 | 16.44 | 0.004 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.90 | 8.52 | 0.106 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 3.41 | 2.96 | 61.7 | 0.4484 | 0.46 | 19.50 | 0.023 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 1.67 | 61.17 | 0.027 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.35 | 8.52 | 0.041 ¹ |
| T6 | 81.5 - 61.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 0.99 | 61.17 | 0.016 ¹ |
| T7 | 61.5 - 41.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 1.85 | 8.52 | 0.217 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.82 | 8.52 | 0.096 ¹ |
| T9 | 21.5 - 6.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 0.31 | 61.17 | 0.005 ¹ |
| T10 | 6.5 - 1.5 | C12x20.7 | 3.07 | 2.83 | 42.5 | 6.0900 | 8.47 | 197.32 | 0.043 ¹ |

* DL controls

¹ P_u / φP_n controls

Bottom Girt Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-------------------|---------|----------------------|------|----------------------|---------------------|----------------------|---------------------------------|
| T1 | 181.5 - 161.5 | L1 3/4x1 3/4x3/16 | 3.41 | 2.96 | 70.9 | 0.3779 | 0.59 | 16.44 | 0.036 ¹ |
| T2 | 161.5 - 141.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.74 | 8.52 | 0.087 ¹ |
| T3 | 141.5 - 121.5 | L2x2x3/16 | 3.41 | 2.96 | 61.7 | 0.4484 | 0.86 | 19.50 | 0.044 ¹ |
| T4 | 121.5 - 101.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 0.55 | 61.17 | 0.009 ¹ |
| T5 | 101.5 - 81.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.64 | 8.52 | 0.075 ¹ |
| T6 | 81.5 - 61.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 3.88 | 61.17 | 0.063 ¹ |
| T7 | 61.5 - 41.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.91 | 8.52 | 0.107 ¹ |
| T8 | 41.5 - 21.5 | TS1.5x16ga | 3.41 | 3.17 | 74.7 | 0.2706 | 0.24 | 8.52 | 0.028 ¹ |
| T9 | 21.5 - 6.5 | L2 1/2x2 1/2x1/2 | 3.41 | 2.93 | 51.5 | 1.4063 | 4.32 | 61.17 | 0.071 ¹ |

¹ P_u / φP_n controls

Top Guy Pull-Off Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L _u ft | KI/r | A in ² | P _u K | φP _n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-----------------|-----------|---------|----------------------|-------|----------------------|---------------------|----------------------|---------------------------------|
| T6 | 81.5 - 61.5 | 4 1/2x3/8 | 3.41 | 3.17 | 351.4 | 1.0547 | 2.91 | 45.88 | 0.063 ¹ |

¹ P_u / φP_n controls

Top Guy Pull-Off Bending Design Data

| Section No. | Elevation ft | Size | M_{ux} kip-ft | ϕM_{nx} kip-ft | Ratio $\frac{M_{ux}}{\phi M_{nx}}$ | M_{uy} kip-ft | ϕM_{ny} kip-ft | Ratio $\frac{M_{uy}}{\phi M_{ny}}$ |
|-------------|-----------------|-----------|--------------------|-------------------------|---------------------------------------|--------------------|-------------------------|---------------------------------------|
| T6 | 81.5 - 61.5 | 4 1/2x3/8 | 0.00 | 5.13 | 0.000 | 0.00 | 0.43 | 0.000 |

Top Guy Pull-Off Interaction Design Data

| Section No. | Elevation ft | Size | Ratio $\frac{P_u}{\phi P_n}$ | Ratio $\frac{M_{ux}}{\phi M_{nx}}$ | Ratio $\frac{M_{uy}}{\phi M_{ny}}$ | Comb. Stress Ratio | Allow. Stress Ratio | Criteria |
|-------------|-----------------|-----------|---------------------------------|---------------------------------------|---------------------------------------|--------------------------|---------------------------|----------|
| T6 | 81.5 - 61.5 | 4 1/2x3/8 | 0.063 | 0.000 | 0.000 | 0.063 ¹ | 1.050 | 4.8.1 |

¹ $P_u / \phi P_n$ controls

Torque-Arm Top Design Data

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in ² | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------------|---------|-----------|-------------|--------|------------------------|------------|-----------------|---------------------------------|
| T1 | 181.5 - 161.5 (396) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.36 | 102.84 | 0.130 ¹ |
| T1 | 181.5 - 161.5 (397) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.37 | 102.84 | 0.130 ¹ |
| T1 | 181.5 - 161.5 (402) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.45 | 102.84 | 0.131 ¹ |
| T1 | 181.5 - 161.5 (403) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.45 | 102.84 | 0.131 ¹ |
| T1 | 181.5 - 161.5 (408) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.49 | 102.84 | 0.131 ¹ |
| T1 | 181.5 - 161.5 (409) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 13.50 | 102.84 | 0.131 ¹ |
| T3 | 141.5 - 121.5 (414) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.34 | 102.84 | 0.120 ¹ |
| T3 | 141.5 - 121.5 (415) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.32 | 102.84 | 0.120 ¹ |
| T3 | 141.5 - 121.5 (420) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.24 | 102.84 | 0.119 ¹ |
| T3 | 141.5 - 121.5 (421) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.38 | 102.84 | 0.120 ¹ |
| T3 | 141.5 - 121.5 (426) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.25 | 102.84 | 0.119 ¹ |
| T3 | 141.5 - 121.5 (427) | P4x.237 | 3.67 | 3.55 | 28.2 | 3.1741 | 12.35 | 102.84 | 0.120 ¹ |

¹ $P_u / \phi P_n$ controls

Torque-Arm Bottom Design Data

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in ² | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------------|---------|-----------|-------------|--------|------------------------|------------|-----------------|---------------------------------|
| T1 | 181.5 - 161.5 (398) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.64 | 102.84 | 0.006 ¹ |

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------------|---------|---------|-------------|--------|-------------|------------|-----------------|---------------------------------|
| T1 | 181.5 - 161.5 (399) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.70 | 102.84 | 0.007 ¹ |
| T1 | 181.5 - 161.5 (404) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.72 | 102.84 | 0.007 ¹ |
| T1 | 181.5 - 161.5 (405) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.74 | 102.84 | 0.007 ¹ |
| T1 | 181.5 - 161.5 (410) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.65 | 102.84 | 0.006 ¹ |
| T1 | 181.5 - 161.5 (411) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 0.76 | 102.84 | 0.007 ¹ |
| T3 | 141.5 - 121.5 (416) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.43 | 102.84 | 0.024 ¹ |
| T3 | 141.5 - 121.5 (417) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.50 | 102.84 | 0.024 ¹ |
| T3 | 141.5 - 121.5 (422) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.56 | 102.84 | 0.025 ¹ |
| T3 | 141.5 - 121.5 (423) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.47 | 102.84 | 0.024 ¹ |
| T3 | 141.5 - 121.5 (428) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.41 | 102.84 | 0.023 ¹ |
| T3 | 141.5 - 121.5 (429) | P4x.237 | 4.35 | 4.21 | 33.5 | 3.1741 | 2.46 | 102.84 | 0.024 ¹ |

¹ $P_u / \phi P_n$ controls

Section Capacity Table

| Section No. | Elevation ft | Component Type | Size | Critical Element | P K | ϕP_{allow} K | % Capacity | Pass Fail |
|-------------|-----------------|-------------------|-------------------|---------------------|--------|-----------------------|------------------|--------------|
| T1 | 181.5 - 161.5 | Leg | Pipe 2.5 STD | 3 | -15.17 | 71.89 | 21.1 | Pass |
| T2 | 161.5 - 141.5 | Leg | Pipe 2.5 STD | 58 | -22.20 | 62.19 | 35.7 | Pass |
| T3 | 141.5 - 121.5 | Leg | Pipe 2.5 STD | 91 | -37.93 | 75.48 | 50.3 | Pass |
| T4 | 121.5 - 101.5 | Leg | Pipe 2.5 STD | 148 | -42.89 | 75.48 | 56.8 | Pass |
| T5 | 101.5 - 81.5 | Leg | Pipe 2.5 STD | 202 | -43.56 | 75.48 | 57.7 | Pass |
| T6 | 81.5 - 61.5 | Leg | Pipe 2.5 STD | 257 | -49.68 | 62.19 | 79.9 | Pass |
| T7 | 61.5 - 41.5 | Leg | Pipe 2.5 STD | 291 | -53.89 | 62.19 | 86.7 | Pass |
| T8 | 41.5 - 21.5 | Leg | Pipe 2.5 STD | 324 | -52.98 | 59.23 | 89.5 | Pass |
| T9 | 21.5 - 6.5 | Leg | Pipe 2.5 STD | 357 | -54.18 | 59.89 | 90.5 | Pass |
| T10 | 6.5 - 1.5 | Leg | Pipe 2.5 STD | 384 | -58.76 | 72.64 | 80.9 | Pass |
| T1 | 181.5 - 161.5 | Diagonal | L1 3/4x1 3/4x3/16 | 31 | 2.53 | 17.26 | 14.6 | Pass |
| T2 | 161.5 - 141.5 | Diagonal | TS1.5x16ga | 69 | -1.72 | 5.88 | 42.1 (b) 29.3 | Pass |
| T3 | 141.5 - 121.5 | Diagonal | L2x2x3/16 | 113 | 2.67 | 20.48 | 36.9 (b) 13.0 | Pass |
| T4 | 121.5 - 101.5 | Diagonal | L2 1/2x2 1/2x1/2 | 199 | -3.45 | 55.87 | 41.0 (b) 6.2 | Pass |
| T5 | 101.5 - 81.5 | Diagonal | TS1.5x16ga | 212 | -2.01 | 5.88 | 23.8 (b) 34.2 | Pass |
| T6 | 81.5 - 61.5 | Diagonal | L2 1/2x2 1/2x1/2 | 273 | -4.43 | 55.87 | 37.4 (b) 7.9 | Pass |
| T7 | 61.5 - 41.5 | Diagonal | L2 1/2x2 1/2x1/2 | 320 | -3.51 | 55.87 | 30.7 (b) 6.3 | Pass |
| T8 | 41.5 - 21.5 | Diagonal | TS1.5x16ga | 353 | -1.79 | 5.88 | 24.2 (b) 30.4 | Pass |
| T9 | 21.5 - 6.5 | Diagonal | L2 1/2x2 1/2x1/2 | 366 | -1.54 | 56.05 | 37.5 (b) 2.8 | Pass |
| T4 | 121.5 - 101.5 | Horizontal | L2 1/2x2 1/2x1/2 | 174 | 1.17 | 71.98 | 10.6 (b) 1.6 | Pass |
| T5 | 101.5 - 81.5 | Horizontal | L2 1/2x2 1/2x1/2 | 227 | 0.80 | 71.98 | 8.1 (b) 1.1 | Pass |
| T10 | 6.5 - 1.5 | Horizontal | C12x20.7 | 391 | 0.02 | 207.18 | 5.5 (b) 1.0 | Pass |
| T1 | 181.5 - 161.5 | Top Girt | L1 3/4x1 3/4x3/16 | 4 | -0.11 | 14.26 | 0.8 1.2 (b) | Pass |


| Section No. | Elevation ft | Component Type | Size | Critical Element | P K | ϕP_{allow} K | % Capacity | Pass Fail | |
|-------------|---------------|---------------------------|-------------------|------------------|--------|--------------------|------------------|-----------|------|
| T2 | 161.5 - 141.5 | Top Girt | TS1.5x16ga | 61 | -0.90 | 6.73 | 13.4 21.0 (b) | Pass | |
| T3 | 141.5 - 121.5 | Top Girt | L2x2x3/16 | 96 | 0.46 | 20.48 | 2.2 7.0 (b) | Pass | |
| T4 | 121.5 - 101.5 | Top Girt | L2 1/2x2 1/2x1/2 | 153 | 1.67 | 64.23 | 2.6 11.5 (b) | Pass | |
| T5 | 101.5 - 81.5 | Top Girt | TS1.5x16ga | 205 | 0.35 | 8.95 | 3.9 8.1 (b) | Pass | |
| T6 | 81.5 - 61.5 | Top Girt | L2 1/2x2 1/2x1/2 | 259 | 0.99 | 64.23 | 1.5 6.8 (b) | Pass | |
| T7 | 61.5 - 41.5 | Top Girt | TS1.5x16ga | 293 | -1.60 | 6.73 | 23.8 43.2 (b) | Pass | |
| T8 | 41.5 - 21.5 | Top Girt | TS1.5x16ga | 326 | -0.71 | 6.73 | 10.5 19.0 (b) | Pass | |
| T9 | 21.5 - 6.5 | Top Girt | L2 1/2x2 1/2x1/2 | 360 | 0.31 | 64.23 | 0.5 2.1 (b) | Pass | |
| T10 | 6.5 - 1.5 | Top Girt | C12x20.7 | 386 | 8.47 | 197.32 | 4.3 | Pass | |
| T1 | 181.5 - 161.5 | Bottom Girt | L1 3/4x1 3/4x3/16 | 8 | -0.62 | 14.26 | 4.4 9.8 (b) | Pass | |
| T2 | 161.5 - 141.5 | Bottom Girt | TS1.5x16ga | 65 | -0.80 | 6.73 | 11.8 17.2 (b) | Pass | |
| T3 | 141.5 - 121.5 | Bottom Girt | L2x2x3/16 | 97 | 0.86 | 20.48 | 4.2 13.3 (b) | Pass | |
| T4 | 121.5 - 101.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 156 | 0.55 | 64.23 | 0.9 3.8 (b) | Pass | |
| T5 | 101.5 - 81.5 | Bottom Girt | TS1.5x16ga | 209 | -0.57 | 6.73 | 8.4 14.8 (b) | Pass | |
| T6 | 81.5 - 61.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 262 | 3.88 | 64.23 | 6.0 26.7 (b) | Pass | |
| T7 | 61.5 - 41.5 | Bottom Girt | TS1.5x16ga | 296 | -0.79 | 6.73 | 11.8 21.2 (b) | Pass | |
| T8 | 41.5 - 21.5 | Bottom Girt | TS1.5x16ga | 329 | 0.24 | 8.95 | 2.7 5.6 (b) | Pass | |
| T9 | 21.5 - 6.5 | Bottom Girt | L2 1/2x2 1/2x1/2 | 362 | 4.32 | 64.23 | 6.7 29.8 (b) | Pass | |
| T10 | 6.5 - 1.5 | Bottom Girt | C12x20.7 | 388 | -3.26 | 197.29 | 6.4 | Pass | |
| T1 | 181.5 - 161.5 | Guy A@169.154 | 9/16 | 407 | 9.63 | 22.05 | 43.7 | Pass | |
| T3 | 141.5 - 121.5 | Guy A@129.154 | 9/16 | 425 | 9.65 | 22.05 | 43.8 | Pass | |
| T6 | 81.5 - 61.5 | Guy A@62.1146 | 3/4 | 435 | 13.89 | 36.73 | 37.8 | Pass | |
| T1 | 181.5 - 161.5 | Guy B@169.154 | 9/16 | 401 | 9.46 | 22.05 | 42.9 | Pass | |
| T3 | 141.5 - 121.5 | Guy B@129.154 | 9/16 | 418 | 9.36 | 22.05 | 42.5 | Pass | |
| T6 | 81.5 - 61.5 | Guy B@62.1146 | 3/4 | 434 | 13.78 | 36.73 | 37.5 | Pass | |
| T1 | 181.5 - 161.5 | Guy C@169.154 | 9/16 | 394 | 9.32 | 22.05 | 42.3 | Pass | |
| T3 | 141.5 - 121.5 | Guy C@129.154 | 9/16 | 412 | 9.60 | 22.05 | 43.5 | Pass | |
| T6 | 81.5 - 61.5 | Guy C@62.1146 | 3/4 | 430 | 13.52 | 36.73 | 36.8 | Pass | |
| T6 | 81.5 - 61.5 | Top Guy Pull-Off@62.1146 | 4 1/2x3/8 | 431 | 2.91 | 48.17 | 6.0 | Pass | |
| T1 | 181.5 - 161.5 | Torque Arm Top@169.154 | P4x.237 | 409 | 13.50 | 107.98 | 12.5 | Pass | |
| T3 | 141.5 - 121.5 | Torque Arm Top@129.154 | P4x.237 | 421 | 12.38 | 107.98 | 11.5 | Pass | |
| T1 | 181.5 - 161.5 | Torque Arm Bottom@169.154 | P4x.237 | 399 | -14.15 | 101.79 | 13.9 | Pass | |
| T3 | 141.5 - 121.5 | Torque Arm Bottom@129.154 | P4x.237 | 417 | -13.17 | 101.79 | 12.9 | Pass | |
| | | | | | | | Summary | | |
| | | | | | | | Leg (T9) | 90.5 | Pass |
| | | | | | | | Diagonal (T1) | 42.1 | Pass |
| | | | | | | | Horizontal (T4) | 8.1 | Pass |
| | | | | | | | Top Girt (T7) | 43.2 | Pass |
| | | | | | | | Bottom Girt (T9) | 29.8 | Pass |
| | | | | | | | Guy A (T3) | 43.8 | Pass |
| | | | | | | | Guy B (T1) | 42.9 | Pass |
| | | | | | | | Guy C (T3) | 43.5 | Pass |
| | | | | | | | Top Guy Pull-Off | 6.0 | Pass |

| Section No. | Elevation ft | Component Type | Size | Critical Element | P K | $\phi P_{allow} / K$ | % Capacity | Pass Fail |
|-------------|--------------|----------------|------|------------------|-----|---------------------------|-------------|-------------|
| | | | | | | (T6) Torque Arm Top | 12.5 | Pass |
| | | | | | | (T1) Torque Arm Bottom | 13.9 | Pass |
| | | | | | | (T1) Bolt Checks | 43.2 | Pass |
| | | | | | | RATING = | 90.5 | Pass |

APPENDIX B
BASE LEVEL DRAWING

Feed Line Plan

— Round
 — Flat
 — App In Face
 — App Out Face



| | | | | |
|---|----------------------------------|---------------------------------|-------------------------------------|------------------------|
|  | BLACK & VEATCH | Black & Veatch Corp. | Job: ES-008 MadisonAWC | |
| | Building a world of difference.® | 6800 W. 115th St., Suite 2292 | Project: 403093 (MadisonAWC) | |
| | | Overland Park, KS 66211 | Client: | Drawn by: Anup Chitale |
| | | Phone: (913) 458-6909 | Code: TIA-222-H | Date: 02/20/20 |
| | | FAX: (913) 458-8136 | Path: | App'd: |
| | | | Scale: NTS | |
| | | | Dwg No. E-7 | |

APPENDIX C
ADDITIONAL CALCULATIONS

Guyed Anchor Block Foundation

Checks capacity of anchor blocks for a guyed tower.

| |
|------------------------|
| ES-008 |
| Madison AWC |
| Location: <i>Inner</i> |

TIA-222 Revision: H

| Design Reactions | | |
|--|--------|------|
| Shear, S: | 13.00 | kips |
| Uplift, Ua: | 5.00 | kips |
| Resultant Force, Rf: | 13.9 | kips |
| Tower Height, H: | 181.50 | ft |
| Guy Anchor Radius, R: | 150.00 | ft |
| Resultant Angle to Horizontal, θ: | 21.0 | deg |

| Guy Anchor Properties | | |
|--|-----|-----------------|
| Depth to Bottom of Deadman, Da: | 6.7 | ft |
| Anchor Width, Wa: | 4.1 | ft |
| Anchor Thickness, Ta: | 2.3 | ft |
| Anchor Length, La: | 7.3 | ft |
| Concrete Volume, Vc: | 2.5 | yd ³ |
| Toe Width, toe: | 0 | ft |
| Guyed Anchor Top Rebar Size, Sat: | 4 | |
| No. of Bars in Top of Block: | 3 | |
| Guyed Anchor Front Rebar Size, Saf: | 4 | |
| No. of Bars in Front of Block: | 2 | |
| Stirrup Size: | 3 | |

| Material Properties | | |
|---------------------------------------|-------|-----|
| Rebar Grade, Fy: | 60 | ksi |
| Concrete Strength, F'c: | 4 | ksi |
| Wt. Avg. Concrete Density, δx: | 0.150 | kcf |
| Clear Cover, cc: | 4 | in |

| Design Checks | | | | |
|---|----------|--------|--------------|-------|
| | Capacity | Demand | Rating* | Check |
| <i>Lateral Capacity (kips):</i> | 23.06 | 13.00 | 53.7% | Pass |
| <i>Uplift Capacity (kips):</i> | 35.97 | 5.00 | 13.2% | Pass |
| <i>Lateral Flexural Capacity (ft*kips):</i> | 80.00 | 11.86 | 14.1% | Pass |
| <i>Uplift Flexural Capacity (ft*kips):</i> | 61.74 | 4.56 | 7.0% | Pass |

*Rating per TIA-222-H Section 15.5

| | |
|----------------------|--------------|
| Soil Rating: | 53.7% |
| Structural Rating: | 14.1% |
| Anchor Shaft Rating: | N/A |

| | | |
|-------------------------------|------|----|
| Neglect Depth, Neg: | 3.33 | ft |
| Groundwater Level, gw: | N/A | ft |

| Soil Properties: | No. of Soil Layers? | | 1 | | | |
|------------------|---------------------|---------|--------|-------|-------------------|--------------|
| Layer | φ, deg | cu, ksf | δ, pcf | d, ft | Ultimate fs (ksf) | N (blows/ft) |
| 1 | 30 | | 110 | 6.70 | | |

*key:

cu = Cohesion / Undrained Shear Strength
δ = Buoyant Soil Unit Weight

d = Depth to Bottom of Layer

Ultimate *fs* = Geotechnical Report-provided skin friction / adhesion

N = SPT Blow Count

| | | | | |
|----------------------------------|---|----------------|--------|-----|
| | $R_{END} = 2 \cdot Ca \cdot A_{end} \cdot \cos\theta$ | $R_{END} =$ | 0.00 | kip |
| Total Lateral Resistance: | $\Phi R_n = \Phi \cdot (R_p + R_{TOP} + R_{END})$ | $\Phi R_n =$ | 23.06 | kip |
| | | RATING: | 56.37% | |

UPLIFT RESISTANCE

| | | | | |
|---|----------------------------|------------|-------|-----|
| Soil Interaction Reduction Factor: | $\Phi_s = 0.75$ | $\Phi_s =$ | 0.75 | |
| Dead Load Reduction Factor: | $\Phi_d = 0.9$ | $\Phi_d =$ | 0.9 | |
| Weight of Concrete: | $W_c = V_c \cdot \delta_x$ | $W_c =$ | 10.33 | kip |

COHESIVE SOIL (CCI Foundation Criteria Section 7.1.3)

| | | | | |
|-----------------------------------|---|------------------|------|-----|
| Perimeter of Top of Block: | $P_o = 2 \cdot Wa + 2 \cdot La$ | $P_o =$ | 22.8 | ft |
| Soil Shear: | Soil Shear = $(C_u \cdot P_o \cdot D_f) / 2$ | Soil Shear = | 0.00 | kip |
| Concrete Adhesion (Front): | Front Adhesion = $Ca \cdot Ta \cdot La$ (Ca is previously adjusted if Neg > (Da-Ta)) | Front Adhesion = | 0.00 | kip |
| Concrete Adhesion (Ends): | End Adhesion = $2 \cdot Ca \cdot Ta \cdot Wa \cdot \sin(\phi)$ (Ca is previously adjusted if Neg > (Da-Ta)) | End Adhesion = | 0.00 | kip |

COHESIONLESS SOIL (CCI Foundation Criteria Section 7.1.4)

| | | | | |
|-------------------------------|---|------------------|------|-----|
| Skin Friction (Front): | Front Friction = $fs \cdot Ta \cdot La$ (fs is previously adjusted if Neg > (Da-Ta)) | Front Friction = | 0.00 | kip |
| Skin Friction (Ends): | End Friction = $2 \cdot fs \cdot Ta \cdot Wa \cdot \sin(\phi)$ (fs is previously adjusted if Neg > (Da-Ta)) | End Friction = | 0.00 | kip |

SILTY SOIL (CCI Foundation Criteria Section 4.6.3 & 7.1.3)

| | | | | |
|-----------------------------------|---|------------------|------|-----|
| Concrete Adhesion (Front): | Front Adhesion = $fs \cdot Ta \cdot La$ (fs is previously adjusted if Neg > (Da-Ta)) | Front Adhesion = | 0.00 | kip |
| Concrete Adhesion (Ends): | End Adhesion = $2 \cdot fs \cdot Ta \cdot Wa \cdot \sin(\phi)$ (fs is previously adjusted if Neg > (Da-Ta)) | End Adhesion = | 0.00 | kip |

| | | | | |
|---------------------------|---|----------------|--------|-----|
| Uplift Resistance: | $\Phi R_n = \Phi_d \cdot (W_s - W_{wedges} + W_c) + \Phi_s \cdot (Cohesion + W_{wedges} + \Sigma Adhesive)$ | $R_n =$ | 35.97 | kip |
| | | RATING: | 13.90% | |

ANCHOR REINFORCEMENT (Lateral)

| | | | | |
|--|---|--------------------|---------------|-----------------|
| Modulus of Elasticity of Steel: | $E_s = 29000$ ksi | $E_s =$ | 29000 | ksi |
| Beta Factor: | $\beta = \begin{cases} IF(F'c \leq 4000, 0.85) \\ IF(F'c > 8000, 0.65) \\ Otherwise (0.85 - ((F'c - 4000) / 1000) * 0.05) \end{cases}$ | $\beta =$ | 0.85 | |
| Effective Beam Depth: | $dc_s = Wa - cc - stirrups - db/2$ | $dc_s =$ | 44.58 | in |
| | Rebar Size: $s_s = 4$ | Rebar Diameter: | $d_b_s = 0.5$ | in |
| | Number of Rebar: $m_s = 2$ | Rebar Area: | $A_b_s = 0.2$ | in ² |
| Total Steel Area: | $Atot_s = m_s \cdot A_b_s$ | $Atot_s =$ | 0.40 | in ² |
| Depth of Equivalent Rectangular Stress Block: | $a_s = Atot_s \cdot F_y / (0.85 \cdot F'c \cdot Ta)$ | $a_s =$ | 0.26 | in |
| Distance from Top to Neutral Axis: | $c_s = a_s / \beta$ | $c_s =$ | 0.30 | in |
| Strain in Steel: | $\epsilon_{s_s} = 0.003 \cdot (dc - c) / c$ | $\epsilon_{s_s} =$ | 0.44144 | in/in |
| Compression-Controlled Strain Limit:: | $\epsilon_{c_s} = F_y / E_s$ | $\epsilon_{c_s} =$ | 0.00207 | in/in |
| Tension-Controlled Strain Limit:: | $\epsilon_{t_s} = 0.005$ | $\epsilon_{t_s} =$ | 0.00500 | in/in |
| Flexure Strength Reduction Factor: | $\phi_{flex_s} = \begin{cases} \text{if}(\text{strain}_s \geq \text{strain}_t) = 0.90 \\ \text{if}(\text{strain}_s \leq \text{strain}_c) = 0.65 \\ \text{if}(\text{strain}_c < \text{strain}_s < \text{strain}_t) = 0.65 + (0.90 - 0.65) \cdot (\text{strain}_s - \text{strain}_c) / (\text{strain}_t - \text{strain}_c) \end{cases}$ | $\phi_{flex_s} =$ | 0.9 | |
| Applied Uniform Load: | $w_s = S / La$ | $w_s =$ | 1.781 | kip/ft |
| Factored Applied Moment: | $Mu_s = (w \cdot La^2) / 8$ | $Mu_s =$ | 11.86 | ft*kip |
| Nominal Moment Capacity: | $Mn_s = Atot \cdot F_y \cdot (dc - a/2)$ | $Mn_s =$ | 88.89 | ft*kip |
| Design Moment Capacity: | $\Phi Mn_s = \phi_{flex} \cdot Mn_u$ | $\Phi Mn_s =$ | 80.00 | ft*kip |
| | | RATING: | 14.83% | |

ANCHOR REINFORCEMENT (Uplift)

| | | | | |
|--|---|--------------------|-----------------|-----------------|
| <i>Effective Beam Depth:</i> | $dc_u = Ta - cc - stirrups - db/2$ | $dc_u =$ | 22.98 | in |
| | Rebar Size: $s_u =$ 4 | Rebar Diameter: | $d_{b_u} =$ 0.5 | in |
| | Number of Rebar: $m_u =$ 3 | Rebar Area: | $A_{b_u} =$ 0.2 | in ² |
| <i>Total Steel Area:</i> | $Atot_u = m_u * Ab_u$ | $Atot_u =$ | 0.60 | in ² |
| <i>Depth of Equivalent Rectangular Stress Block:</i> | $a_u = Atot * Fy / (0.85 * F'c * Wa)$ | $a_u =$ | 0.22 | in |
| <i>Distance from Top to Neutral Axis:</i> | $c_u = a/\beta$ | $c_u =$ | 0.25 | in |
| <i>Strain in Steel:</i> | $\epsilon_{s_u} = 0.003 * (dc-c) / c$ | $\epsilon_{s_u} =$ | 0.26923 | in/in |
| <i>Compression-Controlled Strain Limit:</i> | $\epsilon_{c_u} = Fy / Es$ | $\epsilon_{c_u} =$ | 0.00207 | in/in |
| <i>Tension-Controlled Strain Limit:</i> | $\epsilon_{t_u} = 0.005$ | $\epsilon_{t_u} =$ | 0.00500 | in/in |
| <i>Flexure Strength Reduction Factor:</i> | $\phi_{flex_u} =$ if(strain_s >= strain_t) = 0.90 if(strain_s <= strain_c) = 0.65 if(strain_c < strain_s < strain_t) = 0.65 + (0.90 - 0.65)*(strain_s - strain_c) / (strain_t - strain_c) | $\phi_{flex_u} =$ | 0.9 | |
| <i>Applied Uniform Load:</i> | $w_u = Ua / La$ | $w_u =$ | 0.685 | kip/ft |
| <i>Factored Applied Moment:</i> | $Mu_u = (w * La^2) / 8$ | $Mu_u =$ | 4.56 | ft*kip |
| <i>Nominal Moment Capacity:</i> | $Mn_u = Atot * Fy * (dc-a/2)$ | $Mn_u =$ | 68.60 | ft*kip |
| <i>Design Moment Capacity:</i> | $\Phi Mn_u = \phi_{flex} * Mn_u$ | $\Phi Mn_u =$ | 61.74 | ft*kip |
| | | RATING: | 7.39% | |

Guyed Anchor Block Foundation

Checks capacity of anchor blocks for a guyed tower.

| | |
|-----------|-------------|
| | ES-008 |
| | Madison AWC |
| Location: | Outer |

TIA-222 Revision: H

| Design Reactions | | |
|--|--------|------|
| Shear, S: | 29.00 | kips |
| Uplift, Ua: | 23.00 | kips |
| Resultant Force, Rf: | 37.0 | kips |
| Tower Height, H: | 181.50 | ft |
| Guy Anchor Radius, R: | 184.00 | ft |
| Resultant Angle to Horizontal, θ: | 38.4 | deg |

| Guy Anchor Properties | | |
|--|-----|-----------------|
| Depth to Bottom of Deadman, Da: | 7.5 | ft |
| Anchor Width, Wa: | 4.1 | ft |
| Anchor Thickness, Ta: | 2.5 | ft |
| Anchor Length, La: | 8.9 | ft |
| Concrete Volume, Vc: | 3.4 | yd ³ |
| Toe Width, toe: | 0 | ft |
| Guyed Anchor Top Rebar Size, Sat: | 4 | |
| No. of Bars in Top of Block: | 3 | |
| Guyed Anchor Front Rebar Size, Saf: | 4 | |
| No. of Bars in Front of Block: | 2 | |
| Stirrup Size: | 3 | |

| Material Properties | | |
|---------------------------------------|-------|-----|
| Rebar Grade, Fy: | 60 | ksi |
| Concrete Strength, F'c: | 4 | ksi |
| Wt. Avg. Concrete Density, δx: | 0.150 | kcf |
| Clear Cover, cc: | 4 | in |

| Design Checks | | | | |
|--------------------------------------|----------|--------|---------|-------|
| | Capacity | Demand | Rating* | Check |
| Lateral Capacity (kips): | 34.42 | 29.00 | 80.2% | Pass |
| Uplift Capacity (kips): | 50.44 | 23.00 | 43.4% | Pass |
| Lateral Flexural Capacity (ft*kips): | 79.99 | 32.26 | 38.4% | Pass |
| Uplift Flexural Capacity (ft*kips): | 68.18 | 25.59 | 35.7% | Pass |

*Rating per TIA-222-H Section 15.5

| | |
|----------------------|-------|
| Soil Rating: | 80.2% |
| Structural Rating: | 38.4% |
| Anchor Shaft Rating: | N/A |

| | | |
|-------------------------------|------|----|
| Neglect Depth, Neg: | 3.33 | ft |
| Groundwater Level, gw: | N/A | ft |

| Soil Properties: | No. of Soil Layers? | | 1 | | | |
|------------------|---------------------|---------|--------|-------|-------------------|--------------|
| Layer | φ, deg | cu, ksf | δ, pcf | d, ft | Ultimate fs (ksf) | N (blows/ft) |
| 1 | 30 | | 110 | 7.50 | | |

*key:

cu = Cohesion / Undrained Shear Strength
 δ = Buoyant Soil Unit Weight

d = Depth to Bottom of Layer

Ultimate fs = Geotechnical Report-provided skin friction / adhesion

N = SPT Blow Count

$$R_{END} = 2 * C_a * A_{end} * \cos\theta$$

$$R_{END} = 0.00 \text{ kip}$$

$$\text{Total Lateral Resistance: } \Phi R_n = \Phi * (R_p + R_{TOP} + R_{END})$$

$$\Phi R_n = 34.42 \text{ kip}$$

$$\text{RATING: } 84.26\%$$

UPLIFT RESISTANCE

Soil Interaction Reduction Factor:

$$\Phi_s = 0.75$$

$$\Phi_s = 0.75$$

Dead Load Reduction Factor:

$$\Phi_d = 0.9$$

$$\Phi_d = 0.9$$

Weight of Concrete:

$$W_c = V_c * \delta_x$$

$$W_c = 13.68 \text{ kip}$$

COHESIVE SOIL (CCI Foundation Criteria Section 7.1.3)

Perimeter of Top of Block:

$$P_o = 2 * W_a + 2 * L_a$$

$$P_o = 26 \text{ ft}$$

Soil Shear:

$$\text{Soil Shear} = (C_u * P_o * D_f) / 2$$

$$\text{Soil Shear} = 0.00 \text{ kip}$$

Concrete Adhesion (Front):

$$\text{Front Adhesion} = C_a * T_a * L_a \text{ (} C_a \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{Front Adhesion} = 0.00 \text{ kip}$$

Concrete Adhesion (Ends):

$$\text{End Adhesion} = 2 * C_a * T_a * W_a * \sin(\phi) \text{ (} C_a \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{End Adhesion} = 0.00 \text{ kip}$$

COHESIONLESS SOIL (CCI Foundation Criteria Section 7.1.4)

Skin Friction (Front):

$$\text{Front Friction} = f_s * T_a * L_a \text{ (} f_s \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{Front Friction} = 0.00 \text{ kip}$$

Skin Friction (Ends):

$$\text{End Friction} = 2 * f_s * T_a * W_a * \sin(\phi) \text{ (} f_s \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{End Friction} = 0.00 \text{ kip}$$

SILTY SOIL (CCI Foundation Criteria Section 4.6.3 & 7.1.3)

Concrete Adhesion (Front):

$$\text{Front Adhesion} = f_s * T_a * L_a \text{ (} f_s \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{Front Adhesion} = 0.00 \text{ kip}$$

Concrete Adhesion (Ends):

$$\text{End Adhesion} = 2 * f_s * T_a * W_a * \sin(\phi) \text{ (} f_s \text{ is previously adjusted if Neg > (Da-Ta))}$$

$$\text{End Adhesion} = 0.00 \text{ kip}$$

Uplift Resistance:

$$\Phi R_n = \Phi_d * (W_s - W_{wedges} + W_c) + \Phi_s * (\text{Cohesion} + W_{wedges} + \Sigma \text{ Adhesiv})$$

$$R_n = 50.44 \text{ kip}$$

$$\text{RATING: } 45.60\%$$

ANCHOR REINFORCEMENT (Lateral)

Modulus of Elasticity of Steel:

$$E_s = 29000 \text{ ksi}$$

$$E_s = 29000 \text{ ksi}$$

Beta Factor:

$$\beta = \begin{cases} \text{IF}(F'c \leq 4000, 0.85) \\ \text{IF}(F'c > 8000, 0.65) \\ \text{Otherwise } (0.85 - ((F'c - 4000) / 1000) * 0.05) \end{cases}$$

$$\beta = 0.85$$

Effective Beam Depth:

$$d_{c_s} = W_a - c_c - \text{stirrups} - d_b / 2$$

$$d_{c_s} = 44.58 \text{ in}$$

$$\text{Rebar Size: } s_s = 4$$

$$\text{Rebar Diameter: } d_b = 0.5 \text{ in}$$

$$\text{Number of Rebar: } m_s = 2$$

$$\text{Rebar Area: } A_b = 0.2 \text{ in}^2$$

Total Steel Area:

$$A_{tot_s} = m_s * A_b$$

$$A_{tot_s} = 0.40 \text{ in}^2$$

Depth of Equivalent Rectangular Stress Block:

$$a_s = A_{tot_s} * F_y / (0.85 * F'c * T_a)$$

$$a_s = 0.27 \text{ in}$$

Distance from Top to Neutral Axis:

$$c_s = a_s / \beta$$

$$c_s = 0.32 \text{ in}$$

Strain in Steel:

$$\epsilon_{s_s} = 0.003 * (d_c - c) / c$$

$$\epsilon_{s_s} = 0.41970 \text{ in/in}$$

Compression-Controlled Strain Limit::

$$\epsilon_{c_s} = F_y / E_s$$

$$\epsilon_{c_s} = 0.00207 \text{ in/in}$$

Tension-Controlled Strain Limit::

$$\epsilon_{t_s} = 0.005$$

$$\epsilon_{t_s} = 0.00500 \text{ in/in}$$

Flexure Strength Reduction Factor:

$$\phi_{flex_s} = \begin{cases} \text{if}(\text{strain}_s \geq \text{strain}_t) = 0.90 \\ \text{if}(\text{strain}_s \leq \text{strain}_c) = 0.65 \\ \text{if}(\text{strain}_c < \text{strain}_s < \text{strain}_t) = 0.65 + (0.90 - 0.65) * (\text{strain}_s - \text{strain}_c) / (\text{strain}_t - \text{strain}_c) \end{cases}$$

$$\phi_{flex_s} = 0.9$$

Applied Uniform Load:

$$w_s = S / L_a$$

$$w_s = 3.258 \text{ kip/ft}$$

Factored Applied Moment:

$$M_u_s = (w * L_a^2) / 8$$

$$M_u_s = 32.26 \text{ ft*kip}$$

Nominal Moment Capacity:

$$M_n_s = A_{tot_s} * F_y * (d_c - a / 2)$$

$$M_n_s = 88.88 \text{ ft*kip}$$

Design Moment Capacity:

$$\Phi M_n_s = \phi_{flex_s} * M_n_s$$

$$\Phi M_n_s = 79.99 \text{ ft*kip}$$

$$\text{RATING: } 40.33\%$$

ANCHOR REINFORCEMENT (Uplift)

| | | | | |
|--|---|--------------------|-----------------|-----------------|
| <i>Effective Beam Depth:</i> | $dc_u = Ta - cc - stirrups - db/2$ | $dc_u =$ | 25.38 | in |
| | Rebar Size: $s_u =$ 4 | Rebar Diameter: | $d_{b_u} =$ 0.5 | in |
| | Number of Rebar: $m_u =$ 3 | Rebar Area: | $A_{b_u} =$ 0.2 | in ² |
| <i>Total Steel Area:</i> | $Atot_u = m_u * Ab_u$ | $Atot_u =$ | 0.60 | in ² |
| <i>Depth of Equivalent Rectangular Stress Block:</i> | $a_u = Atot * Fy / (0.85 * F'c * Wa)$ | $a_u =$ | 0.25 | in |
| <i>Distance from Top to Neutral Axis:</i> | $c_u = a/\beta$ | $c_u =$ | 0.29 | in |
| <i>Strain in Steel:</i> | $\epsilon_{s_u} = 0.003 * (dc-c) / c$ | $\epsilon_{s_u} =$ | 0.26008 | in/in |
| <i>Compression-Controlled Strain Limit:</i> | $\epsilon_{c_u} = Fy / Es$ | $\epsilon_{c_u} =$ | 0.00207 | in/in |
| <i>Tension-Controlled Strain Limit:</i> | $\epsilon_{t_u} = 0.005$ | $\epsilon_{t_u} =$ | 0.00500 | in/in |
| <i>Flexure Strength Reduction Factor:</i> | $\phi_{flex_u} =$ if(strain_s >= strain_t) = 0.90 if(strain_s <= strain_c) = 0.65 if(strain_c < strain_s < strain_t) = 0.65 + (0.90 - 0.65)*(strain_s - strain_c) / (strain_t - strain_c) | $\phi_{flex_u} =$ | 0.9 | |
| <i>Applied Uniform Load:</i> | $w_u = Ua / La$ | $w_u =$ | 2.584 | kip/ft |
| <i>Factored Applied Moment:</i> | $Mu_u = (w * La^2) / 8$ | $Mu_u =$ | 25.59 | ft*kip |
| <i>Nominal Moment Capacity:</i> | $Mn_u = Atot * Fy * (dc-a/2)$ | $Mn_u =$ | 75.76 | ft*kip |
| <i>Design Moment Capacity:</i> | $\Phi Mn_u = \phi_{flex} * Mn_u$ | $\Phi Mn_u =$ | 68.18 | ft*kip |
| | | RATING: | 37.53% | |

Pier and Pad Foundation

| |
|------------|
| ES-008 |
| MadisonAWC |
| |

| | |
|-------------------|-------|
| TIA-222 Revision: | H |
| Tower Type: | Guyed |

| | |
|----------------------------------|--------------------------|
| Top & Bot. Pad Rein. Different?: | <input type="checkbox"/> |
| Block Foundation?: | <input type="checkbox"/> |

| Superstructure Analysis Reactions | | |
|--|--------|---------|
| Compression, P_{comp} : | 166.02 | kips |
| Base Shear, V_{u_comp} : | 1.43 | kips |
| | | |
| | | |
| Moment, M_u : | 0 | ft-kips |
| Tower Height, H : | 180 | ft |
| | | |
| | | |
| BP Dist. Above Fdn, bp_{dist} : | 0 | in |
| Bolt Circle / Bearing Plate Width, BC : | | in |

| Pier Properties | | |
|--|--------|----|
| Pier Shape: | Square | |
| Pier Diameter, dpier : | 2 | ft |
| Ext. Above Grade, E : | 1.5 | ft |
| Pier Rebar Size, Sc : | 5 | |
| Pier Rebar Quantity, mc : | 7 | |
| Pier Tie/Spiral Size, St : | 3 | |
| Pier Tie/Spiral Quantity, mt : | 7 | |
| Pier Reinforcement Type: | Tie | |
| Pier Clear Cover, cc_{pier} : | 3 | in |

| Pad Properties | | |
|--|-----|----|
| Depth, D : | 6.2 | ft |
| Pad Width, W : | 4.7 | ft |
| Pad Thickness, T : | 2 | ft |
| Pad Rebar Size (Bottom), Sp : | 5 | |
| Pad Rebar Quantity (Bottom), mp : | 7 | |
| Pad Clear Cover, cc_{pad} : | 3 | in |

| Material Properties | | |
|---|-----|-----|
| Rebar Grade, Fy : | 60 | ksi |
| Concrete Compressive Strength, F'c : | 3 | ksi |
| Dry Concrete Density, δc : | 150 | pcf |

| Soil Properties | | |
|--|--------|---------|
| Total Soil Unit Weight, γ : | 120 | pcf |
| Ultimate Gross Bearing, Qult : | 16.000 | ksf |
| Cohesion, Cu : | | ksf |
| Friction Angle, φ : | 30 | degrees |
| SPT Blow Count, N_{blows} : | 60 | |
| Base Friction, μ : | | |
| Neglected Depth, N : | 3.30 | ft |
| Foundation Bearing on Rock? | Yes | |
| Groundwater Depth, gw : | N/A | ft |

| Foundation Analysis Checks | | | | |
|---------------------------------------|----------|--------|---------|-------|
| | Capacity | Demand | Rating* | Check |
| | | | | |
| <i>Lateral (Sliding) (kips)</i> | 53.72 | 1.43 | 2.5% | Pass |
| <i>Bearing Pressure (ksf)</i> | 9.60 | 9.24 | 91.7% | Pass |
| <i>Overtuning (kip*ft)</i> | 41.55 | 11.01 | 26.5% | Pass |
| <i>Pier Flexure (Comp.) (kip*ft)</i> | 176.74 | 8.15 | 4.4% | Pass |
| | | | | |
| <i>Pier Compression (kip)</i> | 1909.44 | 170.12 | 8.5% | Pass |
| <i>Pad Flexure (kip*ft)</i> | 191.49 | 34.72 | 17.3% | Pass |
| <i>Pad Shear - 1-way (kips)</i> | 92.96 | 0.00 | 0.0% | Pass |
| <i>Pad Shear - 2-way (Comp) (ksi)</i> | 0.164 | 0.000 | 0.0% | Pass |
| <i>Flexural 2-way (Comp) (kip*ft)</i> | 382.98 | 4.89 | 1.2% | Pass |
| | | | | |
| | | | | |

*Rating per TIA-222-H Section 15.5

| | |
|---------------------|-------|
| Soil Rating*: | 91.7% |
| Structural Rating*: | 17.3% |

<--Toggle between Gross and Net

PHYSICAL PARAMETERS

| | | | | |
|--|---|----------------------|------|------|
| Pier Height Above Water Table: | $h_{pier_above} = (MIN(gw, D-T) + E)$ | $h_{pier_above} =$ | 5.7 | ft |
| Pier Height Below Water Table: | $h_{pier_below} = ((D-T) - MIN(gw, D-T))$ | $h_{pier_below} =$ | 0 | ft |
| Buoyant Weight of Pier: | $W_{pier} = (dpier^2) * hpier_above * \delta c / 1000 + (dpier^2) * hpier_below * (\delta c - 62.4) / 1000$ | $W_{pier} =$ | 3.42 | kips |
| Pad Height Above Water Table: | $h_{pad_above} = IF(gw <= D-T, 0, IF(gw > D, T, T - (D-gw)))$ | $h_{pad_above} =$ | 2 | ft |
| Pad Height Below Water Table: | $h_{pad_below} = (T - IF(gw <= D-T, 0, IF(gw > D, T, T - (D-gw))))$ | $h_{pad_below} =$ | 0 | ft |
| Buoyant Weight of Pad: | $W_{pad} = (W^2) * hpad_above * \delta c / 1000 + (W^2) * hpad_below * (\delta c - 62.4) / 1000$ | $W_{pad} =$ | 6.63 | kips |
| Concrete weight: | $W_c = V * \delta c$ | $W_c =$ | 10.0 | kips |
| Soil weight: | $W_s = (D - T) * (W^2 - dpier^2) * \gamma$ | $W_s =$ | 9.1 | kips |
| EIA/TIA-222 Load Factor: | $LF = 1$ | $LF =$ | 1.00 | |
| Soil Depth from Top of Pad to Mid. Layer (Cohesionless Soil): | $H_{cohesionless} = T / 2$ | $H_{cohesionless} =$ | 1.00 | ft |
| Soil Depth from Grade to Mid. Layer (Silty Soil): | $H_{silty} = (D-T) + T/2$ | $H_{silty} =$ | 5.20 | ft |

LATERAL RESISTANCE

| | | | | |
|--|--|------------------------|------------------------|--|
| Total Nominal Pp Resistance: | $P_{p_total} = Pp_pier * Ap_pier + Pp_pad * Ap_pad$ | $P_{p_total} =$ | 20.03 | kips |
| Factored Total Weight for Compression: | $P_{factored_comp} = \phi D * (Wc + Ws + Pcomp / 1.2)$ | $P_{factored_comp} =$ | 141.76 | kips |
| Nominal Base Friction Resistance (Comp): | $R_{s_comp} = P * TAN((2/3) * \phi)$ | $R_{s_comp} =$ | 51.60 | kips |
| Lateral Resistance (Comp): | $Va_comp = \Phi s * (Pp_total + Rs_comp)$ | $Va_comp =$ | 53.72 | kips |
| Check | $Va_comp = 53.72$ kips | \geq | $Vu_comp = 1.43$ kips | RATING: 2.66% OK |

PIER REINFORCEMENT

Pier / Column Compression

| | | | | |
|------------------------------------|---|--|---------------------|--|
| Pier Cross-Sectional Area: | $A_1 = dpier^2$ | $A_1 =$ | 576.00 | in ² |
| Support Area (2H:1V Slope): | $A_2 = (MIN(W, dpier + 4 * T))^2$ | $A_2 =$ | 3180.96 | in ² |
| Compressive Resistance (H/D < 3): | $\Phi P_{n1} = 0.65 * 0.85 * F'c * A_1 * MIN(\sqrt{(A_2/A_1)}, 2)$ | $\Phi P_{n1} =$ | 1909.44 | kips |
| Rebar: | $s_{pier} = 5$ $m_{pier} = 7$ | $d_{b_pier} = 0.625$ in $A_{b_pier} = 0.31$ in ² | | |
| Provided area of steel: | $A_{s_pier} = Ab_pier * m_pier$ | $A_{s_pier} =$ | 2.17 | in ² |
| Compressive Resistance (H/D >= 3): | $\Phi P_{n2} = 0.65 * 0.8 * (0.85 * (F'c) * (A_1 - A_{s_pier}) + ((F_y) * A_{s_pier}))$ | $\Phi P_{n2} =$ | 828.60 | kips |
| | $H/D = (D - T + E) / dpier$ | $H/D =$ | 2.85 | |
| Utilized Compressive Resistance: | $\Phi P_n = P_{n1}$ | $\Phi P_n =$ | 1909.44 | kips |
| Applied Compressive Force: | $P_u = Pcomp + 1.2 * Wpier$ | $P_u =$ | 170.12 | kips |
| Check | $\Phi P_n = 1909.44$ kips | \geq | $P_u = 170.12$ kips | RATING: 8.91% OK |

Pier Flexure

| | | | | |
|---------------------------------------|---------------------------------------|----------------------|-------------------------------------|--|
| Applied Moment to DSMC (Compression): | $M_{u_comp} = (D - T + E) * Vu + Mu$ | $M_{u_comp} =$ | 8.15 | ft-kips |
| Pier Moment Capacity (Compression): | $\Phi M_{n_comp} = \text{from DSMC}$ | $\Phi M_{n_comp} =$ | 176.74 | ft-kips |
| Check | $M_{u_comp} = 8.15$ ft-kips | \geq | $\Phi M_{n_comp} = 176.74$ ft-kips | RATING: 4.61% OK |

PAD REINFORCEMENT

Elastic Bearing Pressure for Soil Checks

| | | | | |
|---------------------|---|--------|-------|---------|
| Overturning Moment: | $Mo = M + Vu_comp * (D + E + bpdist/12)$ | $Mo =$ | 11.01 | ft-kips |
|---------------------|---|--------|-------|---------|

| | | | |
|-------------------------------|---|---------------------------|-----------------|
| Compressive Load for Bearing: | $P_{bearing} = Wc + Ws + P_{comp} / 1.2$ | $P_{bearing} = 157.51$ | kips |
| Load Eccentricity (0.9*D LC): | $ec_{0.9} = Mo / 0.9 * P_{bearing}$ | $ec_{0.9} = 0.08$ | ft $e \leq L/6$ |
| Load Eccentricity (1.2*D LC): | $ec_{1.2} = Mo / 1.2 * P_{bearing}$ | $ec_{1.2} = 0.06$ | ft $e \leq L/6$ |
| Elastic Section Modulus: | $S = W^3 / 6$ | $S = 17.30$ | ft ³ |
| Positive Pressure 0.9*D LC): | $P_{pos_0.9} = 0.9 * P_{bearing} / Area + Mo / S$ | $P_{pos_st_0.9} = 7.05$ | ksf |
| Positive Pressure (1.2*D LC): | $P_{pos_1.2} = 1.2 * P_{bearing} / Area + Mo / S$ | $P_{pos_st_1.2} = 9.19$ | ksf |
| Negative Pressure (0.9*D LC): | $P_{neg_0.9} = 0.9 * P_{bearing} / Area - Mo / S$ | $P_{neg_st_0.9} = 5.78$ | ksf |
| Negative Pressure (1.2*D LC): | $P_{neg_1.2} = 1.2 * P_{bearing} / Area - Mo / S$ | $P_{neg_st_1.2} = 7.92$ | ksf |
| Adjusted Pressure (0.9*D LC): | $Padj_{0.9} = 2 * 0.9 * P_{bearing} / (3 * W * (W/2 - ec_{0.9}))$ | $P_{adj_0.9} = 8.85$ | ksf |
| Adjusted Pressure (1.2*D LC): | $Padj_{1.2} = 2 * 1.2 * P_{bearing} / (3 * W * (W/2 - ec_{0.9}))$ | $P_{adj_1.2} = 11.70$ | ksf |
| Maximum Pressure (0.9*D LC): | $qu_{1,0.9} = IF(P_{neg} \geq 0, P_{pos}, Padj)$ | $qu_{st_0.9} = 7.05$ | ksf |
| Maximum Pressure (1.2*D LC): | $qu_{1,1.2} = IF(P_{neg} \geq 0, P_{pos}, Padj)$ | $qu_{st_1.2} = 9.19$ | ksf |

One-Way Shear

| | | | |
|--|--|--|--|
| Rebar: | $S_{pad} = 5$ $m_{pad} = 7$ | Equally spaced; bottom layer in one direction | $d_{b_pad} = 0.625$ in $A_{b_pad} = 0.31$ in ² |
| Effective depth: | $d_c = T - cc - 1.5 * db$ | | $d_c = 20.1$ in |
| Distance from Edge of Pad to Column Face: | $d' = W / 2 - dpier / 2$ | | $d' = 1.4$ ft |
| Distance from Edge of Pad to d_c from Column Face: | $d'' = d' - d_c / 12$ | | $d'' = 0.00$ ft |
| Distance to qs (0.9D LC): | $L'_{0.9} = (W / 2 - ec_{0.9}) * 3$ | | $L'_{0.9} = 6.82$ ft |
| Distance to qs (1.2D LC): | $L'_{1.2} = (W / 2 - ec_{1.2}) * 3$ | | $L'_{1.2} = 6.88$ ft |
| Slope of qs (0.9*D LC): | $sqs_{0.9} = IF(L' > W, (P_{pos} - P_{neg}) / W, qu / L')$ | | $sqs_{0.9} = 0.27$ kcf |
| Slope of qs (1.2*D LC): | $sqs_{1.2} = IF(L' > W, (P_{pos} - P_{neg}) / W, qu / L')$ | | $sqs_{1.2} = 0.27$ kcf |
| Nominal Shear Strength: | $V_{n1} = 2 * W * \sqrt{F'c * 1000} * dc$ | | $V_{n1} = 123.95$ kips |
| Shear Reduction Factor: | $\phi_{shear} = 0.75$ | | $\phi_{shear} = 0.75$ |
| Design Shear Strength: | $\phi V_{n1} = \phi_{shear} * V_{n1}$ | | $\phi V_{n1} = 92.96$ kips |

Resisting Weight above Critical Section:

| | Thickness (ft) | Unit Weight (kcf) | Weight (kip) (0.9*D LC) | Weight (kip) (1.2*D LC) |
|-------------------------|----------------|-------------------|----------------------------|----------------------------|
| Soil Above Water Table: | 4.2 | 0.120 | 0.00 | 0.00 |
| Soil Below Water Table: | 0 | 0.058 | 0.00 | 0.00 |
| Pad Above Water Table: | 2 | 0.150 | 0.00 | 0.00 |
| Pad Below Water Table: | 0 | 0.088 | 0.00 | 0.00 |
| Total: | | | 0.00 | 0.00 |

| | | | |
|---------------------------|--|---------------------|------|
| Applied Shear (0.9*D LC): | $V_{u1,0.9} = sqs_{0.9} * MIN(L'_{0.9}, d'') * (W / 2 - dpier / 2 - dc) * W$ | $V_{u1,0.9} = 0.00$ | kips |
| Applied Shear (1.2*D LC): | $V_{u1,1.2} = sqs_{1.2} * MIN(L'_{1.2}, d'') * (W / 2 - dpier / 2 - dc) * W$ | $V_{u1,1.2} = 0.00$ | kips |

| | | | | |
|-------|----------------------------|----|----------------------|--|
| Check | $\phi V_{n1} = 92.96$ kips | >= | $V_{u1} = 0.00$ kips | RATING: 0.00% OK |
|-------|----------------------------|----|----------------------|--|

Two-Way Shear (Compression)

| | | |
|--|--|---|
| Pier Shape: | Pier Shape: Square | Pier Shape: Square |
| Pier Diameter: | $d_{pier1} = d_{pier} * 12$ in / ft | $d_{pier1} = 24.00$ in |
| Equivalent Square Pier Diameter: | $d_{pier_sq} = dpier$ | $d_{pier_sq} = 24.00$ in |
| Avg. Effective Depth for Punching Shear: | $dc_{2} = T - cc_{pad} - AVERAGE(0.5 * db_{pad}, 1.5 * d_{b_pad})$ | $dc_{2} = 20.38$ in |
| Area of Concrete in Shear: | $A_c = (4 * (dpier1 + dc_{2})) * dc_{2}$ | $A_c = 3616.56$ in ² |
| Eq. Square Area of Concrete in Shear: | $A_{c_sq} = (4 * (dpier_sq + dc_{2})) * dc_{2}$ | $A_{c_sq} = 3616.56$ in ² |
| Factor of transfer of Moment: | $Y_f = 1 / (1 + (2/3) * \sqrt{dpier1 / dpier1})$ | $Y_f = 0.60$ |
| Factor of transfer of eccentricity of Shear: | $Y_v = 1 - Y_f$ | $Y_v = 0.40$ |
| Moment applied at base of Pier: | $M_v = M_{u_comp} * 12$ in / ft | $M_v = 97.81$ kip*in |
| Polar Moment of Inertia at assumed Critical Section: | $J_{c_1} = \frac{(dc_{2} * (dpier1 + dc_{2})^3) / 6 + ((dpier1 + dc_{2})^2 * (dc_{2}^3) / 6) + (dc_{2}^2 * (dpier1 + dc_{2}) * (dpier1 + dc_{2})^2) / 2}{}$ | $J_{c_1} = 1249477.61$ in ⁴ |

| | | | | |
|--|--|---------------------------------------|-----------------------------|---|
| <i>Eq. Square Polar Moment of Inertia at assumed Critical Section:</i> | $J_{c_sq} = \frac{(dc_2^2(dpier_sq+dc_2)^3)/6 + ((dpier_sq+dc_2)(dc_2^3))/6 + (dc_2^2(dpier_sq+dc_2)^2)(dpier_sq+dc_2)^2)/2}$ | $J_{c_sq} = 1249477.61$ | in ⁴ | |
| <i>Net Bearing Resistance at front of Pier (1.2*D LC):</i> | $q_{u_AB_1.2} = \frac{MAX((qu_st_1.2 - sqs_1.2*(W/2 - (dpier/12+dc_2/12)/2) - 1.2*(Wpad+Ws)/Area)/144,0)}$ | $q_{u_AB_1.2} = 0.06$ | ksi | |
| <i>Net Bearing Resistance at rear of Pier (1.2*D LC):</i> | $q_{u_CD_1.2} = \frac{MAX((qu_st_1.2 - sqs_1.2*(W/2 + (dpier/12+dc_2/12)/2) - 1.2*(Wpad+Ws)/Area)/144,0)}$ | $q_{u_CD_1.2} = 0.05$ | ksi | |
| <i>Net Bearing Resistance at front of Pier_sq (1.2*D LC):</i> | $q_{u_AB_1.2_sq} = \frac{MAX((qu_st_1.2 - sqs_1.2*(W/2 - (dpier_sq/12+MIN(dc_2,(T*12)^3)/12)/2) - 1.2*(Wpad+Ws)/Area)/144,0)}$ | $q_{u_AB_1.2_sq} = 0.06$ | ksi | |
| <i>Net Bearing Resistance at rear of Pier_sq (1.2*D LC):</i> | $q_{u_CD_1.2_sq} = \frac{MAX((qu_st_1.2 - sqs_1.2*(W/2 + (dpier_sq/12+dc_2/12)/2) - 1.2*(Wpad+Ws)/Area)/144,0)}$ | $q_{u_CD_1.2_sq} = 0.05$ | ksi | |
| <i>Applied Shear Force (1.2*D LC):</i> | $V_{u_1.2} = 1.2*Wpier + 1.2 * IF(OR(\$B\$1="G",\$B\$1="H"), Pcomp / 1.2, Pcomp)$ | $V_{u_1.2} = 170.12$ | kip | |
| <i>Controlling Shear Stress (1.2*D LC):</i> | $V_{u_1.2_controlling} = \frac{MAX(0,IF(L/L_0.9 <= W/2 + dpier/2 + (dc_2/12)/2, 0, V_{u_0.9}/Ac + (Y_v * M_v * (dpier + dc_2)/2) / J_{c_1} - MIN(q_{u_AB_0.9}, q_{u_CD_0.9})))}$ | $V_{u_1.2_controlling} = 0.000$ | ksi | |
| <i>Eq. Sq. Controlling Shear Stress (1.2*D LC):</i> | $V_{u_1.2_controlling_sq} = \frac{MAX(0, V_{u_1.2}/Ac_sq + (Y_v * M_v * (dpier_sq + dc_2)/2) / J_{c_sq} - MIN(q_{u_AB_1.2_sq}, q_{u_CD_1.2_sq}))}$ | $V_{u_1.2_controlling_sq} = 0.000$ | ksi | |
| <i>Shear Stress Capacity:</i> | $\Phi V_n = \phi_s * 4 * (\sqrt{F'_c * 1000}) / 1000$ | $\Phi V_n = 0.164$ | ksi | |
| Check | $\Phi V_n = 0.164$ ksi | \geq | $V_{u_demand} = 0.000$ ksi | RATING: 0.00% OK |

Two-Way Shear (Compression, Flexural Component) [BOTTOM REINFORCEMENT]

| | | | |
|--|---|-------------------------------------|-----------------|
| <i>Effective Pad Width:</i> | $b_{pad} = MIN(dpier+3*T,W)$ | $b_{pad} = 4.7$ | ft |
| <i>Bar Spacing:</i> | $B_{s_pad} = B_{s_pad}$ (see design checks below) | $B_{s_pad} = 8.30$ | in |
| <i>Fraction of Bars in Effective Width:</i> | $m_{effective} = IF(b_{pad}=W,mp,12*b_{pad}/B_{s_pad})$ | $m_{effective} = 7.00$ | |
| <i>Area of Steel in Effective Width:</i> | $A_{s_effective} = VLOOKUP(Sp,Ref!\$A\$2:\$C\$12,3,0)*m_{effective}$ | $A_{s_effective} = 2.17$ | in ² |
| <i>Depth of Equivalent Rectangular Stress Block:</i> | $a_{effective} = A_{s_effective} * F_y / (0.85 * F'_c * b_{slab} * 12)$ | $a_{effective} = 0.91$ | in |
| | $\beta_{pad} = \beta_{pad}$ (see design checks below) | $\beta_{pad} = 0.85$ | |
| <i>Distance from Top to Neutral Axis:</i> | $c_{effective} = a_{effective} / \beta_{pad}$ | $c_{effective} = 1.07$ | |
| <i>Effective depth:</i> | $dc = dc$ (see One-Way Shear check above) | $dc = 20.0625$ | in |
| <i>Modulus of Elasticity of Steel:</i> | $E_s = 29000$ ksi | $E_s = 29000$ | ksi |
| <i>Strain in Steel:</i> | $\epsilon_{s_effective} = 0.003 * (dc-c) / c$ | $\epsilon_{s_effective} = 0.05351$ | in/in |
| <i>Compression-Controlled Strain Limit:</i> | $\epsilon_c = F_y / E_s$ | $\epsilon_c = 0.00207$ | in/in |
| <i>Tension-Controlled Strain Limit:</i> | $\epsilon_t = 0.005$ | $\epsilon_t = 0.00500$ | in/in |
| <i>Flexure Strength Reduction Factor:</i> | $\phi_{flex_effective} = IF(\epsilon_s >= \epsilon_t, 0.9, IF(\epsilon_s <= \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$ | $\phi_{flex_effective} = 0.9$ | |
| <i>Nominal Flexural Strength:</i> | $M_{n_effective} = A_{s_effective} * (F_y) * (dc - a_{effective} / 2) * (1/12)$ | $M_{n_effective} = 212.77$ | ft-kips |
| <i>Design Flexural Strength:</i> | $\phi M_{n_effective} = \phi_{flex_effective} * M_{n_effective}$ | $\phi M_{n_effective} = 191.49$ | ft-kips |

Two-Way Shear (Compression, Flexural Component) [TOP REINFORCEMENT]

| | | | | |
|--|---|--|-------------------------------|---|
| <i>Bar Spacing:</i> | $B_{s_pad_top} = (W*12 - 2 * ccpad - VLOOKUP(sptop,Ref!\$A\$2:\$C\$12,2,0)) / (mptop - 1)$ | $B_{s_pad_top} = 4.70$ | in | |
| <i>Fraction of Bars in Effective Width:</i> | $m_{effective_top} = IF(b_{pad}=W,mptop,12*b_{pad}/B_{s_pad_top})$ | $m_{effective_top} = 7.00$ | | |
| <i>Area of Steel in Effective Width:</i> | $A_{s_effective_top} = VLOOKUP(sptop,Ref!\$A\$2:\$C\$12,3,0)*m_{effective_top}$ | $A_{s_effective_top} = 2.17$ | in ² | |
| <i>Depth of Equivalent Rectangular Stress Block:</i> | $a_{effective_top} = A_{s_effective_top} * F_y / (0.85 * F'_c * b_{slab} * 12)$ | $a_{effective_top} = 0.91$ | in | |
| <i>Distance from Top to Neutral Axis:</i> | $c_{effective_top} = a_{effective_top} / \beta_{pad}$ | $c_{effective_top} = 1.07$ | | |
| <i>Effective depth:</i> | $d_{c_top} = T * 12 - ccpad - 1.5 * VLOOKUP(sptop,Ref!\$A\$2:\$C\$12,2,0)$ | $d_{c_top} = 20.0625$ | in | |
| <i>Strain in Steel:</i> | $\epsilon_{s_effective_top} = 0.003 * (dc_top - c_{effective_top}) / c_{effective_top}$ | $\epsilon_{s_effective_top} = 0.05351$ | in/in | |
| <i>Flexure Strength Reduction Factor:</i> | $\phi_{flex_effective_top} = IF(\epsilon_s_top >= \epsilon_t, 0.9, IF(\epsilon_s_top <= \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s_top - \epsilon_c) / (\epsilon_t - \epsilon_c))))$ | $\phi_{flex_effective_top} = 0.9$ | | |
| <i>Nominal Flexural Strength:</i> | $M_{n_effective_top} = A_{s_effective_top} * (F_y) * (dc_top - a_{effective_top} / 2) * (1/12)$ | $M_{n_effective_top} = 212.77$ | ft-kips | |
| <i>Design Flexural Strength:</i> | $\phi M_{n_effective_top} = \phi_{flex_effective_top} * M_{n_effective_top}$ | $\phi M_{n_effective_top} = 191.49$ | ft-kips | |
| <i>Applied Moment:</i> | $Yf * M_{u_comp} = Yf * M_{u_comp}$ | $Yf * M_{u_comp} = 4.8906$ | ft-kips | |
| Check | $\phi M_{n_effective} = 382.98$ ksi | \geq | $Yf * M_{u_comp} = 4.89$ ksi | RATING: 1.28% OK |

Pad Flexure (Net Bearing Pressure)

| | |
|--|----------------------|
| $\beta_{pad} = IF(F'_c <= 4, 0.85, IF(F'_c >= 8, 0.65, 0.85 - (F'_c - 4) * 0.05))$ | $\beta_{pad} = 0.85$ |
|--|----------------------|

| | | | |
|--|---|------------------------|-----------------|
| <i>Provided Steel:</i> | $A_{s_pad} = A_{b_pad} * m_{pad}$ | $A_{s_pad} = 2.17$ | in ² |
| <i>Depth of Equivalent Rectangular Stress Block:</i> | $a = A_{s_pad} * F_y / (0.85 * F'_c * W)$ | $a = 0.91$ | in |
| <i>Distance from Top to Neutral Axis:</i> | $c = a / \beta_{pad}$ | $c = 1.07$ | in |
| <i>Modulus of Elasticity of Steel:</i> | $E_s = 29000$ ksi | $E_s = 29000$ | ksi |
| <i>Strain in Steel:</i> | $\epsilon_s = 0.003 * (dc-c) / c$ | $\epsilon_s = 0.05351$ | in/in |
| <i>Compression-Controlled Strain Limit:</i> | $\epsilon_c = F_y / E_s$ | $\epsilon_c = 0.00207$ | in/in |
| <i>Tension-Controlled Strain Limit:</i> | $\epsilon_t = 0.005$ | $\epsilon_t = 0.00500$ | in/in |
| <i>Flexure Strength Reduction Factor:</i> | $\phi_{flex} = IF(\epsilon_s \geq \epsilon_t, 0.9, IF(\epsilon_s < \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$ | $\phi_{flex} = 0.9$ | |
| <i>Nominal Flexural Strength:</i> | $M_n = A_{s_pad} * (F_y) * (dc - a / 2) * (1/12)$ | $M_n = 212.77$ | ft-kips |
| <i>Design Flexural Strength:</i> | $\phi M_n = \phi_{flex} * M_n$ | $\phi M_n = 191.49$ | ft-kips |
| <i>Bearing Press. at Crit. Section (0.9*D LC):</i> | $q_{mid_0.9} = q_{u_st_0.9} - sqs_{0.9} * d'$ | $q_{mid_0.9} = 6.69$ | ksf |
| <i>Bearing Press. at Crit. Section (1.2*D LC):</i> | $q_{mid_1.2} = q_{u_st_1.2} - sqs_{1.2} * d'$ | $q_{mid_1.2} = 8.83$ | ksf |

Resisting Weight above Critical Section:

| | Thickness (ft) | Unit Weight (kcf) | Weight (kip) (0.9*D LC) | Weight (kip) (1.2*D LC) | Moment Arm (ft) | Resisting Moment (ft-kips) (0.9*D LC) | Resisting Moment (ft-kips) (1.2*D LC) |
|-------------------------|----------------|-------------------|----------------------------|----------------------------|-----------------|--|--|
| Soil Above Water Table: | 4.2 | 0.120 | 2.88 | 3.84 | 0.675 | 1.94 | 2.5902828 |
| Soil Below Water Table: | 0 | 0.058 | 0.00 | 0.00 | 0.675 | 0.00 | 0 |
| Pad Above Water Table: | 2 | 0.150 | 1.71 | 2.28 | 0.675 | 1.16 | 1.541835 |
| Pad Below Water Table: | 0 | 0.088 | 0.00 | 0.00 | 0.675 | 0.00 | 0 |
| Total: | | | 4.59 | 6.12 | | 3.10 | 4.13 |

*Factored Bending Moment (0.9*D LC):* $Mu_{pad_0.9} = ((0.5 * (q_{u_0.9} - q_{mid_0.9})) * (d'^2) * (2/3) + (0.5 * q_{mid_0.9} * (d'^2)) - (0.5 * Wg_{0.9} * (d'^2))) * W$ $Mu_{pad_0.9} = 26.59$ ft-kips

*Factored Bending Moment (1.2*D LC):* $Mu_{pad_1.2} = ((0.5 * (q_{u_1.2} - q_{mid_1.2})) * (d'^2) * (2/3) + (0.5 * q_{mid_1.2} * (d'^2)) - (0.5 * Wg_{1.2} * (d'^2))) * W$ $Mu_{pad_1.2} = 34.72$ ft-kips

Check $\phi M_n = 191.49$ ft-kips \geq $M_{u_pad} = 34.72$ ft-kips **RATING:** 18.13% **OK**

PIER DESIGN CHECKS

Bar Spacing

Bar separation: $B_{s_pier} = (do * \pi) / m_{pier} - db_{pier}$ $B_{s_pier} = 6.84$ in

Check **18.00** in \geq $B_{s_pier} = 6.84$ in **OK**

Vertical Rebar Development Length

| | | |
|----------------------------------|--|--------------------------|
| <i>Reinforcement location:</i> | $\alpha_c =$ if space under bar > 12", 1.3, else use 1.0 | $\alpha_c = 1.3$ |
| <i>Epoxy coating:</i> | $\beta_c =$ for non- epoxy coated, use 1.0 | $\beta_c = 1.0$ |
| <i>Max term:</i> | $\alpha \beta_c =$ product of α x β not to exceed 1.7 | $\alpha \beta_c = 1.3$ |
| <i>Reinforcement size:</i> | $\gamma_c =$ if bar size is 6 or less, 0.8, else use 1.0 | $\gamma_c = 0.8$ |
| <i>Light weight concrete:</i> | $\lambda_c = 1.0$ | $\lambda_c = 1.0$ |
| <i>Spacing/cover:</i> | $c_{c_c} =$ use smaller of half of bar spacing or concrete cover | $c_{c_c} = 3.3$ in |
| <i>Transverse bars:</i> | $k_{tr_c} = 0$ in (per simplification) | $k_{tr_c} = 0$ in |
| <i>Max term:</i> | $c_c' = \text{MIN}(2.5, (c_{c_c} + k_{tr_c}) / db_{c_c})$ | $c_c' = 2.500$ |
| <i>Excess reinforcement:</i> | $R_c = A_{st_c} / A_{s_c}$ | $R_c = 1.33$ |
| <i>Development (tensile):</i> | $L_{d_c}' = (3 / 40) * (F_y * 1000 / \sqrt{F'_c * 1000}) * \alpha \beta_c * \gamma_c * \lambda_c * R_c * db_{c_c} / c_{c_c}'$ | $L_{d_c}' = 28.35$ in |
| <i>Minimum length:</i> | $L_{d_min} = 12$ inches | $L_{d_min} = 12.0$ in |
| <i>Development length:</i> | $L_{d_c} = \text{MAX}(L_{d_min}, L_{d_c}')$ | $L_{d_c} = 28.35$ in |
| <i>Development (comp.):</i> | $L_{dc_c}' = 0.02 * db_{c_c} * F_y * 1000 / \sqrt{F'_c * 1000}$ | $L_{dc_c}' = 13.69$ in |
| | $L_{dc_c}'' = 0.0003 * db_{c_c} * F_y * 1000$ | $L_{dc_c}'' = 11.25$ in |
| <i>Development length:</i> | $L_{dc_c} = \text{MAX}(8, L_{dc_c}', L_{dc_c}'')$ | $L_{dc_c} = 13.69$ in |
| <i>Length available in pier:</i> | $L_{vc} = D - T + E - cc$ | $L_{vc} = 65.4$ in |

| | | | | | | |
|--------------|---------------------------------|-----------|--------|-------------------------|-----------|------------------------------------|
| Check | $L_{vc} = 65.40$ | in | \geq | $L_{dl_c} = 28.35$ | in | <input type="text" value="OK"/> |
| Check | $L_{vc} = 65.40$ | in | \geq | $L_{dc_c} = 13.69$ | in | <input type="text" value="OK"/> |
| | <i>Length available in pad:</i> | | | $L_{vp} = T - cc_{pad}$ | | $L_{vp} = 21.0$ in |
| Check | $L_{vp} = 21.00$ | in | \geq | $L_{dl_c} = 28.35$ | in | <input type="text" value="HOOKS"/> |
| Check | $L_{vp} = 21.00$ | in | \geq | $L_{dc_c} = 13.69$ | in | <input type="text" value="OK"/> |

Vertical Rebar Hook Ending

| | | | | | | |
|------------------------------------|--|-----------|--------|-----------------------|-----------|---------------------------------|
| <i>Bar size & clear cover:</i> | $\alpha_h =$ =if bar ≤ 11 , and cc ≥ 2.5 ", use 0.7, else use 1.0 | | | $\alpha_h = 0.7$ | | |
| <i>Epoxy coating:</i> | $\beta_h =$ for non- epoxy coated, use 1.0 | | | $\beta_h = 1.0$ | | |
| <i>Light weight concrete:</i> | $\lambda_h = 1.0$ | | | $\lambda_h = 1.0$ | | |
| <i>Development (hook):</i> | $L_{dh}' = 0.02 * a_h * \beta_h * \lambda_h * F_y * 1000 / \sqrt{(F'_c * 1000)} * db_c$ | | | $L_{dh}' = 9.6$ | in | |
| <i>Minimum length:</i> | $L_{dh_min} =$ the larger of: $8 * d_b$ or 6 in | | | $L_{dh_min} = 6.0$ | in | |
| <i>Development length:</i> | $L_{dh} = \text{MAX}(L_{dh_min}, L_{dh}')$ | | | $L_{dh} = 9.6$ | in | |
| Check | $L_{vp} = 21.00$ | in | \geq | $L_{dh} = 9.59$ | in | <input type="text" value="OK"/> |
| <i>Hook tail length:</i> | $L_{h_tail} = 12 * db$ beyond the bend radius | | | $L_{h_tail} = 10.0$ | in | |
| <i>Length available in pad:</i> | $L_{h_pad} = (W - dpier) / 2 + cc_{pier} - cc_{pad}$ | | | $L_{h_pad} = 16.2$ | in | |
| Check | $L_{h_pad} = 16.20$ | in | \geq | $L_{h_tail} = 10.00$ | in | <input type="text" value="OK"/> |

Pier Ties

| | | | | | |
|--|---|--|---|-----------------------|-----------|
| <i>Minimum size:</i> [ACI 7.10.5.1] | $s_{t_min} = \text{IF}(s_c \leq 10, 3, 4)$ | | | $s_{t_min} = 3$ | |
| <i>z factor:</i> | $z_seismic = 0.5$ if the SDC is A, B, or C, else 1.0 | | | $z_seismic = 0.5$ | |
| <i>Tie parameters:</i> | $s_t = 3$ $m_t = 7$ | | $d_{b_t} = 0.375$ in $A_{b_t} = 0.11$ in² | | |
| <i>Allowable tie spacing per vertical rebar:</i> | $B_{s_t_max1} = 8 / z * db_c$ | | | $B_{s_t_max1} = 10$ | in |
| <i>per tie size:</i> | $B_{s_t_max2} = 24 / z * db_t$ | | | $B_{s_t_max2} = 18$ | in |

Moment Capacity of Drilled Concrete Shaft (Caisson) for TIA Rev F, G, or H

Note: Shaft assumed to have ties, not spiral, transverse reinforcing

Site Data

| BU#: | |
|------------------------------|------|
| Site Name: <i>MadisonAWC</i> | |
| App #: | |
| Loads Already Factored | |
| For M (WL): | 1.00 |
| For P (DL): | 1.00 |

Pier Properties

| Concrete: | |
|----------------------------|-----------------------|
| Pier Diameter = | 2.0 ft |
| Concrete Area = | 452.4 in ² |
| Reinforcement: | |
| Clear Cover to Tie = | 3.00 in |
| Horiz. Tie Bar Size = | 3 |
| Vert. Cage Diameter = | 1.39 ft |
| Vert. Cage Diameter = | 16.63 in |
| Vertical Bar Size = | 5 |
| Bar Diameter = | 0.63 in |
| Bar Area = | 0.31 in ² |
| Number of Bars = | 7 |
| As Total = | 2.17 in ² |
| A s/ Aconc, Rho: | 0.0048 0.48% |

ACI 10.5, ACI 21.10.4, and IBC 1810.
 Min As for Flexural, Tension Controlled, Shafts:
 $(3) \cdot (\text{sqrt}(f_c) / F_y) = 0.0027$
 $200 / F_y = 0.0033$

Minimum Rho Check:

| | |
|-------------------|-------|
| Assumed Min. Rho: | 0.50% |
| Provided Rho: | 0.48% |

| Ref. Shaft Max Axial Capacities, ϕ Max(Pn or Tn): | |
|--|----------------|
| Max Pu = ($\phi=0.65$) Pn = | |
| per ACI 318 (10-2) | 664.69 kips |
| at Mu=($\phi=0.65$)Mn= | 111.22 ft-kips |
| Max Tu, ($\phi=0.9$) Tn = | 117.18 kips |
| at Mu= $\phi=(0.90)$ Mn= | 0.00 ft-kips |

Maximum Shaft Superimposed Forces

| | | |
|-------------------------|--------|------------------|
| TIA Revision: | H | |
| Max. Factored Shaft Mu: | 8.151 | ft-kips (* Note) |
| Max. Factored Shaft Pu: | 166.02 | kips |
| Max Axial Force Type: | Comp. | |

(* Note: Max Shaft Superimposed Moment does not necessarily equal to the shaft top reaction moment

| Load Factor | Shaft Factored Loads | |
|-------------|----------------------|---------------|
| 1.00 | Mu: | 8.151 ft-kips |
| 1.00 | Pu: | 166.02 kips |

Material Properties


| Concrete Comp. strength, f_c = | 3000 | psi |
|--|---------|-----|
| Reinforcement yield strength, F_y = | 60 | ksi |
| Reinforcing Modulus of Elasticity, E = | 29000 | ksi |
| Reinforcement yield strain = | 0.00207 | |
| Limiting compressive strain = | 0.003 | |
| ACI 318 Code | | |
| Select Analysis ACI Code= | 2014 | |

SOLVE


<-- Press Upon Completing All Input

Results:

Governing Orientation Case: 1



Case 1



Case 2

Dist. From Edge to Neutral Axis: **7.09** in

Extreme Steel Strain, ϵ_t : **0.0056**

$\epsilon_t > 0.0050$, Tension Controlled

Reduction Factor, ϕ : **0.900**

Output Note: Negative Pu=Tension

For Axial Compression, ϕ Pn = Pu: 149.42 kips

Drilled Shaft Moment Capacity, ϕ Mn: **176.74** ft-kips

Drilled Shaft Superimposed Mu: **8.15** ft-kips

| | |
|---|-------------|
| (Mu/ϕMn, Drilled Shaft Flexure CSR): | 4.6% |
|---|-------------|



Maximum Allowable Moment of a Circular Pier

Pu = kips (from Results Tab)
 Axial Force type: (from Results Tab)
 For Internal Calculations:
 Axial Load (Negative for Compression) = kips


| | Case 1 | Case 2 |
|---------------------------|--------|--------|
| Reduction factor, φ2002 = | 0.9 | 0.9 |
| Reduction factor, φ2005 = | 0.9 | 0.9 |
| Reduction factor, φ2014 = | 0.9 | 0.9 |
| IAI code | 0.9 | 0.9 |

<- φ based on ACI 318 2002, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.48+83(εt). Transition zone equation for spirals: φ=0.57+67(εt).
 <- φ based on ACI 318 2005, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65+(εt)-0.002(250i). Transition zone equation for spirals: φ=0.70+(εt)-0.002(200i).
 <- φ based on ACI 318 2014, Section 21.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65+0.25(εt-εty)(0.005-εty). Transition zone equation for spirals: φ=0.75+0.15(εt-εty)(0.005-εty).

Case 1: Single Bar Near the Extreme Fiber



Case 2: (2) Equidistant Bars Near the Extreme Fiber



Case 3: = Case 1, but Pu set at Max Axial Compression per ACI 318 (10-2) and phi=0.65.

Neutral Axis
 Distance from extreme edge to neutral axis, h = **7.09** in
 Equivalent compression zone factor = **0.85**
 Distance from extreme edge to equivalent compression zone factor, a = **6.01** in
 Distance from centroid to neutral axis = **4.92** in

Compression Zone
 Area of steel in compression zone, Asc = **0.31** in²
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **60.08** deg <- 1/2 of total angle
 Area of concrete in compression, Acc = **88.75** in²
 Force in concrete = 0.85 * Fc * Acc, Fc = **226.32** kips <- φ Not Involved = Concrete Pn
 Total reinforcement forces, Fs = **-60.30** kips <- φ Not Involved = Total Steel Pn
 Case 1, φ = **0.900**
 Axial (comp=negative), Pu = **-166.02** kips <- Pu
 Balance Force in concrete, Fs+Fu = **-226.32** kips <- φ Pn=Pu
 Shaft Comp. Capacity, φPn = **149.42** kips
 Sum of the axial forces in the shaft = **0.00** kips **OK**

Maximum Moment
 First moment of the concrete area in compression about the centroid = **750.10** in³
 Distance between centroid of concrete in compression and centroid of pier = **8.45** in
 Moment of concrete in compression = **1912.77** in-kips
 Total reinforcement moment = **438.44** in-kips
 Nominal Moment strength of Drilled Shaft Mn = **2371.21** in-kips
 Moment Capacity of Drilled Shaft, φMn = **177.8404** ft-kips

Neutral Axis
 Distance from extreme edge to neutral axis, h = **7.09** in
 Equivalent compression zone factor = **0.85**
 Distance from extreme edge to equivalent compression zone factor, a = **6.03** in
 Distance from centroid to neutral axis = **4.91** in

Compression Zone
 Area of steel in compression zone, Asc = **0.62** in²
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **60.16** deg <- 1/2 of total angle
 Area of concrete in compression, Acc = **89.03** in²
 Force in concrete = 0.85 * Fc * Acc, Fc = **227.03** kips <- φ Not Involved = Concrete Pn
 Total reinforcement forces, Fs = **-81.01** kips <- φ Not Involved = Total Steel Pn
 Case 2, φ = **0.900**
 Axial (comp=negative), Pu = **-166.02** kips <- Pu
 Balance Force in concrete, Fs+Fu = **-227.03** kips <- φ Pn=Pu
 Shaft Comp. Capacity, φPn = **149.42** kips
 Sum of the axial forces in the shaft = **0.00** kips **OK**

Maximum Moment
 First moment of the concrete area in compression about the centroid = **751.76** in³
 Distance between centroid of concrete in compression and centroid of pier = **8.44** in
 Moment of concrete in compression = **1917.00** in-kips
 Total reinforcement moment = **439.59** in-kips
 Nominal Moment strength of Drilled Shaft Mn = **2356.59** in-kips
 Moment Capacity of Drilled Shaft, φMn = **176.7439** ft-kips

Neutral Axis
 Distance from extreme edge to neutral axis, h = **21.59** in
 Equivalent compression zone factor = **0.85**
 Distance from extreme edge to equivalent compression zone factor, a = **18.35** in
 Distance from centroid to neutral axis = **-9.59** in

Compression Zone
 Area of steel in compression zone, Asc = **1.55** in²
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **121.95** deg <- 1/2 of total angle
 Area of concrete in compression, Acc = **371.16** in²
 Force in concrete = 0.85 * Fc * Acc, Fc = **946.47** kips <- φ Not Involved = Concrete Pn
 Total reinforcement forces, Fs = **76.14** kips <- φ Not Involved = Total Steel Pn
 Case 3, φ = **0.65**
 Magnified, Max Axial Comp. Pn, per ACI 318 (10-2)(φ=0.65) = **-1022.61** kips <- (Pn per ACI 10-2)φ
 Balance Force in concrete, Fs+Fu = **-946.47** kips <- φ Pn=Pu
 Shaft Comp. Capacity, φPn = **664.69** kips
 Sum of the axial forces in the shaft = **0.00** kips **OK**

Maximum Moment
 First moment of the concrete area in compression about the centroid = **703.68** in³
 Distance between centroid of concrete in compression and centroid of pier = **1.90** in
 Moment of concrete in compression = **1794.38** in-kips
 Total reinforcement moment = **258.99** in-kips
 Nominal Moment strength of Drilled Shaft Mn = **2053.37** in-kips
 Moment Capacity of Drilled Shaft, φMn = **111.2244** ft-kips

Case 1, φMn = 177.84 ft-kips

| Final Results | |
|--|---|
| Governing Orientation Case= | 2 |
| phi, φ= | 0.900 |
| Shaft φ*Mn= | 176.74 ft-kips |
| Distance from Edge of Shaft to N.A.= | 7.09 in |
| Shaft Beta= | 0.85 |
| Maximum Tensile Strain= | -0.00559 <- εt > 0.0050, Tension Controlled |
| Shaft Tension Cap., φTn= (φ=0.9)*(Total As)Fy= | 117.18 kips |
| Shaft Max Comp. (φ=0.65)(0.80)(0.85Fc)(Ag-As)Fy= | 664.69 kips |

Case 2, φMn = 176.74 ft-kips

| Final Results | |
|--|---|
| Governing Orientation Case= | 2 |
| phi, φ= | 0.900 |
| Shaft φ*Mn= | 176.74 ft-kips |
| Distance from Edge of Shaft to N.A.= | 7.09 in |
| Shaft Beta= | 0.85 |
| Maximum Tensile Strain= | -0.00559 <- εt > 0.0050, Tension Controlled |
| Shaft Tension Cap., φTn= (φ=0.9)*(Total As)Fy= | 117.18 kips |
| Shaft Max Comp. (φ=0.65)(0.80)(0.85Fc)(Ag-As)Fy= | 664.69 kips |

Individual Bars

| Bar # | Angle from first bar (deg) | Distance to center of shaft (in) | Distance to neutral axis (in) | Distance to equivalent comp. zone (in) | Strain | Area of steel in compressi on (in ²) | Stress (ksi) | Axial force (kips) | Moment (in-kips) |
|-------|----------------------------|----------------------------------|-------------------------------|--|----------|--|--------------|--------------------|------------------|
| 1 | 0.00 | 8.31 | 3.39 | 2.33 | 0.00144 | 0.31 | 41.66 | 12.13 | 100.79 |
| 2 | 51.43 | 5.18 | -0.26 | -0.80 | 0.00011 | 0.00 | 3.19 | 0.99 | 5.12 |
| 3 | 102.86 | -1.85 | -6.77 | -7.83 | -0.00287 | 0.00 | -60.00 | -18.60 | 34.40 |
| 4 | 154.29 | -7.49 | -12.41 | -13.47 | -0.00526 | 0.00 | -60.00 | -18.60 | 139.30 |
| 5 | 205.71 | -7.49 | -12.41 | -13.47 | -0.00526 | 0.00 | -60.00 | -18.60 | 199.30 |
| 6 | 257.14 | -1.85 | -6.77 | -7.83 | -0.00287 | 0.00 | -60.00 | -18.60 | 34.40 |
| 7 | 308.57 | 5.18 | 0.26 | -0.80 | 0.00011 | 0.00 | 3.19 | 0.99 | 5.12 |

| Bar # | Angle from first bar (deg) | Distance to center of shaft (in) | Distance to neutral axis (in) | Distance to equivalent comp. zone (in) | Strain | Area of steel in compressi on (in ²) | Stress (ksi) | Axial force (kips) | Moment (in-kips) |
|-------|----------------------------|----------------------------------|-------------------------------|--|----------|--|--------------|--------------------|------------------|
| 1 | 25.71 | 7.49 | 2.58 | 1.52 | 0.00109 | 0.31 | 31.67 | 9.03 | 67.60 |
| 2 | 77.14 | 1.85 | -3.08 | -4.12 | -0.00129 | 0.00 | -37.52 | -11.63 | -21.51 |
| 3 | 128.57 | -5.18 | -10.09 | -11.15 | -0.00427 | 0.00 | -60.00 | -18.60 | 96.40 |
| 4 | 180.00 | -8.31 | -13.22 | -14.28 | -0.00559 | 0.00 | -60.00 | -18.60 | 154.61 |
| 5 | 231.43 | -5.18 | -10.09 | -11.15 | -0.00427 | 0.00 | -60.00 | -18.60 | 96.40 |
| 6 | 282.86 | 1.85 | -3.08 | -4.12 | -0.00129 | 0.00 | -37.52 | -11.63 | -21.51 |
| 7 | 334.29 | 7.49 | 2.58 | 1.52 | 0.00109 | 0.31 | 31.67 | 9.03 | 67.60 |

Individual Bars

| Bar # | Angle from first bar (deg) | Distance to center of shaft (in) | Distance to neutral axis (in) | Distance to equivalent comp. zone (in) | Strain | Area of steel in compressi on (in ²) | Stress (ksi) | Axial force (kips) | Moment (in-kips) |
|-------|----------------------------|----------------------------------|-------------------------------|--|---------|--|--------------|--------------------|------------------|
| 1 | 0.00 | 8.31 | 17.90 | 14.68 | 0.00249 | 0.31 | 60.00 | 17.81 | 148.04 |
| 2 | 51.43 | 5.18 | 14.77 | 11.53 | 0.00205 | 0.31 | 59.53 | 17.66 | 91.54 |
| 3 | 102.86 | -1.85 | 7.74 | 4.50 | 0.00108 | 0.31 | 31.19 | 8.88 | -16.42 |
| 4 | 154.29 | -7.49 | 2.10 | -1.14 | 0.00029 | 0.00 | 8.46 | 2.62 | -19.65 |
| 5 | 205.71 | -7.49 | 2.10 | -1.14 | 0.00029 | 0.00 | 8.46 | 2.62 | -19.65 |
| 6 | 257.14 | -1.85 | 7.74 | 4.50 | 0.00108 | 0.31 | 31.19 | 8.88 | -16.42 |
| 7 | 308.57 | 5.18 | 14.77 | 11.53 | 0.00205 | 0.31 | 59.53 | 17.66 | 91.54 |

FACTORED LOADS

| | | |
|------------------|-----------------------------------|-------------------------|
| Axial Load 0.9D: | $P_{0.9D} = 0.9 * P_{comp} / 1.2$ | $P_{0.9D} = 124.52$ kip |
| Axial Load 1.2D: | $P_{1.2D} = 1.2 * P_{comp} / 1.2$ | $P_{1.2D} = 166.02$ kip |
| Shear Load: | $V_u = V_{u_comp}$ | $V_u = 1.43$ kip |
| Moment: | $M_u = M_u$ | $M_u = 0.00$ kip*ft |

PASSIVE PRESSURE RESISTANCE

| | | |
|---|---|--------------------------------|
| Force of Pp Applied on Pier: | $Force_{pier} = MIN(V_u, SUM(PpIM2:M7))$ | $Force_{pier} = 1.43$ kip |
| Moment Arm of Pp on Pier: | $M_{arm_pier} = D-T-PpIO2 + T$ | $M_{arm_pier} = 2.43$ ft |
| Force of Pp Applied on Pad: | $Force_{pad} = MIN(V_u - Force_{pier}, SUM(PpIM8:M13))$ | $Force_{pad} = 0.00$ kip |
| Moment Arm of Pp on Pad: | $M_{arm_pad} = D-PpIO8$ | $M_{arm_pad} = 0.94$ ft |
| Unfactored Moment Resistance due to Passive Pressure: | $M_{R_Pp} = Force_{pier} * M_{arm_pier} + Force_{pad} * M_{arm_pad}$ | $M_{R_Pp} = 3.48$ kip*ft |
| Factored Moment Resistance due to Passive Pressure: | $\Phi M_{R_Pp} = \Phi_8 * M_{R_Pp}$ | $\Phi M_{R_Pp} = 2.61$ kip*ft |

PLASTIC BEARING PRESSURE & OVERTURNING MOMENT

| | | |
|---|--|--|
| Compressive Load for Bearing (0.9*D LC): | $P_{bearing_0.9_e} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_0.9_bearing_e}$ | $P_{bearing_0.9_e} = 141.76$ kip |
| Compressive Load for Bearing (1.2*D LC): | $P_{bearing_1.2_e} = P_{1.2D} + 1.2 * (W_s + W_c) + 0.75 * W_{wedges_1.2_bearing_e}$ | $P_{bearing_1.2_e} = 189.02$ kip |
| Factored Overturning Moment: | $M_{overturning} = M_u + V_u * (D+E+bp_{dist}/12)$ | $M_{overturning} = 11.01$ kip*ft |
| Area of Pad: | $Area = W^2$ | $Area = 22.09$ ft ² |
| Elastic Section Modulus of Pad: | $S = W^3 / 6$ | $S = 17.30$ ft ³ |
| Preliminary Load Eccentricity (0.9*D LC): | $pre_ec_{0.9_e} = M_{overturning} / P_{bearing_0.9}$ | $pre_ec_{0.9_e} = 0.08$ ft |
| Preliminary Load Eccentricity (1.2*D LC): | $pre_ec_{1.2_e} = M_{overturning} / P_{bearing_1.2}$ | $pre_ec_{1.2_e} = 0.06$ ft |
| [Goal Seek] Load Eccentricity Iteration (0.9*D LC): | $ec_{0.9_e} = goal\ seek$ | $ec_{0.9_e} = 0.06$ ft e <= L/6 |
| [Goal Seek] Load Eccentricity Iteration (1.2*D LC): | $ec_{1.2_e} = goal\ seek$ | $ec_{1.2_e} = 0.04$ ft e <= L/6 |
| Non-Bearing Length (0.9*D LC): | $NBL_{0.9_e} = 0$ | $NBL_{0.9_e} = 0.00$ ft |
| Non-Bearing Length (1.2*D LC): | $NBL_{1.2_e} = 0$ | $NBL_{1.2_e} = 0.00$ ft |
| Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC): | $\Phi M_{Resisting_0.9_e} = \Phi M_{R_Pp} + SUM(\Phi M_{R_wedges_0.9}, \Phi M_{R_shear_0.9})$ | $\Phi M_{Resisting_0.9_e} = 2.61$ kip*ft |
| Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (1.2*D LC): | $\Phi M_{Resisting_1.2_e} = \Phi M_{R_Pp} + SUM(\Phi M_{R_wedges_1.2}, \Phi M_{R_shear_1.2})$ | $\Phi M_{Resisting_1.2_e} = 2.61$ kip*ft |
| Adjusted Overturning Moment (0.9*D LC): | $M_{overturning_0.9_e} = M_{overturning} - \Phi M_{Resisting_0.9}$ | $M_{overturning_0.9_e} = 8.40$ kip*ft |
| Adjusted Overturning Moment (1.2*D LC): | $M_{overturning_1.2_e} = M_{overturning} - \Phi M_{Resisting_1.2}$ | $M_{overturning_1.2_e} = 8.40$ kip*ft |
| Total Resistance to Overturning (0.9*D LC): | $\Phi M_{Resisting_qu_0.9_e} = P_{bearing_0.9} * ec_{0.9_p} + \Phi M_{Resisting_0.9}$ | $\Phi M_{Resisting_qu_0.9_e} = 11.01$ kip*ft |
| Total Resistance to Overturning (1.2*D LC): | $\Phi M_{Resisting_qu_1.2_e} = P_{bearing_1.2} * ec_{1.2_p} + \Phi M_{Resisting_1.2}$ | $\Phi M_{Resisting_qu_1.2_e} = 11.01$ kip*ft |
| [Goal Seek] Moment Comparison Iteration (0.9D LC): | $\Delta M_{0.9_e} = M_{overturning} - \Phi M_{Resisting_qu_0.9}$ | $\Delta M_{0.9_e} = 0.00$ kip*ft |
| [Goal Seek] Moment Comparison Iteration (1.2D LC): | $\Delta M_{1.2_e} = M_{overturning} - \Phi M_{Resisting_qu_1.2}$ | $\Delta M_{1.2_e} = 0.00$ kip*ft |

Bearing Pressures

| | | |
|---|---|----------------------------------|
| Orthogonal Bearing Pressure (0.9*D LC): | $q_{u_orth_0.9_e} = P_{bearing_0.9_e} / Area + M_{overturning_0.9} / S$ | $q_{u_orth_0.9_e} = 6.90$ ksf |
| Orthogonal Bearing Pressure (1.2*D LC): | $q_{u_orth_1.2_e} = P_{bearing_1.2_e} / Area + M_{overturning_1.2} / S$ | $q_{u_orth_1.2_e} = 9.04$ ksf |
| Ultimate Gross Bearing Pressure: | $Q_{ult} = Q_{ult}$ | $Q_{ult} = 16.00$ ksf |
| Factored Ultimate Gross Bearing Pressure: | $Q_a = \phi_s * Q_{ult}$ | $Q_a = 9.60$ ksf |

| | | | | | | | | | | |
|-------|------|------|-----|----|------|------|-----|---------|--------|----|
| Check | Qa = | 9.60 | ksf | >= | qu = | 9.04 | ksf | RATING: | 94.19% | OK |
|-------|------|------|-----|----|------|------|-----|---------|--------|----|

Soil Wedges (Cohesionless Soil)

| | | |
|--|---|-----------------------------|
| Soil (above pad) Height: | $soilht = D-T$ | $soilht = 4.20$ ft |
| Soil (above pad & under water table) Height: | $soilht_gw = MIN(soilht-gw, D-T)$ | $soilht_gw = 0.00$ ft |
| Soil Wedge Projection at Grade: | $Wedge_proj = TAN(\phi * PI() / 180) * soilht$ | $Wedge_proj = 2.42$ ft |
| Soil Wedge Projection at Water Table: | $Wedge_proj_gw = TAN(\phi * PI() / 180) * (soilht_gw)$ | $Wedge_proj_gw = 0.00$ ft |

Soil Wedges (Cohesionless Soil) (0.9*D LC)

| Soil | Volume (ft ³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) |
|------|---------------------------|--------------------|-----------------|--------------------------------------|
|------|---------------------------|--------------------|-----------------|--------------------------------------|

| | | | | |
|---------------------------------------|-------------|-------------|-------------|-------------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (1) Rear (above Water Table) | 0.00 | 0.00 | 5.51 | 0.00 |
| (1) Rear (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 |
| Total | 0.00 | 0.00 | 0.00 | 0.00 |

| | |
|-------------------------------|------|
| Eccentricity relative to W/2: | |
| Total Moment Arm (ft) = | 0.00 |
| Soil Wedge Wt (kip)= | 0.00 |

Unfactored Resisting Moment of Wedges (0.9*D LC):

$$M_{R_wedges_0.9_e} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$$

$$M_{R_wedges_0.9_e} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (0.9*D LC):

$$\Phi M_{R_wedges_0.9_e} = 0.75 * M_{R_wedges_0.9_e}$$

$$\Phi M_{R_wedges_0.9_e} = 0.00 \text{ kip*ft}$$

Soil Wedges (Cohesionless Soil) (1.2*D LC)

| Soil | Volume (ft³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) |
|---------------------------------------|--------------|--------------------|-----------------|--------------------------------------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (1) Rear (above Water Table) | 0.00 | 0.00 | 5.51 | 0.00 |
| (1) Rear (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 |
| Total | 0.00 | 0.00 | 0.00 | 0.00 |

| | |
|-------------------------------|------|
| Eccentricity relative to W/2: | |
| Total Moment Arm (ft) = | 0.00 |
| Soil Wedge Wt (kip)= | 0.00 |

Unfactored Resisting Moment of Wedges (1.2*D LC):

$$M_{R_wedges_1.2_e} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$$

$$M_{R_wedges_1.2_e} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (1.2*D LC):

$$\Phi M_{R_wedges_1.2_e} = 0.75 * M_{R_wedges_1.2_e}$$

$$\Phi M_{R_wedges_1.2_e} = 0.00 \text{ kip*ft}$$

Soil Shear Strength (Cohesive Soil)

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) |
|-------------------|-------------|------------------|-----------------|--------------------------------------|
| Rear | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 4.70 | 0.00 |
| Total | 0.00 | 0.00 | 0.00 | 0.00 |

| | |
|-------------------------------|------|
| Eccentricity relative to W/2: | |
| Total Moment Arm (ft) = | 0.00 |
| Soil Shear Strength (kip)= | 0.00 |

Unfactored Resisting Moment of Soil Shear (0.9*D LC):

$$M_{R_shear_0.9_e} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R_shear_0.9_e} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (0.9*D LC):

$$\Phi M_{R_shear_0.9_e} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R_shear_0.9_e} = 0.00 \text{ kip*ft}$$

Soil Shear Strength (Cohesive Soil) (1.2*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) |
|-------------------|-------------|------------------|-----------------|--------------------------------------|
| Rear | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 4.70 | 0.00 |
| Total | 0.00 | 0.00 | 0.00 | 0.00 |

| | |
|-------------------------------|------|
| Eccentricity relative to W/2: | |
| Total Moment Arm (ft) = | 0.00 |
| Soil Shear Strength (kip)= | 0.00 |

Unfactored Resisting Moment of Soil Shear (1.2*D LC):

$$M_{R_shear_1.2_e} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R_shear_1.2_e} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (1.2*D LC):

$$\Phi M_{R_shear_1.2_e} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R_shear_1.2_e} = 0.00 \text{ kip*ft}$$

DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (ORTHOGONAL)

Compressive Load for Bearing (0.9*D LC):

$$P_{100_e} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_100_e}$$

$$P_{100_e} = 141.76 \text{ kip}$$

Preliminary Factored Overturning Moment:

$$pre_M_{overturning_100_e} = (\Phi Q_{ult} - P_{100_e} / \text{Area}) * S$$

$$pre_M_{overturning_100_e} = 55.07 \text{ kip*ft}$$

Preliminary Load Eccentricity (0.9*D LC):

$$pre_ec_{100_e} = pre_M_{overturning_100_e} / P_{100}$$

$$pre_ec_{100_e} = 0.39 \text{ ft}$$

[Goal Seek] Load Eccentricity Iteration (0.9*D LC):

$$ec_{100_e} = \text{goal seek}$$

$$ec_{100_e} = 0.37 \text{ ft}$$

e <= L/6

Non-Bearing Length (0.9*D LC):

$$NBL_{100_e} = 0$$

$$NBL_{100_e} = 0.00 \text{ ft}$$

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC):

$$\Phi M_{Resisting_100_e} = \Phi M_{R_Pp} + \text{SUM}(\Phi M_{R_wedges_100} \Phi M_{R_shear_100})$$

$$\Phi M_{Resisting_100_e} = 2.61 \text{ kip*ft}$$

Moment Created by Shear:

$$M_{shear_e} = V_u * (D + E + bP_{dist} / 12)$$

$$M_{shear_e} = 11.01 \text{ kip*ft}$$

Adjusted Overturning Moment (0.9*D LC):

$$M_{overturning_100_e} = M_{u_max_100} - \Phi M_{R_Pp}$$

$$M_{overturning_100_e} = 55.07 \text{ kip*ft}$$

Total Resistance to Overturning (0.9*D LC):

$$\Phi M_{Resisting_qu_100_e} = P_{100} * ec_{100} + \Phi M_{Resisting_100}$$

$$\Phi M_{Resisting_qu_100_e} = 55.07 \text{ kip*ft}$$

[Goal Seek] Moment Comparison Iteration (0.9D LC):

$$\Delta M_{100_e} = M_{overturning} - \Phi M_{Resisting_qu_100}$$

$$\Delta M_{100_e} = 0.00 \text{ ft}$$

Maximum Applied Moment from Superstructure Analysis:

$$M_{u_max_100_e} = pre_M_{overturning_100} + \Phi M_{Resisting_100}$$

$$M_{u_max_100_e} = 57.68 \text{ kip*ft}$$

Check $\mu_{max_100_e} = 57.68 \text{ kip*ft} >= \mu_u = 11.01 \text{ kip*ft}$

RATING: 19.09% OK

Soil Wedges (Cohesionless Soil) (0.9*D LC)

| Soil | Volume (ft³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) |
|---------------------------------------|--------------|--------------------|-----------------|--------------------------------------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 4.70 | 0.00 |

| | | | | | | |
|---------------------------------------|------|------|------|------|-------------------------------|------|
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 4.70 | 0.00 | Eccentricity relative to W/2: | |
| (1) Rear (above Water Table) | 0.00 | 0.00 | 5.51 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (1) Rear (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| Total | 0.00 | 0.00 | 0.00 | 0.00 | Soil Wedge Wt (kip)= | 0.00 |

Unfactored Resisting Moment of Wedges (0.9*D LC): $M_{R_wedges_100_e} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$ $M_{R_wedges_100_e} = 0.00$ kip*ft

Factored Resisting Moment of Wedges (0.9*D LC): $\Phi M_{R_wedges_100_e} = 0.75 * M_{R_wedges_100_e}$ $\Phi M_{R_wedges_100_e} = 0.00$ kip*ft

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2: | |
|-------------------|------------|------------------|-----------------|--------------------------------------|-------------------------------|------|
| Rear | 0.00 | 0.00 | 4.70 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 4.70 | 0.00 | | |
| Total | | 0.00 | | 0.00 | Soil Shear Strength (kip)= | 0.00 |

Unfactored Resisting Moment of Soil Shear (0.9*D LC): $M_{R_shear_100_e} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_100_e} = 0.00$ kip*ft

Factored Resisting Moment of Soil Shear (0.9*D LC): $\Phi M_{R_shear_100_e} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_100_e} = 0.00$ kip*ft

PASSIVE PRESSURE RESISTANCE (DIAGONAL DIRECTION)

Force of Pp Applied on Pier: $\text{Force}_{pp_pier} = \text{MIN}(V_u, \text{SUM}(PpIM2:M7))$ $\text{Force}_{pp_pier} = 1.43$ kip

Moment Arm of Pp on Pier: $M_{arm_pier} = D - T - PpIO2 + T$ $M_{arm_pier} = 2.43$ ft

Force of Pp Applied on Pad: $\text{Force}_{pp_dia} = \text{MIN}(V_u - \text{Force}_{pp_pier}, \text{SUM}(PpIM8:M13)) * (T * W * \text{SQRT}(2)) / (T * W)$ $\text{Force}_{pp_dia} = 0.00$ kip

Moment Arm of Pp on Pad: $M_{arm_pad} = D - PpIO8$ $M_{arm_pad} = 0.94$ ft

Unfactored Moment Resistance due to Passive Pressure: $M_{R_pp} = \text{Force}_{pp_pier} * M_{arm_pier} + \text{Force}_{pp_dia} * M_{arm_pad}$ $M_{R_pp} = 3.48$ kip*ft

Factored Moment Resistance due to Passive Pressure: $\Phi M_{R_pp_dia} = \Phi_s * M_{R_pp}$ $\Phi M_{R_pp_dia} = 2.61$ kip*ft

PLASTIC BEARING PRESSURE & OVERTURNING MOMENT (DIAGONAL DIRECTION)

Compressive Load for Bearing (0.9*D LC): $P_{bearing_0.9_dia_e} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_0.9_bearing_dia_e}$ $P_{bearing_0.9_dia_e} = 141.76$ kip

Compressive Load for Bearing (1.2*D LC): $P_{bearing_1.2_dia_e} = P_{1.2D} + 1.2 * (W_s + W_c) + 0.75 * W_{wedges_1.2_bearing_dia_e}$ $P_{bearing_1.2_dia_e} = 189.02$ kip

Factored Overturning Moment: $M_{overturning} = M_u + V_u * (D + E + bp_{dist}/12)$ $M_{overturning} = 11.01$ kip*ft

Area of Pad: $\text{Area} = W^2$ $\text{Area} = 22.09$ ft²

Preliminary Load Eccentricity (0.9*D LC): $pre_ec_{0.9_e_dia} = M_{overturning} / P_{bearing_0.9_dia_e}$ $pre_ec_{0.9_e_dia} = 0.08$ ft

Preliminary Load Eccentricity (1.2*D LC): $pre_ec_{1.2_e_dia} = M_{overturning} / P_{bearing_1.2_dia_e}$ $pre_ec_{1.2_e_dia} = 0.06$ ft

[Goal Seek] Load Eccentricity Iteration (0.9*D LC): $ec_{0.9_e_dia} = \text{goal seek}$ $ec_{0.9_e_dia} = 0.06$ ft $e \leq (L/6)^{1/4}$

[Goal Seek] Load Eccentricity Iteration (1.2*D LC): $ec_{1.2_e_dia} = \text{goal seek}$ $ec_{1.2_e_dia} = 0.04$ ft $e \leq (L/6)^{1/4}$

$S_{dia} = (W^2) / (6 * \text{SQRT}(2))$ $S_{dia} = 12.24$ ft²

Non-Bearing Length (0.9*D LC): $NBL_{0.9_dia_e} = 0$ $NBL_{0.9_dia_e} = 0.00$ ft

Non-Bearing Length (1.2*D LC): $NBL_{1.2_dia_e} = 0$ $NBL_{1.2_dia_e} = 0.00$ ft

Non-Bearing Length (0.9*D LC): $NBL_{0.9_dia_e_2} = 0$ $NBL_{0.9_dia_e_2} = 0.00$ ft

Non-Bearing Length (1.2*D LC): $NBL_{1.2_dia_e_2} = 0$ $NBL_{1.2_dia_e_2} = 0.00$ ft

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC): $\Phi M_{Resisting_0.9_dia_e} = \Phi M_{R_pp_dia} + \text{SUM}(\Phi M_{R_wedges_0.9_dia_e}, \Phi M_{R_shear_0.9_dia_e})$ $\Phi M_{Resisting_0.9_dia_e} = 2.61$ kip*ft

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (1.2*D LC): $\Phi M_{Resisting_1.2_dia_e} = \Phi M_{R_pp_dia} + \text{SUM}(\Phi M_{R_wedges_1.2_dia_e}, \Phi M_{R_shear_1.2_dia_e})$ $\Phi M_{Resisting_1.2_dia_e} = 2.61$ kip*ft

Adjusted Overturning Moment (0.9*D LC): $M_{overturning_0.9_dia_e} = M_{overturning} - \Phi M_{Resisting_0.9_dia_e}$ $M_{overturning_0.9_dia_e} = 8.40$ kip*ft

Adjusted Overturning Moment (1.2*D LC): $M_{overturning_1.2_dia_e} = M_{overturning} - \Phi M_{Resisting_1.2_dia_e}$ $M_{overturning_1.2_dia_e} = 8.40$ kip*ft

Total Resistance to Overturning (0.9*D LC): $\Phi M_{Resisting_qu_0.9_dia_e} = P_{bearing_0.9_dia_e} * ec_{0.9_e_dia} + \Phi M_{Resisting_0.9_dia_e}$ $\Phi M_{Resisting_qu_0.9_dia_e} = 11.01$ kip*ft

Total Resistance to Overturning (1.2*D LC): $\Phi M_{Resisting_qu_1.2_dia_e} = P_{bearing_1.2_dia_e} * ec_{1.2_e_dia} + \Phi M_{Resisting_1.2_dia_e}$ $\Phi M_{Resisting_qu_1.2_dia_e} = 11.01$ kip*ft

[Goal Seek] Moment Comparison Iteration (0.9D LC): $\Delta M_{0.9_dia_e} = M_{overturning} - \Phi M_{Resisting_qu_0.9_dia_e}$ $\Delta M_{0.9_dia_e} = 0.00$ kip*ft

[Goal Seek] Moment Comparison Iteration (1.2D LC):

$$\Delta M_{1.2_dia_e} = M_{\text{overturning}} - \Phi M_{\text{Resisting_qu_1.2_dia_e}}$$

$$\Delta M_{1.2_dia_e} = 0.00 \text{ kip*ft}$$

Bearing Pressures

Diagonal Bearing Pressure (0.9*D LC): $q_{u_dia_0.9_e} = P_{\text{bearing_0.9_dia_e}} / \text{Area} + M_{\text{overturning_0.9_dia_e}} / S_{\text{dia}}$ $q_{u_dia_0.9_e} = 7.10 \text{ ksf}$

Diagonal Bearing Pressure (1.2*D LC): $q_{u_dia_1.2_e} = P_{\text{bearing_1.2_dia_e}} / \text{Area} + M_{\text{overturning_1.2_dia_e}} / S_{\text{dia}}$ $q_{u_dia_1.2_e} = 9.24 \text{ ksf}$

Ultimate Gross Bearing Pressure: $Q_{ult} = Q_{ult}$ $Q_{ult} = 16.00 \text{ ksf}$

Factored Ultimate Gross Bearing Pressure: $\Phi Q_{ult} = \phi_s * Q_{ult}$ $Q_a = 9.60 \text{ ksf}$

Check $\Phi Q_{ult} = 9.60 \text{ ksf} \geq q_u = 9.24 \text{ ksf}$ **RATING: 96.29% OK**

Soil Wedges (Cohesionless Soil)

Soil (above pad) Height: $\text{soilht} = D - T$ $\text{soilht} = 4.20 \text{ ft}$

Soil (above pad & under water table) Height: $\text{soilht_gw} = \text{MIN}(\text{soilht} - \text{gw}, D - T)$ $\text{soilht_gw} = 0.00 \text{ ft}$

Soil Wedge Projection at Grade: $\text{Wedge_proj} = \text{TAN}(\phi * \text{PI} / 180) * \text{soilht}$ $\text{Wedge_proj} = 2.42 \text{ ft}$

Soil Wedge Projection at Water Table: $\text{Wedge_proj_gw} = \text{TAN}(\phi * \text{PI} / 180) * \text{soilht_gw}$ $\text{Wedge_proj_gw} = 0.00 \text{ ft}$

Soil Wedges (Cohesionless Soil) (0.9*D LC)

| Soil | Volume (ft³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|---------------------------------------|--------------|--------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (1) End Prism (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (1) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Rear Sides (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Rear Sides (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| Total | 0.00 | 0.00 | | 0.00 | Soil Wedge Wt (kip)= | 0.00 |

Unfactored Resisting Moment of Wedges (0.9*D LC): $M_{R_wedges_0.9} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$ $M_{R_wedges_0.9_dia_e} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Wedges (0.9*D LC): $\Phi M_{R_wedges_0.9} = 0.75 * M_{R_wedges_0.9_dia_e}$ $\Phi M_{R_wedges_0.9_dia_e} = 0.00 \text{ kip*ft}$

Soil Wedges (Cohesionless Soil) (1.2*D LC)

| Soil | Volume (ft³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|---------------------------------------|--------------|--------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (1) End Prism (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (1) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Rear (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Rear (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| Total | 0.00 | 0.00 | | 0.00 | Soil Wedge Wt (kip)= | 0.00 |

Unfactored Resisting Moment of Wedges (1.2*D LC): $M_{R_wedges_1.2} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$ $M_{R_wedges_1.2_dia_e} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Wedges (1.2*D LC): $\Phi M_{R_wedges_1.2} = 0.75 * M_{R_wedges_1.2_dia_e}$ $\Phi M_{R_wedges_1.2_dia_e} = 0.00 \text{ kip*ft}$

Soil Shear Strength (Cohesive Soil)

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|-------------------|------------|------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) Rear | 0.00 | 0.00 | 6.65 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 3.32 | 0.00 | | |
| Total | | 0.00 | | 0.00 | Soil Shear Strength (kip)= | 0.00 |

Unfactored Resisting Moment of Soil Shear (0.9*D LC): $M_{R_shear_0.9} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_0.9_dia_e} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Soil Shear (0.9*D LC): $\Phi M_{R_shear_0.9} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_0.9_dia_e} = 0.00 \text{ kip*ft}$

Soil Shear Strength (Cohesive Soil) (1.2*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|-------------------|------------|------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) Rear | 0.00 | 0.00 | 6.65 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 3.32 | 0.00 | | |
| Total | | 0.00 | | 0.00 | Soil Shear Strength (kip)= | 0.00 |

Unfactored Resisting Moment of Soil Shear (1.2*D LC): $M_{R_shear_1.2} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_1.2_dia_e} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Soil Shear (1.2*D LC): $\Phi M_{R_shear_1.2} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_1.2_dia_e} = 0.00 \text{ kip*ft}$

DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (DIAGONAL)

Compressive Load for Bearing (0.9*D LC): $P_{100_dia_e} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_100_dia_e}$ $P_{100_dia_e} = 141.76 \text{ kip}$

Preliminary Factored Overturning Moment: $pre_M_{overturning_100_dia_e} = (\Phi Q_{ult-P_100_dia_e}/Area) * S_{dia}$ $pre_M_{overturning_100_dia_e} = 38.94$ kip*ft

Preliminary Load Eccentricity (0.9*D LC): $pre_ec_{100_dia_e} = pre_M_{overturning_100_dia_e} / P_{100_dia_e}$ $pre_ec_{100_dia_e} = 0.27$ ft

[Goal Seek] Load Eccentricity Iteration (0.9*D LC): $ec_{100_dia_e} = goal\ seek$ $ec_{100_dia_e} = 0.26$ ft

Non-Bearing Length (0.9*D LC): $NBL_{100_dia_e} = 0$ $NBL_{100_dia_e} = 0.00$ ft

Non-Bearing Length (0.9*D LC): $NBL_{100_dia_e_2} = 0$ $NBL_{100_dia_e_2} = 0.00$ ft

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC): $\Phi M_{Resisting_100_dia_e} = \Phi M_{R_Pp_dia} + \text{SUM}(\Phi M_{R_wedges_100_dia}, \Phi M_{R_shear_100_dia})$ $\Phi M_{Resisting_100_dia_e} = 2.61$ kip*ft

Moment Created by Shear: $M_{shear_e} = V_u * (D+E+bp_{dist}/12)$ $M_{shear_e} = 11.01$ kip*ft

Adjusted Overturning Moment (0.9*D LC): $M_{overturning_100_dia_e} = M_{u_max_100_dia} - \Phi M_{R_Pp_dia}$ $M_{overturning_100_dia_e} = 38.94$ kip*ft

Total Resistance to Overturning (0.9*D LC): $\Phi M_{Resisting_qu_100_dia_e} = P_{100_dia_e} * ec_{100_dia_e} + \Phi M_{Resisting_100_dia_e}$ $\Phi M_{Resisting_qu_100_dia_e} = 38.94$ kip*ft

[Goal Seek] Moment Comparison Iteration (0.9D LC): $\Delta M_{100_dia_e} = M_{overturning} - \Phi M_{Resisting_qu_100_dia}$ $\Delta M_{100_dia_e} = 0.00$ kip*ft

Maximum Applied Moment from Superstructure Analysis: $M_{u_max_100_dia_e} = pre_M_{overturning_100_dia} + \Phi M_{Resisting_100_dia}$ $M_{u_max_100_dia_e} = 41.55$ kip*ft

Check $Mu_{max_100_dia_e} = 41.55$ kip*ft $>=$ $Mu = 11.01$ kip*ft **RATING: 26.50% OK**

Soil Wedges (Cohesionless Soil) (0.9*D LC)

| Soil | Volume (ft³) | Soil Weight (kips) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|---------------------------------------|--------------|--------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) End Prisms (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (1) End Prism (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | Soil Wedge Wt (kip)= | 0.00 |
| (1) End Prisms (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Rear Sides (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Rear Sides (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Partial Sides (above Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| (2) Partial Sides (below Water Table) | 0.00 | 0.00 | 0.00 | 0.00 | | |
| Total | 0.00 | 0.00 | | 0.00 | | |

Unfactored Resisting Moment of Wedges (0.9*D LC): $M_{R_wedges_100_dia_e} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$ $M_{R_wedges_100_dia_e} = 0.00$ kip*ft

Factored Resisting Moment of Wedges (0.9*D LC): $\Phi M_{R_wedges_100_dia_e} = 0.75 * M_{R_wedges_100_dia_e}$ $\Phi M_{R_wedges_100_dia_e} = 0.00$ kip*ft

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

| Plane | Area (ft²) | Resistance (kip) | Moment Arm (ft) | Unfactored Resisting Moment (kip*ft) | Eccentricity relative to W/2*SQRT(2): | |
|-------------------|------------|------------------|-----------------|--------------------------------------|---------------------------------------|------|
| (2) Rear | 0.00 | 0.00 | 6.65 | 0.00 | Total Moment Arm (ft) = | 0.00 |
| (2) Partial Sides | 0.00 | 0.00 | 3.32 | 0.00 | | |
| Total | | 0.00 | | 0.00 | Soil Shear Strength (kip)= 0.00 | |

Unfactored Resisting Moment of Soil Shear (0.9*D LC): $M_{R_shear_100_dia_e} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_100_dia_e} = 0.00$ kip*ft

Factored Resisting Moment of Soil Shear (0.9*D LC): $\Phi M_{R_shear_100_dia_e} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_100_dia_e} = 0.00$ kip*ft

ATTACHMENT D – PROOF OF DELIVERY OF NOTICE

ORIGIN ID:RSPA (800) 301-3077
BL GRAPHICS
BL GRAPHICS
355 RESEARCH PARKWAY

SHIP DATE: 22MAY20
ACTWGT: 1.45 LB
CAD: 0765627/CAFE3311

MERIDEN, CT 06450
UNITED STATES US


BILL THIRD PARTY

TO **FIRST SELECTWOMAN PEGGY LYONS**
TOWN OF MADISON
8 CAMPUS DRIVE

MADISON CT 06443

REF: MADISON - BLACK&VEATCH

DEPT: BL GRAPHICS



FedEx
Express




J161219082001 10

TRK# 1714 2090 3848
0201

TUE - 26 MAY 10:30A
PRIORITY OVERNIGHT

00 RSPA

06443
CT-US **BDL**



Align bottom of peel-and-stick airbill or pouch here.

ORIGIN ID:RSPA (800) 301-3077
BL GRAPHICS
BL GRAPHICS
355 RESEARCH PARKWAY

SHIP DATE: 22MAY20
ACTWGT: 1.45 LB MAN
CAD: 0765627/CAFE3311

MERIDEN, CT 06450
UNITED STATES US


BILL THIRD PARTY

TO **DAVID ANDERSON TOWN PLANNER**
TOWN OF MADISON
8 CAMPUS DRIVE

MADISON CT 06443

REF: MADISON-BLACK&VEATCH

DEPT: BL GRAPHICS



FedEx
Express




J191219002003 UN

TRK# 1714 2090 3859
0201

TUE - 26 MAY 10:30A
PRIORITY OVERNIGHT

00 RSPA

06443
CT-US BDL



Align bottom of peel-and-stick airbill or pouch here.

ATTACHMENT E - POWER DENSITY REPORT



C Squared Systems, LLC
65 Dartmouth Drive
Auburn, NH 03032
603-644-2800
support@csquaredsystems.com

Calculated Radio Frequency Emissions Report



ES-008

135 New Road
Madison, CT 06443

April 2, 2020

Table of Contents

| | |
|---|---|
| 1. Introduction..... | 1 |
| 2. FCC Guidelines for Evaluating RF Radiation Exposure Limits..... | 1 |
| 3. Power Density Calculation Methods | 2 |
| 4. Calculated % MPE Results | 3 |
| 5. Conclusion | 4 |
| 6. Statement of Certification..... | 4 |
| Attachment A: References | 5 |
| Attachment B: FCC Limits for Maximum Permissible Exposure (MPE) | 6 |
| Attachment C: Eversource Antenna Data Sheet and Electrical Patterns | 8 |

List of Tables

| | |
|--|---|
| Table 1: Proposed Facility % MPE | 3 |
| Table 2: FCC Limits for Maximum Permissible Exposure (MPE) | 6 |

List of Figures

| | |
|---|---|
| Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE)..... | 7 |
|---|---|

1. Introduction

The purpose of this report is to investigate compliance with applicable FCC regulations for the proposed Eversource installation to be located at 135 New Road in Madison, CT.

Eversource is proposing to install one omnidirectional antenna as part of its 220 MHz communications system.

This report considers the proposed antenna configuration as detailed by Eversource along with power density information for the known existing antennas and field measurements of % MPE (Maximum Permissible Exposure) documented in the CT Siting Council's database to determine the cumulative % MPE of the facility at ground level.

2. FCC Guidelines for Evaluating RF Radiation Exposure Limits

In 1985, the FCC established rules to regulate radio frequency (RF) exposure from FCC licensed antenna facilities. In 1996, the FCC updated these rules, which were further amended in August 1997 by OET Bulletin 65 Edition 97-01. These new rules include Maximum Permissible Exposure (MPE) limits for transmitters operating between 300 kHz and 100 GHz. The FCC MPE limits are based upon those recommended by the National Council on Radiation Protection and Measurements (NCRP), developed by the Institute of Electrical and Electronics Engineers, Inc., (IEEE) and adopted by the American National Standards Institute (ANSI).

The FCC general population/uncontrolled limits set the maximum exposure to which most people may be subjected. General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure.

Public exposure to radio frequencies is regulated and enforced in units of milliwatts per square centimeter (mW/cm^2). The general population exposure limits for the various frequency ranges are defined in the attached "FCC Limits for Maximum Permissible Exposure (MPE)" in Attachment B of this report.

Higher exposure limits are permitted under the occupational/controlled exposure category, but only for persons who are exposed as a consequence of their employment and who have been made fully aware of the potential for exposure, and they must be able to exercise control over their exposure. General population/uncontrolled limits are five times more stringent than the levels that are acceptable for occupational, or radio frequency trained individuals. Attachment B contains excerpts from OET Bulletin 65 and defines the Maximum Exposure Limit.

Finally, it should be noted that the MPE limits adopted by the FCC for both general population/uncontrolled exposure and for occupational/controlled exposure incorporate a substantial margin of safety and have been established to be well below levels generally accepted as having the potential to cause adverse health effects.

3. Power Density Calculation Methods

The power density calculation results were generated using the following formula as outlined in FCC bulletin OET 65, and Connecticut Siting Council recommendations:

$$\text{Power Density} = \left(\frac{1.6^2 \times 1.64 \times \text{ERP}}{4\pi \times R^2} \right) \times \text{Off Beam Loss}$$

Where:

EIRP = Effective Isotropic Radiated Power = 1.64 x ERP

R = Radial Distance = $\sqrt{(H^2 + V^2)}$

H = Horizontal Distance from antenna

V = Vertical Distance from radiation center of antenna

Ground reflection factor of 1.6

Off Beam Loss is determined by the selected antenna pattern

These calculations assume that the antennas are operating at 100 percent capacity and full power, and that all antenna channels are transmitting simultaneously. Obstructions (trees, buildings, etc.) that would normally attenuate the signal are not taken into account. The calculations assume even terrain in the area of study and do not consider actual terrain elevations which could attenuate the signal. As a result, the calculated power density and corresponding % MPE levels reported below are much higher than the actual levels will be from the final installation.

4. Calculated % MPE Results

Table 1 below outlines the power density information for the site. The proposed Eversource omnidirectional antenna has a relatively narrow vertical beamwidth of 30°; therefore, the majority of the RF power is focused out towards the horizon. As a result, there will be less RF power directed below the antennas relative to the horizon, and consequently lower power density levels around the base of the facility. The calculated results in Table 1 include a nominal 10 dB off-beam pattern loss to account for the lower relative gain below any panel and omni-directional antennas, and a nominal 30 dB off-beam pattern loss for the highly directional point-to-point microwave antenna. Please refer to Attachment C, for the vertical pattern of the proposed Eversource antenna. Any inactive or receive-only antennas are not included in the table since they are irrelevant in terms of the % MPE calculations.

| Carrier | Antenna Height (Feet) | Operating Frequency (MHz) | Number of Trans. | ERP Per Transmitter (Watts) | Power Density (mw/cm ²) | Limit | % MPE | |
|------------|-----------------------|---------------------------|------------------|-----------------------------|-------------------------------------|--------------|---------------|-------|
| AT&T | 78.5 | 1900 | 2 | 500 | 0.0068 | 1.0000 | 0.68% | 2.94% |
| AT&T | 78.5 | 880 | 1 | 500 | 0.0034 | 0.5867 | 0.58% | |
| AT&T | 78.5 | 1900 | 1 | 427 | 0.0029 | 1.0000 | 0.29% | |
| AT&T | 78.5 | 880 | 2 | 296 | 0.0041 | 0.5867 | 0.69% | |
| AT&T | 78.5 | 740 | 1 | 500 | 0.0034 | 0.4933 | 0.69% | |
| T-Mobile | 160.5 | 2100 | 2 | 2335 | 0.0070 | 1.0000 | 0.70% | 1.69% |
| T-Mobile | 160.5 | 1900 | 4 | 1167 | 0.0070 | 1.0000 | 0.70% | |
| T-Mobile | 160.5 | 700 | 1 | 865 | 0.0013 | 0.4667 | 0.28% | |
| Sprint | 127.5 | 1900 | 2 | 693 | 0.0034 | 1.0000 | 0.34% | 0.51% |
| Sprint | 127.5 | 850 | 1 | 390 | 0.0010 | 0.5667 | 0.17% | |
| Verizon | 95 | 1970 | 7 | 447 | 0.0142 | 1.0000 | 1.42% | 6.61% |
| Verizon | 95 | 869 | 9 | 416 | 0.0170 | 0.5793 | 2.94% | |
| Verizon | 95 | 2145 | 1 | 2812 | 0.0128 | 1.0000 | 1.28% | |
| Verizon | 95 | 746 | 1 | 1067 | 0.0048 | 0.4973 | 0.97% | |
| Eversource | 190.5 | 936 | 1 | 240 | 0.0003 | 0.6240 | 0.04% | 1.06% |
| Eversource | 190.5 | 451.475 | 1 | 251 | 0.0003 | 0.3010 | 0.09% | |
| Eversource | 187.5 | 49.36 | 1 | 100 | 0.0001 | 0.2000 | 0.05% | |
| Eversource | 176.5 | 6695 | 1 | 871 | 0.0000 | 1.0000 | 0.00% | |
| Eversource | 148.5 | 154.46375 | 1 | 990 | 0.0018 | 0.2000 | 0.88% | |
| Eversource | 183 | 217 | 4 | 124 | 0.0006 | 0.2000 | 0.29% | |
| | | | | | | Total | 13.09% | |

Table 1: Proposed Facility % MPE ^{1 2}

The latest Siting Council power density database (12/13.2019) includes many “Unidentified” operators with a cumulative power density measurement of 13.37%, which was recorded on 4/13/2011 as part of AT&T’s application to the Council for its installation. In reviewing the structural analysis report along with Eversource’s latest antenna inventory, it is understood that all antennas, apart from AT&T, T-Mobile, Sprint, and Verizon (not currently installed), are operated by Eversource and have been accounted for in the table above.

If we are to assume the April 2011 measurement is in addition to the cumulative % MPE calculated above for an even more conservative review, the total % MPE would be 26.46% and remain below the FCC MPE limit. These % MPE totals also include Verizon, which is not currently installed as per the structural analysis report.

¹ Antenna heights listed (except for Verizon) are based upon the Black & Veatch Structural Analysis Report dated March 4, 2020. The Verizon antennas are not installed per the structural analysis but have been left in table based upon their CSC power density record.

² The power density information for carriers other than Eversource was taken directly from the CSC database dated 12/13/2019. Please note that % MPE values listed are rounded to two decimal points and the total % MPE listed is a summation of each unrounded contribution. Therefore, summing each rounded value may not identically match the total value reflected in the table.

5. Conclusion


The above analysis concludes that RF exposure at ground level with the proposed antenna installation will be below the maximum power density limits as outlined by the FCC in the OET Bulletin 65 Ed. 97-01. Using the conservative calculation methods discussed herein, the highest composite percent of Maximum Permissible Exposure expected at ground level with the proposed installation is **13.09% of the FCC General Population/Uncontrolled limit.**

If assuming the % MPE measurement from April 2011 does not include any contributions from the antennas listed for an even more conservative review, the composite (measured + calculated) power density would be **26.46% of the FCC General Population/Uncontrolled limit.**

As noted previously, the calculated % MPE levels are more conservative (higher) than the actual levels will be from the finished installation.


6. Statement of Certification

I certify to the best of my knowledge that the statements in this report are true and accurate. The calculations follow guidelines set forth in FCC OET Bulletin 65 Edition 97-01, IEEE Std. C95.1, and IEEE Std. C95.3.



Report Prepared By: Sokol Andoni
Associate RF Engineer
C Squared Systems, LLC

April 2, 2020
Date



Reviewed/Approved By: Keith Vellante
Director of RF Services
C Squared Systems, LLC

April 2, 2020
Date

Attachment A: References

OET Bulletin 65 - Edition 97-01 - August 1997 Federal Communications Commission Office of Engineering & Technology

IEEE C95.1-2005, IEEE Standard Safety Levels With Respect to Human Exposure to Radio Frequency Electromagnetic Fields, 3 kHz to 300 GHz IEEE-SA Standards Board

IEEE C95.3-2002 (R2008), IEEE Recommended Practice for Measurements and Computations of Radio Frequency Electromagnetic Fields With Respect to Human Exposure to Such Fields, 100 kHz-300 GHz IEEE-SA Standards Board

Attachment B: FCC Limits for Maximum Permissible Exposure (MPE)

(A) Limits for Occupational/Controlled Exposure³

| Frequency Range (MHz) | Electric Field Strength (E) (V/m) | Magnetic Field Strength (E) (A/m) | Power Density (S) (mW/cm ²) | Averaging Time E ² , H ² or S (minutes) |
|-----------------------|-----------------------------------|-----------------------------------|---|---|
| 0.3-3.0 | 614 | 1.63 | (100)* | 6 |
| 3.0-30 | 1842/f | 4.89/f | (900/f ²)* | 6 |
| 30-300 | 61.4 | 0.163 | 1.0 | 6 |
| 300-1500 | - | - | f/300 | 6 |
| 1500-100,000 | - | - | 5 | 6 |

(B) Limits for General Population/Uncontrolled Exposure⁴

| Frequency Range (MHz) | Electric Field Strength (E) (V/m) | Magnetic Field Strength (E) (A/m) | Power Density (S) (mW/cm ²) | Averaging Time E ² , H ² or S (minutes) |
|-----------------------|-----------------------------------|-----------------------------------|---|---|
| 0.3-1.34 | 614 | 1.63 | (100)* | 30 |
| 1.34-30 | 824/f | 2.19/f | (180/f ²)* | 30 |
| 30-300 | 27.5 | 0.073 | 0.2 | 30 |
| 300-1500 | - | - | f/1500 | 30 |
| 1500-100,000 | - | - | 1.0 | 30 |

f = frequency in MHz * Plane-wave equivalent power density

Table 2: FCC Limits for Maximum Permissible Exposure (MPE)

³ Occupational/controlled limits apply in situations in which persons are exposed as a consequence of their employment provided those persons are fully aware of the potential for exposure and can exercise control over their exposure. Limits for occupational/controlled exposure also apply in situations when an individual is transient through a location where occupational/controlled limits apply provided he or she is made aware of the potential for exposure

⁴ General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure





Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE)

Attachment C: Eversource Antenna Data Sheet and Electrical Patterns

| | |
|--|--|
| <p>217 MHz</p> <p>Manufacturer: dbSpectra Model #: DS2C03F36D Frequency Band: 217-222 MHz Gain: 3.0 dBd Vertical Beamwidth: 30° Horizontal Beamwidth: 360° Polarization: Vertical-Polarization Length: 24.3'</p> | <p style="text-align: center;">DS2C03F36D-N DS2C03F36D-D</p>  <p style="text-align: center;">Top Bottom</p> |
|--|--|