



August 25, 2022

**VIA ELECTRONIC MAIL**

Melanie A. Bachman, Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

**RE: CSC Approval EM-CING-082-211207 Middlefield PalisadesDr**  
Generator Installation 134 Kikapoo Road, Middlefield, CT 06455

Dear Ms. Bachman,

The purpose of this letter is to notify the Siting Council that construction activity associated with the above-referenced decisions has been completed.

If you have any questions or need any additional information regarding this facility, please do not hesitate to contact me.

Sincerely,

Steven J. Volkert  
Site Acquisition Specialist  
General Dynamics Wireless Services  
2586 Industry Lane, Ste. 100  
Norristown, Pa 19403  
(318) 642-6190 phone  
[steven.volpert@gdit.com](mailto:steven.volpert@gdit.com)

**GENERAL DYNAMICS**  
Information Technology

## **Generator Contractor Notice of Completion**

I, \_\_\_\_\_, confirm that the awarded scope of work at site \_\_\_\_\_ is complete, and all work meets industry standards and jurisdictional code requirements. All required inspections were completed, and all permits are closed. Please find the required notice of completion form with photos, etc. attached for your review and acceptance.

GC Signature 

Site Xitor ID \_\_\_\_\_

Project Xitor ID \_\_\_\_\_

Workflow ID \_\_\_\_\_

## Generator Contractor Notice of Completion

| General Site Information |  |
|--------------------------|--|
| FA Number                |  |
| Address Line 1           |  |
| Address Line 2           |  |
| City, State, Zip         |  |

| Contractor Information |  |
|------------------------|--|
| Contractor Name        |  |
| PM or POC              |  |
| Phone Number           |  |
| Email Address          |  |

| Final Accounting              |  |
|-------------------------------|--|
| Base PO Amount                |  |
| Approved Work Authorizations  |  |
| Total Due at Final Acceptance |  |
| Release of Liens              |  |

| Documentation                |  |
|------------------------------|--|
| Daily CHA Forms (zipped)     |  |
| Permits Closed Out           |  |
| Fuel Receipt (if applicable) |  |
| Redline CDs                  |  |
| Pre-Start Checklist          |  |

## Notice of Completion - Photos

| General Site Information |  |       |
|--------------------------|--|-------|
| Item #                   | Description  | Photo |
| C1-GD                    | ATS installed and Grounded as per CD's                               |       |
| C2-GD                    | All foundations are oriented as per CD's                             |       |
| C3-GD                    | All foundations set, Square, Level & Correct Size as per CD's        |       |
| C4-GD                    | All Conduits installed as per CD's                                   |       |
| C5-GD                    | Automatic Transfer Switch (ATS) Installed (if applicable) / Cam-Lock |       |
| C6-GD                    | All wiring from the generator to the ATS correct gauge               |       |
| C7-GD                    | Generator Control & Alarm Wires Installed and Labeled w/66 block     |       |
| C8-GD                    | Generator frame attached to ground system with 2 hole lug            |       |
| C9-GD                    | Housekeeping: All trash removed                                      |       |
| C10-GD                   | Remove construction materials and clean site                         |       |
| C11-GD                   | Generator undamaged & clean  |       |
| C12-GD                   | Fuel Tank Installed level and as per CD's                            |       |

| Item #              | Description  | Photo |
|---------------------|--|-------|
| <b>C13-GD</b>       | Initial Fueling Complete, filled to 80%                            |       |
| <b>C14-GD</b>       | Individual alarms labeled and run to the 66 alarm block in shelter |       |
| <b>C15-AT&amp;T</b> | All documentation left on site including manual and keys           |       |
| <b>C17-AT&amp;T</b> | Install information added to log book in site                      |       |
| <b>C18-AT&amp;T</b> | Generator Commissioning Complete                                   |       |
| <b>C22-AT&amp;T</b> | Signage installed on generator                                     |       |
| <b>C23-AT&amp;T</b> | Padlocks installed on ATS and fuel door                            |       |
| <b>A1</b>           | Pre-Construction Photos-General site area                          |       |
| <b>A2</b>           | Foundation rebar photos, measure rebar size and spacing            |       |
| <b>A3</b>           | Generator Anchor Bolts to Slab, 2 each side                        |       |
| <b>A4</b>           | Trench depth photos  |       |
| <b>A5</b>           | Conduit installation depth   |       |
| <b>A6</b>           | CAD Weld from generator ground to existing ground ring             |       |

| Item # | Description                                     | Photo |
|--------|---|-------|
| A7     | Post Construction Photos                        |       |
| B5     | ATS Serial #                                    |       |
| B6     | Engine serial #                                 |       |
| B7     | Labeling of circuit breakers and panel schedule |       |
| B8     | Site signage for compliance                     |       |
| B9     | Daily Logs-Site Log Book Photo Required         |       |



**STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL**

Ten Franklin Square, New Britain, CT 06051  
Phone: (860) 827-2935 Fax: (860) 827-2950  
E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)  
Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

**VIA ELECTRONIC MAIL**

January 24, 2022

Daniel Patrick, Esq.  
Cuddy & Feder LLP  
445 Hamilton Avenue, 14<sup>th</sup> Floor  
White Plains, NY 10601  
[dppatrick@cuddyfeder.com](mailto:dppatrick@cuddyfeder.com)

**RE: EM-CING-082-211207** - New Cingular Wireless, PCS, LLC (AT&T) notice of intent to modify an existing telecommunications facility located at Palisades Drive (a/k/a 134 Kickapoo Road), Middlefield, Connecticut.

Dear Attorney Patrick:

The Connecticut Siting Council (Council) hereby acknowledges your notice to modify this existing telecommunications facility, pursuant to Section 16-50j-73 of the Regulations of Connecticut State Agencies with the following conditions:

1. Construction activities shall take place during daylight working hours consistent with Condition No. 8 of the Council's Decision and Order in Docket No. 40;
2. Any deviation from the proposed modification as specified in this notice and supporting materials submitted to the Council shall render this acknowledgement invalid;
3. Any material changes to this modification as proposed shall require the filing of a new notice with the Council;
4. The Council shall be notified in writing at least two weeks prior to the commencement of site construction activities;
5. Within 45 days after completion of construction, the Council shall be notified in writing that construction has been completed;
6. Any nonfunctioning equipment at this facility owned and operated by AT&T shall be removed within 60 days of the date the equipment ceased to function;
7. The validity of this action shall expire one year from the date of this letter; and
8. The applicant may file a request for an extension of time beyond the one year deadline provided that such request is submitted to the Council not less than 60 days prior to the expiration.

The proposed modifications including the placement of all necessary equipment and shelters within the tower compound are to be implemented as specified here and in your notice dated December 6, 2021. The modifications are in compliance with the exception criteria in Section 16-50j-72 (b) of the Regulations of Connecticut State Agencies as changes to an existing facility site that would not increase

tower height, extend the boundaries of the tower site by any dimension, increase noise levels at the tower site boundary by six decibels or more, and increase the total radio frequencies electromagnetic radiation power density measured at the tower site boundary to or above the standards adopted by the Federal Communications Commission pursuant to Section 704 of the Telecommunications Act of 1996 and by the state Department of Energy and Environmental Protection pursuant to Connecticut General Statutes § 22a-162. This facility has also been carefully modeled to ensure that radio frequency emissions are conservatively below state and federal standards applicable to the frequencies now used on this tower.

This decision is under the exclusive jurisdiction of the Council. Please be advised that the validity of this action shall expire one year from the date of this letter. Any additional change to this facility will require explicit notice to this agency pursuant to Regulations of Connecticut State Agencies Section 16-50j-73. Such notice shall include all relevant information regarding the proposed change with cumulative worst-case modeling of radio frequency exposure at the closest point of uncontrolled access to the tower base, consistent with Federal Communications Commission, Office of Engineering and Technology, Bulletin 65. Thank you for your attention and cooperation.

Sincerely,



Melanie A. Bachman  
Executive Director

MAB/CMW/emr

c: The Honorable Robert Yamartino, First Selectman, Town of Middlefield  
(ryamartino@middlefieldct.org)