

July 13, 2016

Melanie A. Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: **EM-VER-084-141117 – Cellco Partnership d/b/a Verizon Wireless  
185 Research Drive, Milford, Connecticut**

Dear Ms. Bachman:

On December 14, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 185 Research Drive in Milford, Connecticut. The modifications involved the replacement of its antennas.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that the recommendations made in the structural report were complied with. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to the structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment  
Copy to:  
Tim Parks

15017961-v1

June 13, 2016

**Mr. Tim Parks**

Verizon Wireless  
99 East River Drive  
East Hartford, Connecticut 06108

**Re: Tower Modification Certification**

**Project:** Verizon Milford S2  
185 Research Drive, Milford, CT

**Tower Owner:** American Tower Corp.  
3500 Regency Parkway, Suite 100, Cary NC 27518

**Engineer:** American Tower Corp.  
3500 Regency Parkway, Suite 100, Cary NC 27518

**Centek Project No.:** 16003.12 Milford S2

**CSC Exempt Mod Reference No.:** EM-VER-084-141117

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the Structural Analysis Report prepared by American Towers Corp. (ATC Project Number: 302535):

- Review of the American Towers Corp. Structural Analysis dated 02/13/2014.
- Review of American Towers Corp. Modification Drawings dated 07/14/2014.
- Review of Tower Engineering Professionals Modification Inspection Report dated 03/31/2015.
- Field observations by Centek Engineering personnel on 07/12/16 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the aforementioned structural analysis and modification inspection report.

The modification design prepared by ATC demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,

  
Carlo F. Centore, PE  
Principal - Structural

