



56 Prospect Street,
P.O. Box 270
Hartford, CT 06103

Kathleen M. Shanley
Manager – Transmission Siting
Tel: (860) 728-4527

June 25, 2020

Melanie A. Bachman
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: **Notice of Exempt Modification**
Eversource Site # 15215
20 Barnabas Road, Newtown, CT 06470
Latitude: 41-25-39.5 N / Longitude: 73-20-37.5 W

Dear Ms. Bachman:

The Connecticut Light and Power Company doing business as Eversource Energy (“Eversource”) currently maintains multiple antennas and equipment at various mounting heights on an existing 180-foot self-support tower located at 20 Barnabas Road in Newtown. See [Attachment A](#), Parcel Map and Property Card. The tower and property are owned by Eversource. Eversource plans to install two omnidirectional antennas, one bottom mounted and one inverse mounted, at 165 feet above ground level (“AGL”) with a total length of 24.3 feet, and two 7/8-inch diameter coaxial cables. There will be no changes to the area of the fenced compound, the tower, or the antennas and equipment currently mounted on the tower. The tower and existing and proposed equipment on the tower are depicted on [Attachment B](#), Construction Drawings, dated March 26, 2020 and [Attachment C](#), Structural Analysis, dated March 26, 2020. The Connecticut Siting Council approved the self-support tower at this location in Docket No. 144 in November 1991.

The proposed installation is part of Eversource’s program to update the current obsolete analog voice radio communications system to a modern digital voice communications system. The new system will enable the highest level of voice communications under all operating conditions, including during critical emergency and storm restoration activities. The new radio system will also provide for remote control of distribution safety equipment.


Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies (“R.C.S.A.”) §16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this notice is being delivered to Daniel Rosenthal, First Selectman for the Town of Newtown and George Benson, Director of Planning for the Town of Newtown via the United States Postal Service or private carrier. Proof of delivery is attached. See [Attachment D](#), Proof of Delivery of Notice.

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2):

1. There will be no change to the height of the existing tower.
2. The proposed modifications will not require the extension of the site boundary.
3. The proposed modification will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The operation of the new antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard as shown in the attached Calculated Radio Frequency Emissions Report, dated April 3, 2020 (Attachment E – Power Density Report)¹.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, Eversource respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. § 16-50j-72(b)(2). One original copy of this notice has been provided via courier to the Council.

Communications regarding this Notice of Exempt Modification should be directed to Kathleen Shanley at (860) 728-4527.

By: 

Kathleen M. Shanley
Manager – Transmission Siting

cc: Honorable Daniel Rosenthal, First Selectman, Town of Newtown
George Benson, Director of Planning, Town of Newtown

Attachments

- A. Parcel Map and Property Card
- B. Construction Drawings
- C. Structural Analysis
- D. Proof of Delivery of Notice
- E. Power Density Report

¹ Any inactive or receive-only antennas are not included in the Power Density Report, as they are irrelevant in terms of the % MPE calculations.

ATTACHMENT A – PARCEL MAP AND PROPERTY CARD


Town of Newtown, Connecticut - Assessment Parcel Map


Parcel: 5-7-11

Address: 20 BARNABAS ROAD




Legend

 Approximate Tower Location



Approximate Scale:



Disclaimer: This map is for informational purposes only.
All information is subject to verification by any user.
The Town of Newtown and its mapping contractors
assume no legal responsibility for the
information contained herein.

Map Produced Oct 2016




Property Information

Property Location	20 BARNABAS ROAD
Owner	BARNABAS REALTY GROUP GEN PRTSHP
Co-Owner	C/O EVERSOURCE
Mailing Address	107 SELDEN STREET BERLIN CT 06037
Land Use	3400 OFFICE
Land Class	C
Zoning Code	M-1
Census Tract	
Sub Lot	
Neighborhood	C090
Acreage	23.9
Utilities	Well,Septic
Lot Setting/Desc	
Survey Map	
TC Survey Numbers	

Photo



Sketch



Primary Construction Details

Year Built	1991
Stories	1
Building Style	Office
Building Use	Comm/Ind
Building Condition	B
Floors	Carpet
Total Rooms	

Bedrooms	
Full Bathrooms	
Half Bathrooms	
Bath Style	
Kitchen Style	
Roof Style	Flat
Roof Cover	Rolled Compos

Exterior Walls	Concr/CinderBk
Interior Walls	Drywall/Sheet
Heating Type	Hot Water
Heating Fuel	Gas
AC Type	Central
Gross Bldg Area	71702
Total Living Area	40066



Town of Newtown, CT

Property Listing Report

Map Block Lot

5-7-11-1

Account

00696701

Valuation Summary (Assessed value = 70% of Appraised Value)

Item	Appraised	Assessed
Buildings	4870910	3409640
Extras	13200	9240
Outbuildings	300050	210030
Land	2872800	2010960
Total	8056960	5639870

Sub Areas

Subarea Type	Gross Area (sq ft)	Living Area (sq ft)
Canopy	17596	0
Canopy	17596	0
Patio - Concrete	11418	0
Patio - Concrete	11418	0
Open Porch	168	0
Open Porch	168	0
First Floor	40066	40066
First Floor	40066	40066
Loading Platform	2454	0
Total Area	71702	40066

Outbuilding and Extra Items

Type	Description
Fence	1600 L.F.
Fence	1600 L.F.
Tower	1 UNITS
Tower	1 UNITS
Paving	340000 S.F.
Paving	340000 S.F.
Fence	19200 L.F.
Fence	19200 L.F.
Lights	12 UNITS
Lights	12 UNITS

Sales History

Owner of Record	Book/ Page	Sale Date	Sale Price
BARNABAS REALTY GROUP GEN PRTSHP	423 /805	9/25/1990	0
BARNABAS REALTY GROUP GEN PRTSHP	423 /805	9/25/1990	0





Town of Newtown, CT

Property Listing Report



Map Block Lot **5-7-11-1**

Account **00696701**

<p>Photo</p> 	<p>Sketch</p> 
---	---

Primary Construction Details	
Year Built	1991
Stories	1
Building Style	Light Indust
Building Use	Comm/Ind
Building Condition	B
Floors	Concr-Finished
Total Rooms	
Bedrooms	
Bathrooms	
Bath Style	
Half Bath	
Kitchen Style	
Roof Style	Flat
Roof Cover	Rolled Compos
Exterior Walls	Pre-Fin Metal
Interior Walls	Drywall/Sheet
Heating Type	Susp. Space
Heating Fuel	Gas
AC Type	Central
Gross Bldg Area	
Total Living Area	

Sub Areas	Gross Area (sq ft)	Living Area (sq ft)
Subarea Type		
First Floor	9216	9216
First Floor	9216	9216
Total Area		

<p>Photo</p> 	<p>Sketch</p> 
---	--

Primary Construction Details	
Year Built	1995
Stories	1
Building Style	Light Indust
Building Use	Ind/Comm
Building Condition	B
Floors	Concr-Finished
Total Rooms	
Bedrooms	
Bathrooms	
Bath Style	
Half Bath	
Kitchen Style	
Roof Style	Flat
Roof Cover	Rolled Compos
Exterior Walls	Pre-cast Concr
Interior Walls	Minim/Masonry
Heating Type	Susp. Space
Heating Fuel	Gas
AC Type	Central
Gross Bldg Area	
Total Living Area	

Subarea Type	Gross Area (sq ft)	Living Area (sq ft)
First Floor	200	200
First Floor	200	200
Total Area		

ATTACHMENT B – CONSTRUCTION DRAWINGS



EVERSOURCE
ENERGY

107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000



BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

NEWTOWN AWC 20 BARNABAS RD NEWTOWN, CT 06470

PROJECT SUMMARY

THE GENERAL SCOPE OF WORK CONSISTS OF THE FOLLOWING:

1. INSTALL (2) NEW OMNI/WHIP ANTENNAS, (1) AT ELEVATION 180'-0"± AGL AND (1) AT ELEVATION 165'-0"± AGL
2. INSTALL (1) NEW RACK WITH NEW DMR EQUIPMENT IN EXISTING TELECOM ROOM

GOVERNING CODES

2018 CONNECTICUT STATE BUILDING CODE (2015 IBC BASIS)
2017 NATIONAL ELECTRIC CODE
TIA-222-H

GENERAL NOTES

THE FACILITY IS UNMANNED AND NOT FOR HUMAN HABITATION. A TECHNICIAN WILL VISIT THE SITE AS REQUIRED FOR ROUTINE MAINTENANCE. THE PROJECT WILL NOT RESULT IN ANY SIGNIFICANT DISTURBANCE OR EFFECT ON DRAINAGE; NO SANITARY SEWER SERVICE, POTABLE WATER, OR TRASH DISPOSAL IS REQUIRED AND NO COMMERCIAL SIGNAGE IS PROPOSED.

SITE INFORMATION


SITE NAME: NEWTOWN AWC
SITE ID NUMBER: #15215
SITE ADDRESS: 20 BARNABAS RD
NEWTOWN, CT 06470
MAP: 5
BLOCK: 7
LOT: 11
LATITUDE: 41° 25' 39.5" N
LONGITUDE: 73° 20' 37.5" W
ELEVATION: 457'± AMSL
FEMA/FIRM DESIGNATION: X

CONTACT INFORMATION

APPLICANTS:
EVERSOURCE ENERGY
107 SELDEN STREET
BERLIN, CT 06037
PROPERTY OWNER:
EVERSOURCE ENERGY
107 SELDEN STREET
BERLIN, CT 06037
EVERSOURCE ENERGY
PROJECT MANAGER:
NIKOLL PRECI
(860) 655-3079

POWER PROVIDER:
EVERSOURCE ENERGY
(800) 286-2000
TELCO PROVIDER:
FRONTIER
(800) 921-8102
CALL BEFORE YOU DIG:
(800) 922-4455

LOCATION MAP



DESIGN TYPE

SITE UPGRADE
SELF-SUPPORT TOWER

DRAWING INDEX

SHEET NO:	SHEET TITLE
T-1	TITLE SHEET
C-1	SITE PLAN
C-2	TOWER ELEVATION
G-1	GROUNDING DETAILS
N-1	NOTES & SPECIFICATIONS
N-2	NOTES & SPECIFICATIONS
N-3	NOTES & SPECIFICATIONS

DO NOT SCALE DRAWINGS

SUBCONTRACTOR SHALL VERIFY ALL PLANS & EXISTING DIMENSIONS & CONDITIONS ON THE JOB SITE & SHALL IMMEDIATELY NOTIFY THE ENGINEER IN WRITING OF ANY DISCREPANCIES BEFORE PROCEEDING WITH THE WORK OR BE RESPONSIBLE FOR SAME




UNDERGROUND SERVICE ALERT
UTILITIES PROTECTION CENTER, INC.
811

48 HOURS BEFORE YOU DIG

PROJECT NO: 403093
DRAWN BY: TYW
CHECKED BY: THM

REV	DATE	DESCRIPTION
0	03/26/20	ISSUED FOR FILING




IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.



NEWTOWN AWC
20 BARNABAS RD
NEWTOWN, CT 06470

SHEET TITLE
TITLE SHEET

SHEET NUMBER
T-1



- TOP OF EXISTING ANTENNA (NON-EVERSOURCE)
ELEVATION 194'-0"± AGL
- TOP OF EXISTING EVERSOURCE ANTENNA
ELEVATION 180'-0"± AGL
- EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 145'-0"± AGL
- EXISTING ANTENNA (NON-EVERSOURCE)
RAD CL ELEVATION 138'-0"± AGL
- EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 130'-0"± AGL
- EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 120'-0"± AGL
- EXISTING ANTENNAS (NON-EVERSOURCE)
RAD CL ELEVATION 88'-0"± AGL



EVERSOURCE ENERGY

107 SELDEN STREET
BERLIN, CT 06037
PHONE: (800) 286-2000




BLACK & VEATCH

6800 W 115TH ST, SUITE 2292
OVERLAND PARK, KS 66211
PHONE: (913) 458-3595

PROJECT NO:	403093
DRAWN BY:	TYW
CHECKED BY:	THM

REV	DATE	DESCRIPTION
0	03/26/20	ISSUED FOR FILING



IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

NEWTOWN AWC
20 BARNABAS RD
NEWTOWN, CT 06470

SHEET TITLE
TOWER ELEVATION

SHEET NUMBER
C-2

REFERENCE CUTSHEETS

ANT220F6


FIBERGLASS COLLINEAR ANTENNA 6 dBd

The Telewave ANT220F6 is an extremely rugged, medium-gain, fiberglass collinear antenna, designed for operation in all environmental conditions. The antenna is constructed with brass and copper elements, connected at DC ground potential for lightning impulse protection. The ANT220F6 is an excellent choice for wireless PTC systems in urban or rural areas.



All junctions are fully soldered to prevent RF intermodulation, and each antenna is completely protected within a rugged, high-tech radome to ensure survivability in the worst environments. The "Cool Blue" radome provides maximum protection from corrosive gases, ultraviolet radiation, icing, salt spray, acid rain, and wind blown abrasives.

The ANT220F6 includes an ANTC482 dual clamp set for mounting to a 1.5" to 3.5" O.D. support pipe, and a 24" removable RG-213 N-Male jumper. Stand-off and top mounts are also available.

NOTE: THIS ANTENNA IS SHIPPED VIA TRUCK FREIGHT ONLY



ANT220F6 - 221 MHz
Vertical Plane
Gain = 6.11 dBd



SPECIFICATIONS			
Frequency (continuous)	216-225 MHz	Dimensions (L x base diam.) in.	171 x 2.75
Gain	6 dBd	Tower weight (antenna + clamps)	35 lb.
Power rating (typ.)	500 watts	Shipping weight	50 lb.
Impedance	50 ohms	Wind rating / with 0.5" ice	150 / 125 MPH
VSWR	1.5:1 or less	Maximum exposed area	3.1 ft. ²
Pattern	Omnidirectional	Lateral thrust at 100 MPH	122 lb.
Vertical beamwidth	20°	Bending moment at top clamp	494 ft. lb.
Termination	Recessed N Female 7-16 DIN-F opt.	(100 MPH, 40 PSF flat plate equiv.)	

Mast OD

ANT220F6-I w/DIN CONNECTOR to be used for the inverted antenna.

ANT220F6


FIBERGLASS COLLINEAR ANTENNA 6 dBd

The Telewave ANT220F6 is an extremely rugged, medium-gain, fiberglass collinear antenna, designed for operation in all environmental conditions. The antenna is constructed with brass and copper elements, connected at DC ground potential for lightning impulse protection. The ANT220F6 is an excellent choice for wireless PTC systems in urban or rural areas.



All junctions are fully soldered to prevent RF intermodulation, and each antenna is completely protected within a rugged, high-tech radome to ensure survivability in the worst environments. The "Cool Blue" radome provides maximum protection from corrosive gases, ultraviolet radiation, icing, salt spray, acid rain, and wind blown abrasives.

The ANT220F6 includes an ANTC482 dual clamp set for mounting to a 1.5" to 3.5" O.D. support pipe, and a 24" removable RG-213 N-Male jumper. Stand-off and top mounts are also available.

NOTE: THIS ANTENNA IS SHIPPED VIA TRUCK FREIGHT ONLY







ANT220F6 - 221 MHz
Vertical Plane
Gain = 6.11 dBd



SPECIFICATIONS			
Frequency (continuous)	216-225 MHz	Dimensions (L x base diam.) in.	171 x 2.75
Gain	6 dBd	Tower weight (antenna + clamps)	35 lb.
Power rating (typ.)	500 watts	Shipping weight	50 lb.
Impedance	50 ohms	Wind rating / with 0.5" ice	150 / 125 MPH
VSWR	1.5:1 or less	Maximum exposed area	3.1 ft. ²
Pattern	Omnidirectional	Lateral thrust at 100 MPH	122 lb.
Vertical beamwidth	20°	Bending moment at top clamp	494 ft. lb.
Termination	Recessed N Female 7-16 DIN-F opt.	(100 MPH, 40 PSF flat plate equiv.)	

TOWER/MAST SIZE AT PROPOSED ANTENNA ATTACHMENT = 2.875" ± DIAMETER.

EXISTING LEG,
1" TO 8" ROUND LEGS
OR 60° ANGLE LEGS



PARTS LIST						
ITEM	QTY	PART NO.	PART DESCRIPTION	LENGTH	UNIT WT.	NET WT.
1	1	CFM	UPPER GATE FOOT WELDMENT		13.90	13.90
2	1	CFS	LOWER GATE FOOT WELDMENT		12.72	12.72
3	2	GBB	GATE BACKING BAR		4.53	9.06
4	1	4PBG	48" PIPE MOUNT STANDOFF ARM		113.96	113.96
5	8	G12R-12	1/2" x 12" GALV. THREADED ROD		0.67	5.35
5	8	G12R-15	1/2" x 15" GALV. THREADED ROD		0.84	6.69
6	2	A1205	1/2" x 5" A325 HDG BOLT		0.34	0.69
7	18	G12FW	1/2" HDG USS FLATWASHER		0.03	0.61
8	18	G12LW	1/2" HDG LOCKWASHER		0.01	0.25
9	18	G12NUT	1/2" HDG HEAVY 2H HEX NUT		0.07	1.29
					TOTAL WT. #	164.53

TOLERANCE NOTES

TOLERANCES ON DIMENSIONS, UNLESS OTHERWISE NOTED ARE:
 SAWED, SHEARED AND GAS CUT EDGES ($\pm 0.030"$)
 DRILLED AND GAS CUT HOLES ($\pm 0.030"$) - NO CONING OF HOLES
 LASER CUT EDGES AND HOLES ($\pm 0.010"$) - NO CONING OF HOLES
 BENDS ARE $\pm 1/2$ DEGREE
 ALL OTHER MACHINING ($\pm 0.030"$)
 ALL OTHER ASSEMBLY ($\pm 0.060"$)

PROPRIETARY NOTE:
 THE DATA AND TECHNIQUES CONTAINED IN THIS DRAWING ARE PROPRIETARY INFORMATION OF VALMONT INDUSTRIES AND CONSIDERED A TRADE SECRET. ANY USE OR DISCLOSURE WITHOUT THE CONSENT OF VALMONT INDUSTRIES IS STRICTLY PROHIBITED.

DESCRIPTION

48" ULTIMATE UNIVERSAL
STANDOFF FRAME

CPD NO.	DRAWN BY	ENG. APPROVAL
CLASS	DRAWING USAGE	CHECKED BY
81	01	CUSTOMER
		BMC 2/16/2011



Engineering
Support Team:
1-888-753-7446

Locations:
New York, NY
Atlanta, GA
Los Angeles, CA
Plymouth, IN
Salem, OR
Dallas, TX

PART NO.	USF-4U	PAGE
DWG. NO.	USF-4U	1 OF 1

TIEBACK SPECIFICATIONS:

(1) SITE PRO 1 SPTB-NP

(1) SITE PRO 1 P2150 (2.375" O.D. X 12.5' LONG SCHEDULE 40 GALVANIZED PIPE)

Products (<http://www.sitepro1.com/store/cart.php>) > TOWER STEEL (http://www.sitepro1.com/store/cart.php?m=product_list&c=53) > Tower Components (http://www.sitepro1.com/store/cart.php?m=product_list&c=58)

2-3/8" Sliding Pipe Tie-Back Hardware, No Pipe

Qty: 1

Add to Cart

SKU: SPTB-NP

Size: See Description

My CartCheckout (<https://www.sitepro1.com/store/cart.php?m=checkout>)

Total: \$0.00

No items in your cart
Your cart is currently empty. As you add items, they will appear in your cart.

Quick Navigation

Description

- SPTB-NP
- **Universal Sliding Pipe Tie-Back Assemblies**
- 2-3/8" Sliding Pipe Tie-Back Hardware, No Pipe
- Weight 48 lb

- VIEW ALL TOWER COMPONENTS (https://www.sitepro1.com/store/cart.php?m=product_list&c=58)
- VIEW ALL TOWER STEEL (https://www.sitepro1.com/store/cart.php?m=product_list&c=53)
- VIEW COMPLETE PRODUCT CATALOG (https://www.sitepro1.com/store/cart.php?m=product_list)

Need Assistance?

Our support team is available from 8:30 AM - 8:00 PM ET to assist you.

☎ 888-438-7761 (tel:888-438-7761)

☎ 888-753-7446 (tel:888-753-7446)

✉ SP1Support@Valmont.com (mailto:SP1Support@Valmont.com)

Go Back (<https://www.google.com/url?sa=t&rct=j&q=&esrc=s&source=web&cd=1&ved=2ahUKEwjXj5e3y-nAhUK26wKHaL1A80QFJAAgQIBB&url=https%3A%2F>)



© Valmont Site Pro 1

Privacy (<https://www.sitepro1.com/privacy-policy/>) | Terms (<https://www.sitepro1.com/terms-of-use/>)

(<https://www.facebook.com/ValmontSitePro1/>)(<https://twitter.com/SitePro1>)(<https://www.linkedin.com/company/9469062/>)

Resources

A&E Digital Database (<https://www.sitepro1.com/datacenter/>)
Catalogs (<https://www.sitepro1.com/resources/>)
Product Specs & Drawings (<https://www.sitepro1.com/products/specs/>)
Bill of Materials Manager (<https://www.sitepro1.com/store/catalogs/bill-of-materials-manager/>)
SP1 Connection (<https://www.sitepro1.com/connection/>)
Equipment Platforms (<https://sitepro1.com/reader/web/viewer.php?link=../resources/pdf/Modular->

Company

About Us (<https://www.sitepro1.com/company-htm/>)
Leadership Letter (<https://www.sitepro1.com/letter-htm/>)
Customer Service (<https://www.sitepro1.com/customer-htm/>)
Customer Testimonials (<https://www.sitepro1.com/testimonials-htm/>)
Capabilities (<https://www.sitepro1.com/galleries/>)
Holiday Schedule (<https://www.sitepro1.com/holiday-schedule-htm/>)

ATTACHMENT C – STRUCTURAL ANALYSIS REPORT

Date: **March 26, 2020**



Black & Veatch Corp.
6800 W. 115th St., Suite 2292
Overland Park, KS 66211
(913) 458-2522

Subject: **Structural Analysis Report**

Eversource Designation: **Site Number:** ES-066
Site Name: NewtownAWC

Engineering Firm Designation: **Black & Veatch Corp. Project Number:** 403093

Site Data: **20 Barnabas Rd, Newtown, Fairfield County, CT**
Latitude 41° 25' 39.5", Longitude -73° 20' 37.5"
180 Foot - Self Support Tower

Black & Veatch Corp. is pleased to submit this **"Structural Analysis Report"** to determine the structural integrity of the above mentioned tower.

The purpose of the analysis is to determine acceptability of the tower stress level. Based on our analysis we have determined the tower stress level for the structure and foundation, under the following load case, to be:

LC1: Proposed Equipment Configuration **Sufficient Capacity – 96.3%**

This analysis utilizes an ultimate 3-second gust wind speed of 130 mph as required by the 2018 Connecticut State Building Code. Applicable Standard references and design criteria are listed in Section 2 - Analysis Criteria.

Structural analysis prepared by: Robert Hudson II / Christopher Giannotti

Respectfully submitted by:

Joshua J. Riley, P.E.
Professional Engineer




TABLE OF CONTENTS

1) INTRODUCTION

2) ANALYSIS CRITERIA

Table 1 - Proposed Equipment Configuration

Table 2 - Other Considered Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

3.1) Analysis Method

3.2) Assumptions

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Table 5 - Tower Component Stresses vs. Capacity

4.1) Recommendations

5) APPENDIX A

tnxTower Output

6) APPENDIX B

Base Level Drawing

7) APPENDIX C

Additional Calculations

1) INTRODUCTION

This tower is a 180 ft Self Support tower designed by Rohn.

2) ANALYSIS CRITERIA

TIA-222 Revision:	TIA-222-H
Risk Category:	III
Wind Speed:	130 mph ultimate
Exposure Category:	B
Topographic Factor:	1
Ice Thickness:	1.5 in
Wind Speed with Ice:	50 mph
Seismic Ss:	0.207
Seismic S1:	0.066
Service Wind Speed:	60 mph

Table 1 - Proposed Equipment Configuration

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)	Note
165.0	172.5	1	telewave	ANT220F6	2	7/8	-
	165.0	1	site pro 1	USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support]			
	157.5	1	telewave	ANT220F6			

Table 2 - Other Considered Equipment partially shielded

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)	Note
180.0	192.5	1	antennae	10' Dipole	2 1	7/8 1/2	1
	190.5	1	antennae	15' Omni			
	189.0	1	antennae	20' Omni			
	180.0	1	mount pipes	5'x2" Mount Pipe			
		1	mount pipes	5'x4" Mount Pipe			
177.0	177.0	1	dishes	6' Microwave Dish w/ Radome	1	EW63	1
		1	miscl	8' HSS4x4x3/8 Horizontal Mount			
		1	mount pipes	6'x2" Horizontal Pipe			
		1	mount pipes	6'x4" Mount Pipe			
174.0	176.0	1	antennae	12' Dipole	1	1/2	1
	174.0	1	mount pipes	2'x2" Mount Pipe			
157.0	161.0	1	antennae	5' Omni	2	7/8	1
	157.0	1	miscl	18"x18"x6" Junction Box			
		1	tower mounts	Side Arm Mount [SO 305-1]			
	153.0	1	antennae	5' Omni			

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)	Note
145.0	146.0	3	commscope	LNX-6512DS-T4M w/ Mount Pipe	12	1 5/8	1
	145.0	3	ericsson	AIR 21 B2A/B4P w/ Mount Pipe			
		3	mount pipes	5'x4" Horizontal Mount Pipe			
		3	rfscelwave	ATM1900D-1A20			
133.0	138.0	1	antennae	10' Dipole	1	7/8	1
	133.0	1	tower mounts	Side Arm Mount [SO 203-1]			
130.0	132.0	3	ericsson	RRUS 11	6 2 1	1 5/8 1 1/2 3" Conduit	1
	131.0	1	raycap	DC6-48-60-18-8F			
	130.0	3	kathrein	800 10121 w/ Mount Pipe			
		6	powerwave tech	LGP21401			
		3	powerwave tech	P65-16-XLH-RR w/ Mount Pipe			
1	tower mounts	Sector Mount [SM 405-3]					
120.0	123.0	2	rfs celwave	DB-T1-6Z-8AB-0Z	2	1 5/8	1
	122.0	3	alcatel lucent	RRH2X40-AWS			
		3	alcatel lucent	RRH2x40 700			
	121.0	6	amphenol	BXA-171063-12CF-EDIN-X w/ Mount Pipe			
		6	amphenol	BXA-70063-6CF-EDIN-X w/ Mount Pipe			
	120.0	1	tower mounts	Pipe Mount [PM 601-3]			
		1	tower mounts	Sector Mount [SM 502-3]			
88.0	88.0	3	alcatel lucent	1900MHz RRH	3	1 1/4	1
		3	alcatel lucent	800MHz RRH			
		1	powerwave tech	P40-16-XLPP-RR w/ Mount Pipe			
		2	rfs celwave	APXVSP18-C-A20 w/ Mount Pipe			
		1	tower mounts	Sector Mount [SM 502-3]			
56.0	56.0	1	gps	GPS_A	1	1/2	1
		1	mount pipes	3'x2" Horizontal Mount Pipe			

Notes:
 1) Existing Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

Document	Remarks	Reference	Source
GEOTECHNICAL REPORT	Dr. Clarence Welti, P.E., P.C., dated 10/19/2011	-	Eversource
TOWER FOUNDATION DRAWINGS/DESIGN/SPECS	Northeast Utilities Service Co., dated 3/01/1991	-	Eversource
TOWER STRUCTURAL MODIFICATION DRAWINGS	Centek Engineering, dated 11/18/2011	-	Eversource
TOWER STRUCTURAL MODIFICATION ANALYSIS REPORT	Centek Engineering, dated 11/29/2011	-	Eversource
TOWER STRUCTURAL MODIFICATION ANALYSIS REPORT	Centek Engineering, dated 4/09/2014	-	Eversource
TOWER STRUCTURAL MODIFICATION ANALYSIS REPORT	Centek Engineering, dated 11/10/2014	-	Eversource
TOWER STRUCTURAL ANALYSIS REPORT	AECOM, dated 2/16/2017	-	Eversource
TOWER STRUCTURAL MODIFICATION ANALYSIS REPORT	All-Points, dated 10/25/2018	-	Eversource

3.1) Analysis Method

tnxTower (version 8.0.5.0), a commercially available analysis software package, was used to create a three-dimensional model of the tower and calculate member stresses for various loading cases. Selected output from the analysis is included in Appendix A.

3.2) Assumptions

- 1) Tower and structures were built and maintained in accordance with the manufacturer's specifications.
- 2) The configuration of antennas, transmission cables, mounts and other appurtenances are as specified in Tables 1 and 2 and the referenced drawings.
- 3) The existing base plate grout was considered in this analysis. Grout must be maintained and inspected periodically and must be replaced if damaged or cracked.
- 4) Existing tower loading is based on 2018 drone mapping photos and the 2018 Structural Modification Analysis Report prepared by All-Points.
- 5) This analysis was performed under the assumption that all information provided to Black & Veatch is current and correct. This is to include site data, appurtenance loading, tower/foundation details, and geotechnical data.

This analysis may be affected if any assumptions are not valid or have been made in error. Black & Veatch Corp. should be notified to determine the effect on the structural integrity of the tower.

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Section No.	Elevation (ft)	Component Type	Size	Critical Element	P (K)	SF*P_allow (K)	% Capacity	Pass / Fail
T1	180 - 160	Leg	P2.5x0.203	3	-7.40	60.05	12.3	Pass
T2	160 - 140	Leg	P2.5x.276	33	-18.95	61.44	30.8	Pass
T3	140 - 120	Leg	P3x0.216	54	-35.86	74.43	48.2	Pass
T4	120 - 100	Leg	P4x0.337	75	-62.42	167.90	37.2	Pass
T5	100 - 80	Leg	P5x0.258	96	-87.60	150.57	58.2	Pass
T6	80 - 60	Leg	P5x0.375	111	-116.45	211.28	55.1	Pass
T7	60 - 40	Leg	P5x0.375	126	-145.27	211.26	68.8	Pass
T8	40 - 20	Leg	P6x0.432	141	-174.08	318.94	54.6	Pass
T9	20 - 0	Leg	P6x0.432	155	-203.60	318.94	63.8	Pass
T1	180 - 160	Diagonal	L1 3/4x1 3/4x3/16	11	-1.91	6.88	27.7 28.8 (b)	Pass
T2	160 - 140	Diagonal	L2x2x1/8	38	-2.61	4.33	60.3	Pass
T3	140 - 120	Diagonal	L2 1/2x2 1/2x3/16	59	-4.25	9.58	44.4 64.6 (b)	Pass
T4	120 - 100	Diagonal	L2 1/2x2 1/2x1/4	80	-5.91	9.78	60.5 67.6 (b)	Pass
T5	100 - 80	Diagonal	L3x3x3/8	101	-7.77	17.04	45.6 54.3 (b)	Pass
T6	80 - 60	Diagonal	L3 1/2x3 1/2x1/4	116	-8.31	16.01	51.9 86.9 (b)	Pass
T7	60 - 40	Diagonal	L3 1/2x3 1/2x3/8	131	-8.72	19.37	45.0 61.3 (b)	Pass
T8	40 - 20	Diagonal	L4x4x3/8	144	-9.64	25.38	38.0 66.2 (b)	Pass
T9	20 - 0	Diagonal	L4x4x3/8	159	-10.58	21.97	48.2 96.3 (b)	Pass
T1	180 - 160	Top Girt	L2 1/2x2 1/2x3/16	6	-0.17	7.01	2.4	Pass
							Summary	
							Leg (T7)	68.8 Pass
							Diagonal (T9)	96.3 Pass
							Top Girt (T1)	2.4 Pass
							Bolt Checks	96.3 Pass
							Rating =	96.3 Pass

Table 5 - Tower Component Stresses vs. Capacity - LC1

Notes	Component	Elevation (ft)	% Capacity	Pass / Fail
1	Anchor Rods	0	67.5	Pass
1	Base Foundation	0	35.9	Pass
	Base Foundation Soil Interaction		78.3	Pass

Structure Rating (max from all components) =	96.3%
---	--------------

Notes:

- 1) See additional documentation in "Appendix C – Additional Calculations" for calculations supporting the % capacity consumed.

4.1) Recommendations

The tower and its foundation have sufficient capacity to carry the proposed load configuration. No modifications are required at this time.

Maximum Tower Deflections - Service Wind

<i>Section No.</i>	<i>Elevation ft</i>	<i>Horz. Deflection in</i>	<i>Gov. Load Comb.</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Check*</i>
T1	180 - 160	2.408	39	0.1092	0.02	OK
T2	160 - 140	1.948	39	0.106	0.0188	OK
T3	140 - 120	1.506	39	0.0968	0.0133	OK
T4	120 - 100	1.118	39	0.0814	0.0098	OK
T5	100 - 80	0.779	39	0.0698	0.0069	OK
T6	80 - 60	0.506	39	0.0538	0.0054	OK

*Limit State Deformation (TIA-222-H Section 2.8.2)

1) Maximum Rotation = 4 Degrees

2) Maximum Deflection = 0.03 * Tower Height = 65 in.

Critical Deflections of Tower at the MW Dish Elevations - Service Wind

<i>Elevation (ft)</i>	<i>MW Dish</i>	<i>Tilt (°)</i>	<i>Twist (°)</i>	<i>Diameter, D (ft)</i>	<i>Frequency, α (GHz)</i>	<i>Decibel Points</i>	<i>Deformation Limit (θ)*</i>	<i>Deformation Limit Exceeded?</i>
177	6' Microwave Dish w/ Radome	0.1089	0.02	6	10	10 dB	0.885	Not Exceeded

*Limit per TIA-222-H Annex D

Maximum Tower Deflections - Design Wind

<i>Section No.</i>	<i>Elevation ft</i>	<i>Horz. Deflection in</i>	<i>Gov. Load Comb.</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Combined Max</i>	<i>Check*</i>
T1	180 - 160	6.672	39	0.3006	0.0566	0.306	OK
T2	160 - 140	5.408	39	0.291	0.0532	0.296	OK
T3	140 - 120	4.19	39	0.2669	0.0377	0.270	OK
T4	120 - 100	3.117	39	0.2254	0.0278	0.227	OK
T5	100 - 80	2.175	39	0.1938	0.0196	0.195	OK
T6	80 - 60	1.417	39	0.1498	0.0153	0.151	OK


*Up to 0.5 degree is considered acceptable per SUB090 Section 7

Critical Deflections of Tower at the MW Dish Elevations - Design Wind

<i>Elevation ft</i>	<i>Appurtenance</i>	<i>Gov. Load Comb.</i>	<i>Deflection in</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Radius of Curvature ft</i>
177	6' Microwave Dish w/ Radome	39	6.482	0.2995	0.0566	839376.000

APPENDIX A
TNXTOWER OUTPUT

Section	T1	T2	T3	T4	T5	T6	T7	T8	T9
Legs	P2.5x0.203	P2.5x.276	P3x0.216	P4x0.337	P5x0.258	P5x0.375	P6x0.432	P6x0.432	P6x0.432
Leg Grade					A572-50				
Diagonals	L1 3/4x1 3/4x3/16	L2x2x1/8	L2 1/2x2 1/2x3/16	L2 1/2x2 1/2x1/4	L3x3x3/8	L3 1/2x3 1/2x1/4	L3 1/2x3 1/2x3/8	L4x4x3/8	L4x4x3/8
Diagonal Grade					A36				
Top Girts	L2 1/2x2 1/2x3/16				N.A.				
Face Width (ft)	8.56	10.6	12.68	14.77	16.77	18.77	20.86	22.86	24.86
# Panels @ (ft)	4 @ 5	9 @ 6.66667	9 @ 6.66667	9 @ 6.66667	10 @ 10	10 @ 10	10 @ 10	10 @ 10	10 @ 10
Weight (K)	1.0	0.8	1.3	2.1	2.6	2.8	4.8	5.0	5.0



DESIGNED APPURTENANCE LOADING


TYPE	ELEVATION	TYPE	ELEVATION
2" Dia 20' Omni	180	2"x2" Mount Pipe	130
2" Dia 15' Omni	180	2"x2" Mount Pipe	130
5"x4" Mount Pipe	180	2"x2" Mount Pipe	130
BA40-41-DIN (4 diploes (2 bays) 11.5' dipole)	180	Sector Mount [SM 405-3]	130
5"x2" Mount Pipe	180	P65-16-XLH-RR w/ Mount Pipe	130
8' HSS4x4x3/8 Horizontal Mount	177	(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	120
6"x2" Horizontal Pipe	177	(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	120
6"x4" Mount Pipe	177	(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	120
6' Microwave Dish w/ Radome	177	(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	120
2"x2" Mount Pipe	174	(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	120
12' Dipole	174	RRH2x40-AWS	120
ANT220F6	165	RRH2x40-AWS	120
USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support]	165	RRH2x40-AWS	120
ANT220F6	165	RRH2x40 700	120
2" Dia 5' Omni	157	RRH2x40 700	120
18"x18"x6" Junction Box	157	RRH2x40 700	120
Side Arm Mount [SO 305-1]	157	(2) DB-T1-6Z-8AB-0Z	120
2" Dia 5' Omni	157	Sector Mount [SM 502-3]	120
LNx-6512DS-T4M_TIA w/ Mount Pipe	145	Pipe Mount [PM 601-3]	120
LNx-6512DS-T4M_TIA w/ Mount Pipe	145	(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	120
AIR 21 B2A/B4P w/ Mount Pipe	145	P40-16-XLPP-RR w/ Mount Pipe	88
AIR 21 B2A/B4P w/ Mount Pipe	145	APXVSP18-C-A20_TIA w/ Mount Pipe	88
AIR 21 B2A/B4P w/ Mount Pipe	145	800MHZ RRH	88
ATM1900D-1A20	145	800MHZ RRH	88
ATM1900D-1A20	145	800MHZ RRH	88
ATM1900D-1A20	145	1900MHZ RRH	88
ATM1900D-1A20	145	1900MHZ RRH	88
5"x4" Horizontal Mount Pipe	145	1900MHZ RRH	88
5"x4" Horizontal Mount Pipe	145	1900MHZ RRH	88
5"x4" Horizontal Mount Pipe	145	Sector Mount [SM 502-3]	88
LNx-6512DS-T4M_TIA w/ Mount Pipe	145	APXVSP18-C-A20_TIA w/ Mount Pipe	88
Side Arm Mount [SO 203-1]	133	3"x2" Horizontal Pipe	56
BA40-41-DIN (4 diploes (2 bays) 11.5' dipole)	133	GPS_A	56
P65-16-XLH-RR w/ Mount Pipe	130	L3 1/2x3 1/2x1/4	55
P65-16-XLH-RR w/ Mount Pipe	130	L3 1/2x3 1/2x1/4	55
800 10121_TIA w/ Mount Pipe	130	L3 1/2x3 1/2x1/4	55
800 10121_TIA w/ Mount Pipe	130	L3 1/2x3 1/2x1/4	45
800 10121_TIA w/ Mount Pipe	130	L3 1/2x3 1/2x1/4	45
(2) LGP21401 : TMA	130	L3 1/2x3 1/2x1/4	45
(2) LGP21401 : TMA	130	L4x4x1/4	15
(2) LGP21401 : TMA	130	L4x4x1/4	15
RRUS 11	130	L4x4x1/4	15
RRUS 11	130	L4x4x1/4	5
RRUS 11	130	L4x4x1/4	5
DC6-48-60-18-8F	130	L4x4x1/4	5

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi	A36	36 ksi	58 ksi

TOWER DESIGN NOTES

1. Tower designed for Exposure B to the TIA-222-H Standard.
2. Tower designed for a 130 mph basic wind in accordance with the TIA-222-H Standard.
3. Tower is also designed for a 50 mph basic wind with 1.50 in ice. Ice is considered to increase in thickness with height.
4. Deflections are based upon a 60 mph wind.
5. Tower Risk Category III.
6. Topographic Category 1 with Crest Height of 0.00 ft
7. TOWER RATING: 96.3%



Tower Input Data


The main tower is a 3x free standing tower with an overall height of 180.00 ft above the ground line.
 The base of the tower is set at an elevation of 0.00 ft above the ground line.
 The face width of the tower is 8.56 ft at the top and 24.86 ft at the base.
 This tower is designed using the TIA-222-H standard.

The following design criteria apply:

- 1) Tower base elevation above sea level: 457.00 ft.
- 2) Basic wind speed of 130 mph.
- 3) Risk Category III.
- 4) Exposure Category B.
- 5) Simplified Topographic Factor Procedure for wind speed-up calculations is used.
- 6) Topographic Category: 1.
- 7) Crest Height: 0.00 ft.
- 8) Nominal ice thickness of 1.5000 in.
- 9) Ice thickness is considered to increase with height.
- 10) Ice density of 56 pcf.
- 11) A wind speed of 50 mph is used in combination with ice.
- 12) Temperature drop of 50 °F.
- 13) Deflections calculated using a wind speed of 60 mph.
- 14) Pressures are calculated at each section.
- 15) Stress ratio used in tower member design is 1.05.
- 16) Local bending stresses due to climbing loads, feed line supports, and appurtenance mounts are not considered.

Options

Consider Moments - Legs Consider Moments - Horizontals Consider Moments - Diagonals Use Moment Magnification Use Code Stress Ratios ✓ Use Code Safety Factors - Guys Escalate Ice Always Use Max Kz Use Special Wind Profile ✓ Include Bolts In Member Capacity Leg Bolts Are At Top Of Section ✓ Secondary Horizontal Braces Leg Use Diamond Inner Bracing (4 Sided) SR Members Have Cut Ends SR Members Are Concentric	Distribute Leg Loads As Uniform Assume Legs Pinned ✓ Assume Rigid Index Plate ✓ Use Clear Spans For Wind Area ✓ Use Clear Spans For KL/r Retension Guys To Initial Tension ✓ Bypass Mast Stability Checks ✓ Use Azimuth Dish Coefficients ✓ Project Wind Area of Appurt. Autocalc Torque Arm Areas Add IBC .6D+W Combination ✓ Sort Capacity Reports By Component Triangulate Diamond Inner Bracing Treat Feed Line Bundles As Cylinder Ignore KL/ry For 60 Deg. Angle Legs	Use ASCE 10 X-Brace Ly Rules ✓ Calculate Redundant Bracing Forces Ignore Redundant Members in FEA SR Leg Bolts Resist Compression ✓ All Leg Panels Have Same Allowable Offset Girt At Foundation ✓ Consider Feed Line Torque ✓ Include Angle Block Shear Check Use TIA-222-H Bracing Resist. Exemption Use TIA-222-H Tension Splice Exemption <div style="text-align: center; background-color: #e0e0e0; padding: 2px;">Poles</div> Include Shear-Torsion Interaction Always Use Sub-Critical Flow Use Top Mounted Sockets Pole Without Linear Attachments Pole With Shroud Or No Appurtenances Outside and Inside Corner Radii Are Known
--	---	---



Triangular Tower

Tower Section Geometry

<i>Tower Section</i>	<i>Tower Elevation</i>	<i>Assembly Database</i>	<i>Description</i>	<i>Section Width</i>	<i>Number of Sections</i>	<i>Section Length</i>
	<i>ft</i>			<i>ft</i>		<i>ft</i>
T1	180.00-160.00			8.56	1	20.00
T2	160.00-140.00			8.56	1	20.00
T3	140.00-120.00			10.60	1	20.00
T4	120.00-100.00			12.68	1	20.00
T5	100.00-80.00			14.77	1	20.00
T6	80.00-60.00			16.77	1	20.00
T7	60.00-40.00			18.77	1	20.00
T8	40.00-20.00			20.86	1	20.00
T9	20.00-0.00			22.86	1	20.00

Tower Section Geometry (cont'd)

<i>Tower Section</i>	<i>Tower Elevation</i>	<i>Diagonal Spacing</i>	<i>Bracing Type</i>	<i>Has K Brace End Panels</i>	<i>Has Horizontals</i>	<i>Top Girt Offset</i>	<i>Bottom Girt Offset</i>
	<i>ft</i>	<i>ft</i>				<i>in</i>	<i>in</i>
T1	180.00-160.00	5.00	X Brace	No	No	0.0000	0.0000
T2	160.00-140.00	6.67	X Brace	No	No	0.0000	0.0000
T3	140.00-120.00	6.67	X Brace	No	No	0.0000	0.0000
T4	120.00-100.00	6.67	X Brace	No	No	0.0000	0.0000
T5	100.00-80.00	10.00	X Brace	No	No	0.0000	0.0000
T6	80.00-60.00	10.00	X Brace	No	No	0.0000	0.0000
T7	60.00-40.00	10.00	X Brace	No	No	0.0000	0.0000
T8	40.00-20.00	10.00	X Brace	No	No	0.0000	0.0000
T9	20.00-0.00	10.00	X Brace	No	No	0.0000	0.0000

Tower Section Geometry (cont'd)

Tower Elevation ft	Leg Type	Leg Size	Leg Grade	Diagonal Type	Diagonal Size	Diagonal Grade
T1 180.00-160.00	Pipe	P2.5x0.203	A572-50 (50 ksi)	Equal Angle	L1 3/4x1 3/4x3/16	A36 (36 ksi)
T2 160.00-140.00	Pipe	P2.5x.276	A572-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T3 140.00-120.00	Pipe	P3x0.216	A572-50 (50 ksi)	Equal Angle	L2 1/2x2 1/2x3/16	A36 (36 ksi)
T4 120.00-100.00	Pipe	P4x0.337	A572-50 (50 ksi)	Equal Angle	L2 1/2x2 1/2x1/4	A36 (36 ksi)
T5 100.00-80.00	Pipe	P5x0.258	A572-50 (50 ksi)	Equal Angle	L3x3x3/8	A36 (36 ksi)
T6 80.00-60.00	Pipe	P5x0.375	A572-50 (50 ksi)	Equal Angle	L3 1/2x3 1/2x1/4	A36 (36 ksi)
T7 60.00-40.00	Pipe	P5x0.375	A572-50 (50 ksi)	Equal Angle	L3 1/2x3 1/2x3/8	A36 (36 ksi)
T8 40.00-20.00	Pipe	P6x0.432	A572-50 (50 ksi)	Equal Angle	L4x4x3/8	A36 (36 ksi)
T9 20.00-0.00	Pipe	P6x0.432	A572-50 (50 ksi)	Equal Angle	L4x4x3/8	A36 (36 ksi)

Tower Section Geometry (cont'd)

Tower Elevation ft	Top Girt Type	Top Girt Size	Top Girt Grade	Bottom Girt Type	Bottom Girt Size	Bottom Girt Grade
T1 180.00-160.00	Equal Angle	L2 1/2x2 1/2x3/16	A36 (36 ksi)	Equal Angle		A36 (36 ksi)

Tower Section Geometry (cont'd)

Tower Elevation ft	Gusset Area (per face) ft ²	Gusset Thickness in	Gusset Grade	Adjust. Factor A _r	Adjust. Factor A _r	Weight Mult.	Double Angle Stitch Bolt Spacing Diagonals in	Double Angle Stitch Bolt Spacing Horizontal in	Double Angle Stitch Bolt Spacing Redundants in
T1 180.00-160.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T2 160.00-140.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T3 140.00-120.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T4 120.00-100.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T5 100.00-80.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T6 80.00-60.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T7 60.00-40.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T8 40.00-20.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000
T9 20.00-0.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	36.0000	36.0000	36.0000

Tower Section Geometry (cont'd)

Tower Elevation ft	Calc K Single Angles	Calc K Solid Rounds	Legs	K Factors ¹							
				X Brace Diags	K Brace Diags	Single Diags	Girts	Horiz.	Sec. Horiz.	Inner Brace	
				X Y	X Y	X Y	X Y	X Y	X Y	X Y	
T1 180.00-160.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T2 160.00-140.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T3 140.00-120.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T4 120.00-100.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T5 100.00-80.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T6 80.00-60.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T7 60.00-40.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T8 40.00-20.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T9 20.00-0.00	Yes	Yes	1	1	1	1	1	1	1	1	1

¹Note: K factors are applied to member segment lengths. K-braces without inner supporting members will have the K factor in the out-of-plane direction applied to the overall length.

Tower Section Geometry (cont'd)

Tower Elevation ft	Leg		Diagonal		Top Girt		Bottom Girt		Mid Girt		Long Horizontal		Short Horizontal	
	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U
T1 180.00-160.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T2 160.00-140.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T3 140.00-120.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T4 120.00-100.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T5 100.00-80.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T6 80.00-60.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T7 60.00-40.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T8 40.00-20.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T9 20.00-0.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75

Tower Section Geometry (cont'd)

Tower Elevation ft	Leg Connection Type	Leg		Diagonal		Top Girt		Bottom Girt		Mid Girt		Long Horizontal		Short Horizontal	
		Bolt Size in	No.	Bolt Size in	No.	Bolt Size in	No.	Bolt Size in	No.	Bolt Size in	No.	Bolt Size in	No.	Bolt Size in	No.
T1 180.00-160.00	Flange	0.6250 A325N	4	0.5000 A325N	1	0.5000 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T2 160.00-140.00	Flange	0.7500 A325N	4	0.5000 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T3 140.00-120.00	Flange	0.8750 A325N	4	0.5000 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T4 120.00-100.00	Flange	1.0000 A325N	4	0.5000 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T5 100.00-80.00	Flange	1.0000 A325N	4	0.7500 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T6 80.00-60.00	Flange	1.0000 A325N	4	0.7500 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T7 60.00-40.00	Flange	1.0000 A325N	6	0.7500 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T8 40.00-20.00	Flange	1.0000 A325N	6	0.7500 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0
T9 20.00-0.00	Flange	1.0000 A325N	0	0.8750 A325N	1	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0	0.6250 A325N	0

Feed Line/Linear Appurtenances - Entered As Round Or Flat

Description	Face or Leg	Allow Shield	Exclude From Torque Calculation	Component Type	Placement ft	Face Offset in	Lateral Offset (Frac FW)	#	# Per Row	Clear Spacing in	Width or Diameter in	Perimeter in	Weight plf
Feedline Ladder (Af)	B	No	No	Af (CaAa)	180.00 - 15.00	0.0000	-0.45	1	1	2.5000	2.5000		8.40
LDF5-50A(7/8)	B	No	No	Ar (CaAa)	157.00 - 0.00	0.0000	-0.46	3	3	0.5000	1.0300		0.33
LDF5-50A(7/8)	B	No	No	Ar (CaAa)	180.00 - 157.00	0.0000	-0.46	1	1	0.5000	1.0300		0.33
EW63(ELLIP TICAL)	B	No	No	Ar (CaAa)	177.00 - 0.00	0.0000	-0.43	1	1	0.5000	2.0100		0.51
LDF4-50A(1/2)	B	No	No	Ar (CaAa)	174.00 - 0.00	0.0000	-0.45	2	2	0.5000	0.6250		0.15
LDF4-50A(1/2)	B	No	No	Ar (CaAa)	180.00 - 174.00	0.0000	-0.45	1	1	0.5000	0.6250		0.15
LDF5-50A(7/8)	C	No	No	Ar (CaAa)	133.00 - 0.00	0.0000	0.5	2	2	0.5000	1.0300		0.33
LDF5-50A(7/8)	C	No	No	Ar (CaAa)	180.00 - 133.00	0.0000	0.5	1	1	0.5000	1.0300		0.33
* Feedline Ladder (Af)	A	No	No	Af (CaAa)	145.00 - 10.00	0.0000	0.45	1	1	1.5000	1.5000		8.40
LDF7-50A(1-5/8)	A	No	No	Ar (CaAa)	145.00 - 0.00	0.0000	0.45	12	6	0.5000	1.9800		0.82
* Feedline Ladder (Af)	C	No	No	Af (CaAa)	130.00 - 0.00	0.0000	0	1	1	3.0000	3.0000		8.40
LDF7-50A(1-5/8)	C	No	No	Ar (CaAa)	130.00 - 0.00	0.0000	0	6	3	0.5000	1.9800		0.82
3" Flexible Conduit	C	No	No	Ar (CaAa)	130.00 - 0.00	0.0000	0.03	1	1	3.0000	3.0000		0.30
MLC Hybrid 6Power/12Fiber(1 1/2)	C	No	No	Ar (CaAa)	130.00 - 0.00	0.0000	0.03	2	2	0.5000	1.5000		0.98
* Feedline Ladder (Af)	A	No	No	Af (CaAa)	107.00 - 0.00	0.0000	-0.45	1	1	3.0000	3.0000		8.40

Description	Face or Leg	Allow Shield	Exclude From Torque Calculation	Component Type	Placement ft	Face Offset in	Lateral Offset (Frac FW)	#	# Per Row	Clear Spacing in	Width or Diameter in	Perimeter in	Weight plf
LDF7-50A(1-5/8)*	A	No	No	Ar (CaAa)	120.00 - 0.00	0.0000	-0.45	2	2	0.5000	1.9800		0.82
Feedline Ladder (Af)	C	No	No	Af (CaAa)	95.00 - 0.00	0.0000	-0.45	1	1	3.0000	3.0000		8.40
MLE Hybrid 3Power/6Fiber RL 2(1-1/4)*	C	No	No	Ar (CaAa)	88.00 - 0.00	0.0000	-0.45	3	3	0.5000	1.2500		0.68
LDF4-50A(1/2)**	C	No	No	Ar (CaAa)	56.00 - 0.00	0.0000	-0.46	1	1	0.5000	0.6250		0.15
Proposed** LDF5-50A(7/8)	B	No	No	Ar (CaAa)	165.00 - 0.00	0.0000	-0.4	2	2	0.5000	1.0300		0.33

Feed Line/Linear Appurtenances Section Areas

Tower Section n	Tower Elevation ft	Face	A _R ft ²	A _F ft ²	C _A A _A In Face ft ²	C _A A _A Out Face ft ²	Weight K
T1	180.00-160.00	A	0.000	0.000	0.000	0.000	0.00
		B	0.000	0.000	16.965	0.000	0.19
		C	0.000	0.000	2.060	0.000	0.01
T2	160.00-140.00	A	0.000	0.000	13.130	0.000	0.09
		B	0.000	0.000	24.535	0.000	0.22
		C	0.000	0.000	2.060	0.000	0.01
T3	140.00-120.00	A	0.000	0.000	52.520	0.000	0.36
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	26.279	0.000	0.17
T4	120.00-100.00	A	0.000	0.000	63.940	0.000	0.46
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	49.880	0.000	0.32
T5	100.00-80.00	A	0.000	0.000	70.440	0.000	0.57
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	60.380	0.000	0.47
T6	80.00-60.00	A	0.000	0.000	70.440	0.000	0.57
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	67.380	0.000	0.53
T7	60.00-40.00	A	0.000	0.000	70.440	0.000	0.57
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	68.380	0.000	0.54
T8	40.00-20.00	A	0.000	0.000	70.440	0.000	0.57
		B	0.000	0.000	25.153	0.000	0.22
		C	0.000	0.000	68.630	0.000	0.54
T9	20.00-0.00	A	0.000	0.000	67.940	0.000	0.48
		B	0.000	0.000	18.903	0.000	0.09
		C	0.000	0.000	68.630	0.000	0.54

Feed Line/Linear Appurtenances Section Areas - With Ice

Tower Section n	Tower Elevation ft	Face or Leg	Ice Thickness in	A _R ft ²	A _F ft ²	C _A A _A In Face ft ²	C _A A _A Out Face ft ²	Weight K
T1	180.00-160.00	A	2.032	0.000	0.000	0.000	0.000	0.00
		B		0.000	0.000	57.630	0.000	1.00
		C		0.000	0.000	10.189	0.000	0.16
T2	160.00-140.00	A	2.007	0.000	0.000	15.915	0.000	0.36
		B		0.000	0.000	89.419	0.000	1.30
		C		0.000	0.000	10.088	0.000	0.16

Tower Section	Tower Elevation ft	Face or Leg	Ice Thickness in	A _R ft ²	A _F ft ²	C _A A _A In Face ft ²	C _A A _A Out Face ft ²	Weight K
T3	140.00-120.00	A	1.978	0.000	0.000	63.355	0.000	1.43
		B		0.000	0.000	90.661	0.000	1.29
		C		0.000	0.000	61.502	0.000	0.99
T4	120.00-100.00	A	1.946	0.000	0.000	94.753	0.000	1.88
		B		0.000	0.000	89.713	0.000	1.27
		C		0.000	0.000	108.916	0.000	1.78
T5	100.00-80.00	A	1.907	0.000	0.000	105.477	0.000	2.14
		B		0.000	0.000	88.595	0.000	1.24
		C		0.000	0.000	130.965	0.000	2.21
T6	80.00-60.00	A	1.860	0.000	0.000	104.456	0.000	2.10
		B		0.000	0.000	87.227	0.000	1.20
		C		0.000	0.000	148.411	0.000	2.44
T7	60.00-40.00	A	1.798	0.000	0.000	103.128	0.000	2.04
		B		0.000	0.000	85.449	0.000	1.15
		C		0.000	0.000	152.714	0.000	2.45
T8	40.00-20.00	A	1.709	0.000	0.000	101.198	0.000	1.97
		B		0.000	0.000	82.864	0.000	1.09
		C		0.000	0.000	150.479	0.000	2.35
T9	20.00-0.00	A	1.531	0.000	0.000	91.809	0.000	1.66
		B		0.000	0.000	66.894	0.000	0.70
		C		0.000	0.000	142.699	0.000	2.12

Feed Line Center of Pressure

Section	Elevation ft	CP _x in	CP _z in	CP _x Ice in	CP _z Ice in
T1	180.00-160.00	-0.4878	-7.7217	-1.5102	-11.7519
T2	160.00-140.00	-0.5254	-17.1075	-1.4202	-20.8435
T3	140.00-120.00	-1.5798	-19.3685	-2.6834	-21.8040
T4	120.00-100.00	-5.0983	-12.9621	-7.1874	-14.6071
T5	100.00-80.00	-4.0856	-12.4519	-5.7148	-12.3438
T6	80.00-60.00	-1.8741	-11.7443	-2.7117	-11.4486
T7	60.00-40.00	-1.5875	-12.2430	-1.4102	-11.2949
T8	40.00-20.00	-1.4642	-12.1072	-1.0792	-11.4611
T9	20.00-0.00	-1.6275	-9.6518	-1.2253	-7.7627

Shielding Factor Ka

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K _a No Ice	K _a Ice
T1	1	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T1	3	LDF5-50A(7/8)	160.00 - 180.00	0.6000	0.6000
T1	10	EW63(ELLIPTICAL)	160.00 - 177.00	0.6000	0.6000
T1	11	LDF4-50A(1/2)	160.00 - 174.00	0.6000	0.6000
T1	12	LDF4-50A(1/2)	174.00 - 180.00	0.6000	0.6000
T1	14	LDF5-50A(7/8)	160.00 - 180.00	0.6000	0.6000
T1	32	LDF5-50A(7/8)	160.00 - 165.00	0.6000	0.6000
T2	1	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K _a No Ice	K _a Ice
T2	2	LDF5-50A(7/8)	140.00 - 157.00	0.6000	0.6000
T2	3	LDF5-50A(7/8)	157.00 - 160.00	0.6000	0.6000
T2	10	EW63(ELLIPTICAL)	140.00 - 160.00	0.6000	0.6000
T2	11	LDF4-50A(1/2)	140.00 - 160.00	0.6000	0.6000
T2	14	LDF5-50A(7/8)	140.00 - 160.00	0.6000	0.6000
T2	16	Feedline Ladder (Af)	140.00 - 145.00	0.6000	0.6000
T2	17	LDF7-50A(1-5/8)	140.00 - 145.00	0.6000	0.6000
T2	32	LDF5-50A(7/8)	140.00 - 160.00	0.6000	0.6000
T3	1	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T3	2	LDF5-50A(7/8)	120.00 - 140.00	0.6000	0.6000
T3	10	EW63(ELLIPTICAL)	120.00 - 140.00	0.6000	0.6000
T3	11	LDF4-50A(1/2)	120.00 - 140.00	0.6000	0.6000
T3	13	LDF5-50A(7/8)	120.00 - 133.00	0.6000	0.6000
T3	14	LDF5-50A(7/8)	133.00 - 140.00	0.6000	0.6000
T3	16	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T3	17	LDF7-50A(1-5/8)	120.00 - 140.00	0.6000	0.6000
T3	19	Feedline Ladder (Af)	120.00 - 130.00	0.6000	0.6000
T3	20	LDF7-50A(1-5/8)	120.00 - 130.00	0.6000	0.6000
T3	21	3" Flexible Conduit	120.00 - 130.00	1.0000	0.6000
T3	22	MLC Hybrid 6Power/12Fiber(1 1/2)	120.00 - 130.00	0.6000	0.6000
T3	32	LDF5-50A(7/8)	120.00 - 140.00	0.6000	0.6000
T4	1	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T4	2	LDF5-50A(7/8)	100.00 - 120.00	0.6000	0.6000
T4	10	EW63(ELLIPTICAL)	100.00 - 120.00	0.6000	0.6000
T4	11	LDF4-50A(1/2)	100.00 - 120.00	0.6000	0.6000
T4	13	LDF5-50A(7/8)	100.00 - 120.00	0.6000	0.6000
T4	16	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T4	17	LDF7-50A(1-5/8)	100.00 - 120.00	0.6000	0.6000
T4	19	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T4	20	LDF7-50A(1-5/8)	100.00 - 120.00	0.6000	0.6000
T4	21	3" Flexible Conduit	100.00 - 120.00	1.0000	0.6000
T4	22	MLC Hybrid 6Power/12Fiber(1 1/2)	100.00 - 120.00	0.6000	0.6000
T4	24	Feedline Ladder (Af)	100.00 - 107.00	0.6000	0.6000
T4	25	LDF7-50A(1-5/8)	100.00 - 120.00	0.6000	0.6000

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K _a No Ice	K _a Ice
T4	32	LDF5-50A(7/8)	100.00 - 120.00	0.6000	0.6000
T5	1	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T5	2	LDF5-50A(7/8)	80.00 - 100.00	0.6000	0.6000
T5	10	EW63(ELLIPTICAL)	80.00 - 100.00	0.6000	0.6000
T5	11	LDF4-50A(1/2)	80.00 - 100.00	0.6000	0.6000
T5	13	LDF5-50A(7/8)	80.00 - 100.00	0.6000	0.6000
T5	16	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T5	17	LDF7-50A(1-5/8)	80.00 - 100.00	0.6000	0.6000
T5	19	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T5	20	LDF7-50A(1-5/8)	80.00 - 100.00	0.6000	0.6000
T5	21	3" Flexible Conduit	80.00 - 100.00	0.6000	0.6000
T5	22	MLC Hybrid 6Power/12Fiber(1 1/2)	80.00 - 100.00	0.6000	0.6000
T5	24	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T5	25	LDF7-50A(1-5/8)	80.00 - 100.00	0.6000	0.6000
T5	27	Feedline Ladder (Af)	80.00 - 95.00	0.6000	0.6000
T5	28	MLE Hybrid 3Power/6Fiber RL 2(1-1/4)	80.00 - 88.00	0.6000	0.6000
T5	32	LDF5-50A(7/8)	80.00 - 100.00	0.6000	0.6000
T6	1	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T6	2	LDF5-50A(7/8)	60.00 - 80.00	0.6000	0.6000
T6	10	EW63(ELLIPTICAL)	60.00 - 80.00	0.6000	0.6000
T6	11	LDF4-50A(1/2)	60.00 - 80.00	0.6000	0.6000
T6	13	LDF5-50A(7/8)	60.00 - 80.00	0.6000	0.6000
T6	16	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T6	17	LDF7-50A(1-5/8)	60.00 - 80.00	0.6000	0.6000
T6	19	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T6	20	LDF7-50A(1-5/8)	60.00 - 80.00	0.6000	0.6000
T6	21	3" Flexible Conduit	60.00 - 80.00	0.6000	0.6000
T6	22	MLC Hybrid 6Power/12Fiber(1 1/2)	60.00 - 80.00	0.6000	0.6000
T6	24	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T6	25	LDF7-50A(1-5/8)	60.00 - 80.00	0.6000	0.6000
T6	27	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T6	28	MLE Hybrid 3Power/6Fiber RL 2(1-1/4)	60.00 - 80.00	0.6000	0.6000
T6	32	LDF5-50A(7/8)	60.00 - 80.00	0.6000	0.6000
T7	1	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K _a No Ice	K _a Ice
T7	2	LDF5-50A(7/8)	40.00 - 60.00	0.6000	0.6000
T7	10	EW63(ELLIPTICAL)	40.00 - 60.00	0.6000	0.6000
T7	11	LDF4-50A(1/2)	40.00 - 60.00	0.6000	0.6000
T7	13	LDF5-50A(7/8)	40.00 - 60.00	0.6000	0.6000
T7	16	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T7	17	LDF7-50A(1-5/8)	40.00 - 60.00	0.6000	0.6000
T7	19	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T7	20	LDF7-50A(1-5/8)	40.00 - 60.00	0.6000	0.6000
T7	21	3" Flexible Conduit	40.00 - 60.00	0.6000	0.6000
T7	22	MLC Hybrid 6Power/12Fiber(1 1/2)	40.00 - 60.00	0.6000	0.6000
T7	24	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T7	25	LDF7-50A(1-5/8)	40.00 - 60.00	0.6000	0.6000
T7	27	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T7	28	MLE Hybrid 3Power/6Fiber RL 2(1-1/4)	40.00 - 60.00	0.6000	0.6000
T7	30	LDF4-50A(1/2)	40.00 - 56.00	0.6000	0.6000
T7	32	LDF5-50A(7/8)	40.00 - 60.00	0.6000	0.6000
T8	1	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T8	2	LDF5-50A(7/8)	20.00 - 40.00	0.6000	0.6000
T8	10	EW63(ELLIPTICAL)	20.00 - 40.00	0.6000	0.6000
T8	11	LDF4-50A(1/2)	20.00 - 40.00	0.6000	0.6000
T8	13	LDF5-50A(7/8)	20.00 - 40.00	0.6000	0.6000
T8	16	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T8	17	LDF7-50A(1-5/8)	20.00 - 40.00	0.6000	0.6000
T8	19	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T8	20	LDF7-50A(1-5/8)	20.00 - 40.00	0.6000	0.6000
T8	21	3" Flexible Conduit	20.00 - 40.00	0.6000	0.6000
T8	22	MLC Hybrid 6Power/12Fiber(1 1/2)	20.00 - 40.00	0.6000	0.6000
T8	24	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T8	25	LDF7-50A(1-5/8)	20.00 - 40.00	0.6000	0.6000
T8	27	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T8	28	MLE Hybrid 3Power/6Fiber RL 2(1-1/4)	20.00 - 40.00	0.6000	0.6000
T8	30	LDF4-50A(1/2)	20.00 - 40.00	0.6000	0.6000
T8	32	LDF5-50A(7/8)	20.00 - 40.00	0.6000	0.6000
T9	1	Feedline Ladder (Af)	15.00 - 20.00	0.6000	0.6000
T9	2	LDF5-50A(7/8)	0.00 - 20.00	0.6000	0.6000

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K_a No Ice	K_a Ice
T9	10	EW63(ELLIPTICAL)	0.00 - 20.00	0.6000	0.6000
T9	11	LDF4-50A(1/2)	0.00 - 20.00	0.6000	0.6000
T9	13	LDF5-50A(7/8)	0.00 - 20.00	0.6000	0.6000
T9	16	Feedline Ladder (Af)	10.00 - 20.00	0.6000	0.6000
T9	17	LDF7-50A(1-5/8)	0.00 - 20.00	0.6000	0.6000
T9	19	Feedline Ladder (Af)	0.00 - 20.00	0.6000	0.6000
T9	20	LDF7-50A(1-5/8)	0.00 - 20.00	0.6000	0.6000
T9	21	3" Flexible Conduit	0.00 - 20.00	0.6000	0.6000
T9	22	MLC Hybrid	0.00 - 20.00	0.6000	0.6000
T9	24	6Power/12Fiber(1 1/2)	0.00 - 20.00	0.6000	0.6000
T9	25	Feedline Ladder (Af)	0.00 - 20.00	0.6000	0.6000
T9	27	LDF7-50A(1-5/8)	0.00 - 20.00	0.6000	0.6000
T9	28	Feedline Ladder (Af)	0.00 - 20.00	0.6000	0.6000
T9	28	MLE Hybrid 3Power/6Fiber	0.00 - 20.00	0.6000	0.6000
T9	30	RL 2(1-1/4)	0.00 - 20.00	0.6000	0.6000
T9	30	LDF4-50A(1/2)	0.00 - 20.00	0.6000	0.6000
T9	32	LDF5-50A(7/8)	0.00 - 20.00	0.6000	0.6000

Discrete Tower Loads

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustmen t °	Placement ft	C_{AA} Front ft ²	C_{AA} Side ft ²	Weight K	
180									
2" Dia 20' Omni	A	From Leg	0.00 0.00 9.00	0.0000	180.00	No Ice	4.00	4.00	0.02
						1/2" Ice	6.03	6.03	0.05
						1" Ice	8.07	8.07	0.10
						2" Ice	12.20	12.20	0.22
2" Dia 15' Omni	B	From Leg	0.00 0.00 10.50	0.0000	180.00	No Ice	3.00	3.00	0.02
						1/2" Ice	4.53	4.53	0.04
						1" Ice	6.07	6.07	0.08
						2" Ice	9.20	9.20	0.17
5'x4" Mount Pipe	B	From Leg	0.00 0.00 2.50	0.0000	180.00	No Ice	1.45	1.45	0.05
						1/2" Ice	2.08	2.08	0.07
						1" Ice	2.40	2.40	0.09
						2" Ice	3.07	3.07	0.14
BA40-41-DIN (4 diploes (2 bays) 11.5' dipole)	C	From Leg	0.00 0.00 12.50	0.0000	180.00	No Ice	5.40	5.40	0.03
						1/2" Ice	9.24	9.24	0.04
						1" Ice	13.08	13.08	0.05
						2" Ice	20.76	20.76	0.07
5'x2" Mount Pipe	C	From Leg	0.00 0.00 0.00	0.0000	180.00	No Ice	1.19	1.19	0.02
						1/2" Ice	1.50	1.50	0.03
						1" Ice	1.81	1.81	0.04
						2" Ice	2.46	2.46	0.08
177									
8' HSS4x4x3/8 Horizontal Mount	C	From Leg	0.00 0.00 0.00	0.0000	177.00	No Ice	2.67	0.04	0.17
						1/2" Ice	3.37	0.59	0.22
						1" Ice	4.07	1.13	0.26
						2" Ice	5.47	2.23	0.35
6'x2" Horizontal Pipe	C	From Leg	0.00 0.00 0.00	0.0000	177.00	No Ice	1.43	0.01	0.02
						1/2" Ice	1.92	0.04	0.03
						1" Ice	2.29	0.07	0.05
						2" Ice			

Description	Face or Leg	Offset Type	Offsets:			Azimuth Adjustment	Placement	C _{AA} _{Front}	C _{AA} _{Side}	Weight	
			Horz	Lateral	Vert						ft
			ft	ft	ft	°	ft	ft ²	ft ²	K	
6'x4" Mount Pipe	C	From Leg	0.00	0.00	0.00	0.0000	177.00	1" Ice	3.06	0.13	0.09
								2" Ice	1.81	1.81	0.06
								No Ice	2.62	2.62	0.08
								1/2" Ice	3.00	3.00	0.11
								1" Ice	3.78	3.78	0.17
174 12' Dipole	B	From Leg	0.00	0.00	2.00	0.0000	174.00	No Ice	2.20	2.20	0.02
								1/2"	4.62	4.62	0.02
								Ice	7.04	7.04	0.03
								1" Ice	11.88	11.88	0.04
								2" Ice			
2'x2" Mount Pipe	B	From Leg	0.00	0.00	0.00	0.0000	174.00	No Ice	0.34	0.34	0.01
								1/2"	0.47	0.47	0.01
								Ice	0.61	0.61	0.02
								1" Ice	0.92	0.92	0.03
								2" Ice			
**** ANT220F6	A	From Leg	4.00	0.00	7.50	0.0000	165.00	No Ice	3.92	3.92	0.04
								1/2"	5.38	5.38	0.06
								Ice	6.85	6.85	0.10
								1" Ice	9.84	9.84	0.21
								2" Ice			
ANT220F6	A	From Leg	4.00	0.00	-7.50	0.0000	165.00	No Ice	3.92	3.92	0.04
								1/2"	5.38	5.38	0.06
								Ice	6.85	6.85	0.10
								1" Ice	9.84	9.84	0.21
								2" Ice			
USF-4U w/ Tieback [4' SO 203-1 + Vert. Pipe Support]	A	From Leg	2.00	0.00	0.00	0.0000	165.00	No Ice	2.96	5.64	0.18
								1/2"	3.76	6.73	0.22
								Ice	4.63	7.91	0.28
								1" Ice	6.57	10.43	0.43
								2" Ice			
157 2" Dia 5' Omni	A	From Leg	0.00	0.00	4.00	0.0000	157.00	No Ice	1.00	1.00	0.01
								1/2"	1.51	1.51	0.01
								Ice	2.03	2.03	0.02
								1" Ice	3.06	3.06	0.04
								2" Ice			
2" Dia 5' Omni	A	From Leg	0.00	0.00	-4.00	0.0000	157.00	No Ice	1.00	1.00	0.01
								1/2"	1.51	1.51	0.01
								Ice	2.03	2.03	0.02
								1" Ice	3.06	3.06	0.04
								2" Ice			
18"x18"x6" Junction Box	A	From Leg	0.00	0.00	0.00	0.0000	157.00	No Ice	3.33	1.03	0.06
								1/2"	3.56	1.17	0.08
								Ice	3.79	1.31	0.10
								1" Ice	4.25	1.59	0.15
								2" Ice			
Side Arm Mount [SO 305-1]	A	From Leg	0.00	0.00	0.00	0.0000	157.00	No Ice	0.94	1.41	0.03
								1/2"	1.48	2.17	0.04
								Ice	2.02	2.93	0.06
								1" Ice	3.10	4.45	0.08
								2" Ice			
145 LNX-6512DS-T4M_TIA w/ Mount Pipe	A	From Leg	0.00	0.00	1.00	0.0000	145.00	No Ice	5.33	4.53	0.05
								1/2"	5.72	5.15	0.10
								Ice	6.12	5.77	0.15
								1" Ice	6.94	7.07	0.28
								2" Ice			
LNX-6512DS-T4M_TIA w/ Mount Pipe	B	From Leg	0.00	0.00	1.00	0.0000	145.00	No Ice	5.33	4.53	0.05
								1/2"	5.72	5.15	0.10
								Ice	6.12	5.77	0.15
								1" Ice	6.94	7.07	0.28
								2" Ice			

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustment t °	Placement ft		C _{AA} Front ft ²	C _{AA} Side ft ²	Weight K
LNX-6512DS-T4M_TIA w/ Mount Pipe	C	From Leg	0.00 0.00 1.00	0.0000	145.00	2" Ice			
						No Ice	5.33	4.53	0.05
						1/2"	5.72	5.15	0.10
						Ice	6.12	5.77	0.15
						1" Ice	6.94	7.07	0.28
AIR 21 B2A/B4P w/ Mount Pipe	A	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	6.16	5.55	0.10
						1/2"	6.60	6.30	0.16
						Ice	7.03	7.00	0.22
						1" Ice	7.92	8.44	0.37
AIR 21 B2A/B4P w/ Mount Pipe	B	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	6.16	5.55	0.10
						1/2"	6.60	6.30	0.16
						Ice	7.03	7.00	0.22
						1" Ice	7.92	8.44	0.37
AIR 21 B2A/B4P w/ Mount Pipe	C	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	6.16	5.55	0.10
						1/2"	6.60	6.30	0.16
						Ice	7.03	7.00	0.22
						1" Ice	7.92	8.44	0.37
ATM1900D-1A20	A	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	0.73	0.25	0.01
						1/2"	0.84	0.32	0.01
						Ice	0.96	0.40	0.02
						1" Ice	1.21	0.58	0.04
ATM1900D-1A20	B	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	0.73	0.25	0.01
						1/2"	0.84	0.32	0.01
						Ice	0.96	0.40	0.02
						1" Ice	1.21	0.58	0.04
ATM1900D-1A20	C	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	0.73	0.25	0.01
						1/2"	0.84	0.32	0.01
						Ice	0.96	0.40	0.02
						1" Ice	1.21	0.58	0.04
5'x4" Horizontal Mount Pipe	A	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	1.33	0.16	0.05
						1/2"	1.69	0.21	0.15
						Ice	2.07	0.28	0.27
						1" Ice	2.84	0.43	0.51
5'x4" Horizontal Mount Pipe	B	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	1.33	0.16	0.05
						1/2"	1.69	0.21	0.15
						Ice	2.07	0.28	0.27
						1" Ice	2.84	0.43	0.51
5'x4" Horizontal Mount Pipe	C	From Leg	0.00 0.00 0.00	0.0000	145.00	2" Ice			
						No Ice	1.33	0.16	0.05
						1/2"	1.69	0.21	0.15
						Ice	2.07	0.28	0.27
						1" Ice	2.84	0.43	0.51
133	C	From Leg	0.00 0.00 5.00	0.0000	133.00	2" Ice			
No Ice						5.40	5.40	0.03	
1/2"						9.24	9.24	0.04	
Ice						13.08	13.08	0.05	
1" Ice						20.76	20.76	0.07	
Side Arm Mount [SO 203- 1]	C	From Leg	0.00 0.00 0.00	0.0000	133.00	2" Ice			
						No Ice	2.96	3.36	0.13
						1/2"	4.10	4.68	0.15
						Ice	5.24	6.00	0.18
						1" Ice	7.52	8.64	0.24
130	A	From Leg	0.00 0.00	0.0000	130.00	2" Ice			
No Ice						8.37	6.36	0.08	
P65-16-XLH-RR w/ Mount Pipe							8.93	7.54	0.14

Description	Face or Leg	Offset Type	Offsets:			Azimuth Adjustment	Placement	C _{AA} _{Front}	C _{AA} _{Side}	Weight
			Horz	Lateral	Vert					
			ft	ft	ft	ft	ft ²	ft ²	K	
			0.00				1/2" Ice	9.46	8.43	0.22
							2" Ice	10.53	10.24	0.39
P65-16-XLH-RR w/ Mount Pipe	B	From Leg	0.00	0.0000	130.00		No Ice	8.37	6.36	0.08
			0.00				1/2" Ice	8.93	7.54	0.14
			0.00				2" Ice	9.46	8.43	0.22
							1" Ice	10.53	10.24	0.39
P65-16-XLH-RR w/ Mount Pipe	C	From Leg	0.00	0.0000	130.00		No Ice	8.37	6.36	0.08
			0.00				1/2" Ice	8.93	7.54	0.14
			0.00				2" Ice	9.46	8.43	0.22
							1" Ice	10.53	10.24	0.39
800 10121_TIA w/ Mount Pipe	A	From Leg	0.00	0.0000	130.00		No Ice	5.40	4.61	0.07
			0.00				1/2" Ice	5.82	5.36	0.12
			0.00				2" Ice	6.25	6.06	0.17
							1" Ice	7.12	7.49	0.30
800 10121_TIA w/ Mount Pipe	B	From Leg	0.00	0.0000	130.00		No Ice	5.40	4.61	0.07
			0.00				1/2" Ice	5.82	5.36	0.12
			0.00				2" Ice	6.25	6.06	0.17
							1" Ice	7.12	7.49	0.30
800 10121_TIA w/ Mount Pipe	C	From Leg	0.00	0.0000	130.00		No Ice	5.40	4.61	0.07
			0.00				1/2" Ice	5.82	5.36	0.12
			0.00				2" Ice	6.25	6.06	0.17
							1" Ice	7.12	7.49	0.30
(2) LGP21401 : TMA	A	From Leg	0.00	0.0000	130.00		No Ice	1.10	0.35	0.01
			0.00				1/2" Ice	1.24	0.44	0.02
			0.00				2" Ice	1.38	0.54	0.03
							1" Ice	1.69	0.77	0.05
(2) LGP21401 : TMA	B	From Leg	0.00	0.0000	130.00		No Ice	1.10	0.35	0.01
			0.00				1/2" Ice	1.24	0.44	0.02
			0.00				2" Ice	1.38	0.54	0.03
							1" Ice	1.69	0.77	0.05
(2) LGP21401 : TMA	C	From Leg	0.00	0.0000	130.00		No Ice	1.10	0.35	0.01
			0.00				1/2" Ice	1.24	0.44	0.02
			0.00				2" Ice	1.38	0.54	0.03
							1" Ice	1.69	0.77	0.05
RRUS 11	A	From Leg	0.00	0.0000	130.00		No Ice	2.78	1.19	0.05
			0.00				1/2" Ice	2.99	1.33	0.07
			2.00				Ice	3.21	1.49	0.10
							1" Ice	3.66	1.83	0.15
RRUS 11	B	From Leg	0.00	0.0000	130.00		No Ice	2.78	1.19	0.05
			0.00				1/2" Ice	2.99	1.33	0.07
			2.00				Ice	3.21	1.49	0.10
							1" Ice	3.66	1.83	0.15
RRUS 11	C	From Leg	0.00	0.0000	130.00		No Ice	2.78	1.19	0.05
			0.00				1/2" Ice	2.99	1.33	0.07
			2.00				Ice	3.21	1.49	0.10
							1" Ice	3.66	1.83	0.15
DC6-48-60-18-8F	C	From Leg	0.00	0.0000	130.00		No Ice	0.92	0.92	0.02
			0.00				1/2" Ice	1.46	1.46	0.04
			1.00				Ice	1.64	1.64	0.06
							1" Ice	2.04	2.04	0.11
2'x2" Mount Pipe	A	From Leg	0.00	0.0000	130.00		No Ice	0.34	0.34	0.01

Description	Face or Leg	Offset Type	Offsets:		Azimuth Adjustment	Placement	C _{AA} _{Front}	C _{AA} _{Side}	Weight
			Horz	Lateral					
			ft	ft	°	ft	ft ²	ft ²	K
			0.00			1/2"	0.47	0.47	0.01
			2.00			Ice	0.61	0.61	0.02
						1" Ice	0.92	0.92	0.03
						2" Ice			
2'x2" Mount Pipe	B	From Leg	0.00	0.0000	130.00	No Ice	0.34	0.34	0.01
			0.00			1/2"	0.47	0.47	0.01
			2.00			Ice	0.61	0.61	0.02
						1" Ice	0.92	0.92	0.03
						2" Ice			
2'x2" Mount Pipe	C	From Leg	0.00	0.0000	130.00	No Ice	0.34	0.34	0.01
			0.00			1/2"	0.47	0.47	0.01
			2.00			Ice	0.61	0.61	0.02
						1" Ice	0.92	0.92	0.03
						2" Ice			
Sector Mount [SM 405-3]	C	None		0.0000	130.00	No Ice	18.73	18.73	0.86
						1/2"	27.19	27.19	1.26
						Ice	35.65	35.65	1.66
						1" Ice	52.57	52.57	2.47
						2" Ice			
120									
(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	A	From Leg	0.00	0.0000	120.00	No Ice	7.40	5.39	0.06
			0.00			1/2"	8.14	6.10	0.11
			1.00			Ice	8.90	6.83	0.18
						1" Ice	10.46	8.34	0.34
						2" Ice			
(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	B	From Leg	0.00	0.0000	120.00	No Ice	7.40	5.39	0.06
			0.00			1/2"	8.14	6.10	0.11
			1.00			Ice	8.90	6.83	0.18
						1" Ice	10.46	8.34	0.34
						2" Ice			
(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	C	From Leg	0.00	0.0000	120.00	No Ice	7.40	5.39	0.06
			0.00			1/2"	8.14	6.10	0.11
			1.00			Ice	8.90	6.83	0.18
						1" Ice	10.46	8.34	0.34
						2" Ice			
(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	A	From Leg	0.00	0.0000	120.00	No Ice	5.04	5.30	0.04
			0.00			1/2"	5.59	6.47	0.08
			1.00			Ice	6.11	7.36	0.14
						1" Ice	7.18	9.16	0.27
						2" Ice			
(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	B	From Leg	0.00	0.0000	120.00	No Ice	5.04	5.30	0.04
			0.00			1/2"	5.59	6.47	0.08
			1.00			Ice	6.11	7.36	0.14
						1" Ice	7.18	9.16	0.27
						2" Ice			
(2) BXA-171063-12CF-EDIN-X w/ Mount Pipe	C	From Leg	0.00	0.0000	120.00	No Ice	5.04	5.30	0.04
			0.00			1/2"	5.59	6.47	0.08
			1.00			Ice	6.11	7.36	0.14
						1" Ice	7.18	9.16	0.27
						2" Ice			
RRH2X40-AWS	A	From Leg	0.00	0.0000	120.00	No Ice	2.16	1.42	0.04
			0.00			1/2"	2.36	1.59	0.06
			2.00			Ice	2.57	1.77	0.08
						1" Ice	3.00	2.14	0.13
						2" Ice			
RRH2X40-AWS	B	From Leg	0.00	0.0000	120.00	No Ice	2.16	1.42	0.04
			0.00			1/2"	2.36	1.59	0.06
			2.00			Ice	2.57	1.77	0.08
						1" Ice	3.00	2.14	0.13
						2" Ice			
RRH2X40-AWS	C	From Leg	0.00	0.0000	120.00	No Ice	2.16	1.42	0.04
			0.00			1/2"	2.36	1.59	0.06
			2.00			Ice	2.57	1.77	0.08
						1" Ice	3.00	2.14	0.13
						2" Ice			

Description	Face or Leg	Offset Type	Offsets:		Azimuth Adjustment	Placement	C _{AA} _{Front}	C _{AA} _{Side}	Weight
			Horz	Lateral					
			ft	ft	°	ft	ft ²	ft ²	K
RRH2x40 700	A	From Leg	0.00	0.0000	120.00	No Ice	1.96	1.03	0.05
			0.00	1/2"		2.14	1.17	0.07	
			2.00	Ice		2.32	1.31	0.09	
				1" Ice		2.70	1.62	0.13	
				2" Ice					
RRH2x40 700	B	From Leg	0.00	0.0000	120.00	No Ice	1.96	1.03	0.05
			0.00	1/2"		2.14	1.17	0.07	
			2.00	Ice		2.32	1.31	0.09	
				1" Ice		2.70	1.62	0.13	
				2" Ice					
RRH2x40 700	C	From Leg	0.00	0.0000	120.00	No Ice	1.96	1.03	0.05
			0.00	1/2"		2.14	1.17	0.07	
			2.00	Ice		2.32	1.31	0.09	
				1" Ice		2.70	1.62	0.13	
				2" Ice					
(2) DB-T1-6Z-8AB-OZ	C	From Leg	0.00	0.0000	120.00	No Ice	4.80	2.00	0.04
			0.00	1/2"		5.07	2.19	0.08	
			3.00	Ice		5.35	2.39	0.12	
				1" Ice		5.93	2.81	0.21	
				2" Ice					
Sector Mount [SM 502-3]	C	None		0.0000	120.00	No Ice	33.02	33.02	1.67
				1/2"		47.36	47.36	2.22	
				Ice		61.70	61.70	2.77	
				1" Ice		90.38	90.38	3.88	
				2" Ice					
Pipe Mount [PM 601-3]	C	None		0.0000	120.00	No Ice	4.39	4.39	0.20
				1/2"		5.48	5.48	0.24	
				Ice		6.57	6.57	0.28	
				1" Ice		8.75	8.75	0.36	
				2" Ice					
88 APXVSP18-C-A20_TIA w/ Mount Pipe	A	From Leg	0.00	0.0000	88.00	No Ice	8.26	7.47	0.10
			0.00	1/2"		8.82	8.66	0.17	
			0.00	Ice		9.35	9.56	0.24	
				1" Ice		10.42	11.39	0.43	
				2" Ice					
P40-16-XLPP-RR w/ Mount Pipe	B	From Leg	0.00	0.0000	88.00	No Ice	8.24	4.83	0.08
			0.00	1/2"		8.70	5.57	0.15	
			0.00	Ice		9.16	6.27	0.22	
				1" Ice		10.09	7.67	0.38	
				2" Ice					
APXVSP18-C-A20_TIA w/ Mount Pipe	C	From Leg	0.00	0.0000	88.00	No Ice	8.26	7.47	0.10
			0.00	1/2"		8.82	8.66	0.17	
			0.00	Ice		9.35	9.56	0.24	
				1" Ice		10.42	11.39	0.43	
				2" Ice					
800MHZ RRH	A	From Leg	0.00	0.0000	88.00	No Ice	2.13	1.77	0.05
			0.00	1/2"		2.32	1.95	0.07	
			0.00	Ice		2.51	2.13	0.10	
				1" Ice		2.92	2.51	0.16	
				2" Ice					
800MHZ RRH	B	From Leg	0.00	0.0000	88.00	No Ice	2.13	1.77	0.05
			0.00	1/2"		2.32	1.95	0.07	
			0.00	Ice		2.51	2.13	0.10	
				1" Ice		2.92	2.51	0.16	
				2" Ice					
800MHZ RRH	C	From Leg	0.00	0.0000	88.00	No Ice	2.13	1.77	0.05
			0.00	1/2"		2.32	1.95	0.07	
			0.00	Ice		2.51	2.13	0.10	
				1" Ice		2.92	2.51	0.16	
				2" Ice					
1900MHz RRH	A	From Leg	0.00	0.0000	88.00	No Ice	2.49	3.26	0.04
			0.00	1/2"		2.70	3.48	0.08	
			0.00	Ice		2.91	3.72	0.11	
				1" Ice		3.35	4.21	0.19	
				2" Ice					

Description	Face or Leg	Offset Type	Offsets:		Azimuth Adjustment	Placement	C _{AA} Front	C _{AA} Side	Weight	
			Horz	Lateral						Vert
			ft	ft	°	ft	ft ²	ft ²	K	
1900MHz RRH	B	From Leg	0.00	0.00	0.0000	88.00	2" Ice			
			0.00	0.00			No Ice	2.49	3.26	0.04
			0.00	0.00			1/2"	2.70	3.48	0.08
							Ice	2.91	3.72	0.11
							1" Ice	3.35	4.21	0.19
1900MHz RRH	C	From Leg	0.00	0.00	0.0000	88.00	2" Ice			
			0.00	0.00			No Ice	2.49	3.26	0.04
			0.00	0.00			1/2"	2.70	3.48	0.08
							Ice	2.91	3.72	0.11
							1" Ice	3.35	4.21	0.19
Sector Mount [SM 502-3]	C	None			0.0000	88.00	2" Ice			
							No Ice	33.02	33.02	1.67
							1/2"	47.36	47.36	2.22
							Ice	61.70	61.70	2.77
							1" Ice	90.38	90.38	3.88
56 GPS_A	B	From Leg	0.00	0.00	0.0000	56.00	2" Ice			
			0.00	0.00			No Ice	0.26	0.26	0.00
			0.00	0.00			1/2"	0.32	0.32	0.00
							Ice	0.39	0.39	0.01
							1" Ice	0.56	0.56	0.02
3'x2" Horizontal Pipe	B	From Leg	0.00	0.00	0.0000	56.00	2" Ice			
			0.00	0.00			No Ice	0.58	0.01	0.01
			0.00	0.00			1/2"	0.77	0.04	0.02
							Ice	0.97	0.07	0.02
							1" Ice	1.42	0.13	0.05
Ineffective Sec Hztl L3 1/2x3 1/2x1/4	A	From Face	0.00	0.00	0.0000	55.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
L3 1/2x3 1/2x1/4	B	From Face	0.00	0.00	0.0000	55.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
L3 1/2x3 1/2x1/4	C	From Face	0.00	0.00	0.0000	55.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
* L3 1/2x3 1/2x1/4	A	From Face	0.00	0.00	0.0000	45.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
L3 1/2x3 1/2x1/4	B	From Face	0.00	0.00	0.0000	45.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
L3 1/2x3 1/2x1/4	C	From Face	0.00	0.00	0.0000	45.00	2" Ice			
			0.00	0.00			No Ice	5.93	0.00	0.12
			0.00	0.00			1/2"	7.65	0.00	0.18
							Ice	9.38	0.00	0.24
							1" Ice	12.83	0.00	0.37
* L4x4x1/4	A	From Face	0.00	0.00	0.0000	15.00	2" Ice			
			0.00	0.00			No Ice	8.17	0.00	0.16
			0.00	0.00			1/2"	10.18	0.00	0.25
							Ice	12.19	0.00	0.33
							1" Ice	16.22	0.00	0.50

Description	Face or Leg	Offset Type	Offsets:		Azimuth Adjustment	Placement	C _{AA} _{Front}	C _{AA} _{Side}	Weight
			Horz Lateral	Vert					
L4x4x1/4	B	From Face	0.00	0.0000	15.00	No Ice	8.17	0.00	0.16
			0.00	0.00		1/2" Ice	10.18	0.00	0.25
			0.00	0.00		Ice	12.19	0.00	0.33
						1" Ice	16.22	0.00	0.50
						2" Ice			
L4x4x1/4	C	From Face	0.00	0.0000	15.00	No Ice	8.17	0.00	0.16
			0.00	0.00		1/2" Ice	10.18	0.00	0.25
			0.00	0.00		Ice	12.19	0.00	0.33
						1" Ice	16.22	0.00	0.50
						2" Ice			
* L4x4x1/4	A	From Face	0.00	0.0000	5.00	No Ice	8.17	0.00	0.16
			0.00	0.00		1/2" Ice	10.18	0.00	0.25
			0.00	0.00		Ice	12.19	0.00	0.33
						1" Ice	16.22	0.00	0.50
						2" Ice			
L4x4x1/4	B	From Face	0.00	0.0000	5.00	No Ice	8.17	0.00	0.16
			0.00	0.00		1/2" Ice	10.18	0.00	0.25
			0.00	0.00		Ice	12.19	0.00	0.33
						1" Ice	16.22	0.00	0.50
						2" Ice			
L4x4x1/4	C	From Face	0.00	0.0000	5.00	No Ice	8.17	0.00	0.16
			0.00	0.00		1/2" Ice	10.18	0.00	0.25
			0.00	0.00		Ice	12.19	0.00	0.33
						1" Ice	16.22	0.00	0.50
						2" Ice			

Dishes

Description	Face or Leg	Dish Type	Offset Type	Offsets:		Azimuth Adjustment	3 dB Beam Width	Elevation	Outside Diameter	Aperture Area	Weight	
				Horz Lateral	Vert							ft
6' Microwave Dish w/ Radome	C	Paraboloid w/Radome	From Leg	0.00	0.0000	-35.6000		177.00	6.00	No Ice	28.27	0.25
				0.00	0.00					1/2" Ice	29.07	0.40
				0.00	0.00					1" Ice	29.86	0.55
										2" Ice	31.44	0.85

Load Combinations

Comb. No.	Description
1	Dead Only
2	1.2 Dead+1.0 Wind 0 deg - No Ice
3	0.9 Dead+1.0 Wind 0 deg - No Ice
4	1.2 Dead+1.0 Wind 30 deg - No Ice
5	0.9 Dead+1.0 Wind 30 deg - No Ice
6	1.2 Dead+1.0 Wind 60 deg - No Ice
7	0.9 Dead+1.0 Wind 60 deg - No Ice
8	1.2 Dead+1.0 Wind 90 deg - No Ice
9	0.9 Dead+1.0 Wind 90 deg - No Ice
10	1.2 Dead+1.0 Wind 120 deg - No Ice
11	0.9 Dead+1.0 Wind 120 deg - No Ice
12	1.2 Dead+1.0 Wind 150 deg - No Ice
13	0.9 Dead+1.0 Wind 150 deg - No Ice

Comb. No.	Description
14	1.2 Dead+1.0 Wind 180 deg - No Ice
15	0.9 Dead+1.0 Wind 180 deg - No Ice
16	1.2 Dead+1.0 Wind 210 deg - No Ice
17	0.9 Dead+1.0 Wind 210 deg - No Ice
18	1.2 Dead+1.0 Wind 240 deg - No Ice
19	0.9 Dead+1.0 Wind 240 deg - No Ice
20	1.2 Dead+1.0 Wind 270 deg - No Ice
21	0.9 Dead+1.0 Wind 270 deg - No Ice
22	1.2 Dead+1.0 Wind 300 deg - No Ice
23	0.9 Dead+1.0 Wind 300 deg - No Ice
24	1.2 Dead+1.0 Wind 330 deg - No Ice
25	0.9 Dead+1.0 Wind 330 deg - No Ice
26	1.2 Dead+1.0 Ice+1.0 Temp
27	1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp
28	1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp
29	1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp
30	1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp
31	1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp
32	1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp
33	1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp
34	1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp
35	1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp
36	1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp
37	1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp
38	1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp
39	Dead+Wind 0 deg - Service
40	Dead+Wind 30 deg - Service
41	Dead+Wind 60 deg - Service
42	Dead+Wind 90 deg - Service
43	Dead+Wind 120 deg - Service
44	Dead+Wind 150 deg - Service
45	Dead+Wind 180 deg - Service
46	Dead+Wind 210 deg - Service
47	Dead+Wind 240 deg - Service
48	Dead+Wind 270 deg - Service
49	Dead+Wind 300 deg - Service
50	Dead+Wind 330 deg - Service

Maximum Member Forces

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Axial K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft	
T1	180 - 160	Leg	Max Tension	7	5.59	-0.05	0.09	
			Max. Compression	2	-7.40	-0.00	0.11	
			Max. Mx	4	-1.01	0.35	0.18	
			Max. My	3	-0.09	0.04	-0.49	
			Max. Vy	20	0.44	0.03	-0.00	
			Max. Vx	2	-0.41	0.03	0.29	
		Diagonal	Max Tension	5	1.87	0.00	0.00	
			Max. Compression	4	-1.91	0.00	0.00	
			Max. Mx	38	0.13	0.04	-0.00	
			Max. My	7	-0.80	0.00	0.00	
			Max. Vy	38	-0.04	0.04	-0.00	
			Max. Vx	7	-0.00	0.00	0.00	
			Top Girt	Max Tension	11	0.07	0.00	0.00
				Max. Compression	37	-0.17	0.00	0.00
T2	160 - 140	Leg	Max. Mx	26	-0.12	-0.16	0.00	
			Max. Vy	26	0.08	0.00	0.00	
			Max Tension	7	15.40	-0.24	0.02	
			Max. Compression	2	-18.95	0.09	0.00	
			Max. Mx	14	13.32	0.27	0.00	
			Max. My	20	-1.95	-0.01	0.31	
		Diagonal	Max. Vy	14	-0.31	-0.24	0.00	
			Max. Vx	21	-0.30	-0.00	-0.16	
			Max Tension	5	2.58	0.00	0.00	
			Max. Compression	4	-2.61	0.00	0.00	

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Axial K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft		
T3	140 - 120	Leg	Max. Mx	38	0.17	0.06	-0.01		
			Max. My	29	-0.84	0.06	0.01		
			Max. Vy	38	0.05	0.06	-0.01		
			Max. Vx	29	-0.00	0.00	0.00		
			Max Tension	7	28.70	-0.41	0.03		
			Max. Compression	2	-35.86	0.04	0.00		
			Max. Mx	14	20.90	0.79	-0.02		
		Diagonal	Max. My	21	-2.40	-0.03	0.75		
			Max. Vy	6	-0.47	-0.43	0.03		
			Max. Vx	12	-0.49	-0.01	-0.25		
			Max Tension	4	4.21	0.00	0.00		
			Max. Compression	4	-4.25	0.00	0.00		
			Max. Mx	38	0.44	0.10	-0.01		
			Max. My	36	0.73	0.10	-0.01		
T4	120 - 100	Leg	Max. Vy	38	0.07	0.10	0.01		
			Max. Vx	36	0.00	0.00	0.00		
			Max Tension	7	50.13	-0.18	0.02		
			Max. Compression	2	-62.42	0.22	0.03		
			Max. Mx	31	-28.94	0.23	0.00		
			Max. My	20	-5.04	-0.03	-0.46		
			Max. Vy	6	-1.25	0.01	0.04		
		Diagonal	Max. Vx	8	1.12	0.02	-0.19		
			Max Tension	4	5.87	0.00	0.00		
			Max. Compression	4	-5.91	0.00	0.00		
			Max. Mx	38	0.68	0.13	-0.02		
			Max. My	29	-1.68	0.12	0.02		
			Max. Vy	38	0.08	0.13	-0.02		
			Max. Vx	29	-0.00	0.00	0.00		
T5	100 - 80	Leg	Max Tension	7	70.79	-0.76	0.05		
			Max. Compression	2	-87.60	0.56	0.02		
			Max. Mx	22	68.19	-0.78	-0.05		
			Max. My	9	-6.84	-0.05	0.82		
			Max. Vy	22	-0.65	-0.78	-0.05		
			Max. Vx	9	0.65	-0.05	0.82		
			Diagonal	Max Tension	4	7.64	0.00	0.00	
		Max. Compression		4	-7.77	0.00	0.00		
		Max. Mx		27	2.09	0.24	-0.03		
		Max. My		35	1.32	0.23	-0.03		
		Max. Vy		37	0.12	0.24	0.03		
		Max. Vx		35	0.01	0.00	0.00		
		T6		80 - 60	Leg	Max Tension	7	94.60	-0.27
			Max. Compression			2	-116.45	0.58	0.01
Max. Mx	33		-2.01			-0.63	-0.01		
Max. My	20		-8.80			-0.01	-0.56		
Max. Vy	33		0.13			-0.63	-0.01		
Max. Vx	21		-0.14			-0.01	-0.56		
Diagonal	Max Tension		4			8.15	0.00	0.00	
	Max. Compression		4		-8.31	0.00	0.00		
	Max. Mx		37		1.34	0.27	-0.03		
	Max. My		30		-1.74	0.25	0.04		
	Max. Vy		37		0.13	0.27	0.03		
	Max. Vx		30		-0.01	0.00	0.00		
	T7		60 - 40		Leg	Max Tension	23	118.42	-0.40
Max. Compression						2	-145.27	0.59	0.01
Max. Mx		33		-0.71		-1.17	-0.00		
Max. My		9		-10.01		-0.06	0.58		
Max. Vy		33		0.22		-1.17	-0.00		
Max. Vx		9		0.15		-0.06	0.58		
Diagonal		Max Tension		4		8.62	0.00	0.00	
		Max. Compression		4	-8.72	0.00	0.00		
		Max. Mx		37	1.05	0.38	-0.05		
		Max. My		36	2.29	0.35	-0.05		
		Max. Vy		37	0.16	0.35	0.05		
		Max. Vx		36	0.01	0.00	0.00		
		T8		40 - 20	Leg	Max Tension	23	142.15	-0.48
Max. Compression						2	-174.08	0.74	0.00
Diagonal	Max. Mx		37		8.01	-2.42	-0.01		
	Max. My		9		-11.87	-0.06	0.77		
	Max. Vy		33		0.44	-2.41	-0.00		
	Max. Vx		33		0.44	-2.41	-0.00		

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Axial K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft
T9	20 - 0	Diagonal	Max. Vx	9	0.17	-0.06	0.77
			Max Tension	4	9.31	0.00	0.00
			Max. Compression	10	-9.64	0.00	0.00
			Max. Mx	37	0.68	0.52	-0.06
			Max. My	30	3.11	0.41	0.06
			Max. Vy	37	0.19	0.52	-0.06
		Leg	Max. Vx	30	-0.01	0.00	0.00
			Max Tension	23	165.42	-0.67	-0.03
			Max. Compression	10	-203.60	0.00	-0.00
			Max. Mx	37	11.68	-2.42	-0.01
			Max. My	9	-14.48	-0.08	1.28
			Max. Vy	33	-0.49	-2.41	-0.00
		Diagonal	Max. Vx	9	0.25	-0.08	1.28
			Max Tension	4	9.92	0.00	0.00
			Max. Compression	10	-10.58	0.00	0.00
			Max. Mx	37	-0.19	0.60	-0.06
			Max. My	36	4.84	0.39	-0.07
			Max. Vy	37	0.20	0.60	-0.06
			Max. Vx	36	0.01	0.00	0.00

Maximum Reactions

Location	Condition	Gov. Load Comb.	Vertical K	Horizontal, X K	Horizontal, Z K
Leg C	Max. Vert	18	207.04	23.27	-14.07
	Max. H _x	18	207.04	23.27	-14.07
	Max. H _z	7	-168.05	-19.54	11.91
	Min. Vert	7	-168.05	-19.54	11.91
	Min. H _x	7	-168.05	-19.54	11.91
	Min. H _z	18	207.04	23.27	-14.07
Leg B	Max. Vert	10	211.05	-24.05	-14.54
	Max. H _x	23	-171.09	20.21	12.29
	Max. H _z	23	-171.09	20.21	12.29
	Min. Vert	23	-171.09	20.21	12.29
	Min. H _x	10	211.05	-24.05	-14.54
	Min. H _z	10	211.05	-24.05	-14.54
Leg A	Max. Vert	2	210.22	-0.30	27.52
	Max. H _x	21	13.18	4.64	1.16
	Max. H _z	2	210.22	-0.30	27.52
	Min. Vert	15	-164.84	0.28	-22.82
	Min. H _x	8	19.76	-4.68	1.72
	Min. H _z	15	-164.84	0.28	-22.82

Tower Mast Reaction Summary

Load Combination	Vertical K	Shear _x K	Shear _z K	Overtuning Moment, M _x kip-ft	Overtuning Moment, M _z kip-ft	Torque kip-ft
Dead Only	42.66	-0.00	-0.00	-16.27	6.33	0.00
1.2 Dead+1.0 Wind 0 deg - No Ice	51.19	0.10	-44.95	-4158.57	-9.96	-12.42
0.9 Dead+1.0 Wind 0 deg - No Ice	38.39	0.10	-44.95	-4153.69	-11.86	-12.42
1.2 Dead+1.0 Wind 30 deg - No Ice	51.19	21.12	-36.32	-3403.07	-1969.23	-14.88
0.9 Dead+1.0 Wind 30 deg - No Ice	38.39	21.12	-36.32	-3398.19	-1971.13	-14.88
1.2 Dead+1.0 Wind 60 deg - No Ice	51.19	36.00	-20.78	-1967.29	-3361.06	-24.16

Load Combination	Vertical	Shear _x	Shear _z	Overturning Moment, M _x	Overturning Moment, M _z	Torque
	K	K	K	kip-ft	kip-ft	kip-ft
0.9 Dead+1.0 Wind 60 deg - No Ice	38.39	36.00	-20.78	-1962.41	-3362.96	-24.16
1.2 Dead+1.0 Wind 90 deg - No Ice	51.19	43.14	-0.22	-57.99	-3986.28	-35.87
0.9 Dead+1.0 Wind 90 deg - No Ice	38.39	43.14	-0.22	-53.11	-3988.18	-35.87
1.2 Dead+1.0 Wind 120 deg - No Ice	51.19	40.04	22.83	2041.47	-3643.95	-24.19
0.9 Dead+1.0 Wind 120 deg - No Ice	38.39	40.04	22.83	2046.35	-3645.85	-24.19
1.2 Dead+1.0 Wind 150 deg - No Ice	51.19	21.57	37.27	3381.02	-1961.90	1.14
0.9 Dead+1.0 Wind 150 deg - No Ice	38.39	21.57	37.27	3385.89	-1963.80	1.14
1.2 Dead+1.0 Wind 180 deg - No Ice	51.19	-0.10	41.56	3819.54	24.43	12.24
0.9 Dead+1.0 Wind 180 deg - No Ice	38.39	-0.10	41.56	3824.42	22.53	12.24
1.2 Dead+1.0 Wind 210 deg - No Ice	51.19	-21.04	36.15	3333.17	1970.42	14.03
0.9 Dead+1.0 Wind 210 deg - No Ice	38.39	-21.04	36.15	3338.05	1968.52	14.03
1.2 Dead+1.0 Wind 240 deg - No Ice	51.19	-38.46	22.19	2027.40	3552.39	23.09
0.9 Dead+1.0 Wind 240 deg - No Ice	38.39	-38.46	22.19	2032.28	3550.49	23.09
1.2 Dead+1.0 Wind 270 deg - No Ice	51.19	-42.92	0.04	-13.05	3963.89	34.81
0.9 Dead+1.0 Wind 270 deg - No Ice	38.39	-42.92	0.04	-8.17	3961.99	34.81
1.2 Dead+1.0 Wind 300 deg - No Ice	51.19	-37.24	-21.52	-1997.38	3423.01	23.54
0.9 Dead+1.0 Wind 300 deg - No Ice	38.39	-37.24	-21.52	-1992.50	3421.11	23.54
1.2 Dead+1.0 Wind 330 deg - No Ice	51.19	-21.64	-37.58	-3475.12	1988.49	-1.58
0.9 Dead+1.0 Wind 330 deg - No Ice	38.39	-21.64	-37.58	-3470.25	1986.59	-1.58
1.2 Dead+1.0 Ice+1.0 Temp	143.42	-0.00	-0.00	-79.62	29.90	0.00
1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp	143.42	0.02	-12.69	-1295.82	26.63	-3.99
1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp	143.42	6.20	-10.68	-1112.01	-571.24	-6.68
1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp	143.42	10.67	-6.15	-677.21	-1005.76	-9.97
1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp	143.42	12.48	-0.04	-86.30	-1173.85	-10.76
1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp	143.42	11.10	6.35	523.43	-1030.16	-6.25
1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp	143.42	6.22	10.75	947.56	-564.96	0.08
1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp	143.42	-0.02	12.25	1097.98	33.06	3.96
1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp	143.42	-6.19	10.65	947.75	628.76	6.54
1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp	143.42	-10.97	6.32	529.01	1085.38	9.80
1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp	143.42	-12.45	0.01	-78.14	1227.54	10.59
1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp	143.42	-10.74	-6.19	-674.24	1060.38	6.15
1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp	143.42	-6.23	-10.80	-1115.75	626.61	-0.16
Dead+Wind 0 deg - Service	42.66	0.02	-9.57	-897.96	2.59	-2.65
Dead+Wind 30 deg - Service	42.66	4.50	-7.74	-737.02	-414.77	-3.17
Dead+Wind 60 deg - Service	42.66	7.67	-4.43	-431.17	-711.25	-5.15
Dead+Wind 90 deg - Service	42.66	9.19	-0.05	-24.46	-844.44	-7.64
Dead+Wind 120 deg - Service	42.66	8.53	4.86	422.76	-771.52	-5.15

Load Combination	Vertical	Shear _x	Shear _z	Overturning Moment, M _x	Overturning Moment, M _z	Torque
	K	K	K	kip-ft	kip-ft	kip-ft
Dead+Wind 150 deg - Service	42.66	4.60	7.94	708.11	-413.21	0.24
Dead+Wind 180 deg - Service	42.66	-0.02	8.85	801.52	9.91	2.61
Dead+Wind 210 deg - Service	42.66	-4.48	7.70	697.92	424.44	2.99
Dead+Wind 240 deg - Service	42.66	-8.19	4.73	419.77	761.43	4.92
Dead+Wind 270 deg - Service	42.66	-9.14	0.01	-14.89	849.09	7.41
Dead+Wind 300 deg - Service	42.66	-7.93	-4.58	-437.58	733.87	5.02
Dead+Wind 330 deg - Service	42.66	-4.61	-8.01	-752.37	428.29	-0.34

Solution Summary

Load Comb.	Sum of Applied Forces			Sum of Reactions			% Error
	PX K	PY K	PZ K	PX K	PY K	PZ K	
1	0.00	-42.66	0.00	0.00	42.66	0.00	0.000%
2	0.10	-51.19	-44.95	-0.10	51.19	44.95	0.000%
3	0.10	-38.39	-44.95	-0.10	38.39	44.95	0.000%
4	21.12	-51.19	-36.32	-21.12	51.19	36.32	0.000%
5	21.12	-38.39	-36.32	-21.12	38.39	36.32	0.000%
6	36.00	-51.19	-20.78	-36.00	51.19	20.78	0.000%
7	36.00	-38.39	-20.78	-36.00	38.39	20.78	0.000%
8	43.14	-51.19	-0.22	-43.14	51.19	0.22	0.000%
9	43.14	-38.39	-0.22	-43.14	38.39	0.22	0.000%
10	40.04	-51.19	22.83	-40.04	51.19	-22.83	0.000%
11	40.04	-38.39	22.83	-40.04	38.39	-22.83	0.000%
12	21.57	-51.19	37.27	-21.57	51.19	-37.27	0.000%
13	21.57	-38.39	37.27	-21.57	38.39	-37.27	0.000%
14	-0.10	-51.19	41.56	0.10	51.19	-41.56	0.000%
15	-0.10	-38.39	41.56	0.10	38.39	-41.56	0.000%
16	-21.04	-51.19	36.15	21.04	51.19	-36.15	0.000%
17	-21.04	-38.39	36.15	21.04	38.39	-36.15	0.000%
18	-38.46	-51.19	22.19	38.46	51.19	-22.19	0.000%
19	-38.46	-38.39	22.19	38.46	38.39	-22.19	0.000%
20	-42.92	-51.19	0.04	42.92	51.19	-0.04	0.000%
21	-42.92	-38.39	0.04	42.92	38.39	-0.04	0.000%
22	-37.24	-51.19	-21.52	37.24	51.19	21.52	0.000%
23	-37.24	-38.39	-21.52	37.24	38.39	21.52	0.000%
24	-21.64	-51.19	-37.58	21.64	51.19	37.58	0.000%
25	-21.64	-38.39	-37.58	21.64	38.39	37.58	0.000%
26	0.00	-143.42	0.00	0.00	143.42	0.00	0.000%
27	0.02	-143.42	-12.69	-0.02	143.42	12.69	0.000%
28	6.20	-143.42	-10.68	-6.20	143.42	10.68	0.000%
29	10.67	-143.42	-6.15	-10.67	143.42	6.15	0.000%
30	12.48	-143.42	-0.04	-12.48	143.42	0.04	0.000%
31	11.10	-143.42	6.35	-11.10	143.42	-6.35	0.000%
32	6.22	-143.42	10.75	-6.22	143.42	-10.75	0.000%
33	-0.02	-143.42	12.25	0.02	143.42	-12.25	0.000%
34	-6.19	-143.42	10.65	6.19	143.42	-10.65	0.000%
35	-10.97	-143.42	6.32	10.97	143.42	-6.32	0.000%
36	-12.45	-143.42	0.01	12.45	143.42	-0.01	0.000%
37	-10.74	-143.42	-6.19	10.74	143.42	6.19	0.000%
38	-6.23	-143.42	-10.80	6.23	143.42	10.80	0.000%
39	0.02	-42.66	-9.57	-0.02	42.66	9.57	0.000%
40	4.50	-42.66	-7.74	-4.50	42.66	7.74	0.000%
41	7.67	-42.66	-4.43	-7.67	42.66	4.43	0.000%
42	9.19	-42.66	-0.05	-9.19	42.66	0.05	0.000%
43	8.53	-42.66	4.86	-8.53	42.66	-4.86	0.000%
44	4.60	-42.66	7.94	-4.60	42.66	-7.94	0.000%
45	-0.02	-42.66	8.85	0.02	42.66	-8.85	0.000%
46	-4.48	-42.66	7.70	4.48	42.66	-7.70	0.000%

Load Comb.	Sum of Applied Forces			Sum of Reactions			% Error
	PX K	PY K	PZ K	PX K	PY K	PZ K	
47	-8.19	-42.66	4.73	8.19	42.66	-4.73	0.000%
48	-9.14	-42.66	0.01	9.14	42.66	-0.01	0.000%
49	-7.93	-42.66	-4.58	7.93	42.66	4.58	0.000%
50	-4.61	-42.66	-8.01	4.61	42.66	8.01	0.000%

Maximum Tower Deflections - Service Wind

Section No.	Elevation ft	Horz. Deflection in	Gov. Load Comb.	Tilt °	Twist °
T1	180 - 160	2.408	39	0.1092	0.0200
T2	160 - 140	1.948	39	0.1060	0.0188
T3	140 - 120	1.506	39	0.0968	0.0133
T4	120 - 100	1.118	39	0.0814	0.0098
T5	100 - 80	0.779	39	0.0698	0.0069
T6	80 - 60	0.506	39	0.0538	0.0054
T7	60 - 40	0.290	39	0.0405	0.0035
T8	40 - 20	0.138	39	0.0251	0.0022
T9	20 - 0	0.043	43	0.0130	0.0011

Critical Deflections and Radius of Curvature - Service Wind

Elevation ft	Appurtenance	Gov. Load Comb.	Deflection in	Tilt °	Twist °	Radius of Curvature ft
180.00	2" Dia 20' Omni	39	2.408	0.1092	0.0200	Inf
177.00	6' Microwave Dish w/ Radome	39	2.338	0.1089	0.0200	Inf
174.00	12' Dipole	39	2.269	0.1085	0.0199	Inf
165.00	ANT220F6	39	2.062	0.1071	0.0193	577387
157.00	2" Dia 5' Omni	39	1.879	0.1051	0.0182	249205
145.00	LNx-6512DS-T4M_TIA w/ Mount Pipe	39	1.612	0.0999	0.0147	87206
133.00	BA40-41-DIN (4 diploes (2 bays) 11.5' dipole)	39	1.364	0.0915	0.0118	82797
130.00	P65-16-XLH-RR w/ Mount Pipe	39	1.305	0.0891	0.0113	91054
120.00	(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	39	1.118	0.0814	0.0098	124568
88.00	APXVSP18-C-A20_TIA w/ Mount Pipe	39	0.608	0.0603	0.0059	81196
56.00	GPS_A	39	0.254	0.0375	0.0031	69964
55.00	L3 1/2x3 1/2x1/4	39	0.246	0.0367	0.0031	70991
45.00	L3 1/2x3 1/2x1/4	39	0.170	0.0288	0.0025	83429
15.00	L4x4x1/4	43	0.029	0.0099	0.0008	100694
5.00	L4x4x1/4	43	0.008	0.0034	0.0003	302081

Maximum Tower Deflections - Design Wind

Section No.	Elevation ft	Horz. Deflection in	Gov. Load Comb.	Tilt °	Twist °
T1	180 - 160	11.017	2	0.4958	0.0938
T2	160 - 140	8.931	2	0.4798	0.0881
T3	140 - 120	6.922	2	0.4403	0.0624
T4	120 - 100	5.151	2	0.3720	0.0461
T5	100 - 80	3.595	2	0.3201	0.0325
T6	80 - 60	2.347	11	0.2474	0.0253

Section No.	Elevation ft	Horz. Deflection in	Gov. Load Comb.	Tilt °	Twist °
T7	60 - 40	1.350	11	0.1863	0.0163
T8	40 - 20	0.646	11	0.1159	0.0102
T9	20 - 0	0.205	11	0.0601	0.0051

Critical Deflections and Radius of Curvature - Design Wind

Elevation ft	Appurtenance	Gov. Load Comb.	Deflection in	Tilt °	Twist °	Radius of Curvature ft
180.00	2" Dia 20' Omni	2	11.017	0.4958	0.0938	515276
177.00	6' Microwave Dish w/ Radome	2	10.703	0.4939	0.0937	515276
174.00	12' Dipole	2	10.389	0.4920	0.0934	429399
165.00	ANT220F6	2	9.450	0.4851	0.0907	171760
157.00	2" Dia 5' Omni	2	8.621	0.4760	0.0854	61019
145.00	LNx-6512DS-T4M_TIA w/ Mount Pipe	2	7.406	0.4538	0.0691	19810
133.00	BA40-41-DIN (4 diploes (2 bays) 11.5' dipole)	2	6.275	0.4170	0.0553	18822
130.00	P65-16-XLH-RR w/ Mount Pipe	2	6.007	0.4062	0.0530	20767
120.00	(2) BXA-70063-6CF-EDIN-X w/ Mount Pipe	2	5.151	0.3720	0.0461	28708
88.00	APXVSP18-C-A20_TIA w/ Mount Pipe	11	2.811	0.2770	0.0279	17886
56.00	GPS_A	11	1.185	0.1727	0.0148	15178
55.00	L3 1/2x3 1/2x1/4	11	1.146	0.1692	0.0144	15403
45.00	L3 1/2x3 1/2x1/4	11	0.796	0.1330	0.0115	18139
15.00	L4x4x1/4	11	0.138	0.0459	0.0038	21830
5.00	L4x4x1/4	11	0.040	0.0156	0.0013	65490

Bolt Design Data

Section No.	Elevation ft	Component Type	Bolt Grade	Bolt Size in	Number Of Bolts	Maximum Load per Bolt K	Allowable Load per Bolt K	Ratio Load Allowable	Allowable Ratio	Criteria
T1	180	Leg	A325N	0.6250	4	1.40	20.34	0.069	1.05	Bolt Tension Member Bearing
			A325N	0.5000	1	1.87	6.20	0.302	1.05	
T2	160	Top Girt	A325N	0.5000	1	0.17	8.84	0.019	1.05	Bolt Shear Member Bearing
			A325N	0.7500	4	3.85	30.10	0.128	1.05	
T3	140	Leg	A325N	0.8750	4	7.17	41.56	0.173	1.05	Bolt Tension Member Bearing
			A325N	0.5000	1	4.21	6.20	0.678	1.05	
T4	120	Leg	A325N	1.0000	4	12.53	54.52	0.230	1.05	Bolt Tension Member Bearing
			A325N	0.5000	1	5.87	8.27	0.710	1.05	
T5	100	Leg	A325N	1.0000	4	17.70	54.52	0.325	1.05	Bolt Tension Member Bearing
			A325N	0.7500	1	7.64	13.39	0.571	1.05	
T6	80	Leg	A325N	1.0000	4	23.65	54.52	0.434	1.05	Bolt Tension Member Bearing
			A325N	0.7500	1	8.15	8.93	0.913	1.05	
T7	60	Leg	A325N	1.0000	6	19.74	54.52	0.362	1.05	Bolt Tension Member Bearing
			A325N	0.7500	1	8.62	13.39	0.644	1.05	
T8	40	Leg	A325N	1.0000	6	23.69	54.52	0.435	1.05	Bolt Tension Member Bearing
			A325N	0.7500	1	9.31	13.39	0.695	1.05	

Section No.	Elevation ft	Component Type	Bolt Grade	Bolt Size in	Number Of Bolts	Maximum Load per Bolt K	Allowable Load per Bolt K	Ratio Load Allowable	Allowable Ratio	Criteria
T9	20	Diagonal	A325N	0.8750	1	9.92	9.81	1.011	1.05	Member Bearing

Compression Checks

Leg Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	P2.5x0.203	20.00	5.00	63.3 K=1.00	1.7040	-7.40	57.19	0.129 ¹
T2	160 - 140	P2.5x.276	20.03	6.68	86.7 K=1.00	2.2535	-18.95	58.51	0.324 ¹
T3	140 - 120	P3x0.216	20.04	6.68	68.9 K=1.00	2.2285	-35.86	70.89	0.506 ¹
T4	120 - 100	P4x0.337	20.04	6.68	54.3 K=1.00	4.4074	-62.42	159.90	0.390 ¹
T5	100 - 80	P5x0.258	20.03	10.02	64.0 K=1.00	4.2999	-87.60	143.40	0.611 ¹
T6	80 - 60	P5x0.375	20.03	10.02	65.4 K=1.00	6.1114	-116.45	201.22	0.579 ¹
T7	60 - 40	P5x0.375	20.04	10.02	65.4 K=1.00	6.1114	-145.27	201.20	0.722 ¹
T8	40 - 20	P6x0.432	20.03	10.02	54.8 K=1.00	8.4049	-174.08	303.75	0.573 ¹
T9	20 - 0	P6x0.432	20.03	10.02	54.8 K=1.00	8.4049	-203.60	303.75	0.670 ¹

¹ $P_u / \phi P_n$ controls

Diagonal Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	L1 3/4x1 3/4x3/16	9.91	4.71	164.7 K=1.00	0.6211	-1.91	6.55	0.291 ¹
T2	160 - 140	L2x2x1/8	12.24	6.07	183.4 K=1.00	0.4844	-2.61	4.12	0.633 ¹
T3	140 - 120	L2 1/2x2 1/2x3/16	14.02	6.94	168.2 K=1.00	0.9020	-4.25	9.13	0.466 ¹
T4	120 - 100	L2 1/2x2 1/2x1/4	15.89	7.83	191.3 K=1.00	1.1900	-5.91	9.31	0.635 ¹
T5	100 - 80	L3x3x3/8	19.10	9.44	192.9 K=1.00	2.1100	-7.77	16.23	0.479 ¹
T6	80 - 60	L3 1/2x3 1/2x1/4	20.83	10.30	178.1 K=1.00	1.6900	-8.31	15.25	0.545 ¹
T7	60 - 40	L3 1/2x3 1/2x3/8	22.67	11.23	196.2 K=1.00	2.4800	-8.72	18.45	0.473 ¹
T8	40 - 20	L4x4x3/8	24.50	12.08	184.0 K=1.00	2.8600	-9.64	24.17	0.399 ¹
T9	20 - 0	L4x4x3/8	26.33	12.99	197.8 K=1.00	2.8600	-10.58	20.93	0.506 ¹

¹ $P_u / \phi P_n$ controls

Top Girt Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	L2 1/2x2 1/2x3/16	8.56	8.11	196.7 K=1.00	0.9020	-0.17	6.68	0.025 ¹

¹ $P_u / \phi P_n$ controls

Tension Checks

Leg Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	P2.5x0.203	20.00	5.00	63.3	1.7040	5.61	76.68	0.073 ¹
T2	160 - 140	P2.5x.276	20.03	6.68	86.7	2.2535	15.40	101.41	0.152 ¹
T3	140 - 120	P3x0.216	20.04	6.68	68.9	2.2285	28.70	100.28	0.286 ¹
T4	120 - 100	P4x0.337	20.04	6.68	54.3	4.4074	50.13	198.34	0.253 ¹
T5	100 - 80	P5x0.258	20.03	10.02	64.0	4.2999	70.79	193.49	0.366 ¹
T6	80 - 60	P5x0.375	20.03	10.02	65.4	6.1114	94.60	275.01	0.344 ¹
T7	60 - 40	P5x0.375	20.04	10.02	65.4	6.1114	118.42	275.01	0.431 ¹
T8	40 - 20	P6x0.432	20.03	10.02	54.8	8.4049	142.15	378.22	0.376 ¹
T9	20 - 0	P6x0.432	20.03	10.02	54.8	8.4049	165.42	378.22	0.437 ¹

¹ $P_u / \phi P_n$ controls

Diagonal Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	L1 3/4x1 3/4x3/16	9.91	4.71	107.7	0.3779	1.87	16.44	0.114 ¹
T2	160 - 140	L2x2x1/8	12.24	6.07	118.4	0.3047	2.58	13.25	0.195 ¹
T3	140 - 120	L2 1/2x2 1/2x3/16	14.02	6.94	108.6	0.5886	4.21	25.60	0.164 ¹
T4	120 - 100	L2 1/2x2 1/2x1/4	15.89	7.83	123.7	0.7753	5.87	33.73	0.174 ¹
T5	100 - 80	L3x3x3/8	19.10	9.44	125.8	1.3364	7.64	58.13	0.131 ¹
T6	80 - 60	L3 1/2x3 1/2x1/4	20.83	10.30	114.9	1.1034	8.15	48.00	0.170 ¹
T7	60 - 40	L3 1/2x3 1/2x3/8	22.67	11.23	127.5	1.6139	8.62	70.20	0.123 ¹
T8	40 - 20	L4x4x3/8	24.50	12.08	119.2	1.8989	9.31	82.60	0.113 ¹
T9	20 - 0	L4x4x3/8	26.33	12.99	128.2	1.8637	9.92	81.07	0.122 ¹

¹ $P_u / \phi P_n$ controls

Top Girt Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L_u ft	Kl/r	A in ²	P_u K	ϕP_n K	Ratio $\frac{P_u}{\phi P_n}$
T1	180 - 160	L2 1/2x2 1/2x3/16	8.56	8.11	128.3	0.5886	0.07	25.60	0.003 ¹

¹ $P_u / \phi P_n$ controls

Section Capacity Table


Section No.	Elevation ft	Component Type	Size	Critical Element	P K	ϕP_{allow} K	% Capacity	Pass Fail
T1	180 - 160	Leg	P2.5x0.203	3	-7.40	60.05	12.3	Pass
T2	160 - 140	Leg	P2.5x.276	33	-18.95	61.44	30.8	Pass
T3	140 - 120	Leg	P3x0.216	54	-35.86	74.43	48.2	Pass
T4	120 - 100	Leg	P4x0.337	75	-62.42	167.90	37.2	Pass
T5	100 - 80	Leg	P5x0.258	96	-87.60	150.57	58.2	Pass
T6	80 - 60	Leg	P5x0.375	111	-116.45	211.28	55.1	Pass
T7	60 - 40	Leg	P5x0.375	126	-145.27	211.26	68.8	Pass
T8	40 - 20	Leg	P6x0.432	141	-174.08	318.94	54.6	Pass
T9	20 - 0	Leg	P6x0.432	155	-203.60	318.94	63.8	Pass
T1	180 - 160	Diagonal	L1 3/4x1 3/4x3/16	11	-1.91	6.88	27.7	Pass
							28.8 (b)	
T2	160 - 140	Diagonal	L2x2x1/8	38	-2.61	4.33	60.3	Pass
T3	140 - 120	Diagonal	L2 1/2x2 1/2x3/16	59	-4.25	9.58	44.4	Pass
							64.6 (b)	
T4	120 - 100	Diagonal	L2 1/2x2 1/2x1/4	80	-5.91	9.78	60.5	Pass
							67.6 (b)	
T5	100 - 80	Diagonal	L3x3x3/8	101	-7.77	17.04	45.6	Pass
							54.3 (b)	
T6	80 - 60	Diagonal	L3 1/2x3 1/2x1/4	116	-8.31	16.01	51.9	Pass
							86.9 (b)	
T7	60 - 40	Diagonal	L3 1/2x3 1/2x3/8	131	-8.72	19.37	45.0	Pass
							61.3 (b)	
T8	40 - 20	Diagonal	L4x4x3/8	144	-9.64	25.38	38.0	Pass
							66.2 (b)	
T9	20 - 0	Diagonal	L4x4x3/8	159	-10.58	21.97	48.2	Pass
							96.3 (b)	
T1	180 - 160	Top Girt	L2 1/2x2 1/2x3/16	6	-0.17	7.01	2.4	Pass
							Summary	
							Leg (T7)	68.8
							Diagonal (T9)	96.3
							Top Girt (T1)	2.4
							Bolt	96.3
							Checks	
							RATING =	96.3
								Pass

APPENDIX B
BASE LEVEL DRAWING

Feed Line Plan 20'

— Round
 — Flat
 — App In Face
 — App Out Face

Section @ 20'



APPENDIX C
ADDITIONAL CALCULATIONS

References

ANCHOR ROD ANALYSIS

Project Information

Site Name: ES-066 NewtownAWC

TIA Revision:

Rev-G
 Rev-H

TIA-222-G 105% Allowable?

No
 Yes

Max Leg Reactions

Compression

Axial_C := 211·kip

Shear_C := 28·kip

Uplift

Axial_U := 171·kip

Shear_U := 24·kip

Apply TIA-222-H Section 15.5?

No
 Yes

Anchor Rod Data

Diameter of Anchor Rod:

D := 1·in

Anchor Rod Grade:

Number of Anchor Rods:

N := 6

Length from top of concrete to bottom of anchor rod leveling nut:

lar := 0.001·in

Threads in Shear Plane?:

Yes
 No

Thread Series:

Coarse
 Fine
 8-Thread

Consider Base Plate Grout?

Yes
 No

Grout Factor η:

0.90
 0.70
 0.55
 0.50

Threads per Inch: n = 8

(Thread selection invalid if n = 0)

Rod Ultimate Strength: Fu = 120·ksi

Rod Yield Strength: Fy = 92·ksi

Anchor Rod Plastic Section Modulus: (based on tension root diameter)

$$Z := \frac{1}{6} \cdot \left(D - \frac{0.9743 \text{ in}}{n} \right)^3 = 0.113 \cdot \text{in}^3$$

Radius of Gyration:

$$r := \left(\frac{1}{4} \right) \cdot \left(D - \frac{0.9743 \text{ in}}{n} \right) = 0.22 \cdot \text{in}$$

Net Area of Anchor Rod:

$$A_n := \frac{\pi}{4} \cdot \left(D - \frac{0.9743 \text{ in}}{n} \right)^2 = 0.606 \cdot \text{in}^2$$

Nominal Unthreaded Area of Anchor Rod:

$$A_b := \frac{\pi}{4} \cdot (D)^2 = 0.785 \cdot \text{in}^2$$

- F1554-105
- A687
- A354-BC
- A354-BD
- A449
- A572-42
- A572-50
- A572-55
- A572-60
- A572-65
- A588-42
- A588-46
- A588-50
- A36M-42
- A36M-45
- A36M-50
- A36M-55
- A500-50
- A514-GR100
- A53-B-35
- A53-B-42
- A607-60
- A607-65
- S-128
- S-22

TIA-222-G/H Section 4.9.6.1

Anchor Rod Design Capacities

Design Tension Strength:

TIA-222-G/H Section 4.9.6.1

$$R_{nt} := F_u \cdot A_n = 72.689 \cdot \text{kip}$$

$$\phi_t = 0.75$$

$$\phi R_{nt} := \phi_t \cdot R_{nt} = 54.517 \cdot \text{kip}$$

Design Compression Strength:

$$R_{nc} := F_y \cdot A_n = 55.728 \cdot \text{kip}$$

$$\phi_c = 1$$

$$\phi R_{nc} := \phi_c \cdot R_{nc} = 55.728 \cdot \text{kip}$$

Design Buckling Strength:

TIA-222-H Section 4.5.4.2

$$K_0 := 1.2$$

$$F_{cr} = 92 \cdot \text{ksi}$$

$$F_e = 9.581 \times 10^9 \cdot \text{ksi}$$

$$R_{nb} := F_{cr} \cdot A_n = 55.728 \cdot \text{kip}$$

$$\phi_c = 1$$

$$\phi R_{nb} := \phi_c \cdot R_{nb} = 55.728 \cdot \text{kip}$$

Design Shear Strength:

TIA-222-G/H Section 4.9.6.3

$$R_{nv} := \begin{cases} 0.55 \cdot F_u \cdot A_b & \text{if Thread_Type} = \text{"No"} \wedge \text{TIA} = \text{"Rev-G"} \\ 0.45 \cdot F_u \cdot A_b & \text{if Thread_Type} = \text{"Yes"} \wedge \text{TIA} = \text{"Rev-G"} \\ 0.625 \cdot F_u \cdot A_b & \text{if Thread_Type} = \text{"No"} \wedge \text{TIA} = \text{"Rev-H"} \\ 0.5 \cdot F_u \cdot A_b & \text{if Thread_Type} = \text{"Yes"} \wedge \text{TIA} = \text{"Rev-H"} \end{cases}$$

$$R_{nv} = 47.124 \cdot \text{kip}$$

$$R_{nvc} := 0.6 \cdot F_y \cdot 0.5 \cdot A_n = 16.719 \cdot \text{kip}$$

TIA-222-H Section 4.9.9

$$\phi_v = 0.75 \quad \phi_c = 1$$

$$\phi R_{nv} := \phi_v \cdot R_{nv} = 35.343 \cdot \text{kip}$$

$$\phi R_{nvc} := \phi_c \cdot R_{nvc} = 16.719 \cdot \text{kip}$$

Design Flexural Strength:

TIA-222-G/H Section 4.7.1

$$R_{mn} := F_y \cdot Z = 10.386 \cdot \text{kip} \cdot \text{in}$$

$$\phi_f = 0.9$$

$$\phi R_{mn} := \phi_f \cdot R_{mn} = 9.347 \cdot \text{kip} \cdot \text{in}$$

Anchor Rod Loading Demands

Tension Demand:

$$P_{ut} := \frac{\text{Axial_U}}{N} = 28.5 \cdot \text{kip}$$

Compression Demand:

$$P_{uc} := \frac{\text{Axial_C}}{N} = 35.167 \cdot \text{kip}$$

Shear Demand:

$$V_{ut} := \frac{\text{Shear_U}}{N} = 4 \cdot \text{kip}$$

$$V_{uc} := \frac{\text{Shear_C}}{N} = 4.667 \cdot \text{kip}$$

Moment Demand:

$$M_{ut} := 0.65 \cdot l_{ar} \cdot V_{ut} = 2.6 \times 10^{-3} \cdot \text{kip} \cdot \text{in}$$

$$M_{uc} := 0.65 \cdot l_{ar} \cdot V_{uc} = 3.033 \times 10^{-3} \cdot \text{kip} \cdot \text{in}$$

Anchor Rod Interaction Check

TIA-222-G Section 4.9.9

$$SR_g := \begin{cases} \frac{P_{ut} + \frac{V_{ut}}{\eta}}{\phi R_{nt}} & \text{if } \eta > 0.50 \\ \frac{P_{ut} + \frac{V_{ut}}{\eta}}{\phi R_{nt}} & \text{if } \eta = 0.50 \wedge l_{ar} \leq D \wedge P_{ut} > P_{uc} \\ \frac{P_{uc} + \frac{V_{uc}}{\eta}}{\phi R_{nt}} & \text{if } \eta = 0.50 \wedge l_{ar} \leq D \wedge P_{ut} < P_{uc} \\ \left(\frac{V_{ut}}{\phi R_{nv}} \right)^2 + \left(\frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}} \right)^2 & \text{if } \eta = 0.5 \wedge l_{ar} > D \wedge P_{ut} > P_{uc} \\ \left(\frac{V_{uc}}{\phi R_{nv}} \right)^2 + \left(\frac{P_{uc}}{\phi R_{nt}} + \frac{M_{uc}}{\phi R_{mn}} \right)^2 & \text{if } \eta = 0.5 \wedge l_{ar} > D \wedge P_{ut} < P_{uc} \end{cases}$$

$$SR_g = 0.604$$

Anchor Rod Interaction Check

TIA-222-H Section 4.9.9

$$SR_{Pt} := \begin{cases} \left(\frac{P_{ut}}{\phi R_{nt}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } l_{ar} \leq D \\ \left(\frac{P_{ut}}{\phi R_{nt}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } D < l_{ar} \leq 3 \cdot \text{in} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } 3 \cdot \text{in} < l_{ar} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } D < l_{ar} \wedge \text{Grout} = \text{"No"} \end{cases}$$

SR_{Pt} = 0.286

$$SR_{Pc} := \begin{cases} \left(\frac{P_{uc}}{\phi R_{nc}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } l_{ar} \leq D \\ \left(\frac{P_{uc}}{\phi R_{nc}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } D < l_{ar} \leq 3 \cdot \text{in} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{uc}}{\phi R_{nc}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } 3 \cdot \text{in} < l_{ar} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{uc}}{\phi R_{nc}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } D < l_{ar} \leq 4 \cdot D \wedge \text{Grout} = \text{"No"} \\ \left(\frac{P_{uc}}{\phi R_{nb}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } l_{ar} > 4 \cdot D \wedge \text{Grout} = \text{"No"} \end{cases}$$

SR_{Pc} = 0.709

$$SR := \begin{cases} SR_g & \text{if TIA} = \text{"Rev-G"} \\ \max(SR_{Pt}, SR_{Pc}) & \text{if TIA} = \text{"Rev-H"} \wedge S15 = \text{"No"} \\ \frac{\max(SR_{Pt}, SR_{Pc})}{1.05} & \text{if TIA} = \text{"Rev-H"} \wedge S15 = \text{"Yes"} \end{cases} = 0.675$$

$$Check_{SR} := \begin{cases} \text{"Passing"} & \text{if } SR \leq 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Acceptable"} & \text{if } 1.00 < SR \leq 1.05 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Failing"} & \text{if } SR > 1.05 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Passing"} & \text{if } SR \leq 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"No"} \\ \text{"Failing"} & \text{if } SR > 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"No"} \\ \text{"Passing"} & \text{if } SR \leq 1.0 \wedge \text{TIA} = \text{"Rev-H"} \\ \text{"Failing"} & \text{if } SR > 1.0 \wedge \text{TIA} = \text{"Rev-H"} \end{cases} = \text{"Passing"}$$

Anchor Rod Results

Axial Tension Demand:	$P_{ut} = 28.5 \cdot \text{kip}$
Axial Tension Capacity:	$\phi R_{nt} = 54.517 \cdot \text{kip}$
Axial Compression Demand:	$P_{uc} = 35.167 \cdot \text{kip}$
Axial Compression Capacity:	$\phi R_{nc} = 55.728 \cdot \text{kip}$
Shear Tension Demand:	$V_{ut} = 4 \cdot \text{kip}$
Tension Shear Capacity:	$\phi R_{nv} = 35.343 \cdot \text{kip}$
Shear Compression Demand:	$V_{uc} = 4.667 \cdot \text{kip}$
Compression Shear Capacity:	$\phi R_{nvc} = 16.719 \cdot \text{kip}$
Moment Tension Demand:	$M_{ut} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$
Moment Compression Demand:	$M_{uc} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$
Moment Capacity:	$\phi R_{mn} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$

Governing Stress Ratio

$$SR = 67.519\%$$

$$Check_{SR} = \text{"Passing"}$$

Pier and Pad Foundation

Site Name: NewtownAWC

TIA-222 Revision: H
Tower Type: Self Support

Top & Bot. Pad Rein. Different?:
Block Foundation?:

Superstructure Analysis Reactions		
Compression, P_{comp} :	211	kips
Compression Shear, V_{u_comp} :	28	kips
Uplift, P_{uplift} :	171	kips
Uplift Shear, V_{u_uplift} :	24	kips
Tower Height, H :	180	ft
Base Face Width, BW :	24.86	ft
BP Dist. Above Fdn, bp_{dist} :	4	in

Foundation Analysis Checks				
	Capacity	Demand	Rating*	Check
<i>Uplift (kips)</i>	207.98	171.00	78.3%	Pass
<i>Lateral (Sliding) (kips)</i>	75.09	24.00	30.4%	Pass
<i>Bearing Pressure (ksf)</i>	9.89	3.61	34.8%	Pass
<i>Pier Flexure (Comp.) (kip*ft)</i>	768.27	224.00	27.8%	Pass
<i>Pier Flexure (Tension) (kip*ft)</i>	552.10	192.00	33.1%	Pass
<i>Pier Compression (kip)</i>	1819.30	220.00	11.5%	Pass
<i>Pad Flexure (kip*ft)</i>	721.27	149.74	19.8%	Pass
<i>Pad Shear - 1-way (kips)</i>	211.65	44.59	20.1%	Pass
<i>Pad Shear - 2-way (Comp) (ksi)</i>	0.177	0.054	28.9%	Pass
<i>Flexural 2-way (Comp) (kip*ft)</i>	1230.68	134.40	10.4%	Pass
<i>Pad Shear - 2-way (Uplift) (ksi)</i>	0.177	0.067	35.9%	Pass
<i>Flexural 2-way (Tension) (kip*ft)</i>	1230.68	115.20	8.9%	Pass

*Rating per TIA-222-H Section 15.5

Soil Rating*:	78.3%
Structural Rating*:	35.9%

Pier Properties		
Pier Shape:	Square	
Pier Diameter, $dpier$:	2.5	ft
Ext. Above Grade, E :	0.5	ft
Pier Rebar Size, Sc :	7	
Pier Rebar Quantity, mc :	24	
Pier Tie/Spiral Size, St :	3	
Pier Tie/Spiral Quantity, mt :	3	
Pier Reinforcement Type:	Tie	
Pier Clear Cover, cc_{pier} :	2	in

Pad Properties		
Depth, D :	9.5	ft
Pad Width, W :	10	ft
Pad Thickness, T :	2	ft
Pad Rebar Size (Bottom), Sp :	6	
Pad Rebar Quantity (Bottom), mp :	19	
Pad Clear Cover, cc_{pad} :	3	in

Material Properties		
Rebar Grade, Fy :	60	ksi
Concrete Compressive Strength, $F'c$:	3.5	ksi
Dry Concrete Density, δc :	150	pcf

Soil Properties		
Total Soil Unit Weight, γ :	125	pcf
Ultimate Net Bearing, Q_{net} :	12.000	ksf
Cohesion, Cu :		ksf
Friction Angle, ϕ :	34	degrees
SPT Blow Count, N_{blows} :		
Base Friction, μ :	0.6	
Neglected Depth, N :	3.33	ft
Foundation Bearing on Rock?	No	
Groundwater Depth, gw :	N/A	ft

<--Toggle between Gross and Net

PHYSICAL PARAMETERS

<i>Pier Height Above Water Table:</i>	$h_{\text{pier_above}} = (\text{MIN}(\text{gw}, \text{D}-\text{T}) + \text{E})$	$h_{\text{pier_above}} =$	8	ft
<i>Pier Height Below Water Table:</i>	$h_{\text{pier_below}} = ((\text{D}-\text{T}) - \text{MIN}(\text{gw}, \text{D}-\text{T}))$	$h_{\text{pier_below}} =$	0	ft
<i>Buoyant Weight of Pier:</i>	$W_{\text{pier}} = \frac{(\text{dpier}^2) * \text{hpier_above} * \delta\text{c} / 1000 + (\text{dpier}^2) * \text{hpier_below} * (\delta\text{c}-62.4)}{1000}$	$W_{\text{pier}} =$	7.50	kips
<i>Pad Height Above Water Table:</i>	$h_{\text{pad_above}} = \text{IF}(\text{gw} < \text{D}-\text{T}, 0, \text{IF}(\text{gw} > \text{D}, \text{T}, \text{T} - (\text{D}-\text{gw})))$	$h_{\text{pad_above}} =$	2	ft
<i>Pad Height Below Water Table:</i>	$h_{\text{pad_below}} = (\text{T} - \text{IF}(\text{gw} < \text{D}-\text{T}, 0, \text{IF}(\text{gw} > \text{D}, \text{T}, \text{T} - (\text{D}-\text{gw}))))$	$h_{\text{pad_below}} =$	0	ft
<i>Buoyant Weight of Pad:</i>	$W_{\text{pad}} = (\text{W}^2) * \text{hpad_above} * \delta\text{c} / 1000 + (\text{W}^2) * \text{hpad_below} * (\delta\text{c}-62.4) / 1000$	$W_{\text{pad}} =$	30.00	kips
<i>Concrete weight:</i>	$W_{\text{c}} = \text{V} * \delta\text{c}$	$W_{\text{c}} =$	37.5	kips
<i>Soil weight:</i>	$W_{\text{s}} = (\text{D} - \text{T}) * (\text{W}^2 - \text{dpier}^2) * \gamma$	$W_{\text{s}} =$	87.9	kips
<i>EIA/TIA-222 Load Factor:</i>	$\text{LF} = 1$	$\text{LF} =$	1.00	

UPLIFT RESISTANCE

Soil Weight

<i>Soil Height Below Water Table:</i>	$h_1 = \text{MAX}((\text{D}-\text{T}) - \text{gw}, 0)$	$h_1 =$	0	ft
<i>Soil Height Above Water Table:</i>	$h_2 = \text{MIN}(\text{gw}, \text{D}-\text{T})$	$h_2 =$	7.5	ft
<i>Soil Wedge Width 1:</i>	$W'_1 = \text{W} + 2 * (h_1 * \text{IF}(\phi > 25, \text{TAN}(\phi^{\circ}), \text{IF}(\text{AND}(\text{Co}=0, \phi > 0), \text{TAN}(\phi^{\circ}), 0)))$	$W'_1 =$	10.00	ft
<i>Soil Wedge Width 2:</i>	$W'_2 = \text{W}_1 + 2 * (h_2 * \text{IF}(\phi > 25, \text{TAN}(\phi^{\circ}), \text{IF}(\text{AND}(\text{Co}=0, \phi > 0), \text{TAN}(\phi^{\circ}), 0)))$	$W'_2 =$	20.12	ft
<i>Volume of Soil Truncated Pyramid 1 (Below Water Table):</i>	$V'_1 = (h_1/3) * (\text{W}^2 + \text{W}'_1\text{W}_1 + \text{W}_1^2) - ((\text{dpier}^2) * h_1)$	$V'_1 =$	0.00	ft ³
<i>Volume of Soil Truncated Pyramid 2 (Above Water Table):</i>	$V'_2 = (h_2/3) * (\text{W}^2 + \text{W}'_2\text{W}_2 + \text{W}_2^2) - ((\text{dpier}^2) * h_2)$	$V'_2 =$	1717.86	ft ³
<i>Soil Weight of V' 1 (Below Water Table):</i>	$W'_{s1} = V'_1 * (\gamma - \gamma_w)$	$W'_{s1} =$	0.00	kips
<i>Soil Weight of V' 2 (Above Water Table):</i>	$W'_{s2} = V'_2 * \gamma$	$W'_{s2} =$	214.73	kips
<i>Total Weight of Soil:</i>	$W_{\text{s_uplift}} = W'_{s1} + W'_{s2}$	$W_{\text{s_uplift}} =$	214.73	kips

Soil Cohesion

<i>Pad Perimeter:</i>	$P_o = 4 * \text{W}$	$P_o =$	40	ft
<i>Depth to Mid-Layer of Soil:</i>	$H_{\text{shear}} = ((\text{D} - \text{T}) - \text{N}) / 2 + \text{N}$	$H_{\text{shear}} =$	5.42	ft
<i>Cohesion at Mid-Layer of Soil:</i>	$S_u = 0$	$S_u =$	0.00	ksf
<i>Soil Shear:</i>	$\text{Shear}_{\text{soil}} = (S_u/2) * P_o * (\text{D}-\text{T} - \text{MIN}(\text{N}, \text{D}-\text{T}))$	$\text{Shear}_{\text{soil}} =$	0.00	kips

Skin Friction / Adhesion Applied to Pad

<i>Adhesion Factor:</i>	$\alpha = 0$	$\alpha =$	0.00	
<i>Soil Depth from Top of Pad to Mid. Layer (Cohesionless Soil):</i>	$H_{\text{cohesionless}} = \text{T} / 2$	$H_{\text{cohesionless}} =$	1.00	ft
<i>Beta Factor:</i>	$\beta = (\text{MIN}(\text{N_blows}, 15) / 15) * (1.5 - 0.135 * \text{SQRT}(H_{\text{pad}}))$	$\beta =$	0.00	
<i>Pad Side Area:</i>	$A_s = P_o * \text{T}$	$A_s =$	80.00	ft ²
<i>Effective Soil Unit Weight at H_{pad}:</i>	$\gamma_{\text{eff}} = \gamma$	$\gamma_{\text{eff}} =$	0.125	kcf
<i>Soil Depth from Grade to Mid. Layer (Silty Soil):</i>	$H_{\text{silty}} = (\text{D}-\text{T}) + \text{T} / 2$	$H_{\text{silty}} =$	8.50	ft
<i>Cohesion at Mid-Layer of Pad:</i>	$S_{u_pad} = 0$	$S_{u_pad} =$	0.000	ksf
<i>Ultimate Skin Friction / Adhesion:</i>	$f_s = 0$	$f_s =$	0.000	ksf
<i>Skin Friction / Adhesion Resistance:</i>	$F_s = f_s * A_s$	$F_s =$	0.00	kips

Uplift Resistance

<i>Nominal Uplift Resistance:</i>	$R_n = W_c + W'_{s1} + W'_{s2} + \text{Soil}_{\text{shear}} + F_s$	$R_n =$	252.23	kips
<i>Factored Uplift Resistance:</i>	$R_a = \phi D * (W_c + W_s) + \phi su * (\text{Soil}_{\text{shear}} + F_{\text{s}} + W_{\text{s_uplift}} - W_s)$	$R_a =$	207.98	kips

Check Ra = 207.98 kips >= P_{uplift} = 171.00 kips

OK

LATERAL RESISTANCE

Total Nominal Pp Resistance:	$P_{p_total} = P_{p_pier} * A_{p_pier} + P_{p_pad} * A_{p_pad}$	$P_{p_total} = 100.12$	kips
Factored Total Weight for Compression:	$P_{factored_comp} = \phi D * (Wc + Ws + Pcomp / 1.2)$	$P_{factored_comp} = 271.10$	kips
Factored Total Weight for Uplift:	$P_{factored_uplift} = MAX(\phi D * (Wc + Ws) - P_{uplift}, 0)$	$P_{factored_uplift} = 0.00$	kips
Nominal Base Friction Resistance (Comp):	$R_{s_comp} = P * \mu$	$R_{s_comp} = 162.66$	kips
Nominal Base Friction Resistance (Uplift):	$R_{s_uplift} = P * \mu$	$R_{s_uplift} = 0.00$	kips
Lateral Resistance (Comp):	$Va_comp = \Phi s * (P_{p_total} + R_{s_comp})$	$Va_comp = 197.09$	kips
Lateral Resistance (Uplift):	$Va_uplift = \Phi s * (P_{p_total} + R_{s_uplift})$	$Va_uplift = 75.09$	kips
Check	Va_comp = 75.09 kips	>= Vu_uplift = 24.00 kips	RATING: 31.96% OK

PIER REINFORCEMENT

Pier / Column Compression

Pier Cross-Sectional Area:	$A_1 = dpier^2$	$A_1 = 900.00$	in ²
Support Area (2H:1V Slope):	$A_2 = (MIN(W, dpier + 4 * T))^2$	$A_2 = 14400.00$	in ²
Compressive Resistance (H/D < 3):	$\Phi P_{n1} = 0.65 * 0.85 * F'c * A_1 * MIN(\sqrt{A_2/A_1}, 2)$	$\Phi P_{n1} = 3480.75$	kips
Rebar:	$s_{pier} = 7$ $m_{pier} = 24$	$d_{b_pier} = 0.875$ in $A_{b_pier} = 0.6$ in ²	
Provided area of steel:	$A_{s_pier} = A_{b_pier} * m_{pier}$	$A_{s_pier} = 14.40$	in ²
Compressive Resistance (H/D >= 3):	$\Phi P_{n2} = 0.65 * 0.8 * (0.85 * (F'c) * (A_1 - A_{s_pier}) + ((F_y) * A_{s_pier}))$	$\Phi P_{n2} = 1819.30$	kips
	$H/D = (D - T + E) / dpier$	$H/D = 3.20$	
Utilized Compressive Resistance:	$\Phi P_n = P_{n2}$	$\Phi P_n = 1819.30$	kips
Applied Compressive Force:	$P_u = P_{comp} + 1.2 * W_{pier}$	$P_u = 220.00$	kips
Check	$\Phi P_n = 1819.30$ kips	>= $P_u = 220.00$ kips	RATING: 12.09% OK

Pier Flexure

Cross-sectional area:	$A_g = dpier^2$	$A_g = 900.00$	in ²
Min. area of steel (pier):	$A_{smin_pier} = A_g * 0.005$	$A_{smin_pier} = 4.50$	in ²
Cage Width:	$d_o = dpier - 2 * cc - 2 * tie - d_b$	$d_o = 24.38$	in
Check	$A_{s_pier} = 14.40$ in²	>= $A_{smin_pier} = 4.50$ in²	OK
Applied Moment to DSMC (Compression):	$M_{u_comp} = (D - T + E) * Vu + Mu$	$M_{u_comp} = 224.00$	ft-kips
Pier Moment Capacity (Compression):	$\Phi M_{n_comp} = \text{from DSMC}$	$\Phi M_{n_comp} = 768.27$	ft-kips
Check	$M_{u_comp} = 224.00$ ft-kips	>= $\Phi M_{n_comp} = 768.27$ ft-kips	RATING: 29.16% OK
Applied Moment to DSMC (Tension):	$M_{u_tension} = (D - T + E) * Vu + Mu$	$M_{u_tension} = 192.00$	ft-kips
Pier Moment Capacity (Tension):	$\Phi M_{n_tension} = \text{from DSMC}$	$\Phi M_{n_tension} = 552.10$	ft-kips
Check	$M_{u_tension} = 192.00$ ft-kips	>= $\Phi M_{n_tension} = 552.10$ ft-kips	RATING: 34.78% OK

PAD REINFORCEMENT

Elastic Bearing Pressure for Soil Checks

Overturning Moment:	$Mo = 0$	$Mo = 0.00$	ft-kips
Compressive Load for Bearing:	$P_{bearing} = Wc + Ws + Pcomp / 1.2$	$P_{bearing} = 301.22$	kips
Load Eccentricity (0.9*D LC):	$ec_{0.9} = Mo / 0.9 * P_{bearing}$	$ec_{0.9} = 0.00$	ft e <= L/6
Load Eccentricity (1.2*D LC):	$ec_{1.2} = Mo / 1.2 * P_{bearing}$	$ec_{1.2} = 0.00$	ft e <= L/6
Elastic Section Modulus:	$S = W^3 / 6$	$S = 166.67$	ft ³
Positive Pressure (0.9*D LC):	$P_{pos_0.9} = 0.9 * P_{bearing} / Area + Mo / S$	$P_{pos_st_0.9} = 2.71$	ksf
Positive Pressure (1.2*D LC):	$P_{pos_1.2} = 1.2 * P_{bearing} / Area + Mo / S$	$P_{pos_st_1.2} = 3.61$	ksf
Negative Pressure (0.9*D LC):	$P_{neg_0.9} = 0.9 * P_{bearing} / Area - Mo / S$	$P_{neg_st_0.9} = 2.71$	ksf
Negative Pressure (1.2*D LC):	$P_{neg_1.2} = 1.2 * P_{bearing} / Area - Mo / S$	$P_{neg_st_1.2} = 3.61$	ksf
Adjusted Pressure (0.9*D LC):	$Padj_{0.9} = 2 * 0.9 * P_{bearing} / (3 * W * (W/2 - ec_{0.9}))$	$P_{adj_0.9} = 3.61$	ksf
Adjusted Pressure (1.2*D LC):	$Padj_{1.2} = 2 * 1.2 * P_{bearing} / (3 * W * (W/2 - ec_{0.9}))$	$P_{adj_1.2} = 4.82$	ksf
Maximum Pressure (0.9*D LC):	$qu_{1.0.9} = IF(P_{neg} \geq 0, P_{pos}, Padj)$	$qu_{st_0.9} = 2.71$	ksf

Maximum Pressure (1.2*D LC):

$$q_{u1,1.2} = \text{IF}(\text{Pneg} \geq 0, \text{Ppos}, \text{Padj})$$

$$q_{u,sl,1.2} = 3.61 \text{ ksf}$$

One-Way Shear

Rebar:

$$s_{pad} = 6 \text{ Equally spaced; } d_{b,pad} = 0.75 \text{ in}$$

$$m_{pad} = 19 \text{ bottom layer in one direction } A_{b,pad} = 0.44 \text{ in}^2$$

Effective depth:

$$d_c = T - cc - 1.5 * db \quad d_c = 19.9 \text{ in}$$

Distance from Edge of Pad to Column Face:

$$d' = W / 2 - dpier / 2 \quad d' = 3.8 \text{ ft}$$

Distance from Edge of Pad to dc from Column Face:

$$d'' = d' - d_c / 12 \quad d'' = 2.09 \text{ ft}$$

Distance to qs (0.9D LC):

$$L'_{0.9} = (W / 2 - ec_{0.9}) * 3 \quad L'_{0.9} = 10.00 \text{ ft}$$

Distance to qs (1.2D LC):

$$L'_{1.2} = (W / 2 - ec_{1.2}) * 3 \quad L'_{1.2} = 10.00 \text{ ft}$$

Slope of qs (0.9D LC):

$$sqs_{0.9} = \text{IF}(L' > W, (\text{Ppos} - \text{Pneg}) / W, qu / L') \quad sqs_{0.9} = 0.00 \text{ kcf}$$

Slope of qs (1.2D LC):

$$sqs_{1.2} = \text{IF}(L' > W, (\text{Ppos} - \text{Pneg}) / W, qu / L') \quad sqs_{1.2} = 0.00 \text{ kcf}$$

Nominal Shear Strength:

$$V_{n1} = 2 * W * \sqrt{F'c * 1000} * dc \quad V_{n1} = 282.20 \text{ kips}$$

Shear Reduction Factor:

$$\phi_{shear} = 0.75 \quad \phi_{shear} = 0.75$$

Design Shear Strength:

$$\phi V_{n1} = \phi_{shear} * V_{n1} \quad \phi V_{n1} = 211.65 \text{ kips}$$

Resisting Weight above Critical Section:

	Thickness (ft)	Unit Weight (kcf)	Weight (kip) (0.9*D LC)	Weight (kip) (1.2*D LC)
Soil Above Water Table:	7.5	0.125	17.67	23.55
Soil Below Water Table:	0	0.063	0.00	0.00
Pad Above Water Table:	2	0.150	5.65	7.54
Pad Below Water Table:	0	0.088	0.00	0.00
Total:			23.32	31.09

Applied Shear (0.9D LC):

$$V_{u1,0.9} = sqs_{0.9} * \text{MIN}(L'_{0.9}, d'') * (W / 2 - dpier / 2 - dc) * W \quad V_{u1,0.9} = 33.44 \text{ kips}$$

Applied Shear (1.2D LC):

$$V_{u1,1.2} = sqs_{1.2} * \text{MIN}(L'_{1.2}, d'') * (W / 2 - dpier / 2 - dc) * W \quad V_{u1,1.2} = 44.59 \text{ kips}$$

Check

$$\phi V_{n1} = 211.65 \text{ kips} \quad \geq \quad V_{u1} = 44.59 \text{ kips}$$

RATING: **21.07%** **OK**

Two-Way Shear (Compression)

Pier Shape:

$$\text{Pier Shape: Square} \quad \text{Pier Shape: Square}$$

Pier Diameter:

$$d_{pier1} = d_{pier} * 12 \text{ in / ft} \quad d_{pier1} = 30.00 \text{ in}$$

Equivalent Square Pier Diameter:

$$d_{pier_sq} = d_{pier} \quad d_{pier_sq} = 30.00 \text{ in}$$

Avg. Effective Depth for Punching Shear:

$$d_{c,2} = T - cc_{pad} - \text{AVERAGE}(0.5 * d_{b,pad} + 1.5 * d_{b,pad}) \quad d_{c,2} = 20.25 \text{ in}$$

Area of Concrete in Shear:

$$A_c = (4 * (d_{pier1} + d_{c,2})) * dc_{2} \quad A_c = 4070.25 \text{ in}^2$$

Eq. Square Area of Concrete in Shear:

$$A_{c_sq} = (4 * (d_{pier_sq} + d_{c,2})) * dc_{2} \quad A_{c_sq} = 4070.25 \text{ in}^2$$

Factor of transfer of Moment:

$$Y_f = 1 / (1 + (2/3) * \sqrt{(d_{pier1} / d_{pier1})}) \quad Y_f = 0.60$$

Factor of transfer of eccentricity of Shear:

$$Y_v = 1 - Y_f \quad Y_v = 0.40$$

Moment applied at base of Pier:

$$M_v = M_{u_comp} * 12 \text{ in / ft} \quad M_v = 2688.00 \text{ kip*in}$$

Polar Moment of Inertia at assumed Critical Section:

$$J_{c,1} = (dc_{2} * (d_{pier1} + dc_{2})^3) / 6 + ((d_{pier1} + dc_{2}) * (dc_{2}^3)) / 6 + (dc_{2} * (d_{pier1} + dc_{2}) * (d_{pier1} + dc_{2})^2) / 2 \quad J_{c,1} = 1782483.31 \text{ in}^4$$

Eq. Square Polar Moment of Inertia at assumed Critical Section:

$$J_{c_sq} = (dc_{2} * (d_{pier_sq} + dc_{2})^3) / 6 + ((d_{pier_sq} + dc_{2}) * (dc_{2}^3)) / 6 + (dc_{2} * (d_{pier_sq} + dc_{2}) * (d_{pier_sq} + dc_{2})^2) / 2 \quad J_{c_sq} = 1782483.31 \text{ in}^4$$

Net Bearing Resistance at front of Pier (1.2*D LC):

$$q_{u_AB,1.2} = \text{MAX}((q_{u_st,1.2} - sqs_{1.2} * (W / 2 - (d_{pier1} / 12 + d_{c,2} / 2)) - 1.2 * (W_{pad} + W_s) / \text{Area}) / 144.0) \quad q_{u_AB,1.2} = 0.02 \text{ ksi}$$

Net Bearing Resistance at rear of Pier (1.2*D LC):

$$q_{u_CD,1.2} = \text{MAX}((q_{u_st,1.2} - sqs_{1.2} * (W / 2 + (d_{pier1} / 12 + d_{c,2} / 2)) - 1.2 * (W_{pad} + W_s) / \text{Area}) / 144.0) \quad q_{u_CD,1.2} = 0.02 \text{ ksi}$$

Net Bearing Resistance at front of Pier_sq (1.2*D LC):

$$q_{u_AB,1.2_sq} = \text{MAX}((q_{u_st,1.2} - sqs_{1.2} * (W / 2 - (d_{pier_sq} / 12 + \text{MIN}(d_{c,2}, (T * 12)^3) / 2)) - 1.2 * (W_{pad} + W_s) / \text{Area}) / 144.0) \quad q_{u_AB,1.2_sq} = 0.02 \text{ ksi}$$

Net Bearing Resistance at rear of Pier_sq (1.2*D LC):

$$q_{u_CD,1.2_sq} = \text{MAX}((q_{u_st,1.2} - sqs_{1.2} * (W / 2 + (d_{pier_sq} / 12 + d_{c,2} / 2)) - 1.2 * (W_{pad} + W_s) / \text{Area}) / 144.0) \quad q_{u_CD,1.2_sq} = 0.02 \text{ ksi}$$

Applied Shear Force (1.2*D LC):

$$V_{u,1.2} = 1.2 * W_{pier} + 1.2 * \text{IF}(\text{OR}(\$B\$1="G", \$B\$1="H"), P_{comp} / 1.2, P_{comp}) \quad V_{u,1.2} = 220.00 \text{ kip}$$

Controlling Shear Stress (1.2D LC):

$$V_{u,1.2_controlling} = \text{MAX}(0, \text{IF}(L'_{0.9} \leq W / 2 + d_{pier} / 2 + (d_{c,2} / 2), 0, V_{u,0.9} / A_c + (Y_v * M_v * (d_{pier1} + d_{c,2}) / J_{c,1} - \text{MIN}(q_{u_AB,0.9}, q_{u_CD,0.9}))) \quad V_{u,1.2_controlling} = 0.054 \text{ ksi}$$

Eq. Sq. Controlling Shear Stress (1.2D LC):

$$V_{u,1.2_controlling_sq} = \text{MAX}(0, V_{u,1.2} / A_{c_sq} + (Y_v * M_v * (d_{pier_sq} + d_{c,2}) / J_{c_sq} - \text{MIN}(q_{u_AB,1.2_sq}, q_{u_CD,1.2_sq}))) \quad V_{u,1.2_controlling_sq} = 0.054 \text{ ksi}$$

Shear Stress Capacity: $\Phi V_n = \phi_s * 4 * (\sqrt{f_c} * 1000) / 1000$ $\Phi V_n = 0.177$ ksi

Check	$\Phi V_n = 0.177$ ksi	\geq	$V_{u_demand} = 0.054$ ksi	RATING:	30.39%	OK
--------------	------------------------	--------	-----------------------------	----------------	---------------	-----------

Two-Way Shear (Compression, Flexural Component) [BOTTOM REINFORCEMENT]

Effective Pad Width:	$b_{pad} = \text{MIN}(d_{pier} + 3 * T, W)$	$b_{pad} = 8.5$	ft
Bar Spacing:	$B_{s_pad} = B_{s_pad}$ (see design checks below)	$B_{s_pad} = 6.29$	in
Fraction of Bars in Effective Width:	$m_{effective} = \text{IF}(b_{pad} = W, m_p, 12 * b_{pad} / B_{s_pad})$	$m_{effective} = 16.21$	
Area of Steel in Effective Width:	$A_{s_effective} = \text{VLOOKUP}(Sp, \text{Ref!} \$A\$2 : \$C\$12, 3, 0) * m_{effective}$	$A_{s_effective} = 7.13$	in ²
Depth of Equivalent Rectangular Stress Block:	$a_{effective} = A_{s_effective} * F_y / (0.85 * F_c * b_{slab} * 12)$	$a_{effective} = 1.41$	in
	$\beta_{pad} = \beta_{pad}$ (see design checks below)	$\beta_{pad} = 0.85$	
Distance from Top to Neutral Axis:	$c_{effective} = a_{effective} / \beta_{pad}$	$c_{effective} = 1.66$	
Effective depth:	$d_c = d_c$ (see One-Way Shear check above)	$d_c = 19.875$	in
Modulus of Elasticity of Steel:	$E_s = 29000$ ksi	$E_s = 29000$	ksi
Strain in Steel:	$\epsilon_{s_effective} = 0.003 * (d_c - c) / c$	$\epsilon_{s_effective} = 0.03293$	in/in
Compression-Controlled Strain Limit:	$\epsilon_c = F_y / E_s$	$\epsilon_c = 0.00207$	in/in
Tension-Controlled Strain Limit:	$\epsilon_t = 0.005$	$\epsilon_t = 0.00500$	in/in
Flexure Strength Reduction Factor:	$\phi_{flex_effective} = \text{IF}(\epsilon_s \geq \epsilon_t, 0.9, \text{IF}(\epsilon_s \leq \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$	$\phi_{flex_effective} = 0.9$	
Nominal Flexural Strength:	$M_{n_effective} = A_{s_effective} * (F_y) * (d_c - a_{effective} / 2) * (1/12)$	$M_{n_effective} = 683.71$	ft-kips
Design Flexural Strength:	$\Phi M_{n_effective} = \phi_{flex_effective} * M_{n_effective}$	$\Phi M_{n_effective} = 615.34$	ft-kips

Two-Way Shear (Compression, Flexural Component) [TOP REINFORCEMENT]

Bar Spacing:	$B_{s_pad_top} = (W * 12 - 2 * c_{cpad} - \text{VLOOKUP}(s_{top}, \text{Ref!} \$A\$2 : \$C\$12, 2, 0)) / (m_{top} - 1)$	$B_{s_pad_top} = 8.50$	in
Fraction of Bars in Effective Width:	$m_{effective_top} = \text{IF}(b_{pad} = W, m_{top}, 12 * b_{pad} / B_{s_pad_top})$	$m_{effective_top} = 16.21$	
Area of Steel in Effective Width:	$A_{s_effective_top} = \text{VLOOKUP}(s_{top}, \text{Ref!} \$A\$2 : \$C\$12, 3, 0) * m_{effective_top}$	$A_{s_effective_top} = 7.13$	in ²
Depth of Equivalent Rectangular Stress Block:	$a_{effective_top} = A_{s_effective_top} * F_y / (0.85 * F_c * b_{slab} * 12)$	$a_{effective_top} = 1.41$	in
Distance from Top to Neutral Axis:	$c_{effective_top} = a_{effective_top} / \beta_{pad}$	$c_{effective_top} = 1.66$	
Effective depth:	$d_{c_top} = T * 12 - c_{cpad} - 1.5 * \text{VLOOKUP}(s_{top}, \text{Ref!} \$A\$2 : \$C\$12, 2, 0)$	$d_{c_top} = 19.875$	in
Strain in Steel:	$\epsilon_{s_effective_top} = 0.003 * (d_{c_top} - c_{effective_top}) / c_{effective_top}$	$\epsilon_{s_effective_top} = 0.03293$	in/in
Flexure Strength Reduction Factor:	$\phi_{flex_effective_top} = \text{IF}(\epsilon_{s_top} \geq \epsilon_t, 0.9, \text{IF}(\epsilon_{s_top} \leq \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_{s_top} - \epsilon_c) / (\epsilon_t - \epsilon_c))))$	$\phi_{flex_effective_top} = 0.9$	
Nominal Flexural Strength:	$M_{n_effective_top} = A_{s_effective_top} * (F_y) * (d_{c_top} - a_{effective_top} / 2) * (1/12)$	$M_{n_effective_top} = 683.71$	ft-kips
Design Flexural Strength:	$\Phi M_{n_effective_top} = \phi_{flex_effective_top} * M_{n_effective_top}$	$\Phi M_{n_effective_top} = 615.34$	ft-kips
Applied Moment:	$Yf * M_{u_comp} = Yf * M_{u_comp}$	$Yf * M_{u_comp} = 134.4$	ft-kips

Check	$\Phi M_{n_effective} = 1230.68$ ksi	\geq	$Yf * M_{u_comp} = 134.40$ ksi	RATING:	10.92%	OK
--------------	---------------------------------------	--------	---------------------------------	----------------	---------------	-----------

Two-Way Shear (Uplift)

Moment applied at base of Pier:	$M_{v_tension} = \text{IF}(T > D, E + T, (D - T + E)) * V_{u_uplift} * 12$	$M_{v_tension} = 2304.00$	kip*in
Diameter of Longitudinal Rebar Cage:	$d_{cage} = d_{pier} * 12 - 2 * (c_{cpier} + \text{VLOOKUP}(St, \text{Ref!} \$A\$2 : \$C\$12, 2, 0)) - \text{VLOOKUP}(Sc, \text{Ref!} \$A\$2 : \$C\$12, 2, 0)$	$d_{cage} = 24.38$	in
Eq. Square Dia. of Longitudinal Rebar Cage:	$d_{cage_sq} = \text{SQRT}(\text{PI}()) * 2 * d_{cage}$	$d_{cage_sq} = 21.60$	in
Steel Embedment Length:	$L_{embed} = d_{c_2}$	$L_{embed} = 20.25$	in
Area of Concrete in Shear:	$A_{c_tension} = L_{embed} * (d_{cage} + L_{embed}) * \text{PI}()$	$A_{c_tension} = 2838.92$	in ²
Eq. Square Area of Concrete in Shear:	$A_{c_tension_sq} = L_{embed} * (d_{cage_sq} + L_{embed}) * 4$	$A_{c_tension_sq} = 3389.99$	in ²
Polar Moment of Inertia at assumed Critical Section:	$J_{c_tension} = \frac{(L_{embed} * (d_{cage} + L_{embed})^3) / 6 + ((d_{cage} + L_{embed}) * (L_{embed}^3) / 6) + (L_{embed} * (d_{cage} + L_{embed}) * (d_{cage} + L_{embed})^2) / 2}{2}$	$J_{c_tension} = 1261447.65$	in ⁴
Eq. Square Polar Moment of Inertia at assumed Critical Section:	$J_{c_tension_sq} = \frac{(L_{embed} * (d_{cage_sq} + L_{embed})^3) / 6 + ((d_{cage_sq} + L_{embed}) * (L_{embed}^3) / 6) + (L_{embed} * (d_{cage_sq} + L_{embed}) * (d_{cage_sq} + L_{embed})^2) / 2}{2}$	$J_{c_tension_sq} = 1047557.52$	in ⁴
Applied Shear Force (0.9*D LC):	$V_{u_0.9_tension} = \text{MAX}(0.9 * \text{IF}(\text{OR}(\$B\$1 = "G", \$B\$1 = "H"), \text{Puplift} / 0.9, \text{Puplift}) - 0.9 * W_{pier}, 0)$	$V_{u_0.9_tension} = 164.25$	kip
Controlling Shear Stress (0.9*D LC):	$V_{u_0.9_controlling_tension} = \frac{V_{u_0.9_tension} / A_{c_tension} + (Yv * M_{v_tension} * (d_{cage} + L_{embed}) / 2) / J_{c_tension}}{n}$	$V_{u_0.9_controlling_tension} = 0.074$	ksi

Eq. Sq. Controlling Shear Stress (0.9*D LC): $V_{u,0.9_tension_sq} = V_{u,0.9_tension}/Ac_tension_sq + (\gamma_v M_{v_tension} * (d_cage_sq + Lembed) / 2) / Jc_tension_sq$ $V_{u,0.9_tension_sq} = 0.067$ ksi

Shear Stress Capacity: $\Phi V_{n_tension} = \phi_s * 4 * (\sqrt{F_c} * 1000) / 1000$ $\Phi V_{n_tension} = 0.177$ ksi

Check $\Phi V_n = 0.177$ ksi \geq $V_{u_demand} = 0.067$ ksi **RATING: 37.67% OK**

Two-Way Shear (Uplift, Flexural Component)

Applied Moment: $Yf * M_{u_tension} = Yf * M_{u_tension}$ $Yf * M_{u_tension} = 115.2$ ft-kips

Check $\Phi M_{n_effective} = 1230.68$ ksi \geq $Yf * M_{u_tension} = 115.20$ ksi **RATING: 9.36% OK**

Pad Flexure (Net Bearing Pressure)

$\beta_{pad} = IF(F_c \leq 4, 0.85, IF(F_c >= 8, 0.65, 0.85 - (F_c - 4) * 0.05))$ $\beta_{pad} = 0.85$

Provided Steel: $A_{s_pad} = A_{b_pad} * m_{pad}$ $A_{s_pad} = 8.36$ in²

Depth of Equivalent Rectangular Stress Block: $a = A_{s_pad} * F_y / (0.85 * F_c * W)$ $a = 1.41$ in

Distance from Top to Neutral Axis: $c = a / \beta_{pad}$ $c = 1.65$ in

Modulus of Elasticity of Steel: $E_s = 29000$ ksi $E_s = 29000$ ksi

Strain in Steel: $\epsilon_s = 0.003 * (dc - c) / c$ $\epsilon_s = 0.03307$ in/in

Compression-Controlled Strain Limit: $\epsilon_c = F_y / E_s$ $\epsilon_c = 0.00207$ in/in

Tension-Controlled Strain Limit: $\epsilon_t = 0.005$ $\epsilon_t = 0.00500$ in/in

Flexure Strength Reduction Factor: $\phi_{flex} = IF(\epsilon_s >= \epsilon_t, 0.9, IF(\epsilon_s < \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$ $\phi_{flex} = 0.9$

Nominal Flexural Strength: $M_n = A_{s_pad} * (F_y) * (dc - a / 2) * (1/12)$ $M_n = 801.41$ ft-kips

Design Flexural Strength: $\Phi M_n = \phi_{flex} * M_n$ $\Phi M_n = 721.27$ ft-kips

Bearing Press. at Crit. Section (0.9*D LC): $q_{mid_0.9} = q_{u_st_0.9} - sqs_{0.9} * d'$ $q_{mid_0.9} = 2.71$ ksf

Bearing Press. at Crit. Section (1.2*D LC): $q_{mid_1.2} = q_{u_st_1.2} - sqs_{1.2} * d'$ $q_{mid_1.2} = 3.61$ ksf

Resisting Weight above Critical Section:

	Thickness (ft)	Unit Weight (kcf)	Weight (kip) (0.9*D LC)	Weight (kip) (1.2*D LC)	Moment Arm (ft)	Resisting Moment (ft-kips) (0.9*D LC)	Resisting Moment (ft-kips) (1.2*D LC)
Soil Above Water Table:	7.5	0.125	31.64	42.19	1.875	59.33	79.101563
Soil Below Water Table:	0	0.063	0.00	0.00	1.875	0.00	0
Pad Above Water Table:	2	0.150	10.13	13.50	1.875	18.98	25.3125
Pad Below Water Table:	0	0.088	0.00	0.00	1.875	0.00	0
Total:			41.77	55.69		78.31	104.41

Factored Bending Moment (0.9*D LC): $M_{u_pad_0.9} = ((0.5 * (q_{u_0.9} - q_{mid_0.9})) * (d'^2) * (2/3) + (0.5 * q_{mid_0.9} * (d'^2)) - (0.5 * W_g_{0.9} * (d'^2))) * W$ $M_{u_pad_0.9} = 112.31$ ft-kips

Factored Bending Moment (1.2*D LC): $M_{u_pad_1.2} = ((0.5 * (q_{u_1.2} - q_{mid_1.2})) * (d'^2) * (2/3) + (0.5 * q_{mid_1.2} * (d'^2)) - (0.5 * W_g_{1.2} * (d'^2))) * W$ $M_{u_pad_1.2} = 149.74$ ft-kips

Check $\Phi M_n = 721.27$ ft-kips \geq $M_{u_pad} = 149.74$ ft-kips **RATING: 20.76% OK**

PIER DESIGN CHECKS

Minimum Steel

Min. area of steel (pier): $A_{st_c} = A_g * 0.005$ $A_{st_c} = 4.50$ in²

Check $A_{s_pier} = 14.40$ in² \geq $A_{st_c} = 4.50$ in² **RATING: 31.25% OK**

Bar Spacing

Bar separation: $B_{s_pier} = (d_o * \pi) / m_{pier} - db_{pier}$ $B_{s_pier} = 2.32$ in

Check 18.00 in \geq $B_{s_pier} = 2.32$ in **RATING: 12.86% OK**

Vertical Rebar Development Length

Reinforcement location: $\alpha_c =$ if space under bar > 12", 1.3, else use 1.0 $\alpha_c = 1.3$

Epoxy coating: $\beta_c =$ for non- epoxy coated, use 1.0 $\beta_c = 1.0$

Max term: $\alpha \beta_c =$ product of α x β not to exceed 1.7 $\alpha \beta_c = 1.3$

Reinforcement size: $\gamma_c =$ if bar size is 6 or less, 0.8, else use 1.0 $\gamma_c = 1$

Light weight concrete: $\lambda_c = 1.0$ $\lambda_c = 1.0$

Spacing/cover: $c_{c_c} =$ use smaller of half of bar spacing or concrete cover $c_{c_c} = 1.6$ in

Transverse bars: $k_{tr_c} = 0$ in (per simplification) $k_{tr_c} = 0$ in

<i>Max term:</i>	$c_c' = \text{MIN}(2.5, (c_c + ktr_c) / db_c)$	$c_c' = 1.823$	
<i>Excess reinforcement:</i>	$R_c = A_{st_c} / A_{s_c}$	$R_c = 0.31$	
<i>Development (tensile):</i>	$L_{dt_c}' = (3 / 40) * (F_y * 1000 / \sqrt{(F_c' * 1000)}) * \alpha_{\beta_c} * \gamma_c * \lambda_c * R_c * db_c / c_c'$	$L_{dt_c}' = 14.83$	in
<i>Minimum length:</i>	$L_{d_min} = 12$ inches	$L_{d_min} = 12.0$	in
<i>Development length:</i>	$L_{dt_c} = \text{MAX}(L_{d_min}, L_{dt_c}')$	$L_{dt_c} = 14.83$	in
<i>Development (comp.):</i>	$L_{dc_c}' = 0.02 * db_c * F_y * 1000 / \sqrt{(F_c' * 1000)}$	$L_{dc_c}' = 17.75$	in
	$L_{dc_c}'' = 0.0003 * db_c * F_y * 1000$	$L_{dc_c}'' = 15.75$	in
<i>Development length:</i>	$L_{dc_c} = \text{MAX}(8, L_{dc_c}', L_{dc_c}'')$	$L_{dc_c} = 17.75$	in
<i>Length available in pier:</i>	$L_{vc} = D - T + E - cc$	$L_{vc} = 94.0$	in
Check	$L_{vc} = 94.00$ in	\geq	$L_{dt_c} = 14.83$ in OK
Check	$L_{vc} = 94.00$ in	\geq	$L_{dc_c} = 17.75$ in OK
<i>Length available in pad:</i>	$L_{vp} = T - cc_{pad}$	$L_{vp} = 21.0$	in
Check	$L_{vp} = 21.00$ in	\geq	$L_{dt_c} = 14.83$ in OK
Check	$L_{vp} = 21.00$ in	\geq	$L_{dc_c} = 17.75$ in OK

Vertical Rebar Hook Ending

<i>Bar size & clear cover:</i>	$\alpha_h = \text{if bar} \leq 11, \text{ and } cc \geq 2.5", \text{ use } 0.7, \text{ else use } 1.0$	$\alpha_h = 1$	
<i>Epoxy coating:</i>	$\beta_h = \text{for non- epoxy coated, use } 1.0$	$\beta_h = 1.0$	
<i>Light weight concrete:</i>	$\lambda_h = 1.0$	$\lambda_h = 1.0$	
<i>Development (hook):</i>	$L_{dh}' = 0.02 * \alpha_h * \beta_h * \lambda_h * F_y * 1000 / \sqrt{(F_c' * 1000)} * db_c$	$L_{dh}' = 17.7$	in
<i>Minimum length:</i>	$L_{dh_min} = \text{the larger of: } 8 * d_b \text{ or } 6 \text{ in}$	$L_{dh_min} = 7.0$	in
<i>Development length:</i>	$L_{dh} = \text{MAX}(L_{dh_min}, L_{dh}')$	$L_{dh} = 17.7$	in
Check	$L_{vp} = 21.00$ in	\geq	$L_{dh} = 17.75$ in OK
<i>Hook tail length:</i>	$L_{h_tail} = 12 * db$ beyond the bend radius	$L_{h_tail} = 14.0$	in
<i>Length available in pad:</i>	$L_{h_pad} = (W - dpier) / 2 + cc_{pier} - cc_{pad}$	$L_{h_pad} = 44$	in
Check	$L_{h_pad} = 44.00$ in	\geq	$L_{dh_tail} = 14.00$ in OK

Pier Ties

<i>Minimum size:</i> [ACI 7.10.5.1]	$s_{t_min} = \text{IF}(s_c \leq 10, 3, 4)$	$s_{t_min} = 3$	
<i>z factor:</i>	$z_{seismic} = 0.5$ if the SDC is A, B, or C, else 1.0	$z_{seismic} = 0.5$	
<i>Tie parameters:</i>	$s_t = 3$ $m_t = 3$	$d_{b_t} = 0.375$ in $A_{b_t} = 0.11$ in ²	
<i>Allowable tie spacing per vertical rebar:</i>	$B_{s_t_max1} = 8 / z * db_c$	$B_{s_t_max1} = 14$	in
<i>per tie size:</i>	$B_{s_t_max2} = 24 / z * db_t$	$B_{s_t_max2} = 18$	in

per pier diameter:	$B_{s_t_max3} = di / (4 * z^2)$	$B_{s_t_max3} =$	30	in
per seismic zone:	$B_{s_t_max4} = 12"$ in active seismic zones, else 18"	$B_{s_t_max4} =$	18	in
Maximum tie spacing:	$B_{s_t_max} = \text{MIN}(B_{s_t_max1}, B_{s_t_max2}, B_{s_t_max3}, B_{s_t_max4})$	$B_{s_t_max} =$	14	in
Minimum required ties:	$m_{t_min} = (D - T + E) / B_{s_t_max} + 2$	$m_{t_min} =$	9.00	

PAD DESIGN CHECKS

Minimum Steel Required for Shrinkage

Shrinkage:	$\rho_{sh} = \text{IF}(F_y * 1000 \geq 60000, 0.0018, 0.002)$	$\rho_{sh} =$	0.0018	
Min. Required Shrinkage Steel:	$A_{st_p_sh} = \rho_{sh} * W * T$	$A_{st_p_sh} =$	5.184	in ²
Check	$A_{s_p} = 8.36$ in ²	\geq	$A_{st_p} = 5.18$ in ²	OK

Bar Separation

Bar separation:	$B_{s_pad} = (W - 2 * cc - db) / (m - 1)$	$B_{s_pad} =$	6.29	in
Check	18"	\geq	$B_{s_p} = 6.29$ in	\geq 2" OK

Pad Development Length

Reinforcement location:	$\alpha_p =$ if space under bar > 12", 1.3, else use 1.0	$\alpha_p =$	1.3	
Epoxy coating:	$\beta_p =$ for non- epoxy coated, use 1.0	$\beta_p =$	1.0	
Max term:	$\alpha \beta_p =$ product of α x β not to exceed 1.7	$\alpha \beta_p =$	1.3	
Reinforcement size:	$\gamma_p =$ if bar size is 6 or less, 0.8, else use 1.0	$\gamma_p =$	0.8	
Light weight concrete:	$\lambda_p = 1.0$	$\lambda_p =$	1.0	
Spacing/cover:	$c_p =$ use smaller of half of bar spacing or concrete cover	$c_p =$	3.38	in
Transverse bars:	$k_{tr_p} = 0$ in (simplification)	$k_{tr_p} =$	0	in
Max term:	$c_p' = \text{MIN}(2.5, (c + k_{tr}) / db)$	$c_p' =$	2.500	
Required moment ($\phi t = 0.9$):	$M_{nr} = M_{u_pad} / \phi_{flex}$	$M_{nr} =$	166.4	ft-kips
Steel estimate:	$A_{st_p}' = M_{nr} / (\phi t * F_y * dc)$	$A_{st_p}' =$	1.860	in ²
	$a_p = A_{st}' * F_y / (\beta * F_c' * W)$	$a_p =$	0.31	in
Required steel:	$A_{st_p_st} = M_{nr} / (F_y * (dc - a_p / 2))$	$A_{st_p_st} =$	1.688	in ²
Excess reinforcement:	$R_p = A_{st_p} / A_{s_p}$	$R_p =$	0.62	
Development (tensile):	$L_d = (3 / 40) * (F_y * 1000 / \sqrt{F_c' * 1000}) * \alpha \beta * \gamma * \lambda * R * db / c'$	$L_d =$	14.72	in
Minimum length:	$L_{d_min} = 12$ inches	$L_{d_min} =$	12.0	in
Development length:	$L_{dp} = \text{MAX}(L_{d_min}, L_{dp}')$	$L_{dp} =$	14.72	in
Length available in pad:	$L_{pad} = W / 2 - dpier / 2 - cc_{pad}$	$L_{pad} =$	42.00	in
Check	$L_{pad} = 42.00$ in	\geq	$L_{dp} = 14.72$ in	OK

Moment Capacity of Drilled Concrete Shaft (Caisson) for TIA Rev F, G, or H

Note: Shaft assumed to have ties, not spiral, transverse reinforcing

Site Data

NewtownAWC

Loads Already Factored

For M (WL):	1.00	
For P (DL):	1.00	

Pier Properties

Concrete:

Pier Diameter = 2.5 ft
Concrete Area = 706.9 in²

Reinforcement:

Clear Cover to Tie = 2.00 in
Horiz. Tie Bar Size = 3
Vert. Cage Diameter = 2.03 ft
Vert. Cage Diameter = 24.38 in
Vertical Bar Size = 7
Bar Diameter = 0.88 in
Bar Area = 0.6 in²
Number of Bars = 24
As Total = 14.4 in²
A s/ Aconc, Rho: 0.0204 2.04%

ACI 10.5, ACI 21.10.4, and IBC 1810.
Min As for Flexural, Tension Controlled, Shafts:

(3)*(Sqrt(f'c)/Fy) = 0.0030
200 / Fy = 0.0033

Minimum Rho Check:

Assumed Min. Rho: 0.50%
Provided Rho: 2.04% **OK**

Ref. Shaft Max Axial Capacities, ϕ Max(Pn or Tn):		
Max Pu = ($\phi=0.65$) Pn =	1520.51	kips
per ACI 318 (10-2)		
at Mu=($\phi=0.65$)Mn=	307.36	ft-kips
Max Tu, ($\phi=0.9$) Tn =	777.6	kips
at Mu= $\phi(0.90)$ Mn=	0.00	ft-kips

Maximum Shaft Superimposed Forces

TIA Revision:	H	
Max. Factored Shaft Mu:	224	ft-kips (* Note)
Max. Factored Shaft Pu:	211	kips
Max Axial Force Type:	Comp.	

(* Note: Max Shaft Superimposed Moment does not necessarily equal to the shaft top reaction moment

Load Factor	Shaft Factored Loads		
1.00	Mu:	224	ft-kips
1.00	Pu:	211	kips

Material Properties

Concrete Comp. strength, f'c =	3500	psi
Reinforcement yield strength, Fy =	60	ksi
Reinforcing Modulus of Elasticity, E =	29000	ksi
Reinforcement yield strain =	0.00207	
Limiting compressive strain =	0.003	

ACI 318 Code


Select Analysis ACI Code = 2014

SOLVE


← Press Upon Completing All Input

Results:

Governing Orientation Case: 1



Case 1



Case 2

Dist. From Edge to Neutral Axis: 9.89 in

Extreme Steel Strain, ϵ_t : 0.0052

$\epsilon_t > 0.0050$, Tension Controlled

Reduction Factor, ϕ : 0.900

Output Note: Negative Pu=Tension

For Axial Compression, ϕ Pn = Pu: 189.90 kips

Drilled Shaft Moment Capacity, ϕ Mn: 768.27 ft-kips



Drilled Shaft Superimposed Mu: 224.00 ft-kips

(Mu/ ϕ Mn, Drilled Shaft Flexure CSR: 29.2%


Maximum Allowable Moment of a Circular Pier

Pu	211 kips (from Results Tab)	Reduction factor, φ ₂₀₀₂	0.9	0.9	φ based on ACI 318 2002, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.45+83(et). Transition zone equation for spirals: φ=0.57+67(et).
Axial Force type:	Comp. (from Results Tab)	Reduction factor, φ ₂₀₀₅	0.9	0.9	φ based on ACI 318 2005, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65+(et-0.002)(250/3). Transition zone equation for spirals: φ=0.70+(et-0.002)(200/3).
		Reduction factor, φ ₂₀₁₄	0.9	0.9	φ based on ACI 318 2014, Section 21.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65+0.25(et-ty)(0.005-ety). Transition zone equation for spirals: φ=0.75+0.15(et-ty)(0.005-ety).
For Internal Calculations:		ACI code	0.9	0.9	
Axial Load (Negative for Compression)	-211.00 kips				

Case 1: Single Bar Near the Extreme Fiber



Case 2: (2) Equidistant Bars Near the Extreme Fiber



Neutral Axis

Distance from extreme edge to neutral axis, h =	9.89	in
Equivalent compression zone factor =	0.85	
Distance from extreme edge to equivalent compression zone factor, a =	8.41	in
Distance from centroid to neutral axis =	5.11	in

Compression Zone

Area of steel in compression zone, Asc =	4.20	in ²
Angle from centroid of pier to intersection of equivalent compression zone and edge of pier =	63.93	deg
Area of concrete in compression, Acc =	162.26	in ²
Force in concrete = 0.85 * F _c * Acc, F _c =	482.72	kips
Total reinforcement forces, F _s =	-271.72	kips
Case 1, φ =	0.900	
Axial (comp=)negative, Pu =	-211.00	kips
Balance Force in concrete, F _s +F _u =	-482.72	kips
Shaft Comp. Capacity, φP _n =	189.90	kips
Sum of the axial forces in the shaft =	0.00	kips

Maximum Moment

First moment of the concrete area in compression about the centroid =	1630.91	in ³
Distance between centroid of concrete in compression and centroid of pier =	10.05	in
Moment of concrete in compression =	4851.95	in-kips
Total reinforcement moment =	5391.67	in-kips
Nominal Moment strength of Drilled Shaft Mn =	10243.62	in-kips
Moment Capacity of Drilled Shaft, φM _n =	9219.25	in-kips

Case 1, φM_n = 768.27 ft-kips

Final Results	
Governing Orientation Capax	1
φ _h , φ =	0.900
Shaft φ _n M _n =	768.27 ft-kips
Distance from Edge of Shaft to N.A. =	9.89 in
Shaft Beta =	0.85
Maximum Tensile Strain =	-0.00524
Shaft Tension Cap. φ _n T _n (φ=0.9)(Total A _s)F _y =	777.60 kips
Shaft Max Comp. (φ=0.85)(0.85)(F _{ck})(A _g)(A _{st})F _y =	1520.51 kips

Individual Bars

Bar #	Angle from first bar (deg)	Distance to center of shaft (in)	Distance to neutral axis (in)	Distance to equivalent comp. zone (in)	Strain on	Area of steel in compression (in ²)	Stress (ksi)	Axial force (kips)	Moment (in-kips)
1	0.00	12.19	7.08	5.80	0.00215	0.60	60.00	34.22	417.00
2	15.00	11.77	6.67	5.18	0.00202	0.50	58.81	33.38	393.00
3	30.00	10.55	5.45	3.96	0.00165	0.60	47.91	26.96	284.54
4	45.00	8.62	3.51	2.03	0.00106	0.60	30.87	16.74	144.26
5	60.00	6.09	0.99	-0.50	0.00030	0.00	8.68	5.21	31.72
6	75.00	3.15	-1.96	-3.44	-0.00099	0.00	-17.17	-10.30	-32.50
7	90.00	0.00	-5.11	-6.59	-0.00155	0.00	-44.91	-26.95	0.00
8	105.00	-3.15	-8.26	-9.75	-0.00251	0.00	-60.00	-36.00	113.56
9	120.00	-6.09	-11.20	-12.68	-0.00340	0.00	-60.00	-36.00	219.38
10	135.00	-8.62	-13.73	-15.21	-0.00416	0.00	-60.00	-36.00	310.24
11	150.00	-10.55	-15.66	-17.15	-0.00475	0.00	-60.00	-36.00	379.97
12	165.00	-11.77	-16.88	-18.36	-0.00512	0.00	-60.00	-36.00	423.80
13	180.00	-12.19	-17.29	-18.78	-0.00524	0.00	-60.00	-36.00	438.75
14	195.00	-11.77	-16.88	-18.36	-0.00512	0.00	-60.00	-36.00	423.80
15	210.00	-10.55	-15.66	-17.15	-0.00475	0.00	-60.00	-36.00	379.97
16	225.00	-8.62	-13.73	-15.21	-0.00416	0.00	-60.00	-36.00	310.24
17	240.00	-6.09	-11.20	-12.68	-0.00340	0.00	-60.00	-36.00	219.38
18	255.00	-3.15	-8.26	-9.75	-0.00251	0.00	-60.00	-36.00	113.56
19	270.00	0.00	-5.11	-6.59	-0.00155	0.00	-44.91	-26.95	0.00
20	285.00	3.15	-1.96	-3.44	-0.00099	0.00	-17.17	-10.30	-32.50
21	300.00	6.09	0.99	-0.50	0.00030	0.00	8.68	5.21	31.72
22	315.00	8.62	3.51	2.03	0.00106	0.60	30.87	16.74	144.26
23	330.00	10.55	5.45	3.96	0.00165	0.60	47.91	26.96	284.54
24	345.00	11.77	6.67	5.18	0.00202	0.60	58.81	33.38	393.00

Min--> -0.00524 4.20 -271.72 5391.67 449.3055

Neutral Axis

Distance from extreme edge to neutral axis, h =	9.84	in
Equivalent compression zone factor =	0.85	
Distance from extreme edge to equivalent compression zone factor, a =	8.45	in
Distance from centroid to neutral axis =	5.06	in

Compression Zone

Area of steel in compression zone, Asc =	4.80	in ²
Angle from centroid of pier to intersection of equivalent compression zone and edge of pier =	64.09	deg
Area of concrete in compression, Acc =	163.25	in ²
Force in concrete = 0.85 * F _c * Acc, F _c =	485.66	kips
Total reinforcement forces, F _s =	-274.66	kips
Case 2, φ =	0.900	
Axial (comp=)negative, Pu =	-211.00	kips
Balance Force in concrete, F _s +F _u =	-485.66	kips
Shaft Comp. Capacity, φP _n =	189.90	kips
Sum of the axial forces in concrete in the shaft =	0.00	kips

Maximum Moment

First moment of the concrete area in compression about the centroid =	1637.42	in ³
Distance between centroid of concrete in compression and centroid of pier =	10.03	in
Moment of concrete in compression =	4871.33	in-kips
Total reinforcement moment =	5390.57	in-kips
Nominal Moment strength of Drilled Shaft Mn =	10261.89	in-kips
Moment Capacity of Drilled Shaft, φM _n =	9235.70	in-kips

Case 2, φM_n = 768.64 ft-kips

Final Results	
Governing Orientation Capax	1
φ _h , φ =	0.900
Shaft φ _n M _n =	768.27 ft-kips
Distance from Edge of Shaft to N.A. =	9.89 in
Shaft Beta =	0.85
Maximum Tensile Strain =	-0.00524
Shaft Tension Cap. φ _n T _n (φ=0.9)(Total A _s)F _y =	777.60 kips
Shaft Max Comp. (φ=0.85)(0.85)(F _{ck})(A _g)(A _{st})F _y =	1520.51 kips

Individual Bars

Bar #	Angle from first bar (deg)	Distance to center of shaft (in)	Distance to neutral axis (in)	Distance to equivalent comp. zone (in)	Strain on	Area of steel in compression (in ²)	Stress (ksi)	Axial force (kips)	Moment (in-kips)
1	7.50	12.08	7.02	5.53	0.00212	0.60	60.00	34.22	413.43
2	22.50	11.26	6.20	4.71	0.00187	0.60	54.25	30.77	346.41
3	37.50	9.67	4.61	3.11	0.00139	0.60	40.32	22.41	216.66
4	52.50	7.42	2.36	0.86	0.00071	0.60	20.62	10.59	76.56
5	67.50	4.66	-0.40	-1.89	-0.00072	0.00	-3.50	-2.10	-9.80
6	82.50	1.59	-3.47	-4.96	-0.00165	0.00	-30.41	-18.25	-99.03
7	97.50	-1.59	-6.65	-8.15	-0.00201	0.00	-58.27	-34.96	55.62
8	112.50	-4.66	-9.73	-11.22	-0.00294	0.00	-60.00	-36.00	167.90
9	127.50	-7.42	-12.48	-13.97	-0.00377	0.00	-60.00	-36.00	267.09
10	142.50	-9.67	-14.73	-16.22	-0.00445	0.00	-60.00	-36.00	345.00
11	157.50	-11.26	-16.32	-17.81	-0.00493	0.00	-60.00	-36.00	405.35
12	172.50	-12.08	-17.15	-18.64	-0.00518	0.00	-60.00	-36.00	436.00
13	187.50	-12.08	-17.15	-18.64	-0.00518	0.00	-60.00	-36.00	435.00
14	202.50	-11.26	-16.32	-17.81	-0.00493	0.00	-60.00	-36.00	405.35
15	217.50	-9.67	-14.73	-16.22	-0.00445	0.00	-60.00	-36.00	346.00
16	232.50	-7.42	-12.48	-13.97	-0.00377	0.00	-60.00	-36.00	267.09
17	247.50	-4.66	-9.73	-11.22	-0.00294	0.00	-60.00	-36.00	167.90
18	262.50	-1.59	-6.65	-8.15	-0.00201	0.00	-58.27	-34.96	55.62
19	277.50	1.59	-3.47	-4.96	-0.00165	0.00	-30.41	-18.25	29.03
20	292.50	4.66	-0.40	-1.89	-0.00072	0.00	-3.50	-2.10	-9.80
21	307.50	7.42	2.36	0.86	0.00071	0.60	20.62	10.59	76.56
22	322.50	9.67	4.61	3.11	0.00139	0.60	40.32	22.41	216.66
23	337.50	11.26	6.20	4.71	0.00187	0.60	54.25	30.77	346.41
24	352.50	12.08	7.02	5.53	0.00212	0.60	60.00	34.22	413.43

Min--> -0.00518 4.80 -274.66 5390.57 449.2158

Case 3 = Case 1, but Pu set at Max Axial Compression per ACI 318 (10-2) and phi=0.65.

Neutral Axis

Distance from extreme edge to neutral axis, h =	28.71	in
Equivalent compression zone factor =	0.85	
Distance from extreme edge to equivalent compression zone factor, a =	24.41	in
Distance from centroid to neutral axis =	-13.71	in

Compression Zone

Area of steel in compression zone, Asc =	11.40	in ²
Angle from centroid of pier to intersection of equivalent compression zone and edge of pier =	128.83	deg
Area of concrete in compression, Acc =	615.82	in ²
Force in concrete = 0.85 * F _c * Acc, F _c =	1832.06	kips
Total reinforcement forces, F _s =	507.19	kips
φ =	0.65	
Axial (comp=)negative, Pu =	-2339.25	kips
Balance Force in concrete, F _s +F _u =	-1832.06	kips
Shaft Comp. Capacity, (φ=0.65)P _n =	1520.51	kips
Sum of the axial forces in the shaft =	0.00	kips

Maximum Moment

First moment of the concrete area in compression about the centroid =	1063.65	in ³
Distance between centroid of concrete in compression and centroid of pier =	1.73	in
Moment of concrete in compression =	3164.36	in-kips
Total reinforcement moment =	2509.99	in-kips
Nominal Moment strength of Drilled Shaft Mn =	5674.35	in-kips
Moment Capacity of Drilled Shaft, φM _n =	3688.33	in-kips

Case 3, at P_{max}, (φ=0.65)M_n = 307.36 ft-kips

Final Results	
Governing Orientation Capax	1
φ _h , φ =	0.650
Shaft φ _n M _n =	307.36 ft-kips
Distance from Edge of Shaft to N.A. =	28.71 in
Shaft Beta =	0.85
Maximum Tensile Strain =	-0.00524
Shaft Tension Cap. φ _n T _n (φ=0.9)(Total A _s)F _y =	777.60 kips
Shaft Max Comp. (φ=0.85)(0.85)(F _{ck})(A _g)(A _{st})F _y =	1520.51 kips

Individual Bars

Bar #	Angle from first bar (deg)	Distance to center of shaft (in)	Distance to neutral axis (in)	Distance to equivalent comp. zone (in)	Strain on	Area of steel in compression (in ²)	Stress (ksi)	Axial force (kips)	Moment (in-kips)
1	0.00	12.19	25.90	21.59	0.00271	0.60	60.00	34.22	417.00
2	15.00	11.77	25.48	21.18	0.00268	0.60	60.00	34.22	402.78
3	30.00	10.55	24.27	19.96	0.00254	0.60	60.00	34.22	381.13
4	45.00	8.62	22.33	18.02	0.00233	0.60	60.00	34.22	294.86
5	60.00	6.09	19.81	15.50	0.00207	0.60	60.00	34.22	208.50
6	75.00	3.15	16.87	12.56	0.00176	0.60	51.11	29.88	91.09
7	90.00	0.00	13.71	9.41	0.00143	0.60	41.55	23.14	0.00
8	105.00	-3.15	10.56	6.25	0.00110	0.60	31.99	17.41	-54.92
9	120.00	-6.09	7.42	3.11	0.00069	0.60	23.68	12.07	-73.52
10	135.00	-8.62	5.00	0.79	0.00053	0.60	15.44	7.48	-84.43
11	150.00	-10.55	3.16	-1.15	0.00033	0.00			

FACTORED LOADS

Axial Load 0.9D:	$P_{0.9D} = 0.9 * P_{comp} / 1.2$	$P_{0.9D} = 158.25$ kip
Axial Load 1.2D:	$P_{1.2D} = 1.2 * P_{comp} / 1.2$	$P_{1.2D} = 211.00$ kip
Shear Load:	$V_u = V_{u_comp}$	$V_u = 28.00$ kip
Moment:	$M_u = M_u$	$M_u = 0.00$ kip*ft

Solve

*Highlighted cells have been modified

PASSIVE PRESSURE RESISTANCE (ORTHOGONAL DIRECTION)

Force of Pp Applied on Pier:	$Force_{pier} = MIN(V_u \cdot SUM(PpIM2:M7))$	$Force_{pier} = 24.96$ kip
Moment Arm of Pp on Pier:	$M_{arm_pier} = D-T-PpIO2 + T$	$M_{arm_pier} = 3.82$ ft
Force of Pp Applied on Pad:	$Force_{pad} = MIN(V_u - Force_{pier} \cdot SUM(PpIM8:M13))$	$Force_{pad} = 3.04$ kip
Moment Arm of Pp on Pad:	$M_{arm_pad} = D-PpIO8$	$M_{arm_pad} = 0.96$ ft
Unfactored Moment Resistance due to Passive Pressure:	$M_{R_Pp} = Force_{pier} \cdot M_{arm_pier} + Force_{pad} \cdot M_{arm_pad}$	$M_{R_Pp} = 98.20$ kip*ft
Factored Moment Resistance due to Passive Pressure:	$\Phi M_{R_Pp} = \Phi_s \cdot M_{R_Pp}$	$\Phi M_{R_Pp} = 73.65$ kip*ft

PLASTIC BEARING PRESSURE & OVERTURNING MOMENT (ORTHOGONAL DIRECTION)

Compressive Load for Bearing (0.9D LC):	$P_{bearing_0.9} = P_{0.9D} + 0.9 \cdot (W_s + W_c) + 0.75 \cdot W_{wedges_0.9_bearing}$	$P_{bearing_0.9} = 271.10$ kip
Compressive Load for Bearing (1.2D LC):	$P_{bearing_1.2} = P_{1.2D} + 1.2 \cdot (W_s + W_c) + 0.75 \cdot W_{wedges_1.2_bearing}$	$P_{bearing_1.2} = 361.47$ kip
Factored Overturning Moment:	$M_{overturning} = M_u + V_u \cdot (MAX(T,D) + E + b_{pad} / 12)$	$M_{overturning} = 0.00$ kip*ft
Area of Pad:	$Area = W^2$	$Area = 100.00$ ft ²
Plastic Section Modulus of Pad:	$Z = W^2 / 4$	$Z = 250.00$ ft ³
Preliminary Load Eccentricity (0.9D LC):	$pre_ec_{0.9,p} = M_{overturning} / P_{bearing_0.9}$	$pre_ec_{0.9,p} = 0.00$ ft
Preliminary Load Eccentricity (1.2D LC):	$pre_ec_{1.2,p} = M_{overturning} / P_{bearing_1.2}$	$pre_ec_{1.2,p} = 0.00$ ft
[Goal Seek] Load Eccentricity Iteration (0.9D LC):	$ec_{0.9,p} = goal_seek$	$ec_{0.9,p} = 0.00$ ft $e \leq L/4$
[Goal Seek] Load Eccentricity Iteration (1.2D LC):	$ec_{1.2,p} = goal_seek$	$ec_{1.2,p} = 0.00$ ft $e \leq L/4$
Non-Bearing Length (0.9D LC):	$NBL_{0.9} = 0$	$NBL_{0.9} = 0.00$ ft
Non-Bearing Length (1.2D LC):	$NBL_{1.2} = 0$	$NBL_{1.2} = 0.00$ ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9D LC):	$\Phi M_{Resisting_0.9} = \Phi M_{R_Pp} + SUM(\Phi M_{R_wedges_0.9} \cdot \Phi M_{R_shear_0.9})$	$\Phi M_{Resisting_0.9} = 73.65$ kip*ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (1.2D LC):	$\Phi M_{Resisting_1.2} = \Phi M_{R_Pp} + SUM(\Phi M_{R_wedges_1.2} \cdot \Phi M_{R_shear_1.2})$	$\Phi M_{Resisting_1.2} = 73.65$ kip*ft
Adjusted Overturning Moment (0.9D LC):	$M_{overturning_adj_0.9} = M_{overturning} - \Phi M_{Resisting_0.9}$	$M_{overturning_adj_0.9} = 0.00$ kip*ft
Adjusted Overturning Moment (1.2D LC):	$M_{overturning_adj_1.2} = M_{overturning} - \Phi M_{Resisting_1.2}$	$M_{overturning_adj_1.2} = 0.00$ kip*ft
Total Resistance to Overturning (0.9D LC):	$\Phi M_{Resisting_qu_0.9} = P_{bearing_0.9} \cdot ec_{0.9,p} + \Phi M_{Resisting_0.9}$	$\Phi M_{Resisting_qu_0.9} = 73.65$ kip*ft
Total Resistance to Overturning (1.2D LC):	$\Phi M_{Resisting_qu_1.2} = P_{bearing_1.2} \cdot ec_{1.2,p} + \Phi M_{Resisting_1.2}$	$\Phi M_{Resisting_qu_1.2} = 73.65$ kip*ft
[Goal Seek] Moment Comparison Iteration (0.9D LC):	$\Delta M_{0.9} = M_{overturning_adj_0.9} - \Phi M_{Resisting_qu_0.9}$	$\Delta M_{0.9} = -73.65$ kip*ft
[Goal Seek] Moment Comparison Iteration (1.2D LC):	$\Delta M_{1.2} = M_{overturning_adj_1.2} - \Phi M_{Resisting_qu_1.2}$	$\Delta M_{1.2} = -73.65$ kip*ft

Bearing Pressures

Orthogonal Bearing Pressure (0.9D LC):	$q_{u_orth_0.9} = MAX(P_{bearing_0.9} / Area + M_{overturning_0.9} / Z, P_{bearing_0.9} / Area - M_{overturning_0.9} / Z)$	$q_{u_orth_0.9} = 2.71$ ksf
Orthogonal Bearing Pressure (1.2D LC):	$q_{u_orth_1.2} = MAX(P_{bearing_1.2} / Area + M_{overturning_1.2} / Z, P_{bearing_1.2} / Area - M_{overturning_1.2} / Z)$	$q_{u_orth_1.2} = 3.61$ ksf
Ultimate Gross Bearing Pressure:	$Q_{ult} = Quilt + (\gamma / 1000) \cdot D$	$Q_{ult} = 13.19$ ksf
Factored Ultimate Gross Bearing Pressure:	$\Phi Quilt = \phi_s \cdot Quilt$	$Q_a = 9.89$ ksf
Check	$\Phi Quilt = 9.89$ ksf $\geq q_u = 3.61$ ksf	RATING: 36.55% OK

Soil Wedges (Cohesionless Soil)

Soil (above pad) Height:	$soilht = D-T$	$soilht = 7.50$ ft
Soil (above pad & under water table) Height:	$soilht_gw = MIN(soilht-gw, D-T)$	$soilht_gw = 0.00$ ft
Soil Wedge Projection at Grade:	$Wedge_proj = TAN(\phi^*PI/180) \cdot soilht$	$Wedge_proj = 5.06$ ft
Soil Wedge Projection at Water Table:	$Wedge_proj_gw = TAN(\phi^*PI/180) \cdot (soilht_gw)$	$Wedge_proj_gw = 0.00$ ft

Soil Wedges (Cohesionless Soil) (0.9D LC)

Soil	Volume (ft ³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
(2) End Prisms (above Water Table)	0.00	0.00	10.00	0.00
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00
(2) Partial Sides (above Water Table)	0.00	0.00	10.00	0.00
(2) Partial Sides (below Water Table)	0.00	0.00	10.00	0.00
(1) Rear (above Water Table)	0.00	0.00	11.69	0.00
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00
Total	0.00	0.00	0.00	0.00

Eccentricity relative to W/2:

Total Moment Arm (ft) =	0.00
Soil Wedge Wt (kip) =	0.00

Unfactored Resisting Moment of Wedges (0.9D LC):	$M_{R_wedges_0.9} = Total\ Moment\ Arm \cdot Soil\ Wedge\ Wt$	$M_{R_wedges_0.9} = 0.00$ kip*ft
Factored Resisting Moment of Wedges (0.9D LC):	$\Phi M_{R_wedges_0.9} = 0.75 \cdot M_{R_wedges_0.9}$	$\Phi M_{R_wedges_0.9} = 0.00$ kip*ft

Soil Wedges (Cohesionless Soil) (1.2D LC)

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2:	
(2) End Prisms (above Water Table)	0.00	0.00	10.00	0.00	Total Moment Arm (ft) =	0.00
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	0.00	0.00	10.00	0.00		
(2) Partial Sides (below Water Table)	0.00	0.00	10.00	0.00		
(1) Rear (above Water Table)	0.00	0.00	11.69	0.00		
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00		
Total	0.00	0.00		0.00	Soil Wedge Wt (kip)=	0.00

Unfactored Resisting Moment of Wedges (1.2*D LC):

$$M_{R_wedges_1,2} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$$

$$M_{R_wedges_1,2} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (1.2*D LC):

$$\Phi M_{R_wedges_1,2} = 0.75 * M_{R_wedges_1,2}$$

$$\Phi M_{R_wedges_1,2} = 0.00 \text{ kip*ft}$$

Soil Shear Strength (Cohesive Soil)

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2:	
Rear	0.00	0.00	10.00	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	10.00	0.00		
Total		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (0.9*D LC):

$$M_{R_shear_0,9} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R_shear_0,9} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (0.9*D LC):

$$\Phi M_{R_shear_0,9} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R_shear_0,9} = 0.00 \text{ kip*ft}$$

Soil Shear Strength (Cohesive Soil) (1.2*D LC)

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2:	
Rear	0.00	0.00	10.00	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	10.00	0.00		
Total		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (1.2*D LC):

$$M_{R_shear_1,2} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R_shear_1,2} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (1.2*D LC):

$$\Phi M_{R_shear_1,2} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R_shear_1,2} = 0.00 \text{ kip*ft}$$

DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (ORTHOGONAL)

Compressive Load for Bearing (0.9*D LC):

$$P_{100} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_100}$$

$$P_{100} = 323.21 \text{ kip}$$

Preliminary Factored Overturning Moment:

$$pre_M_{overturning_100} = (W/2 - (P_{100} / \Phi_{quilt}) * (2 * W)) * (P_{100})$$

$$pre_M_{overturning_100} = 1087.95 \text{ kip*ft}$$

Preliminary Load Eccentricity (0.9*D LC):

$$pre_ec_{100} = pre_M_{overturning_100} / P_{100}$$

$$pre_ec_{100} = 3.37 \text{ ft}$$

[Goal Seek] Load Eccentricity Iteration (0.9*D LC):

$$ec_{100} = \text{goal seek}$$

$$ec_{100} = 3.14 \text{ ft} \quad L/4 < e <= L/2$$

Non-Bearing Length (0.9*D LC):

$$NBL_{100} = 2 * ec_{100}$$

$$NBL_{100} = 6.28 \text{ ft}$$

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC):

$$\Phi M_{Resisting_100} = \Phi M_{R_Pp} + \text{SUM}(\Phi M_{R_wedges_100}, \Phi M_{R_shear_100})$$

$$\Phi M_{Resisting_100} = 316.87 \text{ kip*ft}$$

Moment Created by Shear:

$$M_{shear} = V_u * (D + E + b_{ps} / 12)$$

$$M_{shear} = 289.33 \text{ kip*ft}$$

Adjusted Overturning Moment (0.9*D LC):

$$M_{overturning_100} = M_{max_100} - \Phi M_{R_Pp}$$

$$M_{overturning_100} = 1331.16 \text{ kip*ft}$$

Total Resistance to Overturning (0.9*D LC):

$$\Phi M_{Resisting_su_100} = P_{100} * ec_{100} + \Phi M_{Resisting_100}$$

$$\Phi M_{Resisting_su_100} = 1331.16 \text{ kip*ft}$$

[Goal Seek] Moment Comparison Iteration (0.9D LC):

$$\Delta M_{100} = M_{overturning} - \Phi M_{Resisting_su_100}$$

$$\Delta M_{100} = 0.00 \text{ ft}$$

Maximum Applied Moment from Superstructure Analysis:

$$M_{i_max_100} = pre_M_{overturning_100} + \Phi M_{Resisting_100}$$

$$M_{i_max_100} = 1404.81 \text{ kip*ft}$$

Check $\mu_{max_100} = 1404.81 \text{ kip*ft} \geq \mu = 0.00 \text{ kip*ft}$

RATING: 0.00% OK

Soil Wedges (Cohesionless Soil) (0.9*D LC)

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Wedge Eccentricity relative to W/2:	
(2) End Prisms (above Water Table)	127.96	15.99	11.90	190.29	Total Moment Arm (ft) =	4.67
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	238.13	29.77	6.86	204.25		
(2) Partial Sides (below Water Table)	0.00	0.00	6.86	0.00		
(1) Rear (above Water Table)	189.71	23.71	11.69	277.12		
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00		
Total	555.80	69.47		671.66	Soil Wedge Wt (kip)=	69.47

Unfactored Resisting Moment of Wedges (0.9*D LC):

$$M_{R_wedges_100} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$$

$$M_{R_wedges_100} = 324.29 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (0.9*D LC):

$$\Phi M_{R_wedges_100} = 0.75 * M_{R_wedges_100}$$

$$\Phi M_{R_wedges_100} = 243.22 \text{ kip*ft}$$

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Wedge Eccentricity relative to W/2:	
Rear	41.70	0.00	10.00	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	52.35	0.00	6.86	0.00		
Total		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (0.9*D LC):

$$M_{R_shear_100} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R_shear_100} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (0.9*D LC):

$$\Phi M_{R_shear_100} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R_shear_100} = 0.00 \text{ kip*ft}$$

PASSIVE PRESSURE RESISTANCE (DIAGONAL DIRECTION)

Force of Pp Applied on Pier:

$$Force_{Pp_pier} = \text{MIN}(V_u, \text{SUM}(Pp; M2; M7))$$

$$Force_{Pp_pier} = 24.96 \text{ kip}$$

Moment Arm of Pp on Pier:

$$M_{arm_pier} = D - T - Pp / O2 + T$$

$$M_{arm_pier} = 3.82 \text{ ft}$$

Force of Pp Applied on Pad:

$$Force_{Pp_pad} = \text{MIN}(V_u - Force_{Pp_pier}, \text{SUM}(Pp; M8; M13)) * (T * W * \text{SQRT}(2)) / (T * W)$$

$$Force_{Pp_pad} = 3.04 \text{ kip}$$

Moment Arm of Pp on Pad:

$$M_{arm_pad} = D - Pp / O8$$

$$M_{arm_pad} = 0.96 \text{ ft}$$

Unfactored Moment Resistance due to Passive Pressure:

$$M_{R_Pp_dis} = Force_{Pp_pier} * M_{arm_pier} + Force_{Pp_pad} * M_{arm_pad}$$

$$M_{R_Pp_dis} = 98.20 \text{ kip*ft}$$

Factored Moment Resistance due to Passive Pressure:

$$\Phi M_{R_Pp_dis} = \Phi_s * M_{R_Pp_dis}$$

$$\Phi M_{R_Pp_dis} = 73.65 \text{ kip*ft}$$

PLASTIC BEARING PRESSURE & OVERTURNING MOMENT (DIAGONAL DIRECTION)

Compressive Load for Bearing (0.9'D LC):	$P_{bearing_0.9_dia} = P_{0.9D} + 0.9 \cdot (W_s + W_c) + 0.75 \cdot W_{wedges_0.9_bearing_dia}$	$P_{bearing_0.9_dia} = 271.10$ kip
Compressive Load for Bearing (1.2'D LC):	$P_{bearing_1.2_dia} = P_{1.2D} + 1.2 \cdot (W_s + W_c) + 0.75 \cdot W_{wedges_1.2_bearing_dia}$	$P_{bearing_1.2_dia} = 361.47$ kip
Factored Overturning Moment:	$M_{overturning} = M_u + V_u \cdot (D + E + b_p \cdot d_{sl}/12)$	$M_{overturning} = 0.00$ kip*ft
Area of Pad:	Area = W ²	Area = 100.00 ft ²
Plastic Section Modulus of Pad:	$Z_{dia} = W^3 / (3 \cdot \sqrt{2})$	$Z_{dia} = 235.70$ ft ³
Preliminary Load Eccentricity (0.9'D LC):	$pre_ec_{0.9_p_dia} = M_{overturning} / P_{bearing_0.9_dia}$	$pre_ec_{0.9_p_dia} = 0.00$ ft
Preliminary Load Eccentricity (1.2'D LC):	$pre_ec_{1.2_p_dia} = M_{overturning} / P_{bearing_1.2_dia}$	$pre_ec_{1.2_p_dia} = 0.00$ ft
[Goal Seek] Load Eccentricity Iteration (0.9'D LC):	$ec_{0.9_p_dia} = goal\ seek$	$ec_{0.9_p_dia} = 0.00$ ft $e \leq (L/4) \cdot \sqrt{2}/2$
[Goal Seek] Load Eccentricity Iteration (1.2'D LC):	$ec_{1.2_p_dia} = goal\ seek$	$ec_{1.2_p_dia} = 0.00$ ft $e \leq (L/4) \cdot \sqrt{2}/2$
Non-Bearing Length (0.9'D LC):	$NBL_{0.9_dia} = 0$	$NBL_{0.9_dia} = 0.00$ ft
Non-Bearing Length (1.2'D LC):	$NBL_{1.2_dia} = 0$	$NBL_{1.2_dia} = 0.00$ ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9'D LC):	$\Phi M_{Resisting_0.9} = \Phi M_{R_Pp_dia} + \text{SUM}(\Phi M_{R_wedges_0.9_dia}, \Phi M_{R_shear_0.9_dia})$	$\Phi M_{Resisting_0.9_dia} = 73.65$ kip*ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (1.2'D LC):	$\Phi M_{Resisting_1.2} = \Phi M_{R_Pp_dia} + \text{SUM}(\Phi M_{R_wedges_1.2_dia}, \Phi M_{R_shear_1.2_dia})$	$\Phi M_{Resisting_1.2_dia} = 73.65$ kip*ft
Adjusted Overturning Moment (0.9'D LC):	$M_{overturning_0.9_dia} = M_{overturning} - \Phi M_{Resisting_0.9_dia}$	$M_{overturning_0.9_dia} = 0.00$ kip*ft
Adjusted Overturning Moment (1.2'D LC):	$M_{overturning_1.2_dia} = M_{overturning} - \Phi M_{Resisting_1.2_dia}$	$M_{overturning_1.2_dia} = 0.00$ kip*ft
Total Resistance to Overturning (0.9'D LC):	$\Phi M_{Resisting_qu_0.9_dia} = P_{bearing_0.9_dia} \cdot ec_{0.9_p_dia} + \Phi M_{Resisting_0.9_dia}$	$\Phi M_{Resisting_qu_0.9_dia} = 73.65$ kip*ft
Total Resistance to Overturning (1.2'D LC):	$\Phi M_{Resisting_qu_1.2_dia} = P_{bearing_1.2_dia} \cdot ec_{1.2_p_dia} + \Phi M_{Resisting_1.2_dia}$	$\Phi M_{Resisting_qu_1.2_dia} = 73.65$ kip*ft
[Goal Seek] Moment Comparison Iteration (0.9D LC):	$\Delta M_{0.9_dia} = M_{overturning} - \Phi M_{Resisting_qu_0.9_dia}$	$\Delta M_{0.9_dia} = -73.65$ kip*ft
[Goal Seek] Moment Comparison Iteration (1.2D LC):	$\Delta M_{1.2_dia} = M_{overturning} - \Phi M_{Resisting_qu_1.2_dia}$	$\Delta M_{1.2_dia} = -73.65$ kip*ft

Bearing Pressures

Diagonal Bearing Pressure (0.9'D LC):	$q_{u_dia_0.9} = P_{bearing_0.9_dia} / \text{Area} + M_{overturning_0.9_dia} / Z_{dia}$	$q_{u_dia_0.9} = 2.71$ ksf
Diagonal Bearing Pressure (1.2'D LC):	$q_{u_dia_1.2} = P_{bearing_1.2_dia} / \text{Area} + M_{overturning_1.2_dia} / Z_{dia}$	$q_{u_dia_1.2} = 3.61$ ksf
Ultimate Gross Bearing Pressure:	$Q_{ult} = Q_{ult} + (\gamma/1000) \cdot D$	$Q_{ult} = 13.19$ ksf
Factored Ultimate Gross Bearing Pressure:	$\Phi Q_{ult} = \phi_s \cdot Q_{ult}$	$Q_a = 9.89$ ksf
Check	$\Phi Q_{ult} = 9.89$ ksf	$Q_a = 9.89$ ksf
	RATING:	36.55% OK

Soil Wedges (Cohesionless Soil)

Soil (above pad) Height:	$soilht = D - T$	$soilht = 7.50$ ft
Soil (above pad & under water table) Height:	$soilht_gw = \text{MIN}(soilht - gw, D - T)$	$soilht_gw = 0.00$ ft
Soil Wedge Projection at Grade:	$Wedge_proj = \text{TAN}(\phi/180) \cdot soilht$	$Wedge_proj = 5.06$ ft
Soil Wedge Projection at Water Table:	$Wedge_proj_gw = \text{TAN}(\phi/180) \cdot (soilht_gw)$	$Wedge_proj_gw = 0.00$ ft

Soil Wedges (Cohesionless Soil) (0.9'D LC)

Soil	Volume (ft ³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
(2) End Prisms (above Water Table)	0.00	0.00	0.00	0.00
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00
(1) End Prism (above Water Table)	0.00	0.00	0.00	0.00
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00
(2) Partial Sides (above Water Table)	0.00	0.00	6.18	0.00
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00
(2) Rear (above Water Table)	0.00	0.00	11.50	0.00
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00
Total	0.00	0.00	0.00	0.00

Eccentricity relative to W/2*SQRT(2):

Total Moment Arm (ft) =	0.00
Soil Wedge Wt (kip) =	0.00

Unfactored Resisting Moment of Wedges (0.9'D LC):	$M_{R_wedges_0.9} = \text{Total Moment Arm} \cdot \text{Soil Wedge Wt}$	$M_{R_wedges_0.9_dia} = 0.00$ kip*ft
Factored Resisting Moment of Wedges (0.9'D LC):	$\Phi M_{R_wedges_0.9} = 0.75 \cdot M_{R_wedges_0.9_dia}$	$\Phi M_{R_wedges_0.9_dia} = 0.00$ kip*ft

Soil Wedges (Cohesionless Soil) (1.2'D LC)

Soil	Volume (ft ³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
(2) End Prisms (above Water Table)	0.00	0.00	0.00	0.00
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00
(1) End Prism (above Water Table)	0.00	0.00	0.00	0.00
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00
(2) Partial Sides (above Water Table)	0.00	0.00	6.18	0.00
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00
(2) Rear (above Water Table)	0.00	0.00	11.50	0.00
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00
Total	0.00	0.00	0.00	0.00

Eccentricity relative to W/2*SQRT(2):

Total Moment Arm (ft) =	0.00
Soil Wedge Wt (kip) =	0.00

Unfactored Resisting Moment of Wedges (1.2'D LC):	$M_{R_wedges_1.2} = \text{Total Moment Arm} \cdot \text{Soil Wedge Wt}$	$M_{R_wedges_1.2_dia} = 0.00$ kip*ft
Factored Resisting Moment of Wedges (1.2'D LC):	$\Phi M_{R_wedges_1.2} = 0.75 \cdot M_{R_wedges_1.2_dia}$	$\Phi M_{R_wedges_1.2_dia} = 0.00$ kip*ft

Soil Shear Strength (Cohesive Soil)

Plane	Area (ft ²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
(2) Rear	0.00	0.00	10.61	0.00
(2) Partial Sides	0.00	0.00	7.07	0.00

Eccentricity relative to W/2*SQRT(2):

Total Moment Arm (ft) =	0.00
-------------------------	------

Total		0.00		0.00	Soil Shear Strength (kip)=	0.00
-------	--	------	--	------	----------------------------	------

Unfactored Resisting Moment of Soil Shear (0.9*D LC): $M_{R_shear_0.9_dia} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_0.9_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Factored Resisting Moment of Soil Shear (0.9*D LC): $\Phi M_{R_shear_0.9} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_0.9_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Soil Shear Strength (Cohesive Soil) (1.2*D LC)

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) Rear	0.00	0.00	10.61	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	7.07	0.00		
Total		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (1.2*D LC): $M_{R_shear_1.2} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_1.2_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Factored Resisting Moment of Soil Shear (1.2*D LC): $\Phi M_{R_shear_1.2} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_1.2_dia} = 0.00 \text{ kip}\cdot\text{ft}$

DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (DIAGONAL)

Compressive Load for Bearing (0.9*D LC): $P_{100_dia} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges_100_dia}$ $P_{100_dia} = 271.10 \text{ kip}$

Preliminary Factored Overturning Moment: $pre_M_{overturning_100_dia} = (P_{100_dia} / (\text{SQRT}(2))) * (W - \text{SQRT}(P_{100_dia} / \Phi Q_{out}))$ $pre_M_{overturning_100_dia} = 913.35 \text{ kip}\cdot\text{ft}$

Preliminary Load Eccentricity (0.9*D LC): $pre_ec_{100_dia} = pre_M_{overturning_100_dia} / P_{bearing_0.9}$ $pre_ec_{100_dia} = 3.37 \text{ ft}$

[Goal Seek] Load Eccentricity Iteration (0.9*D LC): $ec_{100_dia} = \text{goal seek}$ $ec_{100_dia} = 3.10 \text{ ft}$ $(L/4) * \text{SQRT}(2) / 2 < e < (L/2) * \text{SQRT}(2)$

Non-Bearing Length (0.9*D LC): $NBL_{100_dia} = 0$ $NBL_{100_dia} = 0.00 \text{ ft}$

Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC): $\Phi M_{Resisting_100_dia} = \Phi M_{R_Pp_dia} + \text{SUM}(\Phi M_{R_wedges_100_dia}) + \Phi M_{R_shear_100_dia}$ $\Phi M_{Resisting_100_dia} = 73.65 \text{ kip}\cdot\text{ft}$

Moment Created by Shear: $M_{shear} = V_u * (D + E + b_{ps} / 12)$ $M_{shear} = 289.33 \text{ kip}\cdot\text{ft}$

Adjusted Overturning Moment (0.9*D LC): $M_{overturning_100_dia} = M_{u_max_100_dia} - \Phi M_{R_Pp_dia}$ $M_{overturning_100_dia} = 913.35 \text{ kip}\cdot\text{ft}$

Total Resistance to Overturning (0.9*D LC): $\Phi M_{Resisting_qu_100_dia} = P_{bearing_0.9} * ec_{100_dia} + \Phi M_{Resisting_100_dia}$ $\Phi M_{Resisting_qu_100_dia} = 913.35 \text{ kip}\cdot\text{ft}$

[Goal Seek] Moment Comparison Iteration (0.9D LC): $\Delta M_{100_dia} = M_{overturning} - \Phi M_{Resisting_qu_100_dia}$ $\Delta M_{100_dia} = 0.00 \text{ ft}$

Maximum Applied Moment from Superstructure Analysis: $M_{u_max_100_dia} = pre_M_{overturning_100_dia} + \Phi M_{Resisting_100_dia}$ $M_{u_max_100_dia} = 987.00 \text{ kip}\cdot\text{ft}$

Check $M_{u_max_100_dia} = 987.00 \text{ kip}\cdot\text{ft}$ $>=$ $M_u = 0.00 \text{ kip}\cdot\text{ft}$ **RATING: 0.00% OK**

Soil Wedges (Cohesionless Soil) (0.9*D LC)

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) End Prisms (above Water Table)	0.00	0.00	0.00	0.00		
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(1) End Prism (above Water Table)	0.00	0.00	0.00	0.00		
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	0.00	0.00	6.18	0.00		
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00		
(2) Rear (above Water Table)	0.00	0.00	11.50	0.00	Total Moment Arm (ft) =	0.00
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00		
Total	0.00	0.00		0.00	Soil Wedge Wt (kip)=	0.00

Unfactored Resisting Moment of Wedges (0.9*D LC): $M_{R_wedges_100_dia} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$ $M_{R_wedges_100_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Factored Resisting Moment of Wedges (0.9*D LC): $\Phi M_{R_wedges_100_dia} = 0.75 * M_{R_wedges_100_dia}$ $\Phi M_{R_wedges_100_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Soil Shear Strength (Cohesive Soil) (0.9*D LC)

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) Rear	0.00	0.00	10.61	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	7.07	0.00		
Total		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (0.9*D LC): $M_{R_shear_100_dia} = \text{Total Moment Arm} * \text{Soil Shear Strength}$ $M_{R_shear_100_dia} = 0.00 \text{ kip}\cdot\text{ft}$

Factored Resisting Moment of Soil Shear (0.9*D LC): $\Phi M_{R_shear_100_dia} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$ $\Phi M_{R_shear_100_dia} = 0.00 \text{ kip}\cdot\text{ft}$

ATTACHMENT D – PROOF OF DELIVERY OF NOTICE

Ref: CT578100-ES-066 Date: 25Jun20
Dep: BL GRAPHICS Wgt: 1.05 LBS

SHIPPING: 0.00
SPECIAL: 0.00
HANDLING: 0.00
TOTAL: 0.00

DV:

Svcs: PRIORITY OVERNIGHT
TRCK: 1714 2090 5391

ORIGIN ID:RSPA (800) 301-3077
BL GRAPHICS
BL GRAPHICS
355 RESEARCH PARKWAY

SHIP DATE: 25JUN20
ACTWGT: 1.05 LB MAN
CAD: 0765627/CAFE3311

MERIDEN, CT 06450
UNITED STATES US


BILL THIRD PARTY

TO **GEORGE BENSON DIRECTOR OF PLANNING
TOWN OF NEWTOWN
3 PRIMROSE STREET**

NEWTOWN CT 06470

REF: CT578100-ES-066

DEPT: BL GRAPHICS



FedEx
Express




J191219082001uv

TRK# 1714 2090 5391
0201

**FRI - 26 JUN 10:30A
PRIORITY OVERNIGHT**

EG DXRA

**06470
CT-US SWF**



481 135 148 431 11 0201 2022 81

S65C1/C700/05A2

Ref: CT578100-ES-066 Date: 25Jun20 SHIPPING: 0.00
Dep: BL GRAPHICS Wgt: 1.05 LBS SPECIAL: 0.00
D.V: 0.00 HANDLING: 0.00
TOTAL: 0.00

Svs: PRIORITY OVERNIGHT
TRCK: 1714 2090 5380

ORIGIN ID:RSPA (800) 301-3077
BL GRAPHICS
BL GRAPHICS
355 RESEARCH PARKWAY
MERIDEN, CT 06450
UNITED STATES US


SHIP DATE: 25JUN20
ACTWGT: 1.05 LB
CAD: 0765627/CAFE3311
BILL THIRD PARTY

TO **FIRST SELECTMAN DAN ROSENTHAL**
TOWN OF NEWTOWN
3 PRIMROSE STREET

NEWTOWN CT 06470

REF: CT678100-ES-066

DEPT: BL GRAPHICS




TRK# 1714 2090 5380
0201

FRI - 26 JUN 10:30A
PRIORITY OVERNIGHT

EG DXRA

06470
CT-US SWF



555CL/CTD/0542

Ref: 1714 2090 5380

ATTACHMENT E - POWER DENSITY REPORT



C Squared Systems, LLC
65 Dartmouth Drive
Auburn, NH 03032
603-644-2800
support@csquaredsystems.com

Calculated Radio Frequency Emissions Report



ES-066

20 Barnabas Road

Newtown, CT 06470

April 3, 2020

Table of Contents

1. Introduction.....	1
2. FCC Guidelines for Evaluating RF Radiation Exposure Limits.....	1
3. Power Density Calculation Methods	2
4. Calculated % MPE Results	3
5. Conclusion	4
6. Statement of Certification.....	4
Attachment A: References	5
Attachment B: FCC Limits for Maximum Permissible Exposure (MPE)	6
Attachment C: Eversource Antenna Data Sheets and Electrical Patterns.....	8

List of Tables

Table 1: Proposed Tower % MPE	3
Table 2: FCC Limits for Maximum Permissible Exposure (MPE)	6

List of Figures

Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE).....	7
---	---

1. Introduction

The purpose of this report is to investigate compliance with applicable FCC regulations for the proposed Eversource installation to be located at 20 Barnabas Road in Newtown, CT.

Eversource is proposing to install two omnidirectional antennas as part of its 220 MHz communications system – one transmit and one receive antenna.

This report considers the planned and existing antenna configuration as provided by Eversource along with power density information of the other existing antennas to calculate the cumulative % MPE (Maximum Permissible Exposure) of the proposed facility at ground level.

2. FCC Guidelines for Evaluating RF Radiation Exposure Limits

In 1985, the FCC established rules to regulate radio frequency (RF) exposure from FCC licensed antenna facilities. In 1996, the FCC updated these rules, which were further amended in August 1997 by OET Bulletin 65 Edition 97-01. These new rules include Maximum Permissible Exposure (MPE) limits for transmitters operating between 300 kHz and 100 GHz. The FCC MPE limits are based upon those recommended by the National Council on Radiation Protection and Measurements (NCRP), developed by the Institute of Electrical and Electronics Engineers, Inc., (IEEE) and adopted by the American National Standards Institute (ANSI).

The FCC general population/uncontrolled limits set the maximum exposure to which most people may be subjected. General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure.

Public exposure to radio frequencies is regulated and enforced in units of milliwatts per square centimeter (mW/cm^2). The general population exposure limits for the various frequency ranges are defined in the attached “FCC Limits for Maximum Permissible Exposure (MPE)” in Attachment B of this report.

Higher exposure limits are permitted under the occupational/controlled exposure category, but only for persons who are exposed as a consequence of their employment and who have been made fully aware of the potential for exposure, and they must be able to exercise control over their exposure. General population/uncontrolled limits are five times more stringent than the levels that are acceptable for occupational, or radio frequency trained individuals. Attachment B contains excerpts from OET Bulletin 65 and defines the Maximum Exposure Limit.

Finally, it should be noted that the MPE limits adopted by the FCC for both general population/uncontrolled exposure and for occupational/controlled exposure incorporate a substantial margin of safety and have been established to be well below levels generally accepted as having the potential to cause adverse health effects.

3. Power Density Calculation Methods

The power density calculation results were generated using the following formula as outlined in FCC bulletin OET 65, and Connecticut Siting Council recommendations:

$$\text{Power Density} = \left(\frac{1.6^2 \times 1.64 \times \text{ERP}}{4\pi \times R^2} \right) \times \text{Off Beam Loss}$$

Where:

EIRP = Effective Isotropic Radiated Power = 1.64 x ERP

R = Radial Distance = $\sqrt{(H^2 + V^2)}$

H = Horizontal Distance from antenna

V = Vertical Distance from radiation center of antenna

Ground reflection factor of 1.6

Off Beam Loss is determined by the selected antenna pattern

These calculations assume that the antennas are operating at 100 percent capacity and full power, and that all antenna channels are transmitting simultaneously. Obstructions (trees, buildings, etc.) that would normally attenuate the signal are not taken into account. The calculations assume even terrain in the area of study and do not consider actual terrain elevations which could attenuate the signal. As a result, the calculated power density and corresponding % MPE levels reported below are much higher than the actual levels will be from the final installation.

4. Calculated % MPE Results

Table 1 below outlines the power density information for the site. The proposed Eversource omnidirectional antenna has a relatively narrow vertical beamwidth of 20°; therefore, the majority of the RF power is focused out towards the horizon. Please refer to Attachment C for the vertical pattern of the proposed Eversource antenna. Research of the vertical patterns of the other existing antennas also confirms varying degrees of directionality. Therefore, the calculated results in Table 1 include a nominal 3dB off-beam pattern loss for the Eversource half-wave dipole (44.34 MHz), 10 dB off-beam pattern loss for the omnidirectional and panel antennas and 30 dB off-beam pattern loss for the highly directional microwave dish to account for the lower relative gain below the antennas. As a result, there will be less RF power directed below the antennas relative to the horizon, and consequently lower power density levels around the base of the facility. Any inactive or receive-only antennas are not included in the table, as they are irrelevant in terms of the % MPE calculations.

Carrier	Antenna Height (Feet)	Operating Frequency (MHz)	Number of Trans.	ERP Per Transmitter (Watts)	Power Density (mw/cm ²)	Limit	%MPE
<i>6755 MHz system</i>		<i>6755</i>			<i>0.0000</i>	<i>1.0000</i>	<i>0.00%</i>
<i>37.48, 37.74, 48.34, 154.46375 MHz systems</i>					<i>0.0096</i>	<i>1.0000</i>	<i>0.10%</i>
T-Mobile	145	1900	2	953	0.0035	1.0000	0.35%
T-Mobile	145	2100	4	477	0.0036	1.0000	0.36%
Sprint	88	1900	2	693	0.0074	1.0000	0.74%
Sprint	88	850	1	390	0.0021	0.5667	0.37%
AT&T	130	850	2	419	0.0020	0.5667	0.35%
AT&T	130	850	2	885	0.0041	0.5667	0.73%
AT&T	130	850	2	553	0.0026	0.5667	0.46%
AT&T	130	1900	4	1469	0.0137	1.0000	1.37%
AT&T	130	700	2	745	0.0035	0.4667	0.75%
Verizon	121	1970	15	432	0.0176	1.0000	1.76%
Verizon	121	869	9	400	0.0098	0.5793	1.69%
Verizon	121	2145	1	1750	0.0048	1.0000	0.48%
Verizon	121	698	1	828	0.0023	0.4653	0.48%
Town of Newtown	192.5	150	1	200	0.0002	0.2000	0.10%
Eversource	190.5	44.34	1	370	0.0020	0.2000	0.98%
Eversource	189	154.46375	1	990	0.0011	0.2000	0.53%
Eversource	177	5945.2	1	9772	0.0001	1.0000	0.01%
Eversource	176	37.48	1	370	0.0005	0.2000	0.23%
Eversource	153	900	1	240	0.0004	0.6000	0.07%
Eversource	157.5	217	4	124	0.0008	0.2000	0.39%
						Total	12.20%

Table 1: Proposed Tower % MPE^{1 2 3}

The CT Siting Council power density database reflects miscellaneous entries, which are assumed to be for the existing Eversource and Town of Newtown installation (based on an FCC license assigned to the Town for this location). These entries are shown as grey in the table above and should be replaced by the green shaded entries, which are based upon updated operating parameters provided by Eversource as part of this project and FCC license information for the Town of Newtown (WPQZ382). The blue entry reflects the parameters of the proposed Eversource transmit antenna. Therefore, the total % MPE calculated does not include the grey entries.

¹ The power density information for carriers other than Eversource was taken directly from the CSC database dated 12/13/2019. Please note that % MPE values listed are rounded to two decimal points and the total % MPE listed is a summation of each unrounded contribution. Therefore, summing each rounded value may not identically match the total value reflected in the table.

² The proposed and existing antenna heights listed are in reference to Black & Veatch Structural Analysis Report dated 03/26/2020.

³ Operating parameters for the existing antennas listed for Eversource are in reference to an antenna inventory dated December 23, 2019. In cases when the transmitter and receiver antennas cannot be distinguished from each other for the same frequency, then the antenna with the lowest center line has been chosen for this analysis as the worst-case scenario.

5. Conclusion

The above analysis concludes that RF exposure at ground level with the proposed antenna installation will be below the maximum power density limits as outlined by the FCC in the OET Bulletin 65 Ed. 97-01. Using the conservative calculation methods discussed herein, the highest expected percent of Maximum Permissible Exposure at ground level with the proposed installation is **12.20% of the FCC General Population/Uncontrolled limit**.

As noted previously, the calculated % MPE levels are more conservative (higher) than the actual levels will be from the finished installation.

6. Statement of Certification

I certify to the best of my knowledge that the statements in this report are true and accurate. The calculations follow guidelines set forth in FCC OET Bulletin 65 Edition 97-01, IEEE Std. C95.1, and IEEE Std. C95.3.

Keith Vellante

Keith Vellante
Director of RF Services
C Squared Systems, LLC

April 3, 2020

Date

Attachment A: References

OET Bulletin 65 - Edition 97-01 - August 1997 Federal Communications Commission Office of Engineering & Technology

IEEE C95.1-2005, IEEE Standard Safety Levels With Respect to Human Exposure to Radio Frequency Electromagnetic Fields, 3 kHz to 300 GHz IEEE-SA Standards Board

IEEE C95.3-2002 (R2008), IEEE Recommended Practice for Measurements and Computations of Radio Frequency Electromagnetic Fields With Respect to Human Exposure to Such Fields, 100 kHz-300 GHz IEEE-SA Standards Board

Attachment B: FCC Limits for Maximum Permissible Exposure (MPE)

(A) Limits for Occupational/Controlled Exposure⁴

Frequency Range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (E) (A/m)	Power Density (S) (mW/cm ²)	Averaging Time E ² , H ² or S (minutes)
0.3-3.0	614	1.63	(100)*	6
3.0-30	1842/f	4.89/f	(900/f ²)*	6
30-300	61.4	0.163	1.0	6
300-1500	-	-	f/300	6
1500-100,000	-	-	5	6

(B) Limits for General Population/Uncontrolled Exposure⁵

Frequency Range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (E) (A/m)	Power Density (S) (mW/cm ²)	Averaging Time E ² , H ² or S (minutes)
0.3-1.34	614	1.63	(100)*	30
1.34-30	824/f	2.19/f	(180/f ²)*	30
30-300	27.5	0.073	0.2	30
300-1500	-	-	f/1500	30
1500-100,000	-	-	1.0	30

f = frequency in MHz * Plane-wave equivalent power density

Table 2: FCC Limits for Maximum Permissible Exposure (MPE)

⁴ Occupational/controlled limits apply in situations in which persons are exposed as a consequence of their employment provided those persons are fully aware of the potential for exposure and can exercise control over their exposure. Limits for occupational/controlled exposure also apply in situations when an individual is transient through a location where occupational/controlled limits apply provided he or she is made aware of the potential for exposure

⁵ General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure




Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE)

Attachment C: Eversource Antenna Data Sheets and Electrical Patterns

