

November 2, 2015

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-097-140325 – Cellco Partnership d/b/a Verizon Wireless 24 Dinglebrook Road, Newtown, Connecticut**

Dear Ms. Bachman:

On April 16, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 24 Dinglebrook Road in Newtown, Connecticut. The modifications involved the replacement of its antennas, the installation of coaxial cable diplexers.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that the tower modifications described in the Structural Analysis Report were completed. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the modifications were completed.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

14261339-v1

October 30, 2015

Mr. Tim Parks
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Newtown North
24 Dinglebrook Road, Newtown, CT

Tower Owner: Crown Castle
3530 Toringdon Way, Suite 300, Charlotte, NC

Engineer: GPD Group
520 South Main Street, Suite 2531, Akron, OH

Centek Project No.: 15003.048

CSC Exempt Mod Reference No.: EM-VER-097-140325

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by GPD Group (GPD Group Project Number: 2013723.01.99800.03):

- Review of the GPD Group Structural Analysis dated 01/22/2014 and subsequent structural analysis dated 09/03/2014.
- Review of GPD Group Modification Drawings S-1 thru S-13 dated 09/03/2014.
- Review of the Tower Engineering Professionals Modification Inspection Report dated 04/24/2015.
- Field observations by Centek Engineering personnel on 10/21/2015 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the structural analysis report prepared by GPD Group on 01/22/2014 and subsequent structural analysis dated 09/03/2014.

The modification design prepared by GPD Group demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,



Carlo F. Centore, PE
Principal - Structural

