

From: Krystle Craft <kcraft@qualtekwireless.com>
Sent: Thursday, October 7, 2021 4:11 PM
To: CSC-DL Siting Council <Siting.Council@ct.gov>
Subject: EM-CING-109-210308 // AT&T // NOTICE OF INTENT TO MODIFY AN EXISTING TELECOMMUNICATIONS FACILITY // 45 SPAULDING ROAD PLAINFIELD CT // CT2051 LTE 5C

Good morning,

Qualtek Wireless had completed the AT&T modifications on the existing telecommunications facilities for the above referenced site, and would like to get the CSC Permit closed as soon as possible. Please see the attached Final CCA/SSI for your review and records. Should your team require any additional information or documentation, please let me know. I appreciate your assistance!

Thank you,

Krystle Craft / Construction Operations Specialist / 978.846.1990 /
kcraft@qualtekwireless.com
16 Esquire Rd, North Billerica, MA 01862



Disclaimer: This email is intended only for the use of the individual or entity to which it is addressed, and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you received this communication in error, please do not distribute it and notify us immediately by email (administrator@qualtekservices.com) or via telephone (484.804.4500) and delete the original message. Unless expressly stated in this email, nothing in this message or any attachment should be construed as a digital or electronic signature.

INFINIGY®

FROM ZERO TO INFINIGY
the solutions are endless

1033 WATERVLIET SHAKER RD, ALBANY, NY 12205

September 22, 2021

Jason Blinkhorn
Project Manager
401-787-6007
jblinkhorn@qualtekwireless.com
16 Esquire Rd, N Billerica MA 01862

RE:	PE Close Out Letter	
	AT&T Site Name:	Plainfield, Spaulding Rd
	AT&T Site ID:	CTL02051
	FA Site Number:	10035013
	Site Address:	45 Spaulding Road, Plainfield, CT 06374

To Whom It May Concern,


Infinigy has conducted a post construction review of the above-mentioned site. Infinigy has prepared the drawings for the above-mentioned site and as such, we have conducted a final review of the proposed installation for the sole purpose to verify that the installation was completed in accordance with the site plans.

Based on our review of the Signed and Sealed Engineering Drawings for this site completed by Infinigy (Revision 1, Dated 06/18/21), and contractor-provided As-Built Drawings & closeout photos, it is the opinion of Infinigy that the site was built in general conformance with the site plans as prepared by Infinigy.

Please free to contact me at (518) 690-0790 if you have any questions or require additional information.

Sincerely,

Chris Warren, P.E.
Infinigy Engineering



New York Georgia California New Jersey Colorado Florida New Hampshire

INFINIGY®