

KENNETH C. BALDWIN

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

Also admitted in Massachusetts

August 5, 2016

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

**Re: EM-VER-115-150108 – Cellco Partnership d/b/a Verizon Wireless
54 Waterbury Road, Prospect, Connecticut**

Dear Ms. Bachman:

On February 2, 2015, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 54 Waterbury Road in Prospect, Connecticut. The modifications involved the replacement of antennas and installation of remote radio heads.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that it had complied with the recommendations made in the structural report attached to that filing. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to that structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment
Copy to:
Tim Parks

15077055-v1

August 2, 2016

Mr. Tim Parks

Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Prospect N.
54 Waterbury Street
Prospect, CT

Tower Owner: Charles Bradshaw

Engineer: Armor Tower Engineering
9 North Main Street, 2nd Floor
Cortland, NY 13045

Centek Project No.: 16003.13

CSC Exempt Mod Reference No.: EM-VER-115-150108

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by Armor Tower Engineering:

- Review of the Armor Tower Engineering Structural Analysis dated 06/10/2014.
- Field observations by Centek Engineering personnel on 07/26/16 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the aforementioned structural analysis report.

The modification design prepared by Armor Tower Engineering demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,



Carlo F. Centore, PE
Principal - Structural

