

October 14, 2015

VIA EMAIL AND OVERNIGHT DELIVERY

Ms. Melanie A. Bachman  
Acting Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051

RE: T-Mobile Northeast LLC CT11116 – Notice of Exempt Modification  
101 Mountain Road, Redding, CT

Dear Ms. Bachman:

This letter and attachments are submitted on behalf of T-Mobile Northeast LLC (“T-Mobile”). T-Mobile is undertaking modifications to certain existing sites in its Connecticut network in order to implement updated technology. In order to do so, T-Mobile will modify antenna and equipment configurations at a number of existing sites. Please accept this letter and attachments as notification, pursuant to R.C.S.A. Section 16-50j-73, of construction which constitutes an exempt modification pursuant to R.C.S.A. Section 16-50j-72(b)(2). In compliance with R.C.S.A. Section 16-50j-73, a copy of this letter and attachments is being sent to the First Selectman of the Town of Redding, and the property owner, Eversource Energy. Please also see the letter of authorization from Eversource Energy attached hereto.

T-Mobile plans to modify the existing facility at 101 Mountain Road owned by Eversource Energy/Connecticut Light and Power (coordinates 41.27846, -73.44256). Attached are drawings depicting the planned changes, and documentation of the structural sufficiency of the tower to accommodate the revised antenna configuration. Also included is a power density calculation reflecting the modification to T-Mobile’s operations at the site.

The changes to the facility do not constitute a modification as defined in Connecticut General Statutes (“C.G.S.”) Section 16-50i(d) because the general physical characteristics of the facility will not be significantly changed. Rather, the planned changes to the facility fall squarely within those activities explicitly provided for in R.C.S.A. Section 16-50j-72(b)(2).

1. The height of the overall structure will be unaffected. T-Mobile proposes to replace two (2) existing antennas at a centerline height of 74’ AGL on a replacement mast. Additionally, T-Mobile will remove the existing microwave dish and mounting pipe, install four (4) new 7/8” coax cables and reuse four (4) existing 7/8” cables.
2. The proposed changes will not extend the site boundaries. T-Mobile will


remove two (2) GMA's and install four (4) GMA's, and replace an equipment cabinet on the existing concrete pad. Thus, there will be no effect on the site compound or T-Mobile's leased area.

3. The proposed changes will not increase the noise level at the existing facility by six decibels or more. The incremental effect of the proposed changes will be negligible.

4. The changes to the facility will not increase the calculated "worst case" power density for the combined operations at the site to a level at or above the applicable standard for uncontrolled environments as calculated for a mixed frequency site. As indicated in the attached power density calculations, T-Mobile's operations at the site will result in a power density of 1.228%; the combined site operations will result in a total power density of 1.228%.

Please feel free to call me with any questions or concerns regarding this matter. Thank you for your consideration.

Respectfully submitted,

By:   
Eric Dahl, Agent for T-Mobile  
[edahl@comcast.net](mailto:edahl@comcast.net)  
860-227-1975

#### Attachments

cc: First Selectman Julia Pemberton, Town of Redding  
Hank O'Brien, Eversource Energy

September 21, 2015

David Karpinski, General Manager  
T-Mobile Northeast LLC  
35 Griffin Road, South  
Bloomfield, CT 06002

Re: Site Permitting Authorization

Dear Mr. Karpinski,

Authorization is hereby given to T-Mobile Northeast LLC , its employees and its duly authorized agents and independent contractors (hereinafter collectively referred to as "T-Mobile Northeast LLC "), to apply for any and all local municipal, state and federal licenses, permits and approvals, including but not limited to Connecticut Siting Council, building permits, zoning variances, zoning special exceptions, site plan and subdivision approvals, driveway, wetlands and terrain alteration permits, which are or may be necessary or required for T-Mobile Northeast LLC to construct, operate and maintain a wireless communications system (PCS System), and/or antenna site on the following property owned by The Connecticut Light & Power Company dba Eversource Energy (ES):

**101 Mountain Road  
Redding, CT 06896  
Pole 3275, Line 1470  
CT11116C**


The foregoing authorization is given subject to the following conditions:

1. This authorization shall be nonexclusive. Nothing herein shall prevent or restrict ES from authorizing any other person or entity to apply for any similar licenses, permits or approvals to construct, operate and maintain any other communication system or facility of any type on the property at any time.
2. This authorization shall not obligate ES to pay for or reimburse any costs or expenses or to provide any assistance of any kind in connection with any applications, or bind or obligate ES to agree or be responsible for any on-site or off-site improvements, development restrictions, impact fees or assessments, capital improvement charges, bonds or other security, or any other fee, assessment, charge or expense imposed or required as a condition of any license, permit or approval. T-Mobile Northeast LLC shall be solely and fully responsible for all fees, charges costs and expenses of any kind in connection with any applications. ES agrees to reasonably cooperate with T-Mobile Northeast LLC in signing such applications or other similar documents as may be required in order for T-Mobile Northeast LLC to apply for any license, permit or approval.




3. This authorization shall not be deemed or construed to grant or transfer to T-Mobile Northeast LLC any interest in the property, whatsoever, and shall not in any respect obligate or require ES to sell, lease or license the Property to T-Mobile Northeast LLC or otherwise allow T-Mobile Northeast LLC to use or occupy the property for any purpose, regardless of whether any licenses, permits and approvals applied for by T-Mobile Northeast LLC for the property are granted. T-Mobile Northeast LLC understands and acknowledges that any and all applications filed by T-Mobile Northeast LLC for the property at T-Mobile Northeast LLC sole risk and without any enforceable expectation that the property will be made available for T-Mobile Northeast LLC ' use.
4. T-Mobile Northeast LLC shall be required to supply to ES, free of charge and contemporaneous with T-Mobile Northeast LLC filing of same, a complete copy of any and all applications, plans, reports and other public filings made by T-Mobile Northeast LLC with any local, municipal, state or federal governmental or regulatory officer, agency board, bureau, commission or other person or body for any licenses, permits or approvals for the property, and to keep ES fully informed on a regular basis of the status of T-Mobile Northeast LLC ' applications.
5. This authorization shall automatically expire six (6) months after the date of this letter, unless extended in writing by mutual agreement of ES and T-Mobile Northeast LLC.

Very truly yours,



T & D ROW & Survey Engineering  
Eversource Energy

**AGREED TO ON BEHALF OF  
T-MOBILE NORTHEAST LLC**

By:  \_\_\_\_\_  
Duly Authorized

Date: 10-9-2015

101 Mountain Road  
Redding, CT 06896  
Pole 3275, Line 1470  
CT11116C

**TECTONIC**  
 • PLANNING  
 • ENGINEERING  
 • SURVEYING  
 • CONSTRUCTION  
 • MANAGEMENT

TECTONIC Engineering & Surveying  
 Consultants P.C.  
 1079 New York Street  
 Middletown, CT 06457  
 Phone: 860.339.3333  
 Fax: 860.339.3337

**Mobile**  
 NORTHEAST LLC  
 1000 Main Street  
 Southington, CT 06488

T-MOBILE LABELING	DATE	BY
CONSTRUCTION	03/19/14	JZ
REVISION	DATE	BY
04/07/14	04/07/14	JZ
04/07/14	04/07/14	JZ

DATE	BY
03/19/14	JZ

CT11116C  
 RIDGFIELD/ETHAN ALLEN H  
 101 MOUNTAIN RD.  
 CL&P #3275  
 REDDING, CT 06896

EQUIPMENT PLAN  
 & SITE PLAN

SHEET NUMBER  
 L-1

**NOTE:**  
 REFER TO STRUCTURAL ANALYSIS BY  
 CENTEK MARKED REV. 1 DATED  
 03/19/14.




**1**  
 L-1  
 SITE PLAN  
 SCALE: 1/4" = 1'-0"



**2**  
 L-1  
 EQUIPMENT PLAN  
 SCALE: 1/2" = 1'-0"

CONFIGURATION  
 4B  
 REFER TO LATEST T-MOBILE RF DATA  
 SHEET FOR FINAL RF DESIGN & BOM.



# TECTONIC

PLANNING • DESIGN • CONSTRUCTION MANAGEMENT  
 ENGINEERING • SURVEYING  
 PROTONS Engineering & Surveying  
 Consultants P.C.  
 1079 Main Street  
 Middletown, CT 06455  
 Phone: 860.342.2333  
 Fax: 860.342.2333

**Mobile**  
 NORTHEAST LLC  
 100 HARTFORD AVENUE  
 ROOM 1110 SOUTH  
 BRIDGEFIELD, CT 06802


T-MOBILE LANDLORD	DATE
CONSTRUCTION	DATE
PROJECT NUMBER	DESIGNED BY
044-CT1010C	AS
REV. DATE	REVISION
12/28/14	FOR COMMENT
DRAWN BY	

SITE INFORMATION  
 CT11116C  
 RIDGEFIELD/ETHAN ALLEN H  
 101 MOUNTAIN RD.  
 CL&P #3275  
 REDDING, CT 06896

SHEET TITLE  
 ELEVATION &  
 ANTENNA PLAN

L-2

**NOTE:**  
 REFER TO STRUCTURAL ANALYSIS BY  
 CEATEX MARKED REV. 1 DATED  
 03/19/14.



**Structural Analysis of PCS  
Mast and CL&P Pole**

*T-Mobile Site Ref: CT11116C*

*CL&P Structure No. 3275  
80' Electric Transmission Pole*

*101 Mountain Road  
Redding, CT*

*CEN TEK Project No. 14025.005*

*~~Date: February 10, 2014~~*

*Rev 1: March 19, 2014*



**Prepared for:**  
**T-Mobile Towers**  
**4 Sylvan Way**  
**Parsippany, NJ 07054**



## **Table of Contents**

### **SECTION 1 - REPORT**

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANALYSIS
- DESIGN BASIS
- RESULTS
- CONCLUSION

### **SECTION 2 - CONDITIONS & SOFTWARE**

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAMS
  - RISA 3-D
  - PLS POLE

### **SECTION 3 - DESIGN CRITERIA**

- CRITERIA FOR DESIGN OF PCS FACILITIES ON OR EXTENDING ABOVE METAL ELECTRIC TRANSMISSION TOWERS
- NU DESIGN CRITERIA TABLE
- PCS SHAPE FACTOR CRITERIA
- WIRE LOADS SHEET

### **SECTION 4 - DRAWINGS**

- EL-1 TOWER AND MAST ELEVATION
- FP-1 FEEDLINE PLAN

### **SECTION 5 - EIA/TIA-222-F LOAD CALCULATIONS FOR MAST DESIGN**

- MAST WIND & ICE LOAD

### **SECTION 6 - MAST DESIGN PER EIA/TIA-222F**

- LOAD CASES AND COMBINATIONS (TIA/EIA LOADING)
- RISA 3-D ANALYSIS REPORT
- MAST CONNECTION TO CL&P POLE ANALYSIS



**SECTION 7 - NESC/NU LOAD CALCULATIONS FOR OBTAINING  
MAST REACTIONS APPLIED TO UTILITY STRUCTURE**

- MAST WIND LOAD

**SECTION 8 - MAST ANALYSIS PER NESC/NU FOR OBTAINING  
REACTIONS APPLIED TO UTILITY STRUCTURE**

- LOAD CASES AND COMBINATIONS (NESC/NU LOADING)
- RISA 3-D ANALYSIS REPORT

**SECTION 9 - PLS POLE RESULTS FROM MAST REACTIONS  
CALCULATED IN RISA WITH NESC/NU CRITERIA**

- COAX CABLE LOAD ON CL&P POLE CALCULATION
- PLS REPORT

**SECTION 10 - REFERENCE MATERIAL**

- RF DATA SHEET
- EQUIPMENT CUT SHEETS
- BORING LOG

## Introduction

The purpose of this report is to analyze the existing PCS mast and 80' (12' embedded) CL&P tower located at 101 Mountain Road in Redding, CT for the proposed T-Mobile antenna upgrade.

The existing/proposed loads consist of the following:

- **T-MOBILE (Existing to be Removed):**  
Antennas: Two (2) EMS FR65-17-02DP panel antennas and one (1) microwave dish mounted on a PCS mast with a RAD center elevation of 74-ft above grade.  
Coax Cables: One (1) 7/8"  $\varnothing$  coax cable running on the outside of the tower.
- **T-MOBILE (Existing to remain):**  
Mast: One (1) 4" Sch. 40 pipe mast (O.D. = 4.5").  
Coax Cables: Four (4) 7/8"  $\varnothing$  coax cables running on the outside of the tower.
- **T-MOBILE (Proposed):**  
Antennas: Two (2) RFS APX16DWV-16DWVS-E-A20 panel antennas mounted on a site pro triple sector chain mount p/n CHM3 to the existing PCS mast with a RAD center elevation of 74-ft above grade.  
Coax Cables: Four (4) 7/8"  $\varnothing$  coax cables running on the outside of the tower.

## Primary assumptions used in the analysis

- Allowable steel stresses are defined by AISC-ASD 9<sup>th</sup> edition for design of the PCS Mast and antenna supporting elements.
- ASCE Manual No. 72, "Design of Steel Transmission Pole Structures Second Edition", defines allowable steel stresses for evaluation of the CL&P utility pole.
- All utility pole members are adequately protected to prevent corrosion of steel members.
- All proposed antenna mounts are modeled as listed above.
- Pipe mast will be properly installed and maintained.
- No residual stresses exist due to incorrect pole erection.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds conform to the requirements of AWS D1.1.
- Pipe mast and utility pole will be in plumb condition.
- Utility pole was properly installed and maintained and all members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.
- Any deviation from the analyzed loading will require a new analysis for verification of structural adequacy.

## Analysis

Structural analysis of the existing *PCS Mast Structure* was independently completed using the current version of RISA-3D computer program licensed to CENTEK Engineering, Inc.

The existing mast consisting of a 4-in SCH. 40 pipe (O.D. = 4.5") connected at two points to the existing tower was analyzed for its ability to resist loads prescribed by the TIA/EIA standard. Section 5 of this report details these gravity and lateral wind loads. NESC prescribed loads were also applied to the mast structure in order to obtain reactions needed for analyzing the CL&P tower structure. These loads are developed in Section 7 of this report. Load cases and combinations used in RISA-3D for TIA/EIA loading and for NESC/NU loading are listed in report Sections 6 and 8, respectively.

An envelope solution was first made to determine maximum and minimum forces, stresses, and deflections to confirm the selected section as adequate. Additional analyses were then made to determine the NESC forces to be applied to the CL&P tower structure.

The RISA-3D program contains a library of all AISC shapes and corresponding section properties are computed and applied directly within the program. The program's Steel Code Check option was also utilized. The forces calculated in RISA-3D using NESC guidelines were then applied to the CL&P pole using PLS-Pole. Maximum usage for the pole was calculated considering the additional forces from the mast and associated appurtenances.

## Design Basis

Our analysis was performed in accordance with TIA/EIA-222-F-1996, ASCE Manual No. 72 – "Design of Steel Transmission Pole Structures Second Edition", NESC C2-2007 and Northeast Utilities Design Criteria.

The CL&P pole structure, considering existing and future conductor and shield wire loading, with the pcs antenna mast was analyzed under two conditions:

- **UTILITY POLE ANALYSIS**

The purpose of this analysis is to determine the adequacy of the existing utility pole to support the proposed antenna loads. The loading and design requirements were analyzed in accordance with the NU Design Criteria Table, NESC C2-2007 ~ Construction Grade B, and ASCE Manual No. 72.

Load cases considered:

Load Case 1: NESC Heavy

Wind Pressure.....	4.0 psf
Radial Ice Thickness.....	0.5"
Vertical Overload Capacity Factor.....	1.50
Wind Overload Capacity Factor.....	2.50
Wire Tension Overload Capacity Factor.....	1.65

Load Case 2: NESC Extreme

Wind Speed.....	110 mph <sup>(1)</sup>
Radial Ice Thickness.....	0"



▪ **MAST ASSEMBLY ANALYSIS**

Mast, appurtenances and connections to the utility pole were analyzed and designed in accordance with the NU Design Criteria Table, TIA/EIA-222-F, and AISC-ASD standards.

Load cases considered:

Load Case 1:

Wind Speed..... 85 mph <sup>(2)</sup>  
 Radial Ice Thickness..... 0"

Load Case 2:

Wind Pressure..... 75% of 85 mph wind pressure  
 Radial Ice Thickness..... 0.5"

| Note 2: Per NU Mast Design Criteria Exception 1.

Results

▪ **MAST ASSEMBLY**

The existing mast was determined to be structurally adequate. **Contractor to verify in field the existing PCS mast dimensions prior to antenna upgrade.**

Member	Stress Ratio (% of capacity)	Result
4" Sch. 40 Mast	74.2%	<b>PASS</b>
Mast Connection to CL&P Tower	18.9% <sup>(1)</sup>	<b>PASS</b>

Note 1 – 1/3 increase in allowable stress not used for connection to tower per OTRM 059.

▪ **UTILITY POLE**

This analysis finds that the subject utility pole is adequate to support the proposed antenna mast and related appurtenances. The pole stresses meet the requirements set forth by the ASCE Manual No. 72, "Design of Steel Transmission Pole Structures Second Edition", for the applied NESC Heavy and Hi-Wind load cases. The detailed analysis results are provided in Section 9 of this report. The analysis results are summarized as follows:

A maximum usage of **73.73%** occurs in the utility pole under the **NESC Heavy** loading condition.

POLE SECTION:

The utility pole was found to be within allowable limits.

Tower Section	Elevation	Stress Ratio (% of capacity)	Result
Tubular Davit 3	60' (AGL)	73.73%	<b>PASS</b>
Tube Number 2	28.00'-48.00' (AGL)	73.62%	<b>PASS</b>



▪ **BASE REACTIONS:**

From PLS-Pole analysis of CL&P pole based on NESC/NU prescribed loads.

Load Case	Shear	Axial	Moment
NESC Heavy Wind	7.19 kips	48.88 kips	456.60 ft-kips
NESC Extreme Wind	9.88 kips	16.51 kips	495.43 ft-kips

Note 1 – 10% increase applied to tower base reactions per OTRM 051

▪ **FOUNDATION**

The existing CL&P pole is directly embedded 12-ft into the ground, which consists of solid rock ledge. Refer to the boring log located in section 10 of this report. The embedment was determined to be structurally sufficient to support the proposed loading.

Conclusions and Recommendations

This analysis shows that the subject utility tower **is adequate** to support the proposed T-Mobile equipment upgrade.

The analysis is based, in part on the information provided to this office by Northeast Utilities and T-Mobile. If the existing conditions are different than the information in this report, CENTEK engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.


Respectfully Submitted by:



Carlo F. Centore, PE  
Principal ~ Structural Engineer



Prepared by:



Timothy J. Lynn, PE  
Structural Engineer

STANDARD CONDITIONS FOR FURNISHING OF  
PROFESSIONAL ENGINEERING SERVICES ON  
EXISTING STRUCTURES

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of CENTEK engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to CENTEK engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an un-corroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the "as new" condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222.
- All services are performed, results obtained, and recommendations made in accordance with generally accepted engineering principles and practices. CENTEK engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.

## GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ RISA - 3D

RISA-3D Structural Analysis Program is an integrated structural analysis and design software package for buildings, bridges, tower structures, etc.

### Modeling Features:

- Comprehensive CAD-like graphic drawing/editing capabilities that let you draw, modify and load elements as well as snap, move, rotate, copy, mirror, scale, split, merge, mesh, delete, apply, etc.
- Versatile drawing grids (orthogonal, radial, skewed)
- Universal snaps and object snaps allow drawing without grids
- Versatile general truss generator
- Powerful graphic select/unselect tools including box, line, polygon, invert, criteria, spreadsheet selection, with locking
- Saved selections to quickly recall desired selections
- Modification tools that modify single items or entire selections
- Real spreadsheets with cut, paste, fill, math, sort, find, etc.
- Dynamic synchronization between spreadsheets and views so you can edit or view any data in the plotted views or in the spreadsheets
- Simultaneous view of multiple spreadsheets
- Constant in-stream error checking and data validation
- Unlimited undo/redo capability
- Generation templates for grids, disks, cylinders, cones, arcs, trusses, tanks, hydrostatic loads, etc.
- Support for all units systems & conversions at any time
- Automatic interaction with RISASection libraries
- Import DXF, RISA-2D, STAAD and ProSteel 3D files
- Export DXF, SDNF and ProSteel 3D files

### Analysis Features:

- Static analysis and P-Delta effects
- Multiple simultaneous dynamic and response spectra analysis using Gupta, CQC or SRSS mode combinations
- Automatic inclusion of mass offset (5% or user defined) for dynamic analysis
- Physical member modeling that does not require members to be broken up at intermediate joints
- State of the art 3 or 4 node plate/shell elements
- High-end automatic mesh generation — draw a polygon with any number of sides to create a mesh of well-formed quadrilateral (NOT triangular) elements.
- Accurate analysis of tapered wide flanges - web, top and bottom flanges may all taper independently
- Automatic rigid diaphragm modeling
- Area loads with one-way or two-way distributions
- Multiple simultaneous moving loads with standard AASHTO loads and custom moving loads for bridges, cranes, etc.
- Torsional warping calculations for stiffness, stress and design
- Automatic Top of Member offset modeling
- Member end releases & rigid end offsets
- Joint master-slave assignments
- Joints detachable from diaphragms
- Enforced joint displacements
- 1-Way members, for tension only bracing, slipping, etc.



- 1-Way springs, for modeling soils and other effects
- Euler members that take compression up to their buckling load, then turn off.
- Stress calculations on any arbitrary shape
- Inactive members, plates, and diaphragms allows you to quickly remove parts of structures from consideration
- Story drift calculations provide relative drift and ratio to height
- Automatic self-weight calculations for members and plates
- Automatic subgrade soil spring generator

Graphics Features:

- Unlimited simultaneous model view windows
- Extraordinary “true to scale” rendering, even when drawing
- High-speed redraw algorithm for instant refreshing
- Dynamic scrolling stops right where you want
- Plot & print virtually everything with color coding & labeling
- Rotate, zoom, pan, scroll and snap views
- Saved views to quickly restore frequent or desired views
- Full render or wire-frame animations of deflected model and dynamic mode shapes with frame and speed control
- Animation of moving loads with speed control
- High quality customizable graphics printing

Design Features:

- Designs concrete, hot rolled steel, cold formed steel and wood
- ACI 1999/2002, BS 8110-97, CSA A23.3-94, IS456:2000, EC 2-1992 with consistent bar sizes through adjacent spans
- Exact integration of concrete stress distributions using parabolic or rectangular stress blocks
- Concrete beam detailing (Rectangular, T and L)
- Concrete column interaction diagrams
- Steel Design Codes: AISC ASD 9th, LRFD 2nd & 3rd, HSS Specification, CAN/CSA-S16.1-1994 & 2004, BS 5950-1-2000, IS 800-1984, Euro 3-1993 including local shape databases
- AISI 1999 cold formed steel design
- NDS 1991/1997/2001 wood design, including Structural Composite Lumber, multi-ply, full sawn
- Automatic spectra generation for UBC 1997, IBC 2000/2003
- Generation of load combinations: ASCE, UBC, IBC, BOCA, SBC, ACI
- Unbraced lengths for physical members that recognize connecting elements and full lengths of members
- Automatic approximation of K factors
- Tapered wide flange design with either ASD or LRFD codes
- Optimization of member sizes for all materials and all design codes, controlled by standard or user-defined lists of available sizes and criteria such as maximum depths
- Automatic calculation of custom shape properties
- Steel Shapes: AISC, HSS, CAN, ARBED, British, Euro, Indian, Chilean
- Light Gage Shapes: AISI, SSMA, Dale / Incor, Dietrich, Marino\WARE
- Wood Shapes: Complete NDS species/grade database
- Full seamless integration with RISAFoot (Ver 2 or better) for advanced footing design and detailing
- Plate force summation tool



*CENTEK Engineering, Inc.*  
*Structural Analysis – 80-ft CL&P Pole # 3275*  
*T-Mobile Antenna Upgrade – CT11116C*  
*Redding, CT*  
*Rev 1 ~ March 19, 2014*

Results Features:

- Graphic presentation of color-coded results and plotted designs
- Color contours of plate stresses and forces with quadratic smoothing, the contours may also be animated
- Spreadsheet results with sorting and filtering of: reactions, member & joint deflections, beam & plate forces/stresses, optimized sizes, code designs, concrete reinforcing, material takeoffs, frequencies and mode shapes
- Standard and user-defined reports
- Graphic member detail reports with force/stress/deflection diagrams and detailed design calculations and expanded diagrams that display magnitudes at any dialed location
- Saved solutions quickly restore analysis and design results.

## GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ PLS-POLE

PLS-POLE provides all of the capabilities a structural engineer requires to design transmission, substation or communications structures. It does so using a simple easy to use graphical interface that rests upon our time tested finite element engine. Regardless of whether you want to model a simple wood pole or a guyed steel X-Frame; PLS-POLE can handle the job simply, reliably and efficiently.

### Modeling Features:

- Structures are made of standard reusable components that are available in libraries. You can easily create your own libraries or get them from a manufacturer
- Structure models are built interactively using interactive menus and graphical commands
- Automatic generation of underlying finite element model of structure
- Steel poles can have circular, 4, 6, 8, 12, 16, or 18-sided, regular, elliptical or user input cross sections (flat-to-flat or tip-to-tip orientations)
- Steel and concrete poles can be selected from standard sizes available from manufacturers
- Automatic pole class selection
- Cross brace position optimizer
- Capability to specify pole ground line rotations
- Capability to model foundation displacements
- Can optionally model foundation stiffness
- Guys are easily handled (modeled as exact cable elements in nonlinear analysis)
- Powerful graphics module (members color-coded by stress usage)
- Graphical selection of joints and components allows graphical editing and checking
- Poles can be shown as lines, wire frames or can be rendered as 3-d polygon surfaces

### Analysis Features:

- Automatic distribution of loads in 2-part suspension insulators (v-strings, horizontal vees, etc.)
- Design checks for ASCE, ANSI/TIA/EIA 222 (Revisions F and G) or other requirements
- Automatic calculation of dead and wind loads
- Automated loading on structure (wind, ice and drag coefficients) according to:
  - ASCE 74-1991
  - NESC 2002
  - NESC 2007
  - IEC 60826:2003
  - EN50341-1:2001 (CENELEC)
  - EN50341-3-9:2001 (UK NNA)
  - EN50341-3-17:2001 (Portugal NNA)
  - ESAA C(b)1-2003 (Australia)
  - TPNZ (New Zealand)
  - REE (Spain)
  - EIA/TIA 222-F
  - ANSI/TIA 222-G
  - CSA S37-01
- Automated microwave antenna loading as per EIA/TIA 222-F and ANSI/TIA 222-G
- Detects buckling by nonlinear analysis

*CEN TEK Engineering, Inc.*  
*Structural Analysis – 80-ft CL&P Pole # 3275*  
*T-Mobile Antenna Upgrade – CT11116C*  
*Redding, CT*  
*Rev 1 ~ March 19, 2014*

Results Features:

- Detects buckling by nonlinear analysis
- Easy to interpret text, spreadsheet and graphics design summaries
- Automatic determination of allowable wind and weight spans
- Automatic determination of interaction diagrams between allowable wind and weight spans
- Automatic tracking of part numbers and costs

Criteria for Design of PCS Facilities On or  
Extending Above Metal Electric Transmission  
Towers & Analysis of Transmission Towers  
Supporting PCS Masts <sup>(1)</sup>

Introduction

This criteria is the result from an evaluation of the methods and loadings specified by the separate standards, which are used in designing telecommunications towers and electric transmission towers. That evaluation is detailed elsewhere, but in summary; the methods and loadings are significantly different. This criteria specifies the manner in which the appropriate standard is used to design PCS facilities including masts and brackets (hereafter referred to as "masts"), and to evaluate the electric transmission towers to support PCS masts. The intent is to achieve an equivalent level of safety and security under the extreme design conditions expected in Connecticut and Massachusetts.

ANSI Standard TIA/EIA-222 covering the design of telecommunications structures specifies a working strength/allowable stress design approach. This approach applies the loads from extreme weather loading conditions, and designs the structure so that it does not exceed some defined percentage of failure strength (allowable stress).

ANSI Standard C2-2007 (National Electrical Safety Code) covering the design of electric transmission metal structures is based upon an ultimate strength/yield stress design approach. This approach applies a multiplier (overload capacity factor) to the loads possible from extreme weather loading conditions, and designs the structure so that it does not exceed its ultimate strength (yield stress).

Each standard defines the details of how loads are to be calculated differently. Most of the NU effort in "unifying" both codes was to establish what level of strength each approach would provide, and then increasing the appropriate elements of each to achieve a similar level of security under extreme weather loadings.

Two extreme weather conditions are considered. The first is an extreme wind condition (hurricane) based upon a 50-year recurrence (2% annual probability). The second is a winter condition combining wind and ice loadings.

The following sections describe the design criteria for any PCS mast extending above the top of an electric transmission tower, and the analysis criteria for evaluating the loads on the transmission tower from such a mast from the lower portions of such a mast, and loads on the pre-existing electric lower portions of such a mast, and loads on the pre-existing electric transmission tower and the conductors it supports.

Note 1: Prepared from documentation provide from Northeast Utilities.



### PCS Mast

The PCS facility (mast, external cable/trays, including the initial and any planned future support platforms, antennas, etc. extending the full height above the top level of the electric transmission structure) shall be designed in accordance with the provisions of TIA/EIA Standard 222 with two exceptions:

1. An 85 mph extreme wind speed shall be used for locations in all counties throughout the NU system.
2. The allowable stress increase of TIA Section 3.1.1.1 is allowed for mast section, but is disallowed for the mast to CL&P structure connection.
3. The combined wind and ice condition shall consider ½" radial ice in combination with the wind load (0.75  $W_i$ ) as specified in TIA section 2.3.16.

### ELECTRIC TRANSMISSION TOWER

The electric transmission tower shall be analyzed using yield stress theory in accordance with the attached table titled "NU Design Criteria". This specifies uniform loadings (different from the TIA loadings) on the each of the following components of the installed facility:

- PCS mast for its total height above ground level, including the initial and planned future support platforms, antennas, etc. above the top of an electric transmission structure.
- Conductors are related devices and hardware.
- Electric transmission structure. The loads from the PCS facility and from the electric conductors shall be applied to the structure at conductor and PCS mast attachment points, where those load transfer to the tower.

The uniform loadings and factors specified for the above components in the table are based upon the National Electrical Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to TIA and its loads and factors with the exceptions noted above. (Note that the NESC does not require the projected wind surfaces of structures and equipment to be increased by the ice covering.)

In the event that the electric transmission tower is not sufficient to support the additional loadings of the PCS mast, reinforcement will be necessary to upgrade the strength of the overstressed members.



Attachment A

NU Design Criteria

		Basic Wind Speed	Pressure	Height Factor	Gust Factor	Load or Stress Factor	Force Coef - Shape Factor	
		V (MPH)	Q (PSF)	Kz	Gh			
Ice Condition	TIA/EIA	Antenna Mount	TIA	TIA (.75Wi)	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	NESIC Heavy	Tower/Pole Analysis with antennas extending above top of Tower/Pole (Yield Stress)	----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
		Tower/Pole Analysis with Antennas below top of Tower/Pole (on two faces)	----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
	Conductors:		Conductor loads provided by NU					
High Wind Condition	TIA/EIA	Antenna Mount	85	TIA	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	NESIC Extreme Wind	Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESIC C2-2007, Section 25, Rule 250C: Extreme Wind Loading 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna				1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESIC C2-2007, Section 25, Rule 250C: Extreme Wind Loading Height above ground level based on top of Tower/Pole				1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU					
NESIC Extreme Ice with Wind Condition*		Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESIC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna				1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESIC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load Height above ground level based on top of Tower/Pole				1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU					

\* Only for Structures Installed after 2007

Communication Antennas on Transmission Structures (CL&P & WMECo Only)





Shape Factor Criteria shall be per TIA Shape Factors.

- 2) STEP 2 - The electric transmission structure analysis and evaluation shall be performed in accordance with NESC requirements and shall include the mast and antenna loads determined from NESC applied loading conditions (not TIA/EIA Loads) on the structure and mount as specified below, and shall include the wireless communication mast and antenna loads per NESC criteria)

The structure shall be analyzed using yield stress theory in accordance with Attachment A, "NU Design Criteria." This specifies uniform loadings (different from the TIA loadings) on each of the following components of the installed facility:

- a) Wireless communication mast for its total height above ground level, including the initial and any planned future equipment (Support Platforms, Antennas, TMA's etc.) above the top of an electric transmission structure.
- b) Conductors and related devices and hardware (wire loads will be provided by NU).
- c) Electric Transmission Structure
  - i) The loads from the wireless communication equipment components based on NESC and NU Criteria in Attachment A, and from the electric conductors shall be applied to the structure at conductor and wireless communication mast attachment points, where those loads transfer to the tower.

- ii) Shape Factor Multiplier:

NESC Structure Shape	Cd
Polyround (for polygonal steel poles)	1.3
Flat	1.6
Open Lattice	3.2

- iii) When Coaxial Cables are mounted along side the pole structure, the shape multiplier shall be:

Mount Type	Cable Cd	Pole Cd
Coaxial Cables on outside periphery (One layer)	1.45	1.45
Coaxial Cables mounted on stand offs	1.6	1.3

- d) The uniform loadings and factors specified for the above components in Attachment A, "NU Design Criteria" are based upon the National Electric Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to the TIA and its loads and factors with the exceptions noted above.

**Note:** The NESC does not require ice load be included in the supporting structure. (Ice on conductors and shield wire only, and NU will provide these loads).

- e) Mast reaction loads shall be evaluated for local effects on the transmission structure members at the attachment points.

### Communication Antennas on Transmission Structures (CL&P & WMECo Only)

Northeast Utilities  
Approved by: KMS (NU)

Design  
NU Confidential Information

OTRM 059  
Page 3 of 9

Rev.1  
03/17/2011

Wire Ld

TITLE CL&P, READING CT  
 STRUCT 3275

10/18/99

CONDUCTOR

	AHEAD	BACK
LINNET	LINNET	LINNET
	336	336
	26/7 ACSR	26/7 ACSR
DIAM =	0.720	0.720
WEIGHT =	0.462	0.462
TENSION (LBS)	AHEAD 4,500	BACK 4,500

LOADCASE	NESC HEAVY
WIND (PSF)	4
ICE (IN)	0.50
OLF ANG	1.65
OLF WIND	2.50
OLF WT	1.50

STR	ANGLE	WIND SPAN	WGT SPAN	NESC HEAVY		
				H	L	V
BACK	0	236	1491	338	-7425	2730
AHEAD	0	236	1491	338	7425	2730
TOTALS	0.0	472	2982	676	0	5460



Wire Ld

TITLE CL&P, READING, CT  
 STRUCT 3275

10/18/99

CONDUCTOR

	AHEAD	BACK
LINNET	▼	LINNET ▼
	336	336
	26/7 ACSR	26/7 ACSR
DIAM =	0.720	0.720
WEIGHT =	0.462	0.462
TENSION (LBS)	AHEAD 3,204	BACK 3,204

LOADCASE	HI WIND ▼
WIND (PSF)	20
ICE (IN)	0.00
OLF ANG	1.15
OLF WIND	1.15
OLF WT	1.15

STR	ANGLE	WIND SPAN	WGT SPAN	HI WIND		
				H	L	V
BACK	0	236	1491	325	-3685	792
AHEAD	0	236	1491	326	3685	792
TOTALS	0.0	472	2982	651	0	1584

Wire Ld

TITLE CL 4P, READING, CT.  
 STRUCT 3275

10/18/99

SHIELD WIRE CONDUCTOR

AHEAD		BACK	
3/8 AW	▼	3/8 AW	▼

0.000                      0.000

7 #8 Al Weld                      7 #8 Al Weld

DIAM =	0.385	0.385
WEIGHT =	0.262	0.262

TENSION (LBS)	AHEAD	4,200	BACK	4,200
---------------	-------	-------	------	-------

LOADCASE	NESC HEAVY	▼
WIND (PSF)	4	
ICE (IN)	0.50	
OLF ANG	1.65	
OLF WIND	2.50	
OLF WT	1.50	

STR	ANGLE	WIND SPAN	WGT SPAN	NESC HEAVY		
				H	L	V
BACK	0	236	1491	272	-6930	1816
AHEAD	0	236	1491	272	6930	1816
TOTALS	0.0	472	2982	545	0	3632

Wire Ld

TITLE CLIP, REDDING CT.  
 STRUCT 3275


10/18/99

SHIELD WIRE CONDUCTOR

	AHEAD	BACK
	3/8 AW	3/8 AW
	0.000	0.000
	7 #8 Al Weld	7 #8 Al Weld
DIAM =	0.385	0.385
WEIGHT =	0.262	0.262
TENSION (LBS)	AHEAD 2,814	BACK 2,814

LOADCASE	HI WIND
WIND (PSF)	20
ICE (IN)	0.00
OLF ANG	1.15
OLF WIND	1.15
OLF WT	1.15

STR	ANGLE	WIND SPAN	WGT SPAN	HI WIND		
				H	L	V
BACK	0	236	1491	174	-3236	449
AHEAD	0	236	1491	174	3236	449
TOTALS	0.0	472	2982	348	0	898



1
**TOWER & MAST ELEVATION**  
 EL-1 SCALE: NOT TO SCALE

REVISIONS		
0	2/10/14	ISSUED FOR NJ REVIEW
1	3/17/14	CONSTRUCTION

**CEN<sup>TEK</sup> engineering**  
 Centered on Solutions™  
 www.CentekEng.com  
 (203) 486-0580  
 (203) 486-8587 Fax  
 63-2 North Branford Road, Branford, CT 06403

CT11116C  
 CL&P 3275  
 101 MOUNTAIN ROAD  
 REDDING, CT 06896

PROJECT NO: 14025.005  
 DRAWN BY: T.J.L.  
 CHECKED BY: C.F.C.  
 SCALE: AS NOTED  
 DATE: 2/10/14




TOWER AND MAST  
 ELEVATION  
**EL-1**  
 DWG. 1 OF 2



EXISTING 4" SCH. 40  
X 20' LONG PIPE MAST

T-MOBILE EXISTING FOUR (4)  
AND PROPOSED FOUR (4) 7/8"  
DIA. COAX CABLES BANDED TO  
EXISTING MAST @ 4' O.C.



**1** FEEDLINE PLAN  
FP-1 SCALE: 1" = 3'-0"

EXISTING 80' TALL CL&P  
STEEL TRANSMISSION  
STRUCTURE NO. 3275

T-MOBILE EXISTING FOUR  
(4) 7/8"  $\phi$  COAX CABLES  
BANDED TO CL&P POLE @  
4' O.C.

T-MOBILE PROPOSED FOUR  
(4) 7/8"  $\phi$  COAX CABLES  
BANDED TO CL&P POLE @  
4' O.C.



**2** FEEDLINE PLAN  
FP-1 SCALE: 1" = 1'-0"

REVISIONS		
0	2/10/14	ISSUED FOR NJ REVIEW
1	3/17/14	CONSTRUCTION

**CEN TEK** engineering  
Centered on Solutions™  
www.CentekEng.com  
(203) 485-0280  
(203) 485-8857 Fax  
69-2 North Starford Road, Starford, CT 06405

CT11116C  
CL&P 3275  
101 MOUNTAIN ROAD  
REDDING, CT 06896

PROJECT NO: 14025.005  
DRAWN BY: T.J.L.  
CHECKED BY: CFC  
SCALE: AS NOTED  
DATE: 2/10/14

FEEDLINE  
PLAN  
**FP-1**  
DWG. 2 OF 2

**RADIO FREQUENCY EMISSIONS ANALYSIS REPORT  
EVALUATION OF HUMAN EXPOSURE POTENTIAL  
TO NON-IONIZING EMISSIONS**

**T-Mobile Existing Facility**

**Site ID: CT11116C**

**Ridgefield / Ethan Allen**

**101 Mountain Road  
Redding, CT 06896**

**March 28, 2014**

**EBI Project Number: 62141885**

March 28, 2014

T-Mobile USA  
Attn: Jason Overbey, RF Manager  
35 Griffin Road South  
Bloomfield, CT 06002

Re: Emissions Values for Site: **CT11116C - Ridgefield / Ethan Allen**

EBI Consulting was directed to analyze the proposed T-Mobile facility located at 101 Mountain Road, Redding, CT, for the purpose of determining whether the emissions from the Proposed T-Mobile Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ( $\mu\text{W}/\text{cm}^2$ ). The number of  $\mu\text{W}/\text{cm}^2$  calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits, therefore it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) – (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

General population/uncontrolled exposure limits apply to situations in which the general public may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general public would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

Public exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ( $\mu\text{W}/\text{cm}^2$ ). The general population exposure limit for the cellular band is  $567 \mu\text{W}/\text{cm}^2$ , and the general population exposure limit for the PCS band is  $1000 \mu\text{W}/\text{cm}^2$ . Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.



Occupational/controlled exposure limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.

## CALCULATIONS

Calculations were done for the proposed T-Mobile Wireless antenna facility located at 101 Mountain Road, Redding, CT, using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65. Since T-Mobile is proposing highly focused directional panel antennas, which project most of the emitted energy out toward the horizon, the actual antenna pattern gain value in the direction of the sample area was used. For this report the sample point is a 6 foot person standing at the base of the tower

For all calculations, all equipment was calculated using the following assumptions:

- 1) 2 GSM channels (1940.000 MHz—to 1950.000 MHz) were considered for each sector of the proposed installation.
- 2) 2 UMTS channels (2110.000 MHz to 2120.000 MHz / 2140.000 MHz to 2145.000 MHz) were considered for each sector of the proposed installation
- 3) 2 LTE channels (2110.000 MHz to 2120.000 MHz / 2140.000 MHz to 2145.000 MHz) were considered for each sector of the proposed installation
- 4) All radios at the proposed installation were considered to be running at full power and were uncombined in their RF transmissions paths per carrier prescribed configuration. Per FCC OET Bulletin No. 65 - Edition 97-01 recommendations to achieve the maximum anticipated value at each sample point, all power levels emitting from the proposed antenna installation are increased by a factor of 2.56 to account for possible in-phase reflections from the surrounding environment. This is rarely the case, and if so, is never continuous.
- 5) For the following calculations the sample point was the top of a six foot person standing at the base of the tower. The actual gain in this direction was used per the manufactures supplied specifications.
- 6) The antenna used in this modeling is the Ericsson AIR21 for LTE, UMTS and GSM. This is based on feedback from the carrier with regards to anticipated antenna selection. This antenna has a 15.6 dBd gain value at its main lobe. Actual antenna gain values were used for all calculations as per the manufacturers specifications





# EBI Consulting

environmental | engineering | due diligence

---

- 7) The antenna mounting height centerline of the proposed antennas is **74 feet** above ground level (AGL)
- 8) Emissions values for additional carriers were taken from the Connecticut Siting Council active database. Values in this database are provided by the individual carriers themselves.

All calculation were done with respect to uncontrolled / general public threshold limits

Site ID	CT11116C- Blufffield / Ethan Allen
Site Address	101 Mountain Road, Middling, CT 06895
Site Type	Monopole

Antenna Number	Antenna Make	Antenna Model	Status	Frequency Band	Technology	Power Out Per Channel (Watts)	Number of Channels	Composite Power	Antenna Gain in direction of sample point (dBi)	Antenna Height (ft)	Antenna analysis height (ft)	Cable Size	Cable Loss (dB)	Additional Loss	ERP	Power Density Value	Power Density Percentage
1A	RF5	APX16DWW-16DWYS-E-A20	Passive	PCS - 1950 MHz	GSM / UMTS	30	2	60	-3.25	74	68	7/8"	1.2	0	21.535316	1.674324	0.16743%
1B	RF5	APX16DWW-16DWYS-E-A20	Passive	AWS - 2100 MHz	UMTS/LTE	40	4	160	-3.25	74	68	7/8"	1.2	0	57.42751	4.464863	0.44649%

Sector total Power Density Value: 0.614%

Antenna Number	Antenna Make	Antenna Model	Status	Frequency Band	Technology	Power Out Per Channel (Watts)	Number of Channels	Composite Power	Antenna Gain in direction of sample point (dBi)	Antenna Height (ft)	Antenna analysis height (ft)	Cable Size	Cable Loss (dB)	Additional Loss	ERP	Power Density Value	Power Density Percentage
1A	RF5	APX16DWW-16DWYS-E-A20	Passive	PCS - 1950 MHz	GSM / UMTS	30	2	60	-3.25	74	68	7/8"	1.2	0	21.535316	1.674324	0.16743%
1B	RF5	APX16DWW-16DWYS-E-A20	Passive	AWS - 2100 MHz	UMTS/LTE	40	4	160	-3.25	74	68	1-5/8"	1.2	0	57.42751	4.464863	0.44649%

Sector total Power Density Value: 0.614%

Site Composite MPE %	
Carrier	MPE %
T-Mobile	1.228%
Total Site MPE %	
1.228%	

## Summary

All calculations performed for this analysis yielded results that were well within the allowable limits for general public exposure to RF Emissions.

The anticipated Maximum Composite contributions from the T-Mobile facility are **1.228% (0.614% from each sector)** of the allowable FCC established general public limit considering both sectors simultaneously.

The anticipated composite MPE value for this site assuming all carriers present is **1.228%** of the allowable FCC established general public limit. This is based upon values listed in the Connecticut Siting Council database for existing carrier emissions.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite values calculated were within the allowable 100% threshold standard per the federal government.



**Scott Heffernan**  
RF Engineering Director

**EBI Consulting**  
21 B Street  
Burlington, MA 01803